

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWERSTATIONTITLE:1.#M-STATION DD BALDE C-CHANNEL ( RHS & LHS ) CRACKS REPAIR,REPLACEMENT OF VERTICAL STRIPS & MAIN HOLLOW FRAME REINFORCEMENT.2.#HINGE TO MAIN LOAD BEARING STRUCTURE & CEN TERING DEVICE CRACKRECTIFICATION AND REINFORCEMENT PLATE INSTALLATION.B.#DURATION:1.#03 DAYSC.#SCHEDULE1.#HRSG 12 WORK TO BE CARRIED OUT DURING UNIT OUTAGE.2.#THIS SCHEDULE MAY BE CHANGE BASED ON OPERATIONAL REQUIREMENT,ACCORDINGLY IF THERE WILL BE ANY CHANGES IT WILL BE INFORMED AND WORK TOBE CARRIED OUT ACCORDINGLY.D.#PRE-BID SITE INSPECTION:1.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE TH EMSELVES FULLYFAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES,	1	AU				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COMPLEXITIES,ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED. 2.#THE SCOPE OF WORK MENTIONED HERE ONLY PROVIDES A BROAD OUTLINE OF THE TASK. THE BIDDER MUST REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORK TO CARRY OUT THE REQUIRED TASKS AND ADD ANY ADDITIONAL WORK THAT ARE NEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT. 3.#CONTACT PERSON FOR SITE VISIT</p> <p>T3.1.#ASHIL PRABHAKAR , ASHIL.PRABHAKAR@DEWA.GOV.AE / MOB: 05858395853. 2.#SHABBIR AHMAD ENULHAQUE, SHABBIR.ENULHAQUE@DEWA.GOV.AE / MOB: 0586407243E. #QUALIFICATION OF BIDDER: 1.#THE BIDDER SHALL HAVE ADEQUATE AND PROVEN EXPERIENCE IN THE PAST IN MAINTENANCE AND REPAIR OF DIVERTER DAMPERS. EVIDENCE TO BE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROVIDED.2.#ALL WORK SHALL BE DONE AT SITE AS PER RECOMMENDATION AND SUPERVISION OF DIVERTER DAM</p> <p>PER SPECIALIST.3.#DIVERTER DAMPER SPECIALIST MUST HAVE AT LEAST 25 YEARS OF WORK EXPERIENCE IN DD INSPECTION AND MAINTENANCE. HIS CV IS TO BE PROVIDED.F.#SCOPE OF WORK:PREPARATION1.#MOBILIZE MEN/EQUIPMENT WITHIN 01 DAY OF ADVANCE NOTICE.2.#OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE) &amp; HOT WORK PERMIT FROM DEWA.3.#THE FOLLOWING DOCUMENTS ARE TO BE SUBMITTED TO OBTAIN PTW,3.1.#METHOD STATEMENT3.2.#RISK ASSESSMENT OF THE WORK3.3.#TOOLBOX TALK REPORT.4.#ENSURE PROPER ISOLATION OF THE EQUIPMENT &amp; VALID HWP IS AVAILABLE.5.#ENSURE NO FLAMMABLE MATERIALS NEAR THE HOT WORK AREA.6.#ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.7.#CO</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.8.#BARRICADE THE AREA WITH SIGNAGE.9.#VERIFY THAT SCAFFOLDS ARE SAFE TO WORK, AND VALID SCAFFOLDING TAGS ARE PROVIDED PRIOR TO USE.10.#IF THE WORKING ENVIRONMENT IS SAFE, THEN THE CONTRACTOR CAN PROCEED WITH THE FOLLOWING STEPS.11.#NOTE: ALL WORKS SHALL BE AS PER RECOMMENDATION OF SPECIALIST AND HIS SUPERVISION(1)#RHS &amp; LHS</p> <p>C CHANNEL - CRACKS REPAIR AND INSTALLATION OF 2 STRIPS &amp; MAIN HOLLOW FRAME REINFORCEMENT12.#ERECT SCAFFOLDING ON THE GT SIDE WHICH SHALL PROVIDE PROPER ACCESS (ASSURED THAT WOODEN PLANKS ARE USED PRIOR TO INSTALLING THE SCAFFOLDING TO PROTECT INSULATION/CLADDING).13</p> <p>.#PROTECT THE WOODEN PLANKS BY USING FIRE BLANKETS, FROM WELDING SPARKS, PERFORMING HOT WORK14.#REMOVE THE LINERS AND</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSULATIONS FRO M THE LHS/RHS WALL AND THE LAMELLAS 15. #GRIND OFF THE CRACK AND WELD NEW IN C-CHANNEL AND MAIN HORIZONTAL HOLLOW FRAME. 16. #INSTALL 6MM VERTICAL STRIPS IN GT SIDE OF RHS/LHS C-CHANNELS. 17. #REMOVE THE REQUIRED LAMELLAS FOR ACCESSING THE JOB LOCATION IN HOLLOW FRAME. 18. # INSTALL T-TYPE REINFORCEMENT IN MAIN HOLLOW HORIZONTAL FRAME IN BOTH LHS/RHS OF HRSG SIDE. 19. #MOVE THE BLADE TO AN ANGLE OF APPROX. 3 0° USING HYDRAULIC POWER UNIT. 20. #THE BLADE MUST BE SECURED BY TEMPORARY SUPPORTS, JACKS, CHAIN BLOCKS ETC. 21. #TIGHTEN THE LIFTING DEV ICE IN THE 30° POSITION OF THE DIVERTER BLADE TO CREATE A SAFE WORK ENVIRONMENT. 22. #ERECT SCAFFOLDING ON THE HRSG SIDE WHICH SHALL PR OVIDE PROPER ACCESS (ASSURE WOODEN PLANKS ARE USED PRIOR TO INSTALLING</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THESCAFFOLDING TO PROTECT INSULATION/CLADDING).23.#PROTECT THE WOODEN PLANKS BY USING FIRE BLANKETS, FROM WELDINGSPARKS, PERFORMING HOT WORK24.#GRIND OFF THE CRACK AND WELD NEW IN C-CHANNEL AND MAIN HORIZONTALHOLLOW FRAME.25.#INSTALL 6MM VERTICAL STRIPS IN GT SIDE OF RHS/LHS C-CHANNELS.26.#REMOVE THE REQUIRED LAMELLAS FOR AC CESSING THE JOB LOCATION INHOLLOW FRAME.27.#INSTALL T-TYPE REINFORCEMENT IN MAIN HOLLOW HORIZONTAL FRAME INBOTH LHS/RHS OF GT SIDE.28.#VISUAL INSPECTION OF THE WELDING JOINT &amp; DPT.29.#CARRY OUT MINOR REPAIR LIKE CRACK RECTIFICATION RE-WELDING THECRACKS ETC. AS PER DD SPECIALISTRECOMMENDATIONS.30.#RETHREADIN G &amp; INSTALLATION OF LINER BOLTS AND REPLACE IF ANYDAMAGE. DEWA WILL PROVIDE STUDS.31.#RE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSTALL THE LAMELLAS, LINERS, AND INSULATIONS OF THE BLADE32.#TIGHTENING OF THE NUTS AND TACK WELDING OF THE NUTS WITH WASHER.(II)#H</p> <p>INGE TO MAIN LOAD BEARING STRUCTURE &amp; CENTERING DEVICE CRACKRECTIFICATION AND REINFORCEMENT PLATE</p> <p>INSTALLATION.33.#CRACKS ON THE HINGE TO MAIN LOAD BEARING STRUCTURE AND CRACK ON THECENTERING DEVICE/CASING TO BE REMOVED AND NEW WELDING TO BE CARRIED OUTAS PER DD S</p> <p>PECIALIST.34.#NEW REINFORCEMENT PLATES ( APPROX 15 MM THICK ) ARE TO BEINSTALLED INSIDE AND OUTSIDE OF THE CASING PLATE OVER THE EX</p> <p>ISTING PLATEAND WELD SECURE.35.#ANY ADDITIONAL REINFORCEMENT RIBS/STRIP SHALL BE ADDED AS PER THESPECIALIST.36.#ALL THE FINAL WELDIN</p> <p>G SHALL BE VISUALLY INSPECTED AND DPT SHALL BECONDUCTED.37.#ALL THE REMOVED LINER PLATES AND INSULATION SHALL BE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSTALLED BACK.38.# DISMANTLE SCAFFOLDING ON HRSG SIDE OF THE BLADE. PRIOR TO STARTING WITH FOLLOWING STEP ASSURE NO OBSTACLES ARE IN THE WAY FOR FREE MOVEMENT OF THE BLADE IN HRSG CLOSED DIRECTION (EG. SCAFFOLDING, ETC.).39.# REMOVE THE LIFTING BELTS, CHAIN BLOCK INCLUDING ALL LIFTING DEVICES40.# LOWER THE BLADE CAREFULLY BY USING THE ORIGINAL HYDRAULIC POWER UNIT. THE END POSITION WILL BE THE HRSG CLOSED POSITION41.# AFTER COMPLETION OF ALL WORKS, BLADES SHALL BE TESTED FOR ALIGNMENT, BALANCE &amp; FUNCTION. NOTE: TEST TO BE DONE UNDER SUPERVISION OF DD SPECIALIST.G.# GENERAL1.# REMOVE TEMPORARY SUPPORT IF ANY.2.# REMOVE ALL METAL SCRAPS, TEMPORARY SUPPORTS AND ANY OTHER SCRAPS FROM THE WORKPLACE AND DISPOSE AS PER DEWA ENGINEER'S INSTRUCTION.3.# AFTER COMPLETION</p>						



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF THE SCOPE OF WORK, A JOINT INSPECTION SHALL BEDONE WITH DEWA ENGINEER.4.#CARRY OUT DAMPER HRSG CLOSE, BYPASS CLOSE AND EMERGENCY CLOSE TESTAND CHECK THE SEAL AIR PRESSURECONDITIONS.5.#A QUALIFIED JOB SUPERVISOR SHALL BE ASSIGNED FOR THE JOB.6.#SKILLED FABRICATORS / QUALIFIED WELDERS SHALL CARRY OUT ALL THEJOBS.7.#WELD JOINTS TO BE MADE BY QUALIFIED WELDER ACCORDING TO APPLICABLEWPS &amp; ASME REQUIREMENTS.(PQR, WPS &amp; WELDER CERTIFICATES TO BE PROVIDED IN ADVANCE)8.#CERTIFIED AND QUALIFIED RIGGERS TO BE ENGAGED FOR ALL RIGGING WORK.9.#HOUSEKEEPING AND DISPOSAL OF WASTE TO BE DONE BEFORE SITE CLEARANCE.10.#DE-MOBILIZE MEN AND EQUIPMENT AFTER COMPLETION OF THE JOB.11.#WORK COMPLETION REPORT TO BE SUBMITTED. THE REPORT SHALL CONTAINRELEVANT PHOTOS AND</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>QUALITYDOCUMENTS.12.#ALL CONSUMABLES, TOOLS &amp; TACKLES ARE IN CONTRACTOR'S SCOPE.13.#PROPER AND TESTED TOOLS TO BE USED.14.#ALL LIFTING &amp; POWER TOOLS SHALL HAVE A VALID 3RD PARTY TESTCERTIFICATE AND TO BE SUBMITTED TO DEWA I NADVANCE.15.#WELDING MACHINES SHALL HAVE A VALID 3RD PARTY CALIBRATIONCERTIFICATE AND TO BE SUBMITTED TO DEWA IN ADVANCE.16.#WORK CO MPLETION REPORT, FULL REPAIRING REPORTS, MATERIAL TESTCERTIFICATES, WELDING CONSUMABLE &amp; MATERIAL TEST CERTIFICATES TO BESUBMITTED T O DEWA17.#DEWA SCOPE:17.1.#SCAFFOLDING (CONTRACTOR TO PROVIDE REQUIREMENT IN ADVANCE)17.2.#SUPPLY OF PLATE FOR SHIMS FABRICATION, IN SULATION STUDS,INSULATION IF REQUIRED.H.#WARRANTY1.#THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OFCOMPLETION OF</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WORK CERTIFIED BY DEWA.2.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE C ONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORTPERIOD.I.#GENERAL TERMS & CONDITION S1.#THE CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SAME JOB2.#THE CONTRACTOR SHALL SUBMIT THE METHO						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

M-Station Diverter Damper Blade cracks repair and reinforcement plate installation.[ Note : DD specialist supervsion is required and work to be done as perthe attached scope of work ]Contact : ashil.prabhakar@dewa.gov.ae / +971-43226179

### STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503419  
**DATE** : 26.12.2025  
**REQ No** : 1032506496  
**REQ TITLE** : 1032506496 M-Station Diverter  
**DELIVERY LOCATION**  
**CLOSING DATE** : 31.12.2025  
**CLOSING TIME** : 10:00:00

- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**