

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503442  
**DATE** : 30.12.2025  
**REQ No** : 1032506404  
**REQ TITLE** : Replacement of Condenser Coil  
**DELIVERY LOCATION**  
**CLOSING DATE** : 06.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	1.#INTRODUCTIONTHE BRIEF SCOPE OF THE ENQUIRY IS AS BELOW,A.#SUPPLY AND SERVICES SCOPE: G RO CHILLER- 2, YORK MAKE, MODEL:YVAA0413HB F50BAV IS EQUIPPED WITH 20 NOS. ALUMINUM MICROCHANNEL TYPECONDENSER COILS. WE PROPOSE REPLACING THESE COILS WITH NEW ALUMINUMMICROCHANNEL TYPE CONDENSER COILS WITH THERMO-GUARD COATING.THIS CHILLER VFD COOLING SYSTEM USES 4 NOS. GLYCOL CONDENSER COILS WITHCOPPER TUBES & ALUMINUM FINs. WE PROPOSE REPLACING THESE CONDENSER COILSWITH THE SAME CONDENSER COILS TYPE WITH THERMO-GUARD COATING.B.#SUPPLY SCOPE: SUPPLY OF 2 NOS. ALUMINUM MICROCHANNEL TYPE CONDENSERCOILS WITH THERMO-GUARD COATING AS A SPARE FOR REPLACING IN G ROCHILLER- 1, YORK MAKE, MODEL: YVAA0413HBF50BAV AND OTHER CHILLERS IN THEPLANT.2.#DETAILED SCOPE:A.#SUPPLY AND SERVICES	20	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503442  
**DATE** : 30.12.2025  
**REQ No** : 1032506404  
**REQ TITLE** : Replacement of Condenser Coil  
**DELIVERY LOCATION**  
**CLOSING DATE** : 06.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SCOPE:1.#REMOVAL OF 20 NOS. EXISTING MICROCHANNEL TYPE CONDENSER COILS OFG-RO PLANT YORK MAKE VFD CHILLER-2 AFTER RECOVERY OF REFRIGERANT (R-134AGAS) FROM THE SYSTEM. (TECHNICAL SPECIFICATION TABLE ITEM#1)2.#SUPPLY, INSTALLATION & COMMISSIONING OF 20 NOS. NEW MICROCHANNELTYPE CONDENSER COILS WITH THERMO-GUARD COATING.3.#REMOVAL OF FOUR EXISTING GLYCOL CONDENSER COILS OF COPPER TUBES &ALUMINUM FINS FOR VFD COOLING SYSTEM AFTER RECOVERY OF GLYCOL FROM THE SYSTEM AND SUPPLY, INSTALLATION & COMMISSIONING OF NEW COILS OF SAMETYPE. (REFER TECHNICAL SPECIFICATION TABLE ITEM- 2).4.#IT IS THE CONTRACTOR#S RESPONSIBILITY TO DESIGN THE NEW MICROCHANNELTYPE CONDENSER COILS TO MATCH THE SPECIFICATIONS AND PERFORMANCE OF THEEXISTING MICROCHANNEL TYPE COILS.5.#THE						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503442  
**DATE** : 30.12.2025  
**REQ No** : 1032506404  
**REQ TITLE** : Replacement of Condenser Coil  
**DELIVERY LOCATION**  
**CLOSING DATE** : 06.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NEW COILS MUST BE EQUIVALENT IN BOTH PERFORMANCE AND DESIGN TO THE ORIGINAL MICROCHANNEL COILS CURRENTLY INSTALLED IN THE SYSTEM.B.#SUPPLY SCOPE: THE CONTRACTOR SHALL SUPPLY 2 NOS. OF ALUMINUM MICROCHANNEL COILS WITH THERMOS-GUARD COATING. (REFER TECHNICAL SPECIFICATION TABLE ITEM-3) AS SPARE CONDENSER COIL FOR THE REMAINING CHILLERS.C.#ALL THE MECHANICAL & ELECTRICAL WORK REQUIRED FOR COMPLETING THE JOB SUCH AS CLEANING OF THE BASE, CUTTING, BRAZING REFRIGERANT PIPES, DISCONNECTION, RECONNECTION, REMOVAL, REINSTALLATION OF CONDENSER COOLING FANS & MOTORS AND TESTING & RE-COMMISSIONING OF THE CHILLERS SHALL BE CARRIED OUT BY CONTRACTOR.D.#REMOVED EXISTING CONDENSER COIL TO BE TRANSPORTED TO THE DEWAD-STATION SCRAP YARD BY THE CONTRACTOR. MATERIAL						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503442  
**DATE** : 30.12.2025  
**REQ No** : 1032506404  
**REQ TITLE** : Replacement of Condenser Coil  
**DELIVERY LOCATION**  
**CLOSING DATE** : 06.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RETURN NOTE WILL BE PROVIDED BY DEWA.E.#THE CONTRACTOR SHALL CARRY OUT THE REPLACEMENT OF FILTER DRIER CORE,OIL FILTER &amp; COMPRESSOR OIL FOR CHILLERS.F.#BIDDERS MUST SUBMIT RECORDS OF PREVIOUSLY COMPLETED SIMILAR JOBS TO SUPPORT THEIR QUALIFICATION AND ENABLE EVALUATION OF THEIR OFFER.G.#ONLY BIDDERS WITH A DOCUMENTED HISTORY OF SIMILAR JOBS, WILL BE CONSIDERED FOR THIS PROJECT.H.#THE BIDDERS SHALL SUBMIT THE EXPECTED LIFETIME OF THEIR PROPOSED CONDENSER COILS TO EVALUATE THEIR OFFER.I.#PRESSURE TESTS WITH NITROGEN GAS SHALL BE CARRIED OUT AT 200 PSI AND RESTORE THE UNIT IN NORMAL WORKING CONDITION.J.#IT IS THE CONTRACTOR'S RESPONSIBILITY TO TAKE ACTUAL MEASUREMENTS OF COILS REQUIRED TO COMPLETE THE JOB AS PER SITE REQUIREMENTS.K.#ANY ITEM NOT MENTIONED</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503442  
**DATE** : 30.12.2025  
**REQ No** : 1032506404  
**REQ TITLE** : Replacement of Condenser Coil  
**DELIVERY LOCATION**  
**CLOSING DATE** : 06.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ED IN THE SCOPE BUT NECESSARY FOR THEINSTALLATION & COMMISSIONING OF CONDENSER COILS SHALL BE IN THECONTRACTOR'S SCOPE.3.#TECHNICAL SPECIFICATION OF EXISTING AND REQUIRED CONDENSER COILSSR.#UNIT DESCRIPTION#TYPE OF EXISTING CONDENSER COIL#NO. OF COILS#SIZE- L X H X W OF COIL IN MM#TYPE OF REQUIRED CONDENSER COILS1#CHILLER- 2YORK CHILLER MODEL: YVAA0413HBF50BAV(SUPPLY & SERVICES SCOPE)#ALUMINUM MICROCHANNEL#20#2115 X1211X 25#THERMO-GUARD COATED ALUMINUM MICROCHANNEL2#CHILLER- 2YORK CHILLER MODEL: YVAA0413HBF50BAV(SUPPLY & SERVICES SCOPE)#CU TUBE & AL FINS (GLYCOL)#4#450 X 600 X 25#THERMO-GUARD COATED COPPER TUBES WITH ALUMINUM FINS CONDENSER COILS3#SPAR E CONDENSER COIL (SUPPLY SCOPE ONLY)#ALUMINUM MICROCHANNEL#2#2115 X1211X 25#THERMO-GUARD COATED ALUMINUM						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503442  
**DATE** : 30.12.2025  
**REQ No** : 1032506404  
**REQ TITLE** : Replacement of Condenser Coil  
**DELIVERY LOCATION**  
**CLOSING DATE** : 06.01.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MICROCHANNEL COILS						
2		ITEM-00001	3.#REMOVAL OF FOUR EXISTING GLYCOL CONDENSER COILS OF COPPER TUBES &ALUMINUM FINS FOR VFD COOLING SYSTEM OF YORK CHILLER MODEL:YVAA0413HBF50BAV,AFTER RECOVERY OF GLYCOL FROM THE SYSTEM AND SUPPLY,INSTALLATION & COMMISSIONING OF NEW COILS OF SAME TYPE. (REFER TECHNICALSPECIFICATION TABLE ITEM- 2).	4	EA				
3		ITEM-00001	B.#SUPPLY SCOPE: THE CONTRACTOR SHALL SUPPLY 2 NOS. OF ALUMINUMMICROCHANNEL COILS OF YORK CHILLER MODEL: YVAA0413HBF50BAV, WITHTHERMOS-GUARD COATING. (REFER TECHNICAL SPECIFICATION TABLE ITEM-3)	2	EA				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### **SPECIAL NOTES / INSTRUCTIONS:**

Replacement of Condenser Coils of York VFD Chiller at G RO Plant.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503442  
**DATE** : 30.12.2025  
**REQ No** : 1032506404  
**REQ TITLE** : Replacement of Condenser Coil  
**DELIVERY LOCATION**  
**CLOSING DATE** : 06.01.2026  
**CLOSING TIME** : 10:00:00

Enquiry may send to Dolphin Radiators along with other parties

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
  - 2) Quotation to be submitted only in local currency U.A.E Dirhams
  - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
  - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
  - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
  - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332503442  
**DATE** : 30.12.2025  
**REQ No** : 1032506404  
**REQ TITLE** : Replacement of Condenser Coil  
**DELIVERY LOCATION**  
**CLOSING DATE** : 06.01.2026  
**CLOSING TIME** : 10:00:00

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**