

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATION TITLE: M STATION HRSG 21 DESUPERHEATER NOZZLE ASSEMBLY REPLACEMENT. A.#QUANTITY & SPECIFICATION:##QUANTITY: - 01##SIZE: DIA.- 457 MM X THICKNESS - 29.36 MM##MATERIAL: P 91##REF ER ATTACHED DRAWINGS. B.#DURATION:##04 DAYS. C.#SCHEDULE##WORK TO BE CARRIED OUT DURING OUTAGE IN BETWEEN JAN#26 TO MAY#27. ##THE EXACT UNIT AND SCHEDULE WILL BE CONFIRMED LATER. D.#PRE-BID SITE INSPECTION:##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED. E.#QUALIFICATION OF BIDDER:##THE	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBS AND SHALL SUBMIT EVIDENCE.##THE BIDDER SHALL BE A VALID ASME #R# STAMP HOLDER.##SCOPE OF WORK:##CONTRACTOR SHALL SUBMIT ITP ALONG WITH WPS, LIFTING PLAN AND ERECTION PLAN AFTER GETTING PO AND BEFORE COMMENCING OF WORK.##MOBILIZE MEN/EQUIPMENT WITHIN 01 DAY OF ADVANCE NOTICE.##OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE) & HOT WORK PERMIT FROM DEWA.##THE FOLLOWING DOCUMENTS TO BE SUBMITTED TO OBTAIN PTW,A.#METHOD STATEMENTB.#RISK ASSESSMENT OF THE WORKC.#TOOLBOX TALK REPORT.##ENSURE PROPER ISOLATION OF THE LINE & VALID HWP IS AVAILABLE.##ENSURE NO FLAMMABLE MATERIALS NEAR THE HOT WORK AREA.##ENSURE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.##CONDUCT SITE SURVEY AND SAFETY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSPECTION TO ASSESS THE WORKING ENVIRONMENT.## ARRICADE THE AREA WITH SIGNAGE.##VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALID SCAFFOLDING TAGS ARE PROVIDED PRIOR TO USE.##IF THE WORKING ENVIRONMENT IS SAFE, THEN THE CONTRACTOR CAN PROCEED WITH THE FOLLOWING STEPS.##FOR HOT WORK, WELDING BOOTHS ARE TO BE PROVIDED USING FIRE BLANKETS TO PREVENT WELDING SPARK, SPATTER OR CUTTING MATERIALS COMING OUT FROM HOT WORK AREA. ENSURE TO PROVIDE ENOUGH FIRE EXTINGUISHERS AND FIRE BLANKETS AT SITE.##REMOVE ALL THE REQUIRED CLADDING SHEETS, INSULATION AND INSULATION FIXING CLAMPS, KEEP THE DAMAGED INSULATION IN RED BAG AT DESIGNATED AREAS AS PER DEWA RULES AND REGULATIONS. KEEP THE CLADDING SHEET AND GOOD INSULATION IN A PROPER WAY.##PROTECT THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NEARBY/UNDERNEATH LINES/EQUIPMENT / CABLES BY USING AFIRE BLANKET.##CHECK THE NEW SPARE DESUPERHEATER A SSEMBLY DIMENSIONS ANDORIENTATIONS WITH THE EXISTING ASSEMBLY AND PRIOR TO START OF ANYCUTTING INFORM DEWA IF THERE IS ANY DIFFERENC E / ISSUE.##SHIFT THE NEW DESUPERHEATER ASSEMBLY TO WORKPLACE.##PREPARE ADDITIONAL SUPPORTS TO HOLD THE EXISTING PIPELINE IN POSITIO N AND CUT EXISTING SUPPORTS IF REQUIRED AND LOCK THE SPRING HANGER ALSO.##COMPARE THE DIMENSIONS & ORIENTATION OF DESUPERHEATER FOR SPRAYNOZZLE INSTALLATION. (DEWA WILL ARRANGE TO REMOVE AND REINSTALL THESPRAY NOZZLE)##REMOVE THE LUG PLATES FOR INSTRUMENTATION PIPING AND ANY OTHERSUPPORTS ATTACHED WITH PIPELINE IF ANY.##CUT AND REMOVE THE SPRAY WATER LINE. (DN 80, NUMBER OF JOINTS TO BECONFIRME</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>D BASED ON SITE VISIT)##CUT THE EXISTING DESUPERHEATER ASSEMBLY AFTER VERIFYING THE LENGTH OF PROVIDED NEW DESUPERHEATER ASSEMBLY AND</p> <p>AFTER MARKING THE ORIENTATIONS(LENGTH OF THE NEW DESUPERHEATER ASSEMBLY CAN BE VARIED FROM WHAT SHOWN IN THE DRAWING.</p> <p>BEFORE BIDDING</p> <p>, PARTY SHALL TAKE INTO CONSIDERATION OF ANY CHANGE OF LENGTH THAN EXISTING DESUPERHEATER ASSEMBLY)##REMOVE THE SEGMENT AND FIT UP WITH NEW DESUPERHEATER ASSEMBLY</p> <p>AFTER ALIGNING PROPERLY INCLUDING THE SPRAY NOZZLE.##SHIFT THE OLD ASSEMBLY FROM THE WORKPLACE AS INSTRUCTED BY DEWA.##FINAL ALIGNMENT OF EACH FIT-UP JOINT SHALL BE VERIFIED BY CONTRACTOR QC IN THE PRESENCE OF DEWA.##PREHEATING OF THE WELDING JOINTS.##WELD THE NEW DESUPERHEATER ASSEMBLY AND SPRAY WATER LINE JOINTS.##THE CONTRACTOR SHALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FABRICATE PAD SUPPORTS FROM REMOVED DESUPERHEATER ASSEMBLY PIPING AND SHALL FIX THE SAME IN NEW DESUPERHEATER PIPING ASSEMBLY AS PER EXISTING SUPPORT DIMENSION AND ORIENTATION IF REQUIRED.##APPLICABLE NDE OF THE WELD JOINT AS MENTIONED IN THE WPS.##UPON SUCCESSFUL NDE, PWHT OF THE WELD JOINT.##R EINSTATE ALL SUPPORTS IF REMOVED OR LOCKED.##REMOVE ALL TEMPORARY SUPPORT.##REMOVE OLD PIPE, ALL METAL SCRAPS, TEMPORARY SUPPORTS AND ANY OTHER SCRAPS FROM WORKPLACE AND DISPOSE AS PER DEWA ENGINEER INSTRUCTION.##AFTER FINAL CLEARANCE FROM DEWA, INSTALL BACK INSULATION CLAMPS, INSULATION AND CLADDING SHEETS.##AFTER COMPLETION OF THE ABOVE SCOPE OF WORK, A JOINT INSPECTION SHALL BE DONE WITH DEWA ENGINEER.##A QUALIFIED JOB SUPERVISOR SHALL BE ASSIGNED FOR THE JOB.##SKILLED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FABRICATORS / QUALIFIED WELDERS SHALL CARRY OUT ALL THE JOBS.##WELD JOINTS TO BE MADE BY QUALIFIED WELDER ACCORDING TO APPLICABLE WPS & ASME REQUIREMENTS. (PQR, WPS & WELDER CERTIFICATES)</p> <p>TO BE PROVIDED BY THE CONTRACTOR IN ADVANCE)##CERTIFIED AND QUALIFIED RIGGERS TO BE ENGAGED FOR ALL RIGGING WORK.##HOUSEKEEPING AND DISPOSAL OF WASTE TO BE DONE BEFORE SITE CLEARANCE.##DE-MOBILIZE MEN AND EQUIPMENT AFTER COMPLETION OF THE JOB.##WORK COMPLETION REPORT TO BE SUBMITTED. REPORT SHALL CONTAIN RELEVANT PHOTOS.##ALL CONSUMABLES, TOOLS & TACKLES ARE IN CONTRACTOR'S SCOPE.##PROPER AND TESTED TOOLS TO BE USED.##ALL LIFTING & POWER TOOLS SHALL HAVE VALID 3RD PARTY TEST CERTIFICATE AND TO BE SUBMITTED TO DEWA IN ADVANCE.</p> <p>##WELDING MACHINES SHALL HAVE A VALID 3RD</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PARTY CALIBRATION CERTIFICATE AND TO BE SUBMITTED TO DEWA IN ADVANCE.##WORK COMPLETION REPO RT, FULL REPAIRING REPORTS, MATERIAL TEST CERTIFICATES, WELDING CONSUMABLE & MATERIAL TEST CERTIFICATES TO BE SUBMITTED TO DEWA##DEWA SCOPE: A.#SCAFFOLDING (CONTRACTOR TO PROVIDE REQUIREMENT IN ADVANCE) B.#NDE, PREHEATING AND PWHTC. #SUPPLY OF DESUPERHEATER ASSEMBLY. D. #CRANE IF REQUIRED. HOWEVER, THE CONTRACTOR SHALL SUBMIT REQUEST ATLEAST 02 WORKING DAYS IN ADVANCE MENTIONING THE CAPACITY AND WITH LIFTING PLAN. NOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES A BROAD OUTLINE OF THE TASK. THE BIDDER MUST REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORK TO CARRY OUT REQUIRED TASKS AND ADD ANY ADDITIONAL WORKS THAT ARE NEEDED FOR SATISFACTORY COMPLETION OF THIS P						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROJECT.G.#WARRANTY##THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OF COMPLETION OF WORK CERTIFIED BY DEWA.##IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORT PERIOD.H.#GENERAL TERMS & CONDITIONS##CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SAME JOB##CONTRACTOR SHALL SUBMIT METHOD OF STATEMENT, WPS AND SCHEDULE UPON RECEIPT OF PO.##ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THESE EQUIPMENT#S SHOULD BE DULY TESTED AND CERTIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED.##THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID.##THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATED PLACES.##ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATION SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA.##SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA.##THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT.##CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600025
DATE : 06.01.2026
REQ No : 1032600051
REQ TITLE : PRJ-M Station HRSG 21
DELIVERY LOCATION
CLOSING DATE : 12.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE PERIOD OF WORK.## DEWA WILL ARRANGE NECESSARY PTW / L C / HWP FROM OPERATION, CHEMICAL LAB / FIRE DEPARTMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDER THIS CONTRACT.## THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.## ALL THE PERSONS SHOULD WEAR ALL THE REQUIRED PPE						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

PRJ-M Station HRSG 21 Desuperheater Nozzle Assembly replacement.(SCOPE OF WORK ATTACHED)
BIDDER MUST BE 'R' STAMP

CONTACT-SHABBIR.ENULHAQUE@DEWA.GOV.AE

STANDARD TERMS & CONDITIONS

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332600025
DATE	: 06.01.2026
REQ No	: 1032600051
REQ TITLE	: PRJ-M Station HRSG 21
DELIVERY LOCATION	
CLOSING DATE	: 12.01.2026
CLOSING TIME	: 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP