

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE:</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6 310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: T OSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487</p>						
2		ITEM-00001	<p>FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PERIOD WILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE</p> <p>D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH</p> <p>SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA</p> <p>ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90</p> <p>-Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: TOSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL:</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487						
3		ITEM-00001	FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: TOSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487						
4		ITEM-00001	FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6 310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: T OSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14 MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487</p>						
5		ITEM-00001	FABRICATION THE LV MOTORS COOLING FANS AS	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: T OSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487</p>						
6		ITEM-00001	<p>FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: TOSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS;</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLEASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487						
7		ITEM-00001	HRSG DUCT BURNER AGMNT ,75 KW	2	EA				
8		ITEM-00001	FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V- 50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6 310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: T OSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487						
9		ITEM-00001	FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6 310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: T OSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487</p>						
10		ITEM-00001	FABRICATION THE LV MOTORS COOLING FANS AS	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: T OSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487</p>						
11		ITEM-00001	<p>FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: TOSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS;</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLEASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487						
12		ITEM-00001	FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLING FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDED DURING ANNUAL OH OF MOTORS IN 2024-2025.5	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>-FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: TOSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE:						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE)</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487						
13		ITEM-00001	FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6 310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90 -Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: T OSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14 MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA</p> <p>TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND</p> <p>E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KW FOR ANY TECHNICAL CLARIFICATIONS PLE</p> <p>ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102</p> <p>2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487</p>						
14		ITEM-00001	FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE D DURING ANNUAL OH OF MOTORS IN 2024-2025.5 -FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH SE.M2BA 132 S4 A, 3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL: HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6310ZC3,ENCL:IP65,AMPS: 44.5,CODE:</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90</p> <p>-Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: T OSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487</p>						
15		ITEM-00001	<p>FABRICATION THE LV MOTORS COOLING FANS AS PER THE SAMPLES.1-ALUMINUM MATERIAL SHALL BE USE FOR FABRICATION AND DO BALANCING THECOOLI NG FAN.2 -THE VENDOR SHALL PROVIDE 6 MONTHS WARRANTY AND THE WARRANTY PERIODWILL START FROM THE DATE OF DELIVERY OF MOTOR.3-COLLECT</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE SAMPLE ONCE GET PO AND DELIVER THE MATERIAL TO DEWA, JAPS,L1-STATION, EMD -DEPT., JABEL ALI, DUBAI.4-FAN SAMPLES WILL BE PROVIDE</p> <p>D DURING ANNUAL OH OF MOTORS IN 2024-2025.5</p> <p>-FOR MORE DETAIL, PLEASE REVIEW THE MOTOR NAME PLATE W.R.T SR#.MOTOR SR#1MAKE: ABB, 3-PH</p> <p>SE.M2BA 132 S4 A,</p> <p>3GBA132110-ASA/EEXNA.11.T3/11 2G/2003,400V-50HZ, 4.8KWMOTOR SR#2HRSG BLOWDOWN PUMP MOTOR, 22KW(30HP) -4P-380V,FRA</p> <p>ME 180M,SLNO.8CO73E01-001,HYUNDAI HEAVY INDUSTRIES,MODEL:</p> <p>HL1830R257HPTJP,DUTY:CONT,TYPE: HL/SD-F,BEARING DE:6310ZC3,BEARING NDE: 6310ZC3,ENCL:IP65,AMPS: 44.5,CODE: H,HERTZ:50H.MOTOR SR#3MOTOR FOR VAPOR EXTRACTOR, KW: 4.5, AMPS: 9.0, 380V, 50HZ, TYPE:1LA61302AA90</p> <p>-Z, IMB3, 132S, IP: 55, PF: 0.89, RPM: 2925, MADE INGERMANY.MOTOR SR#4BPST TURNING GEAR MOTOR 6310ZZ P/N.2.8.52CNE/015/2002 (MAKE: T</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OSHIBA,5KW, 380V-3PHASE, 50HZ, 36A, 1450RPM, TYPE: TIKK, FRAME SIZE: 180M.MOTOR SR#5DC MOTOR FOR EMERGENCY SEAL OIL PUMP,20 HP,3000 RPM,120V DC, 140 AMP,SHUNT WOUND,0.88A FIELD AMP, 120 OHM FIELD OHM AT 25DEG C, CLASS FINSULATION,CONT DUTY,FIELD VOLTAGE 120V,TYPE CD328APY,ENCL TEFC, MODEL#5BY536ZD808C800, SER YV-8-79-ZV.MOTOR SR#6MOTOR FOR GT WATER WASH SKID, HP: 20, AMPS:26, VOLTS:400, HZ:50 ,RPM:2910, FRAME:284TSC, MAKE:BALDOR RELIANCER.MOTOR SR#7MOTOR FOR HRSG DUCT BURNER AGMNT AIR FAN, HP:100, AMPS:133, 380V, 50HZ, SP EC:16H066Y149G1, FRAME:D250M, RPM:2900.MOTOR SR#8MOTOR FOR GT WATER INJECTION PUMP, HP: 350, AMPS: 461, VOLTS: 380, HZ:50, RPM: 2970 , PF: 0.90, FRAME SIZE: 449TS, MODEL: 5KS449AS1005, MAKE:GEMOTOR SR#9GT 88BT FAN MOTOR 100HP/75KW MOTOR FR 280S, PN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CF-24316-121-CMO TOR SR#10DM PLANT NEUTRALIZATION PIT MOTORS 415/3/50, PN 4681-0706-MTR, 60 HP.MOTOR SR#11CLEAN DRAIN PUMP ASSEMBLY WITH MOTOR, TYPE: 150WUC-2M-4/WUCBRNG211290PUM,S/N: G211290,TAG NO: 70LCM12AP001,MAKE: FLOW SERVEMOTOR SR#12MOTOR FOR EHC OIL PUMP OF BPST, KW: 37, A MPS: 74A, VOLTAGE: 380V, 50HZ,RPM: 980, FRAME SIZE: F50-250, MAKE: TOSHIBAMOTOR SR#13BPST LUBE OIL MAIN PUMP MOTOR P/N.25.2CNE/015/2 002 MAKE: TOSHIBA, 55KW,380V-3 PHASE, 102A, 50HZ, 1450 RPM MOTOR SR#14MOTOR FOR MIXED BED AIR BLOWER, KW:30, RATED CURRENT: 55.7A, RA TEDVOLTAGE:380V, FRAME SIZE:200Z, 50HZ, 2POLE, RATED SPEED:2960RPM, INSLCLASS:F, DUTY CYCLE:S1, IP:55, BEARING DE:6312-C3, BEARINGND E:6212-Z-C3.MOTOR SR# 15CONDENSATE TRANSFER PUMP (TESTIAC); MAKE SIEMENS; MODEL 1AV3163A; 13.8KWFOR ANY TECHNICAL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CLARIFICATIONS PLE ASE CONTACT MR. AMEER SHAIK(AMEER.SHAIK@DEWA.GOV.AE) 0553876541 / 048024554 (OR) MR. MUDASSAR(MUDASSAR.ASGHAR@DEWA.GOV.AE) 056272102 2 / 048024556 MR. SAIF ALSUBOUSI(SAIF.ALSUBOUSI@DEWA.GOV.AE) 0507447487						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

FABRICATION OF COOLING FANS FOR LOW VOLTAGE MOTORS AS PER THE SAMPLES.

FOR L1 STATION EMD.

FOR ANY TECHNICAL CLARIFICATIONS PLEASE CONTACT MR. AMEER SHAIK

(ameer.shaik@dewa.gov.ae) 0553876541 / 048024554 (OR) MR. MUDASSAR (

mudassar.asghar@dewa.gov.ae) 0562721022 / 048024556 MR. SAIF ALSUBOUSI (saif.alsubousi@dewa.gov.ae) 0507447487

STANDARD TERMS & CONDITIONS

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

- 2) Quotation to be submitted only in local currency U.A.E Dirhams
 - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
 - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
 - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
 - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600192
DATE : 22.01.2026
REQ No : 1032600153
REQ TITLE : FABRICATION OF COOLING
DELIVERY LOCATION
CLOSING DATE : 30.01.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP