

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600271
DATE : 29.01.2026
REQ No : 1032600445
REQ TITLE : JAPS L1-STATION GAS
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|--|-----|-----|--------------|----------|------------|-------------|
| 1 | | ITEM-00001 | <p>SCOPE OF WORK: GTL-71 (GE FRAME 9FA) # DIFFUSER CONE OUTSIDE INSULATION INTEGRITY INSPECTION & REPAIRS</p> <p>SCOPE OVERVIEW: THIS SCOPE OF WORK IS TO CARRY OUT INSPECTION, ASSESSMENT, AND REPAIR OF THE OUTSIDE HIGH-TEMPERATURE INSULATION SYSTEM OF THE GAS TURBINE GTL-71 DIFFUSER CONE TO RESTORE AND ENSURE INSULATION INTEGRITY, PERSONNEL SAFETY, AND COMPLIANCE WITH APPLICABLE STANDARDS AND OEM RECOMMENDATION</p> <p>S. SCOPE OF WORK: 1. # VISUAL AND PHYSICAL INSPECTION OF EXISTING DIFFUSER CONE OUTSIDE INSULATION, INSULATION CLADDING, AND FASTENING SYSTEM. 2. # IDENTIFICATION OF DAMAGED, LOOSE, MISSING, OR DEGRADED INSULATION MATERIAL, INSULATION BLANKETS/CLOTHES, CLADDING SHEETS, AND FASTENERS. 3. # ASSESSMENT OF INSULATION INTEGRITY WITH RESPECT TO THERMAL PERFORMANCE, HOT SPOTS, AND</p> | 1 | EA | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600271
DATE : 29.01.2026
REQ No : 1032600445
REQ TITLE : JAPS L1-STATION GAS
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|--|-----|-----|--------------|----------|------------|-------------|
| | | | MECHANICAL DAMAGE.4.#SUBMISSION OF INSPECTION FINDINGS AND RECOMMENDED REPAIR SCOPE TO THE MAINTENANCE TEAMS PRIOR TO EXECUTION.5.#REMOVAL OF DAMAGED OR DEFECTIVE INSULATION MATERIALS, INSULATION CLOTHES/BLANKETS, CLADDING, AND FASTENERS AS REQUIRED.6.#SUPPLY AND INSTALLATION OF NEW HIGH-TEMPERATURE INSULATION MATERIALS SUITABLE FOR GE FRAME 9FA DIFFUSER CONE OPERATING TEMPERATURES.7.#SUPPLY INSTALLATION OF INSULATION BLANKETS/ CLOTHES WITH PROPER FITTING TO AVOID GAPS, SAGGING, OR THERMAL BRIDGES.8.#SUPPLY AND INSTALLATION OF CLADDING WITH PROPER OVERLAPS AND SEALING.9.#REPLACEMENT AND TIGHTENING OF ALL REQUIRED FASTENERS TO ENSURE SECURE FIXING AND LONG-TERM INTEGRITY.10.#ENSURING INSULATION THICKNESS, DENSITY, AND INSTALLATION METHOD MEET OEM AND INDUSTRY | | | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600271
DATE : 29.01.2026
REQ No : 1032600445
REQ TITLE : JAPS L1-STATION GAS
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| | | | <p>STANDARDS.11.#CONTRACTOR SHALL SUPPLY ALL REQUIRED MATERIALS, INCLUDING BUT NOT LIMITED TO:A.#HIGH-TEMPERATURE INSULATION MATERIALS.B.#INSULATION BLANKETS/CLOTHES.C.#CLADDING SHEETS.D.#FASTENERS, BANDS, CLIPS, AND ACCESSORIES.E.#ALL TOOLS, EQUIPMENT, AND CONSUMABLES NECESSARY FOR SAFE AND EFFICIENT EXECUTION OF THE WORK.12.#ALL WORK SHALL BE CARRIED OUT IN ACCORDANCE WITH OEM RECOMMENDATIONS, APPLICABLE INTERNATIONAL STANDARDS, AND SITE SAFETY PROCEDURES.13.# CONTRACTOR SHALL ENSURE PROPER WORKMANSHIP, ALIGNMENT, AND FINISHING OF INSULATION AND CLADDING.14.#HOUSEKEEPING AND REMOVAL OF DEBRIS FROM THE WORK AREA UPON COMPLETION.15.#ALL REMOVED INSULATION DISPOSAL CARRIED OUT AS PER DUBAI MUNICIPAL GUIDELINES.16.#CONTRACTOR</p> | | | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600271
DATE : 29.01.2026
REQ No : 1032600445
REQ TITLE : JAPS L1-STATION GAS
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| | | | SHALL PROVIDE QUALIFIED, EXPERIENCED, AND CERTIFIED MANPOWER FOR INSULATION INSPECTION AND REPAIR WORKS ON GAS TURBINES.17.#CONTRACTOR SHALL PROVIDE INSPECTION AND REPAIR COMPLETION REPORT.18.#CONTRACTOR SHALL PROVIDE LIST OF MATERIALS USED AND AREAS REPAIRED.19.#CONFIRMATION OF INSULATION INTEGRITY RESTORATION.20.#THE CONTRACTOR SHALL BE FULLY RESPONSIBLE FOR MATERIALS, WORKMANSHIP, TOOLS, SAFETY COMPLIANCE, AND QUALITY OF EXECUTION THROUGHOUT THE DURATION OF THE WORK.21.#THE WORK SHALL BE COMPLETED WITHIN THE AGREED TIME FRAME AS PER SITE SCHEDULE AND COORDINATION WITH MAINTENANCE TEAMS. NOTE: THIS SCOPE OF WORK IS INTENDED TO OUTLINE THE GENERAL TASKS AND REQUIREMENTS. CONTACT PERSON FROM DEWA1. SYED SHOWKAT ALI - SYEDS.ALI@DEWA.GOV.AE / 048140513 OR2. MUHAMMAD SHAMIM KHAN- | | | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600271
DATE : 29.01.2026
REQ No : 1032600445
REQ TITLE : JAPS L1-STATION GAS
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| | | | MUHAMMAD.KHAN @DEWA.GOV.AE / 043226023 | | | | | | |

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

JAPS L1-STATION GAS TURBINE GTL71 DIFFUSER CONE OUTSIDE INSULATION

INTEGRITY INSPECTION <(>&<>) REPAIR. For any additional information /

details, please contact: Muhammad.Khan@dewa.gov.ae / 04-32-26023 /

+971502806027

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

| | |
|--------------------------|-----------------------|
| RFQ NUMBER | : 2332600271 |
| DATE | : 29.01.2026 |
| REQ No | : 1032600445 |
| REQ TITLE | : JAPS L1-STATION GAS |
| DELIVERY LOCATION | |
| CLOSING DATE | : 04.02.2026 |
| CLOSING TIME | : 10:00:00 |

connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP