

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600298
DATE : 03.02.2026
REQ No : 1032600516
REQ TITLE : G station Desalination Plant
DELIVERY LOCATION
CLOSING DATE : 09.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SCOPE OF WORK:#COMPLETELY REMOVE THE EXISTING SCALE/CORROSION TO BARE METAL FINISHBY ABRASIVE BLAST CLEANING TO MINIMUM SA 2.5 AS PE R ISO 8501 AND CREATEREQUIRED PROFILE FOR NEW COATING ADHESION. MANUAL CLEANING USING HANDAND POWER TOOLS WHEREVER NECESSARY AT NON-REACHABLE AREAS..#SUPPLYING SUITABLE BLAST GRITS, SEALANTS, CLEANING AGENTS, ALLAPPLICABLE COATING MATERIALS, APPLICATION / INSPECTI ON TOOLS & EQUIPMENTAND ALL REQUIRED CONSUMABLES ARE TO BE COVERED UNDER THIS CONTRACT..#REPAIR FOR ALL CORRODED AND PITTED LOCATION S BY WELD AND GRIND THEWELDED AREA TO ACHIEVE SMOOTH SURFACE BEFORE APPLICATION OF COATINGSYSTEM. ANY OTHER SUITABLE REPAIR METHOD S HALL BE APPROVED BY DEWAENGINEER IN CHARGE..#THE BLASTED SURFACE SHALL BE CLEANED WITH POTABLE WATER ANDDEGREASED,	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600298
DATE : 03.02.2026
REQ No : 1032600516
REQ TITLE : G station Desalination Plant
DELIVERY LOCATION
CLOSING DATE : 09.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND SURFACE SHALL BE SUBJECTED TO CHLORIDE FREE TEST BEFORE APPLICATION OF COATING. #BIDDER NEED TO ENSURE THAT THE ENTIRE PUMP CASING IS THOROUGHLY COVERED WITH BELZONA 1121 METAL PUTTY. THIS IS CRUCIAL FOR ACHIEVING THE BEST RESULTS AND ENSURING THE INTEGRITY OF THE REPAIR. ONCE THE METALPUTTY HAS BEEN APPLIED AND CURED, BIDDER WILL PROCEED WITH APPLYING TWO COATS OF BELZONA 5821 CERAMIC COATING. OUR GOAL IS TO ACHIEVE A DRY FILM THICKNESS (DFT) OF 500 MICRONS, ENSURING OPTIMAL PROTECTION AND DURABILITY. #THE COATED SURFACE SHOULD BE SMOOTH AND FREE OF SAG. AFTER COMPLETION OF THE COATING AND FULLY DRIED, THE WHOLE SURFACE WILL BE SCANNED WITH SPARK TESTER. THE SURFACE SHOULD SHOW #ZERO# DEFECTS. IN CASE OF ANY DEFECT, THE SURFACE SHALL BE REPAIRED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600298
DATE : 03.02.2026
REQ No : 1032600516
REQ TITLE : G station Desalination Plant
DELIVERY LOCATION
CLOSING DATE : 09.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND RECOATED AS RECOMMENDED BY THEPAINT MANUFACTURER..#CONTRACTOR SHALL SUBMIT THE COMPLETE QUALITY PROCEDURE OF COATINGAPPLICATION ALONG WITH INTERNAL TEST PLAN ALONG WITH OFFER FOREVALUATION..#CONTRACTOR SHALL SUBMIT BACK-TO-BACK COATING PRODUCT WARRANTY FORPERIOD OF 5 YEAR ANY DEFECTS NOTICED WITHIN THE WARRANTY PERIOD SHALL BEREPAIRED AS PER COATING MANUFACTURE REPAIR PROCEDURES WITHOUT ADDITIONALCOST TO DEWA..#UPON APPLICATION COATING ADHESION TEST SHALL BE CARRIED OUT AS PERTHE MANUFACTURER GUIDELINES..#THE APPLICATORS (PAINTERS) SHOULD HAVE ADEQUATE SKILL AND EXPERIENCEWITH THE PAINT SYSTEM, ESPECIALLY THE GLASS FLAKE FILLED SYSTEM. HESHOULD ALSO PROVE IT WITH A CERTIFICATE OF PROFICIENCY FOR THAT EFFECT ISSUED BY THE PAINT MANUFACTURER..#FOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600298
DATE : 03.02.2026
REQ No : 1032600516
REQ TITLE : G station Desalination Plant
DELIVERY LOCATION
CLOSING DATE : 09.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANY FURTHER CLARIFICATIONS YOU MIGHT NEED, PLEASE FEEL FREE TOCONTACT MR. MOHAMMAD RAFI, SEN IOR ENGINEER. YOU CAN REACH THEM VIA EMAILAT MOHAMMAD.HOSUR@DEWA.GOV.AE OR BY PHONE AT 08044964/0529740743.						
2		ITEM-00001	SCOPE OF WORK:#COMPLETELY REMOVE THE EXISTING SCALE/CORROSION TO BARE METAL FINISHBY ABRASIVE BLAST CLEANING TO MINIMUM SA 2.5 AS PE R ISO 8501 AND CREATEREQUIRED PROFILE FOR NEW COATING ADHESION. MANUAL CLEANING USING HANDAND POWER TOOLS WHEREVER NECESSARY AT NON- REACHABLE AREAS.#SUPPLYING SUITABLE BLAST GRITS, SEALANTS, CLEANING AGENTS, ALLAPPLICABLE COATING MATERIALS, APPLICATION / INSPECTI ON TOOLS & EQUIPMENTAND ALL REQUIRED CONSUMABLES ARE TO BE COVERED UNDER THIS CONTRACT.#REPAIR FOR ALL CORRODED AND PITTED LOCATION S BY WELD AND GRIND THEWELDED AREA TO	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600298
DATE : 03.02.2026
REQ No : 1032600516
REQ TITLE : G station Desalination Plant
DELIVERY LOCATION
CLOSING DATE : 09.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ACHIEVE SMOOTH SURFACE BEFORE APPLICATION OF COATINGSYSTEM. ANY OTHER SUITABLE REPAIR METHOD S</p> <p>HALL BE APPROVED BY DEWAENGINEER IN CHARGE..#THE BLASTED SURFACE SHALL BE CLEANED WITH POTABLE WATER ANDDEGREASED, AND SURFACE SHALL BE SUBJECTED TO CHLORIDE FREE TEST BEFOREAPPLICATION OF COATING..#BIDDER NEED TO ENSURE THAT THE ENTIRE PUMP CASING IS THOROUGHLYCO</p> <p>VERED WITH BELZONA 1121 METAL PUTTY. THIS IS CRUCIAL FOR ACHIEVING THEBEST RESULTS AND ENSURING THE INTEGRITY OF THE REPAIR. ONCE TH</p> <p>E METALPUTTY HAS BEEN APPLIED AND CURED, BIDDER WILL PROCEED WITH APPLYING TWO COATS OF BELZONA 5821 CERAMIC COATING. OUR GOAL IS TO</p> <p>ACHIEVE A DRY FILMTHICKNESS (DFT) OF 500 MICRONS, ENSURING OPTIMAL PROTECTION ANDDURABILITY..#THE COATED SURFACE SHOULD BE SMOOTH AN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600298
DATE : 03.02.2026
REQ No : 1032600516
REQ TITLE : G station Desalination Plant
DELIVERY LOCATION
CLOSING DATE : 09.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>D FREE OF SAG. AFTER COMPLETION OF THE COATING AND FULLY DRIED, THE WHOLE SURFACE WILL BE SCANNED WITH SPARK TESTER. THE SURFACE SHOULD SHOW #ZERO# DEFECTS. IN CASE OF ANY DEFECT, THE SURFACE SHALL BE REPAIRED AND RECOATED AS RECOMMENDED BY THE PAINT MANUFACTURER. #CONTRACTOR SHALL SUBMIT THE COMPLETE QUALITY PROCEDURE OF COATING APPLICATION ALONG WITH INTERNAL TEST PLAN ALONG WITH OFFER FOR EVALUATION. #CONTRACTOR SHALL SUBMIT BACK-TO-BACK COATING PRODUCT WARRANTY FOR PERIOD OF 5 YEAR ANY DEFECTS NOTICED WITHIN THE WARRANTY PERIOD SHALL BE REPAIRED AS PER COATING MANUFACTURE REPAIR PROCEDURES WITHOUT ADDITIONAL COST TO DEWA. #UPON APPLICATION COATING ADHESION TEST SHALL BE CARRIED OUT AS PER THE MANUFACTURER GUIDELINES. #THE APPLICATORS (PAINTERS) SHOULD HAVE ADEQUATE SKILL AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600298
DATE : 03.02.2026
REQ No : 1032600516
REQ TITLE : G station Desalination Plant
DELIVERY LOCATION
CLOSING DATE : 09.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EXPERIENCE WITH THE PAINT SYSTEM, ESPECIALLY THE GLASS FLAKE FILLED SYSTEM. HE SHOULD ALSO PROVE IT WITH A CERTIFICATE OF PROFICIENCY FOR THAT EFFEC ISSUED BY THE PAINT MANUFACTURER. #FOR ANY FURTHER CLARIFICATIONS YOU MIGHT NEED, PLEASE FEEL FREE TO CONTACT MR. MOHAMMAD RAFI, SENIOR ENGINEER. YOU CAN REACH THEM VIA EMAIL AT MOHAMMAD.HOSUR@DEWA.GOV.AE OR BY PHONE AT 08044964/0529740743.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

G station Desalination Plant 13, Blow down pump and seawater recycle pump blasting and coating works.

For any further clarifications contact mohammad.hosur@dewa.gov.ae / 08044964/0529740743.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332600298
DATE	: 03.02.2026
REQ No	: 1032600516
REQ TITLE	: G station Desalination Plant
DELIVERY LOCATION	
CLOSING DATE	: 09.02.2026
CLOSING TIME	: 10:00:00

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600298
DATE : 03.02.2026
REQ No : 1032600516
REQ TITLE : G station Desalination Plant
DELIVERY LOCATION
CLOSING DATE : 09.02.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP