

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600306  
**DATE** : 03.02.2026  
**REQ No** : 1032600494  
**REQ TITLE** : Supply and Replacement of Exi  
**DELIVERY LOCATION**  
**CLOSING DATE** : 09.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>DEWA-CONFIDENTIAL SUPPLY AND REPLACEMENT OF EXISTING AHU FAN MOTORS AT AL WARSAN TP ADMINBUILDING.1. SCOPE OF WORKTHE SCOPE OF THIS PROJECT INCLUDES THE SUPPLY, REPLACEMENT,INSTALLATION, TESTING, AND COMMISSIONING OF EXISTING AIR HANDLING UNIT(AHU) FAN MOTORS AT AL WARSAN TP ADMIN BUILDING. THE REPLACEMENT FANMOTORS SHALL BE OF THE SAME BRAND (TECO), MODEL SERIES, CAPACITY, SPEED,AND ELECTRIC AL CHARACTERISTICS AS THE EXISTING MOTORS, ENSURING 100%COMPATIBILITY WITH THE EXISTING AHU SYSTEMS, FAN ASSEMBLIES, ANDELECTRICAL/C ONTROL ARRANGEMENTS.THE MOTORS LISTED IN THE SCHEDULE UNDER CLAUSE 3.4 SHALL BE SUPPLIED ANDINSTALLED STRICTLY ON A LIKE-FOR-LIKE RE PLACEMENT BASIS, WITH NODEVIATION IN MAKE, CAPACITY, RPM, OR MOUNTING ARRANGEMENT.2. GENERAL REQUIREMENTS##THE CONTRACTOR</p>	1	NO				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600306  
**DATE** : 03.02.2026  
**REQ No** : 1032600494  
**REQ TITLE** : Supply and Replacement of Exi  
**DELIVERY LOCATION**  
**CLOSING DATE** : 09.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL CONDUCT A DETAILED SITE SURVEY PRIOR TO EXECUTION TO VERIFY THE EXISTING MOTOR SPECIFICATIONS, RATINGS, MOUNTING ARRANGEMENTS, AND ELECTRICAL CONNECTIONS.## ALL SUPPLIED MOTORS SHALL BE NEW AND ORIGINAL FROM THE MANUFACTURER(OEM).## THE REPLACEMENT WORKS SHALL NOT ALTER THE EXISTING AHU PERFORMANCE, AIRFLOW, STATIC PRESSURE, OR SYSTEM BALANCE.## ALL WORKS SHALL BE EXECUTED DURING APPROVED WORKING HOURS AND COORDINATED WITH THE SITE REPRESENTATIVE.## NECESSARY SHUTDOWNS, ISOLATION, AND REINSTATEMENT OF SYSTEMS SHALL BE INCLUDED IN THE SCOPE.3. TECHNICAL SPECIFICATIONS # AHU FAN MOTORS THE AHU FAN MOTORS TO BE SUPPLIED AND INSTALLED SHALL MEET THE FOLLOWING MINIMUM REQUIREMENTS:3.1 MOTOR MAKE AND MODEL## MAKE: TECO## MODEL SERIES:</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600306  
**DATE** : 03.02.2026  
**REQ No** : 1032600494  
**REQ TITLE** : Supply and Replacement of Exi  
**DELIVERY LOCATION**  
**CLOSING DATE** : 09.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AEEBKB-FMTL##CONDITION: BRAND NEW, UNUSED, OEM SUPPLIED##APPLICATION: AHU FAN DUTY##3.2 ELECTRICAL CHARACTERISTICS##SUPPLY VOLTAGE: 415 V ±10##FREQUENCY: 50 HZ##PHASE: 3 PHASE##DUTY TYPE: CONTINUOUS DUTY (S1)##INSULATION CLASS: CLASS F (MINIMUM)##PROTECTION CLASS: IP55 (MINIMUM)##EFFICIENCY: SAME AS EXISTING (IE2 / IE3 AS APPLICABLE) DEWA-CONFIDENTIAL3.3 MECHANICAL CHARACTERISTICS##SPEED (RPM): SAME AS EXISTING MOTOR##MOUNTING ARRANGEMENT: SAME AS EXISTING (B3 / B5 / B35 OR EQUIVALENT)##COOLING TYPE: TEFC OR AS PER EXISTING##SHAFT SIZE AND KEYWAY: SAME AS EXISTING##BEARINGS: HEAVY-DUTY SEALE D BALL BEARINGS SUITABLE FOR AHU APPLICATION##ROTATION DIRECTION: SAME AS EXISTING3.4 EXISTING AHU FAN MOTOR SCHEDULE (LIKE-FOR-LIKE REPLACEMENT) SL. NO#MAKE #MODEL NO.						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600306  
**DATE** : 03.02.2026  
**REQ No** : 1032600494  
**REQ TITLE** : Supply and Replacement of Exi  
**DELIVERY LOCATION**  
**CLOSING DATE** : 09.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			#SERIAL NO. #PHASE #HZ #RPM #KW #HP #REQUIREDQTY #1 #TECO #AEEBKB-FMTL #1273000910-1 #3 #50 #145 0 #15 #20 #1 #2 #TECO #AEEBKB-FMTL #1273000909-1 #3 #50 #1455 #11 #15 #1 #3 #TECO #AEEBKB-FMTL #1273000907-1 #3 #50 #1450 #7.5 #10 # 1 #4 #TECO #AEEBKB-FMTL #1273000905-1 #3 #50 #1450 #5.5 #7.5 #1 #5 #TECO #AEEBKB-FMTL #1372006533-4 #3 #50 #1440 #4 #5 #1 #6 #TECO # AEEBKB-FMTL #1372006534-2 #3 #50 #1435 #3 #4 #1 #7 #TECO #AEEBKB-FMTL #1372006532-1 #3 #50 #1425 #2.2 #3 #1 #4. COMPATIBILITY REQUI REMENTS##THE NEW MOTOR SHALL BE FULLY COMPATIBLE WITH THE EXISTING##FAN ASSEMBLY##PULLEYS AND BELTS (IF APPLICABLE)##VARIABLE FREQUE NCY DRIVE (VFD), IF INSTALLED##MOTOR STARTER AND PROTECTION DEVICES##NO MODIFICATION TO THE AHU CASING, BASE FRAME, ELECTRICAL PANEL S, ORCONTROL WIRING SHALL BE REQUIRED.5. INSTALLATION WORKSTHE CONTRACTOR SHALL						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600306  
**DATE** : 03.02.2026  
**REQ No** : 1032600494  
**REQ TITLE** : Supply and Replacement of Exi  
**DELIVERY LOCATION**  
**CLOSING DATE** : 09.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING INSTALLATION ACTIVITIES:##SAFE DISMANTLING AND REMOVAL OF EXISTING DEFECTIVE FAN MOTORS##SUPPLY AND INSTALLATION OF NEW FAN MOTORS DEWA-CONFIDENTIAL##ALIGNMENT OF MOTOR AND FAN (BELT / DIRECT COUPLING)##REPLACEMENT OF BELTS (IF DISTURBED OR DAMAGED DURING WORKS)##ELECTRIC AL TERMINATION, EARTHING, AND INSULATION CHECKS##REINSTATEMENT OF AHU PANELS AND ACCESS COVERS6. TESTING AND COMMISSIONING AFTER INSTALLATION, THE CONTRACTOR SHALL CARRY OUT THE FOLLOWING:##INSULATION RESISTANCE (IR) TESTING##NO-LOAD AND LOAD RUN TESTING##VERIFICATION OF CURRENT, VOLTAGE, AND ROTATION DIRECTION##CHECKING VIBRATION AND NOISE LEVELS##FUNCTIONAL TESTING OF AHU OPERATION WITH BMS / CONTROLS##A COMMISSIONING REPORT SHALL						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600306  
**DATE** : 03.02.2026  
**REQ No** : 1032600494  
**REQ TITLE** : Supply and Replacement of Exi  
**DELIVERY LOCATION**  
**CLOSING DATE** : 09.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BE SUBMITTED FOR APPROVAL.7. STANDARDS AND CODES THE SUPPLY AND INSTALLATION SHALL COMPLY WITH THE LATEST EDITIONS OF THE FOLLOWING STANDARDS:##IEC / BS / ISO STANDARDS FOR ELECTRIC MOTORS##MANUFACTURER'S INSTALLATION AND OPERATION MANUALS##LOCAL AUTHORITY AND FACILITY REGULATIONS8. SUBMITTALS THE CONTRACTOR SHALL SUBMIT THE FOLLOWING DOCUMENTS FOR APPROVAL PRIOR TO EXECUTION:##TECHNICAL DATASHEETS OF THE PROPOSED FAN MOTORS##MANUFACTURER'S CATALOGUES AND COMPLIANCE STATEMENT##METHOD STATEMENT##RISK ASSESSMENT##MATERIAL DELIVERY SCHEDULE9. WARRANTY##THE SUPPLIED FAN MOTORS SHALL CARRY A MINIMUM 12-MONTH WARRANTY FROM THE DATE OF COMMISSIONING AGAINST MANUFACTURING DEFECTS.##WARRANTY CERTIFICATES SHALL BE SUBMITTED UPON COMPLETION OF WORKS.10. HAND</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600306  
**DATE** : 03.02.2026  
**REQ No** : 1032600494  
**REQ TITLE** : Supply and Replacement of Exi  
**DELIVERY LOCATION**  
**CLOSING DATE** : 09.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OVER DEWA-CONFIDENTIAL UPON COMPLETION, THE CONTRACTOR SHALL PROVIDE:##AS-BUILT DETAILS##TEST AND COMMISSIONING REPORTS##WARRANTY DOCUMENTS##OPERATION AND MAINTENANCE (O&M) MANUALS11. COMPLETION##THE SYSTEM SHALL BE CONSIDERED COMPLETE ONLY AFTER SUCCESSFUL TESTING, COMMISSIONING, DOCUMENTATION SUBMISSION, AND FORMAL ACCEPTANCE BY THE DEWA ENGINEER.12. CONTACT ENGINEERS IN DEWA CIVIL TEAM FOR DOCUMENTS SUBMISSION ONSITE VISIT:##MR. MOHIDEEN ESMAIL (EMAIL: MOHIDEEN.ESMAIL@DEWA.GOV.AE / TEL.04-3227879/MOB: 055-3810513)##MR. RASHED KHAMIS (EMAIL: RASHED.MANA@DEWA.GOV.AE/ MOB: 050-5158400)*****						
2		ITEM-00001	15 HP	1	NO				
3		ITEM-00001	10 HP	1	NO				
4		ITEM-00001	7.5 HP	1	NO				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600306  
**DATE** : 03.02.2026  
**REQ No** : 1032600494  
**REQ TITLE** : Supply and Replacement of Exi  
**DELIVERY LOCATION**  
**CLOSING DATE** : 09.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
5		ITEM-00001	5 HP	1	NO				
6		ITEM-00001	4 HP	1	NO				
7		ITEM-00001	3 HP	1	NO				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

Supply and Replacement of Existing AHU Fan Motors at Al Warsan TP Admin Building.

Contact: Mr.Mohideen - 055-3810513

Payment Terms: after completion.

Site Visit Date: 06.02.2026 at 09:00AM

### STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2332600306
<b>DATE</b>	: 03.02.2026
<b>REQ No</b>	: 1032600494
<b>REQ TITLE</b>	: Supply and Replacement of Exi
<b>DELIVERY LOCATION</b>	
<b>CLOSING DATE</b>	: 09.02.2026
<b>CLOSING TIME</b>	: 10:00:00

perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

### SUPPLIER'S REMARKS :

### SUPPLIER'S SIGNATURE AND STAMP