

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATION TITLE: M STATION HRSG DESUPERHEATER ASSEMBLY LINER REPLACEMENT. A.#QUANTITY & SPECIFICATION:##QUANTITY: - 01##REFER ATTACHED DRAWINGS. B.#DURATION:##05 DAYS. C.#PRE-BID SITE INSPECTION:##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OF WORK. D.#QUALIFICATION OF BIDDER:##THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBS AND SHALL SUBMIT EVIDENCE. E.#THE BIDDER SHALL BE A VALID ASME #S# STAMP HOLDER##AN ASME INSPECTOR TO BE ENGAGED DURING EXECUTION OF JOB. F.#SCOPE	1	LS				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OF WORK:# #SUBMIT THE ITP & METHOD STATEMENT APPROVED BY ASME INSPECTOR.##MOBILIZE REQUIRED MANPOWER WITHIN 01 DAY OF ADVANCE NOTICE AFTER POA ND COLLECT THE BELOW ITEMS FROM DEWA JABEL ALI PERMISSIBLE.A.#OUTER PIPE (PIPE SPECIFICATION: 18 IN, SCH 120, SA 335 P91;APPROXIMATE SPOOL 1.3M)B.#INNER PIPE (PIPE SPECIFICATION: 16 IN, SCH 140, SA335-P22;APPROXIMATE SPOOL LENGTH: 975MM)C.#LINER PIPE FOR SAMPLE.D.#OUTER PIPE FOR SAMPLE.##CONDUCT A SITE SURVEY AND SAFETY INSPECTION PRIOR TO COMMENCEMENT OF WORK TO ASSESS SITE CONDITIONS.##DEWA WILL PROVIDE MTC & PMI REPORT FOR OUTER & INNER PIPE.##TRANSPORT ALL THE 04 ITEMS WITH THE EXISTING COMPLETE DESUPERHEATER ASSEMBLY FROM M STATION, DEWA, JABEL ALI, TO THE CONTRACTOR'S WORKSHOP FOR FURTHER FABRICATION ACTIVITIES.##VERIFY AND RECORD						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE DIMENSIONS AND ORIENTATION OF THE EXISTING LINER##BASED ON THE VERIFIED DIMENSIONS AND ORIENTATION, MACHINE THE 16-INCH PIPE SPOOL TO THE REQUIRED SPECIFICATIONS.##FOR OUTER PIPE AND INNER PIPE, 3 NOS. OF HOLES TO BE DRILLED AS PER SAMPLE PIPES.##OUTER PIPE BOTH SIDES BEVELING (REFER ATTACHED DRAWING FOR DETAILS)##CUT NOZZLE PIPES ASSEMBLY (3 NUMBER) INCLUDING NOZZLE HOLDERS FROM SAMPLE OUTER PIPE AND WELD TO N NEW OUTER PIPE WITH SIMILAR ORIENTATION AS PER SAMPLE OUTER PIPE.##PERFORM ALL REQUIRED NON-DESTRUCTIVE EXAMINATION (NDE) LIKE ; REPLICATEST, DPT, UTG, HEAT TREATMENT, PREHEAT, RT & HARDNESS TEST ON THE NEWLY MACHINED LINER AND ON THE EXTERNAL PIPE OF THE DESUPERHEATER ASSEMBLY.##CARRY OUT DIMENSIONAL INSPECTION OF THE MACHINED LINER PRIOR						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TO INSTALLATION## UPON SATISFACTORY NDE RESULTS, INSTALL THE NEWLY FABRICATED LINER INSIDE THE DESUPERHEATER PIPE## ENSURE PROPER ALIGNMENT AND FIT-UP OF THE LINER INSIDE THE DESUPERHEATER PIPE PRIOR TO WELDING## CARRY OUT WELDING IN ACCORDANCE WITH THE EXISTING APPLICABLE WELDING PROCEDURES## PERFORM NDE ON ALL WELD JOINTS.## CARRY OUT PWHT FOR THE WELD JOINTS AS PER APPLICABLE CODES AND PROCEDURES.## ALL ACTIVITIES SHALL BE EXECUTED BY SKILLED MACHINISTS, QUALIFIED FABRICATORS, AND CERTIFIED WELDERS.## WELDING SHALL BE PERFORMED BY QUALIFIED WELDERS IN ACCORDANCE WITH APPROVED WPS AND ASME REQUIREMENTS. (PQR, WPS, AND WELDER QUALIFICATION CERTIFICATES SHALL BE SUBMITTED IN ADVANCE.)## UPON COMPLETION OF ALL QUALITY CHECKS, DELIVER THE DESUPERHEATER ASSEMBLY						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ALONG WITH THEREMOVED OLD LINER BACK TO M STATION, DEWA, JEBEL ALI.##SUBMIT A WORK COMPLETION REPORT TO DEWA, INCLUDING BUT NOT LIMITED TO THE FOLLOWING: A.#NDE REPORTS B.#WELDING CONSUMABLE CERTIFICATES C.#WPS AND PQRD. #PWHT REPORT D.#WELDER QUALIFICATION CERTIFICATES E.#CALIBRATION CERTIFICATES F.#WARRANTY##THE SCOPE OF WORK MENTIONED HERE ONLY PROVIDES A BROAD OUTLINE OF THE TASK. THE BIDDER MUST REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORK TO CARRY OUT REQUIRED TASKS AND ADD ANY ADDITIONAL WORK THAT ARE NEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT. F.#WARRANTY##THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OF INSTALLATION BY DEWA.##IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORT PERIOD. G. #GENERAL TERMS &amp; CONDITIONS</p> <p>CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR SIMILAR JOB AND SHALL PROVIDE EVIDENCE. #CONTRACTOR SHALL SUBMIT METHOD OF STATEMENT AND SCHEDULE UPON RECEIPT OF PO. #ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THESE EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND. #THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID. #THE WORK INSIDE DEWA SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REQUIREMENT.##CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THEPERIOD OF WORK.##ALL THE CONTRACTOR PERSONS SHOULD WEAR ALL THE REQUIRED PPE WHILE ATWORK.##ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT POWER STATIONSECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWASECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWAENGINEER IN CHARGE ON DAILY BASIS.</p> <p>THIS DOCUMENT WILL BE THE BASIS FORTHE CLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.</p>						
2		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATIONTITLE: M STATION HRSG DESUPERHEATER ASSEMBLY LINER REPLACEMENT.A.#QUANTITY &amp; SPECIFICATION:##QUANTITY: - 01##REFER ATTACHED DRAWINGS.B.#DURATION:##05</p>	1	LS				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DAYSC.#PRE-BID SITE INSPECTION:##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLYFAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES,ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOREXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED.D.#QUALIFICATION OF BIDDER:##THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBS AND SHALLSUBMIT EVIDENCE.##THE BIDDER SHALL BE A VALID ASME #S# STAMP HOLDER##AN ASME INSPECTOR TO BE ENGAGED DURING EXECUTION OF JOB.E.#SCOPE OF WORK:# #SUBMIT THE ITP &amp; METHOD STATEMENT APPROVED BY ASME INSPECTOR.##MOBILIZE REQUIRED MANPOWER WITHIN 01 DAY OF ADVANCE NOTICE AFTER POA ND COLLECT THE BELOW ITEMS FROM DEWA JABEL ALI PERMISSIBLE.A.#OUTER PIPE (PIPE </p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SPECIFICATION: 18 IN, SCH 120, SA 335 P91; APPROXIMATE SPOOL 1.3M) B. #INNER PIPE (PIPE SPECIFICATION: 16 IN, SCH 140, SA335-P22; APPROXIMATE SPOOL LENGTH: 975MM) C. #LINER PIPE FOR SAMPLE. D. #OUTER PIPE FOR SAMPLE. ## CONDUCT A SITE SURVEY AND SAFETY INSPECTION PRIOR TO COMMENCEMENT OF WORK TO ASSESS SITE CONDITIONS. ## DEWA WILL PROVIDE MTC & PMI REPORT FOR OUTER & INNER PIPE. ## TRANSPORT ALL THE 04 ITEMS WITH THE EXISTING COMPLETE DESUPERHEATER ASSEMBLY FROM M STATION, DEWA, JEBEL ALI, TO THE CONTRACTOR'S WORKSHOP FOR FURTHER FABRICATION ACTIVITIES. ## VERIFY AND RECORD THE DIMENSIONS AND ORIENTATION OF THE EXISTING LINER. ## BASED ON THE VERIFIED DIMENSIONS AND ORIENTATION, MACHINE THE 16-INCH PIPE SPOOL TO THE REQUIRED SPECIFICATIONS. ## FOR OUTER PIPE AND INNER PIPE, 3 NOS. OF HOLES TO BE DRILLED AS						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PERSAMPLE PIPES.##OUTER PIPE BOTH SIDES BEVELING (REFER ATTACHED DRAWING FOR DETAILS)##CUT NOZZLE PIPES ASSEMBLY (3 NUMBER) INCLUDING NOZZLE HOLDERS FROMSAMPLE OUTER PIPE AND WELD TO N EW OUTER PIPE WITH SIMILAR ORIENTATION AS PER SAMPLE OUTER PIPE.##PERFORM ALL REQUIRED NON-DESTRUCTIVE EXAMINATION (NDE) LIKE ; REPLICATEST, DPT, UTG, HEAT TREATMENT, PREHEAT, RT & HARDNESS TEST ON THE NEWLYMACHINED LINER AND ON THE EXTERNAL PIPE OF THE DESUPERHEATER ASSEMBLY.##CARRY OUT DIMENSIONAL INSPECTION OF THE MACHINED LINER PRIOR TO INSTALLATION##UPON SATISFACTORY NDE RESULTS, INSTALL THE NEWLY FABRICATED LINERINSIDE THE DESUPERHEATER PIPE##ENSURE PROPER ALIGNMENT AND FIT-UP OF THE LINER INSIDE THEDESUPERHEATER PIPE PRIOR TO WELDING##CARRY OUT WELDING IN						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ACCORDANCE WITH THE EXISTING APPLICABLE WELDING PROCEDURES## PERFORM NDE ON ALL WELD JOINTS.## CARRY OUT PWHT FOR THE WELD JOINTS AS PER APPLICABLE CODES AND PROCEDURES.## ALL ACTIVITIES SHALL BE EXECUTED BY SKILLED MACHINISTS, QUALIFIED FABRICATORS, AND CERTIFIED WELDERS.## WELDING SHALL BE PERFORMED BY QUALIFIED WELDERS IN ACCORDANCE WITH APPROVED WPS AND ASME REQUIREMENTS. (PQR, WPS, AND WELDER QUALIFICATION CERTIFICATES SHALL BE SUBMITTED IN ADVANCE.)## UPON COMPLETION OF ALL QUALITY CHECKS, DELIVER THE DESUPERHEATER ASSEMBLY ALONG WITH THE REMOVED OLD LINER BACK TO M STATION, DEWA, JEBEL ALI.## SUBMIT A WORK COMPLETION REPORT TO DEWA, INCLUDING BUT NOT LIMITED TO THE FOLLOWING: A. NDE REPORTS B. WELDING CONSUMABLE CERTIFICATES C. WPS AND PQR D. PWHT REPORT						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SE.#WELDER QUALIFICATION CERTIFICATES F.#CALIBRATION CERTIFICATES NOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES A BROAD OUTLINE OF THE TASK. THE BIDDER MUST REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORK TO CARRY OUT REQUIRED TASKS AND ADD ANY ADDITIONAL WORK THAT ARE NEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT. F.#WARRANTY## THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OF INSTALLATION BY DEWA.## IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORT PERIOD. G.# GENERAL TERMS & CONDITIONS## CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR SIMILAR JOB AND SHALL PROVIDE EVIDENCE.## CONTRACTOR SHALL						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SUBMIT METHOD OF STATEMENT AND SCHEDULE UPON RECEIPT OF PO.##ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THESE EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND.##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID.##THE WORK INSIDE DEWA SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT.##CONTRACTOR'S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK.##ALL THE CONTRACTOR PERSONS SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.##ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600339  
**DATE** : 06.02.2026  
**REQ No** : 1032600611  
**REQ TITLE** : M Station HRSG Desuperheater  
**DELIVERY LOCATION**  
**CLOSING DATE** : 12.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DECLARED AT POWER STATION SECURITY GATE AND THE LIST OF THE SE ITEMS SHALL BE SIGNED BY DEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWA ENGINEER IN CHARGE ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

**SPECIAL NOTES / INSTRUCTIONS:**

M Station HRSG Desuperheater assembly liner replacement.

Note : For more details refer the attached scope of work

Contact : shabbir.enulhaque@dewa.gov.ae / +971-4322-5969

**STANDARD TERMS & CONDITIONS**

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2332600339
<b>DATE</b>	: 06.02.2026
<b>REQ No</b>	: 1032600611
<b>REQ TITLE</b>	: M Station HRSG Desuperheater
<b>DELIVERY LOCATION</b>	
<b>CLOSING DATE</b>	: 12.02.2026
<b>CLOSING TIME</b>	: 10:00:00

2) Quotation to be submitted only in local currency U.A.E Dirhams

3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

### SUPPLIER'S REMARKS :

### SUPPLIER'S SIGNATURE AND STAMP