

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>SCOPE OF WORK # GRP PIPELINE EXTENSION AT K-RO INTAKE FOREBAY1.#THE SCOPE OF WORK INCLUDES THE EXTENSION OF THE EXISTING GRP PIPELINE AT THE K-RO INTAKE FOREBAY.2.#THE EXISTING PIPELINE SIZE IS DN300, AND THE EXTENDED PIPELINE SHALL BE DN350, INCLUDING THE SUPPLY AND INSTALLATION OF A SUITABLE REDUCER TO CONNECT DN300 TO DN350.3.#DEWA HAS LIMITED DN350 GRP PIPES AVAILABLE AT SITE, WHICH SHALL BE UTILIZED FOR THE WORKS.4.#ANY ADDITIONAL DN350 PIPES, FITTINGS, OR ACCESSORIES REQUIRED TO COMPLETE THE JOB SHALL BE SUPPLIED BY THE VENDOR.4.#THE GRP PIPELINE SHALL BE EXTENDED UP TO +4.0 METERS ABOVE THE TANK FLOOR LEVEL, INCLUDING THE PROVISION OF ADEQUATE AND PROPERLY DESIGNED SUPPORTS.5.#ALL SUPPORTS, FASTENERS, BOLTS, NUTS, CLAMPS, AND ASSOCIATED MATERIALS SHALL</p>	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BE:0#CORROSION-RESISTANT#SUITABLE FOR MARINE / SEAWATER ENVIRONMENT#COMPLIANT WITH RELEVANT STANDARDS6.#A MANDATORY SITE VISIT IS REQUIRED PRIOR TO SUBMISSION OF THE QUOTATION. NO CLAIMS RELATED TO SITE CONDITIONS SHALL BE ENTERTAINED LATER.7. ALL MATERIALS REQUIRED FOR THE WORK SHALL BE MOBILIZED TO SITE ATLEAST THREE (03) DAYS PRIOR TO INITIATION OF THE WORK. THE ACTIVITY SHALL COMMENCE IMMEDIATELY UPON ISSUANCE OF THE PERMIT TO WORK (PTW).8.#THE ENTIRE WORK SHALL BE COMPLETED WITHIN 10 DAYS FROM THE ISSUANCE OF THE PERMIT TO WORK (PTW).9.#THE VENDOR SHALL BE FULLY RESPONSIBLE FOR PROVIDING ALL VENTILATION ARRANGEMENTS, AS REQUIRED FOR SAFE EXECUTION OF THE WORKS IN CONFINED OR CLOSED AREAS.10.#THE VENDOR SHALL PROVIDE:0#ALL REQUIRED TOOLS AND EQUIPMENT#SKILLED AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			UNSKILLED MANPOWER#SUPERVISION AND SAFETY COMP LIANCE FOR EXECUTION OF THE WORK11.#DEWA#S SCOPE SHALL BE LIMITED TO PROVIDING:O#SCAFFOLDING#WATER, ELECTRICITY, AND COMPRESSED AIR O#NECESSARY PERMITS, CONFINED SPACE.12.#WATER, ELECTRICITY, AND AIR WILL BE PROVIDED AT THE NEAREST AVAILABLE POINT ONLY.O#THE VENDOR SHALL ARRANGE ALL NECESSARY EXTENSIONS, HOSES, CABLES, AND CONNECTIONS FROM THE SOURCE TO THE WORK LOCATION.						
2		ITEM-00001	SCOPE OF WORK # EXTENSION OF STORM WATER DISCHARGE AND PUMP PIPING1.#THE CONTRACTOR SHALL CARRY OUT THE EXTENSION OF THE EXISTING DN 600 STORM WATER DISCHARGE HEADER UP TO THE SURFACE-MOUNTED PUMP INSTALLED ON THE CONCRETE FOUNDATION.2.#THE PUMP DISCHARGE NOZZLE SIZE IS DN 400; THEREFORE, A SUITABLE DN400 x DN 600 REDUCER SHALL BE PROVIDED AND	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSTALLED NEAR THE PUMPDISCHARGE.3.#ALL DISCHARGE AND SUCTION PIPING SHALL BE GRP (GLASS REINFORCEDPLASTIC), INCLUDING PIPES, FITTINGS, AND FLANGES, SUITABLE FOR THEINTENDED SERVICE AND OPERATING CONDITIONS.4.#THE EXISTING DN 600 STORM WATER DISCHARGE HEADER IS CURRENTLYPROVIDED WITH A BLIND FLANGE AT ONE END. THE CONTRACTOR SHALL REMOVE THEBLIND FLANGE AND CONNECT THE NEW DN 600 DISCHARGE LINE TO THE EXISTINGHEADER USING A FLANGED JOINT.5.#AN ISOLATION VALVE OF DN 600, TO BE PROVIDED BY DEWA, SHALL BEINSTALLED ON THE DISCHARGE LINE AT THE DESIGNATED LOCATION. THECONTRACTOR SHALL BE RESPONSIBLE FOR INSTALLATION, ALIGNMENT, ANDINTEGRATION OF THE VALVE.6.#THE PUMP SUCTION LINE DN 400 SHALL BE EXTENDED FROM THE PUMP TO THESTORM WATER TANK, WITH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE SUCTION PIPE TERMINATING AT 1 METER ABOVE THE TANK FLOOR LEVEL.7.#ALL PIPE SUPPORTS, SHOES, CLAMPS, AND STRUCTURAL SUPPORTS SHALL BE DESIGNED AND PROVIDED TO BE SEAWATER RESISTANT AND SUITABLE FOR THE SITE ENVIRONMENTAL CONDITIONS.8.#WHERE GI MATERIALS ARE USED FOR SUPPORTS OR ACCESSORIES, THEY SHALL BE HOT-DIP GALVANIZED AND PAINTED WITH A C5 MARINE-GRADE COATING SYSTEM IN ACCORDANCE WITH APPLICABLE INTERNATIONAL STANDARDS.9.#ALL FASTENERS, INCLUDING BOLTS, NUTS, AND WASHERS, REQUIRE D FOR PIPING, FLANGES, VALVES, AND SUPPORTS SHALL BE SUPPLIED BY THE CONTRACTOR AND SHALL BE MADE OF SS 316L.10.#THE CONTRACTOR SHALL PROVIDE ALL NECESSARY GASKETS, FITTINGS, ANCHORS, ACCESSORIES, AND INSTALLATION HARDWARE REQUIRED FOR THE COMPLETE AND FUNCTIONAL INST						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ALLATION.11.#ALL WORKS SHALL BE EXECUTED IN ACCORDANCE WITH APPLICABLE STANDARDS, APPROVED DRAWINGS, AND DEWA REQUIREMENTS, AND SHALL INCLUDE INSPECTION, TESTING, AND FINAL HANDOVER.12. GRP LINE PRESSURE RATING TO BE GRP PN 1013. ALL THE WORK TO BE PERFORMED & COMPLETED WITHIN 07 DAYS FROM PTW ISSUANCE DATE.						
3		ITEM-00001	SCOPE OF WORK # EXTENSION OF DMF WWP DISCHARGE AND PUMP PIPING1.#THE CONTRACTOR SHALL CARRY OUT THE EXTENSION OF THE EXISTING DN 350 DMF WWP DISCHARGE HEADER UP TO THE SURFACE-MOUNTED PUMP INSTALLED ON THE CONCRETE FOUNDATION.2.#THE PUMP DISCHARGE NOZZLE SIZE IS DN 250; THEREFORE, A SUITABLE DN250 x DN 350 REDUCER SHALL BE PROVIDED AND INSTALLED NEAR THE PUMP DISCHARGE.3.#ALL DISCHARGE AND SUCTION PIPING SHALL BE GRP (GLASS REINFORCED PLASTIC), INCLUDING PIPES,	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FITTINGS, FLANGES, AND REDUCERS, SUITABLE FOR THE INTENDED SERVICE AND OPERATING CONDITIONS. 4.# THE EXISTING DN 350 DMF WWP DISCHARGE HEADER IS CURRENTLY PROVIDED WITH A BLIND FLANGE AT ONE END. THE CONTRACTOR SHALL REMOVE THE BLIND FLANGE AND CONNECT THE NEW DN 350 DISCHARGE LINE TO THE EXISTING HEADER USING A FLANGED JOINT. 5.# AN ISOLATION VALVE OF DN 350, TO BE PROVIDED BY DEWA, SHALL BE INSTALLED ON THE DISCHARGE LINE AT THE DESIGNATED LOCATION.</p> <p>THE CONTRACTOR SHALL BE RESPONSIBLE FOR INSTALLATION, ALIGNMENT, AND INTEGRATION OF THE VALVE. 6.# THE PUMP SUCTION LINE OF DN 300 SHALL BE EXTENDED FROM THE PUMP TO THE DMF WWP TANK, WITH THE SUCTION PIPE TERMINATING AT 1.0 METERS ABOVE THE TANK FLOOR LEVEL. 7.# THE CONTRACTOR SHALL SUPPLY AND INSTALL A BLIND FLANGE TO BLANK</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OFFAN EXISTING DN 250 T-JOINT, INCLUDING ALL ASSOCIATED GASKETS ANDFASTENERS.8.#ALL PIPE SUPPORTS, SHOES, CLAMPS, AND STRUCTURAL SUPPORTS SHALL BEDESIGNED AND PROVIDED TO BE SEAWATER RESISTANT AND SUITABLE FOR THE SITEENVIRONMENTAL CONDITIONS.9.#WHERE GI MATERIALS ARE USED FOR SUPPORTS OR ACCESSORIES, THEY SHALLBE HOT-DIP GALVANIZED AND PAINTED WITH A C 5 MARINE-GRADE COATING SYSTEMIN ACCORDANCE WITH APPLICABLE INTERNATIONAL STANDARDS.10.#ALL FASTENERS, INCLUDING BOLTS, NUTS, AND WASHERS, REQUIRED FORPIPING, FLANGES, VALVES, SUPPORTS, AND BLIND FLANGES SHALL BE SUPPLIEDBY THE CONTRACTOR AND SHALL BE MADE OF SS 316L.11.#THE CONTRACTOR SHALL PROVIDE ALL NECESSARY GASKETS, FITTINGS,ANCHORS, ACCESSORIES, AND INSTALLATION HARDWARE REQUIRED FOR THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMPLETE AND FUNCTIONAL INSTALLATION.12.#ALL WORKS SHALL BE EXECUTED IN ACCORDANCE WITH APPLICABLE STANDARDS, APPROVED DRAWINGS, AND DEWA REQUIREMENTS, AND SHALL INCLUDE INSPECTION, TESTING, AND FINAL HANDOVER.13. GRP LINE PRESSURE RATING TO BE GRP PN 1014. ALL THE WORK TO BE PERFORMED & COMPLETED WITHIN 07 DAYS FROM PTW ISSUANCE DATE.						
4		ITEM-00001	SCOPE OF WORK # I&C TAPPING JOINTS ON EXISTING GRP LINE1.#THE CONTRACTOR SHALL PROVIDE AND INSTALL I&C TAPPING JOINTS ON THE EXISTING GRP PIPELINE FOR THE PURPOSE OF INSTRUMENT INSTALLATION.2.#A TOTAL OF FOUR (4) TAPPING POINTS OF SIZE 1½ INCH SHALL BE PROVIDED, COMPRISING:O#TWO (2) TAPPING POINTS ON THE HP HEADER O#TWO (2) TAPPING POINTS ON THE ERD HEADER3.#ALL TAPPING JOINTS, SADDLES, BRANCHES,	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OR STUB CONNECTIONS SHALL BE MADE OF GRP MATERIAL, COMPATIBLE WITH THE EXISTING PIPELINE MATERIAL, PRESSURE RATING, AND SERVICE CONDITIONS. 4.# EACH TAPPING POINT SHALL BE PROVIDED WITH A FLANGED CONNECTIONS SUITABLE FOR MOUNTING OF I&C INSTRUMENTS. 5.# ANY ISOLATION VALVES, IF REQUIRED, SHALL BE SUPPLIED BY DEWA. THE CONTRACTOR SHALL BE RESPONSIBLE FOR INSTALLATION OF THE VALVES. 6.# THE MATING FLANGES PROVIDED BY THE CONTRACTOR FOR THE TAPPING POINTS SHALL BE MANUFACTURED TO MATCH THE PRESSURE CLASS AND PITCH CIRCLE DIAMETER (PCD) OF THE DEWA-SUPPLIED ISOLATION VALVES. 7.# ALL FASTENERS, INCLUDING BOLTS, NUTS, AND WASHERS REQUIRED FOR THE TAPPING JOINTS, FLANGES, INSTRUMENTS, AND VALVE CONNECTIONS SHALL BE SUPPLIED BY THE CONTRACTOR AND SHALL BE MADE OF SS 316L. 8.# THE CONTRACTOR SHALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PROVIDE ALL NECESSARY GASKETS, SUPPORTS (IF REQUIRED), ACCESSORIES, AND CONSUMABLES FOR THE COMPLETE AND PROPER INSTALLATION. 9.# ALL WORKS SHALL BE EXECUTED IN ACCORDANCE WITH APPLICABLE STANDARDS, APPROVED DRAWINGS, AND DEWA REQUIREMENTS, AND SHALL INCLUDE INSPECTION, TESTING, AND FINAL HANDOVER. 10.# ALL WORKS TO BE COMPLETED WITHIN 07 DAYS FROM RECEIVING THE PTW. 11.# HP TAPPING POINT SHOULD GRP PN 25 AND FOR ERD GRP PN 10						
5		ITEM-00001	SCOPE OF WORK # GRP PIPELINE LEAK ARRESTING 1.# THE CONTRACTOR SHALL CARRY OUT LEAK ARRESTING ON THE EXISTING GRP PIPELINE AT MULTIPLE LOCATIONS USING GRP LAMINATION REPAIR. 2.# ALL REPAIR MATERIALS, INCLUDING RESINS, GLASS FIBERS, LAMINATES, AND CONSUMABLES, SHALL BE SUPPLIED BY THE CONTRACTOR. 3.# SCAFFOLDING	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FOR ACCESS SHALL BE PROVIDED BY DEWA; THE CONTRACTOR SHALL COORDINATE FOR SAFE EXECUTION.4.# THE CONTRACTOR SHALL ENSURE PROPER SURFACE PREPARATION, LAMINATION, CURING, AND SUBMISSION OF A COMPLETION REPORT.5.#ALL WORKS SHALL COMPLY WITH APPLICABLE STANDARDS, MANUFACTURER PROCEDURES, DEWA REQUIREMENTS, AND SITE SAFETY REGULATIONS.6. ALL WORKS TO BE COMPLETE D WITHIN 07 DAYS FROM PTW ISSUANCE.						
6		ITEM-00001	SCOPE OF WORK # CUTTING AND RE-LAMINATING EXISTING GRP DN 450 LINE FOR DMF TANKS1.#THE CONTRACTOR SHALL CUT THE EXISTING DN 450 GRP PIPELINE ASSOCIATED WITH 22 DMF TANKS TO CREATE A GAP, AS THE CURRENT ARRANGEMENT HAS NO PROVISION FOR SPACING.2.#NO ADDITIONAL PIPING OR ALTERATIONS SHALL BE MADE; ONLY THE EXISTING PIPE SHALL BE CUT AND SUBSEQUENTLY RE-LAMINATED AFTER APPROVAL FROM	22	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600356
DATE : 09.02.2026
REQ No : 1032600265
REQ TITLE : GRP Lamination & GRP piping
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DEWASTAFF CONFIRMING THE REQUIRED GAP.3.#ALL LAMINATION MATERIALS, INCLUDING RESINS, GLASS FIBERS, AND CONSUMABLES, SHALL BE SUPPLIED BY THE CONTRACTOR.</p> <p>R.4.#THE CONTRACTOR SHALL VISIT THE SITE PRIOR TO QUOTING TO VERIFY CONDITIONS, DIMENSIONS, AND ACCESS REQUIREMENTS.5.#THE WORK SHALL BE COMPLETED WITHIN 07 DAYS FROM THE ISSUANCE OF THE PERMIT TO WORK (PTW).6.#ALL WORKS SHALL BE EXECUTED IN ACCORDANCE WITH APPLICABLE STANDARDS, MANUFACTURER PROCEDURES, DEWA REQUIREMENTS, AND SITE SAFETY REGULATIONS.</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

GRP Lamination & GRP piping work @ K-Station RO Plant during the

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332600356
DATE	: 09.02.2026
REQ No	: 1032600265
REQ TITLE	: GRP Lamination & GRP piping
DELIVERY LOCATION	
CLOSING DATE	: 13.02.2026
CLOSING TIME	: 10:00:00

total shutdwon

Contact: sidharth.prakash@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332600356
DATE	: 09.02.2026
REQ No	: 1032600265
REQ TITLE	: GRP Lamination & GRP piping
DELIVERY LOCATION	
CLOSING DATE	: 13.02.2026
CLOSING TIME	: 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP