

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600358
DATE : 09.02.2026
REQ No : 1032600557
REQ TITLE : E Station CCST6 Sea Water Sys
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	1. INSPECTION OF RUBBER LINING (DN 1200 MM PIPELINE AND ELBOWS, 4 LINES,CONDENSER)SCOPE QUANTITY:# DN 1200 MM RUBBER-LINED PIPELINE AND ELBOW SECTIONS # 4 LINES# EBONITE RUBBER LINING IN CONDENSER # 1 UNITS SCOPE OF WORK:# VISUAL INSPECTION OF INTERNAL RUBBER LINING FOR CRACKS, BLISTERING,DETACHMENT, WEAR, OR OTHER DEFECTS# SPARK TESTING OF RUBBER LINING TO DETECT PINHOLES, CRACKS, OR VOIDS# MEASUREMENT OF LINING THICKNESS AT REPRESENTATIVE LOCATIONS# HARDNESS TESTING OF RUBBER OR EBONITE LINING USING APPROPRIATEDUROMETER# IDENTIFICATION AND MARKING OF DEFECTIVE AREAS# DOCUMENTATION AND REPORTING OF ALL INSPECTION RESULTS INCLUDINGOBSERVATIONS AND RECOMMENDATIONS# SUBMISSION OF FINAL INSPECTION REPORT FOR ALL 4 PIPELINES ANDCONDENSER UNIT GENERAL REQUIREMENTS:# MOBILIZATION	4	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600358
DATE : 09.02.2026
REQ No : 1032600557
REQ TITLE : E Station CCST6 Sea Water Sys
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND DEMOBILIZATION OF QUALIFIED MANPOWER, TOOLS, AND TESTING EQUIPMENT# SUBMISSION OF INSPECTION PROCEDURE, TESTING METHODS, AND SAFETY DOCUMENTS PRIOR TO WORK# COORDINATION WITH SITE OPERATIONS FOR ACCESS, PERMITS, AND SAFETY REQUIREMENTS# DELIVERABLES:# VISUAL INSPECTION REPORTS# SPARK TEST RESULTS# THICKNESS AND HARDNESS MEASUREMENT RECORDS# FINAL CONSOLIDATED INSPECTION REPORT WITH RECOMMENDATIONS						
2		ITEM-00001	2. REPAIR OF DN 100 MM NOZZLE (PIPELINE AND FLANGE) SCOPE QUANTITY:# DN 100 MM NOZZLE INCLUDING PIPELINE SECTION AND FLANGE # 2 NUMBER SCOPE OF WORK:# REMOVAL OF DAMAGED RUBBER LINING FROM NOZZLE, PIPELINE SECTION, AND FLANGE# SURFACE PREPARATION INCLUDING CLEANING, GRIT BLASTING, AND PRIMING ASPER LINING PROCEDURE# APPLICATION OF HARD RUBBER	2	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600358
DATE : 09.02.2026
REQ No : 1032600557
REQ TITLE : E Station CCST6 Sea Water Sys
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LINING ON NOZZLE, PIPELINE, AND FLANGE AREA# CURING O F RUBBER LINING AS PER MANUFACTURER#S RECOMMENDATIONS# VISUAL INSPECTION AFTER LINING REPAIR# SPARK TESTING OF REPAIRED AREA TO CONF IRM INTEGRITY# REPLACEMENT OF STUDS, BOLTS, OR FLANGE GASKETS IF DAMAGED DURINGREPAIR# DOCUMENTATION AND REPORTING OF REPAIR AND INS PECTION RESULTSGENERAL REQUIREMENTS:# MOBILIZATION AND DEMOBILIZATION OF QUALIFIED MANPOWER, TOOLS, ANDMATERIALS# SUBMISSION OF REPA IR PROCEDURE, TESTING METHODS, AND SAFETY DOCUMENTSPRIOR TO WORK# COORDINATION WITH SITE OPERATIONS FOR ACCESS, PERMITS, AND SAFETYR EQUIREMENTSDELIVERABLES:# VISUAL INSPECTION REPORT OF REPAIRED NOZZLE# SPARK TEST RESULTS CONFIRMING INTEGRITY# REPAIR COMPLETION RE PORT WITH APPROVAL FOR RE-COMMISSIONING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600358
DATE : 09.02.2026
REQ No : 1032600557
REQ TITLE : E Station CCST6 Sea Water Sys
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

E Station CCST6 Sea Water System: Inspection and Repair of DN 1200
Rubber-Lined Pipelines, DN 100 Nozzles, and Ebonite-Lined Condenser

Contact mahmood.mohammad@dewa.gov.ae Tel: 04-3226177 / 0504231413

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
 - 2) Quotation to be submitted only in local currency U.A.E Dirhams
 - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
 - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
 - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
 - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600358
DATE : 09.02.2026
REQ No : 1032600557
REQ TITLE : E Station CCST6 Sea Water Sys
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP