

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600362
DATE : 09.02.2026
REQ No : 1032600641
REQ TITLE : ST-85&86 SEA WATER SEAL
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|--|-----|-----|--------------|----------|------------|-------------|
| 1 | | ITEM-00001 | <p>TECHNICAL AND GENERAL SPECIFICATION FOR OUTSOURCING WORKL-2 STATION, JEBEL ALI POWER STATION#NAME OF WORK : ST-85 SEA WATER SEAL PIT</p> <p>GRP COVER REPAIR WORK #PERIOD OF WORK : 5 DAYS#SCOPE OF WORK FOR GRP COVERS & GRP SUPPORT MAINTENANCEØ#THE FOLLOWING SCOPE OF WORK</p> <p>DESCRIBES THE MAINTENANCE ACTIVITIES FORGRP COVERS AT SEA WATER SEAL PITØ# CLEAN ALL SEA WATER SEAL PIT GRP COVERS THOROUGHLY TO REMOVE DIRT,DUST, AND CONTAMINANTS.Ø# OPEN THE DAMAGED SEA WATER SEAL PIT GRP COVERS, REPAIR AND RECTIFYTHE DAMAGED AREAS, AND REINSTALL WITH PROPER SEALINGØ#AFTER RECTIFICATION CONTRACTOR MUST ENSURE ALL THE GRP COVERS AREPROPERLY SEALED WITH PROPER SEALANTØ#WHILE RESTORE THE GRP COVER CONTRACTOR MUST WEAR SUITABLE PPE ON THETOP OF GRP COVERØ# REPLACE AND INSTALL THE GRP</p> | 1 | EA | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600362
DATE : 09.02.2026
REQ No : 1032600641
REQ TITLE : ST-85&86 SEA WATER SEAL
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| | | | SUPPORT AND GRP COVER IF REQUIRED.Ø#REPLACE ALL DAMAGED, CORRODED, OR MISSING BOLTS WITH NEW SUITABLEBOLTS.Ø#GRIND THE TOP SURFACE OF ALL GRP COVERS TO PREP ARE FOR LAMINATION ANDCOATING.Ø# APPLY TWO LAYERS OF TISSUE ON ALL JOINTS OF THE GRP COVERS.Ø# APPLY A TOPCOAT WITH SAND ON THE TOP SURFACE OF THE GRP COVERS TOPROVIDE A NON-SLIPØ#FINISH.Ø# CARRY OUT LAMINATION AT THE BASE OF THE STEEL POSTS TO ENSURE PROPERPROTEC TION ANDØ#REINFORCEMENT.Ø#SEAL AND CLOSE ALL GAPS BETWEEN THE GRP COVERS AND GRP SUPPORTS.Ø# PERFORM COMPLETE HOUSEKEEPING AND CLEAN THE SURROUNDING WORK AREA. COMPLETE THE WORK IN ACCORDANCE WITH DEWA SITE REQUIREMENTS AND SAFETYSTANDARDS.# | | | | | | |
| 2 | | ITEM-00001 | TECHNICAL AND GENERAL SPECIFICATION FOR OUTSOURCING WORKL2 STATION, JEBEL ALI POWER STATION#NAME OF WORK : ST-86 SEA | 1 | EA | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600362
DATE : 09.02.2026
REQ No : 1032600641
REQ TITLE : ST-85&86 SEA WATER SEAL
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|--|-----|-----|--------------|----------|------------|-------------|
| | | | <p>WATER SEAL PIT</p> <p>GRP COVER REPAIR WORK #PERIOD OF WORK : 5 DAYS#SCOPE OF WORK FOR GRP COVERS & GRP SUPPORT MAINTENANCEØ#THE FOLLOWING SCOPE OF WORK D</p> <p>ESCRIBES THE MAINTENANCE ACTIVITIES FORGRP COVERS AT SEA WATER SEAL PITØ# CLEAN ALL SEA WATER SEAL PIT GRP COVERS THOROUGHLY TO REMO</p> <p>VE DIRT,DUST, AND CONTAMINANTS.Ø# OPEN THE DAMAGED SEA WATER SEAL PIT GRP COVERS, REPAIR AND RECTIFYTHE DAMAGED AREAS, AND REINSTALL</p> <p>WITH PROPER SEALINGØ#AFTER RECTIFICATION CONTRACTOR MUST ENSURE ALL THE GRP COVERS AREPROPERLY SEALED WITH PROPER SEALANTØ#WHILE RE</p> <p>STORE THE GRP COVER CONTRACTOR MUST WEAR SUITABLE PPE ON THETOP OF GRP COVERØ# REPLACE AND INSTALL THE GRP SUPPORT AND GRP COVER IF</p> <p>REQUIRED.Ø#REPLACE ALL DAMAGED, CORRODED, OR MISSING BOLTS WITH NEW</p> | | | | | | |

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600362
DATE : 09.02.2026
REQ No : 1032600641
REQ TITLE : ST-85&86 SEA WATER SEAL
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

| SL NO | ITEM CODE | SERVICE ID | DESCRIPTION | QTY | UOM | BRAND/ORIGIN | WARRANTY | UNIT PRICE | TOTAL PRICE |
|-------|-----------|------------|---|-----|-----|--------------|----------|------------|-------------|
| | | | SUITABLE BOLTS.Ø#GRIND THE TOP SURFACE OF ALL GRP COVERS TO PREPARE FOR LAMINATION AND COATING.Ø# APPLY TWO LAYERS OF TISSUE ON ALL JOINTS OF THE GRP COVERS.Ø# APPLY A TOPCOAT WITH SAND ON THE TOP SURFACE OF THE GRP COVERS TO PROVIDE A NON-SLIPØ#FINISH.Ø# CARRY OUT LAMINATION AT THE BASE OF THE STEEL POSTS TO ENSURE PROPER PROTECTION ANDØ#REINFORCEMENT.Ø#SEAL AND CLOSE ALL GAPS BETWEEN THE GRP COVERS AND GRP SUPPORTS.Ø# PERFORM COMPLETE HOUSEKEEPING AND CLEAN THE SURROUNDING WORK AREA. COMPLETE THE WORK IN ACCORDANCE WITH DEWA SITE REQUIREMENTS AND SAFETY STANDARDS.# | | | | | | |

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600362
DATE : 09.02.2026
REQ No : 1032600641
REQ TITLE : ST-85&86 SEA WATER SEAL
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

ST-85<(>&<)>86 SEA WATER SEAL PIT GRP COVER REPAIR WORK AT L-2 STATION

Contact arunkumar.sethuraman@dewa.gov.ae Tel: 04-322-6104

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
 - 2) Quotation to be submitted only in local currency U.A.E Dirhams
 - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
 - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
 - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
 - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600362
DATE : 09.02.2026
REQ No : 1032600641
REQ TITLE : ST-85&86 SEA WATER SEAL
DELIVERY LOCATION
CLOSING DATE : 13.02.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP