

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600394  
**DATE** : 12.02.2026  
**REQ No** : 1032600633  
**REQ TITLE** : Urgent 1032600633 HRSG 81  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>DEWA-CONFIDENTIAL TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK</p> <p>L2 STATION, JEBEL ALI POWER STATION</p> <p>TITLE: HRSG 81 STEAM SILENCER REPAIR WORK</p> <p>QTY: 1. STEAM SILENCER REPAIR WORK 6NOS.</p> <p>DURATION: 2 DAYS/ EACH.</p> <p>TENTATIVE SCHEDULE: DURING HRSG OUTAGE</p> <p>A. SCOPE OF WORK</p> <ul style="list-style-type: none"> <li>THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID.</li> <li>TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS AND METHOD STATEMENT PRIOR TO START THE WORK.</li> <li>CHECK CONDITION SUITABLE TO CARRY OUT WORK.</li> <li>CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.</li> <li>IF WORKING ENVIRONMENT IS SAFE PROCEED THE FOLLOWING STEPS.</li> <li>A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK</li> </ul>	3	AU				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600394  
**DATE** : 12.02.2026  
**REQ No** : 1032600633  
**REQ TITLE** : Urgent 1032600633 HRSG 81  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INVOLVE D IN METHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE GIVEN TO THE EMPLOYEES.. MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. ON 48 HRS. NOTICE PERIOD.(3 TIMES IF REQUIRED). SAFETY HARNESS FOR ALL TEAM DURING WORK.. AWARDING THE PO DOES NOT GUARANTEE THAT COMP LETE QUANTITY IN THE PO WILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDED BASED ON INSPECTION AND PAYMENT SHALL BE BASED ON ACTUAL WORK CARRIED OUT. SCOPE OF WORK FOR HP DRUM SAFETY VALVE SILENCER: REMOVAL INLET PIPE INSULATION, REMOVAL OF THE BOTTOM OUTER CASING, REMOVAL OF THE DIFFUSER FROM THE SILENCER. REPLACE THE INLET PIPE MATERIAL SA 106 GR B, OD 273 MM, THICKNESS 9.27 MM, LENGTH 450 MM (TWO WELDING JOINT ONE DIFFUSER SIDE AND ONE PIPE SIDE)</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600394  
**DATE** : 12.02.2026  
**REQ No** : 1032600633  
**REQ TITLE** : Urgent 1032600633 HRSG 81  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSTALLATION AND WELDING OF THE BOTTOM OUTER CASING.O PR OPER WPS HAS TO BE FOLLOWED DURING THE WELDING.O NDT INSPECTION FOR THE WELD JOINTS.O INSPECTION OF THE DIFFUSER BY DEWA PERSON.O IN LET PIPE INSULATION FIXINGDEWA-CONFIDENTIALDEWA SCOPE- PIPE.. SCAFFOLDING IF REQUIRED.. AIR, WATER AND ELECTRICITY.. INSULATIONCONTR ACTOR SCOPE OF SUPPLY.. TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.. MANPOWER.. WELDING CONSUMABLES- ITP, WPS, NDT PLAN, ERECT ION PLAN & PWHT PROCEDURES.. TEMPORARY SUPPORTSWARRANTY.. THE WARRANTY PERIOD FOR THE WORK SHALL BE ONE YEAR FROM THE DATE OFCOMPLETIO N OF WORK CERTIFIED BY DEWA.. IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600394  
**DATE** : 12.02.2026  
**REQ No** : 1032600633  
**REQ TITLE** : Urgent 1032600633 HRSG 81  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORTPERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.						
2		ITEM-00001	DEWA-CONFIDENTIAL TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK 2 STATION, JEBEL ALI POWER STATION TITLE: HRSG 84 STEAM SILENCER REPAIR WORK QTY: 1. STEAM SILENCER REPAIR WORK 6 NOS. DURATION: 2 DAYS/EACH. TENTATIVE SCHEDULE: DURING HRSG OUTAGE A. SCOPE OF WORK - THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID. - TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS AND METHOD STATEMENT PRIOR TO START THE WORK. - CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE	3	AU				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600394  
**DATE** : 12.02.2026  
**REQ No** : 1032600633  
**REQ TITLE** : Urgent 1032600633 HRSG 81  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WORKING ENVIRONMENT.. IF WORKING ENVIRONMENT IS SAFE PROCEED THE FOLLOWING STEPS.. A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED IN METHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE GIVEN TO THE EMPLOYEES.. MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. ON 48 HRS. NOTICE PERIOD.(3 TIMES IF REQUIRED). SAFETY HARNESS FOR ALL TEAM DURING WORK.. AWARDING THE PO DOES NOT GUARANTEE THAT COMPLETE QUANTITY IN THE PO WILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDED BASED ON INSPECTION AND PAYMENT SHALL BE BASED ON ACTUAL WORK CARRIED OUT. SCOPE OF WORK FOR HP DRUM SAFETY VALVE SILENCER: REMOVAL INLET PIPE INSULATION REMOVAL OF THE BOTTOM OUTER CASING REMOVAL OF THE DIFFUSER FROM THE SILENCER. REPLACE THE INLET PIPE						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600394  
**DATE** : 12.02.2026  
**REQ No** : 1032600633  
**REQ TITLE** : Urgent 1032600633 HRSG 81  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MATERIAL SA 106 GR B, OD 273 MM , THICKNESS9.27 MM , LENGTH 450 MM ( TWO WELDING JOINT ONE DIFFUSER SIDE AND ONEPIPE SIDE) INSTALLATION AND WELDING OF THE BOTTOM OUTER CASING.O PR OPER WPS HAS TO BE FOLLOWED DURING THE WELDING.O NDT INSPECTION FOR THE WELD JOINTS.O INSPECTION OF THE DIFFUSER BY DEWA PERSON.O IN LET PIPE INSULATION FIXINGDEWA-CONFIDENTIALDEWA SCOPE- PIPE.. SCAFFOLDING IF REQUIRED.. AIR, WATER AND ELECTRICITY.. INSULATIONCONTR ACTOR SCOPE OF SUPPLY.. TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.. MANPOWER. WELDING CONSUMABLES. ITP, WPS, NDT PLAN, ERECT ION PLAN & PWHT PROCEDURES. TEMPORARY SUPPORTSWARRANTY. THE WARRANTY PERIOD FOR THE WORK SHALL BE ONE YEAR FROM THE DATE OFCOMPLETIO N OF WORK CERTIFIED BY DEWA.. IN CASE OF ANY						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600394  
**DATE** : 12.02.2026  
**REQ No** : 1032600633  
**REQ TITLE** : Urgent 1032600633 HRSG 81  
**DELIVERY LOCATION**  
**CLOSING DATE** : 16.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORT PERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

**SPECIAL NOTES / INSTRUCTIONS:**

HRSG 81 and 84 STEAM SILENCER REPAIR WORK. Contact suood.khamis@dewa.gov.ae

**STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2332600394
<b>DATE</b>	: 12.02.2026
<b>REQ No</b>	: 1032600633
<b>REQ TITLE</b>	: Urgent 1032600633 HRSG 81
<b>DELIVERY LOCATION</b>	
<b>CLOSING DATE</b>	: 16.02.2026
<b>CLOSING TIME</b>	: 10:00:00

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**