

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600396  
**DATE** : 12.02.2026  
**REQ No** : 1032600657  
**REQ TITLE** : Repair, Calibration and cert  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	#### REPAIR, CALIBRATION AND CERTIFICATION OF PRESSURE TRANSMITTER ATDEWA WATER NETWORK BY ISO 9000 PARTY FOR ZONE -1.CALIBRATION AND CERTIFICATION OF PRESSURE TRANSMITTERS SPECIFICATION AND SCOPE OF WORKS1.#THE CALIBRATION SHALL BE DONE AS PER THE MANUFACTURER'S RECOMMENDED PRACTICES/PROCEDURES AND TRACEABLE TO NATIONAL & INTERNATIONAL STANDARDS.2.#COMPANY HAS TO BE ACCREDITED TO LATEST INTERNATIONAL STANDARD. (ISO9001-2008)3.#A DETAILED CALIBRATION PROCEDURE TO BE SUBMITTED FOR THE SAID CALIBRATION METHOD FOR REVIEW.4.#ALL MASTERS INSTRUMENTS/EQUIPMENT'S USED FOR CALIBRATION SHOULD BE CALIBRATED AND THE ACCURACY SHALL BE TRACEABLE TO NATIONAL/INTERNATIONAL STANDARDS. THE CERTIFICATE SHOULD BE PROVIDED TO DEWA FOR REFERENCE.5.#ALL THE CALIBRATION JOB TO BE DONE AT VARIOUS SITES	1.400	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600396  
**DATE** : 12.02.2026  
**REQ No** : 1032600657  
**REQ TITLE** : Repair, Calibration and cert  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AT DUBAIE MIRATES AS PER THE SCHEDULED BY DEWA ENGINEER ONLY. THE PERMIT AND CO-ORDINATION WITH MATER CONTROL STATION WILL BE DONE FROM DEWA E ND.6.#THE COMPANY SHALL COLLECT PTS IN BATCHES AND RETURN THE PTS DULY CALIBRATED IN 03 WORKING DAYS TO DEWA # BMC RUWAIYAH OFFICE FO R A MINIMUM QTY AS PER REQUIREMENT.7.#THE COMPANY SHOULD PROVIDE THE PT REPORT IN DETAIL AFTER THE CALIBRATION WORK DONE.8.#PRIOR TO C ALIBRATION OF PTS, CLEANING OF HOUSING WITH ALL INTERNAL/EXTERNAL PARTS OF PT TO BE DONE AND POWER SUPPLY TO THE PRESSURE TRANSMITTER WHICH ASSOCIATED WIRING/CABLE NEED TO BE CLEAN, CHECK AND INSPECT BEFORE THE CALIBRATION PROCESS.9.#PTS LCD TO BE CHECKED FOR NORMAL OPERATION BEFORE THE CALIBRATION.10.#PTS SHOULD BE CALIBRATED WITH PNEUMATIC/WATER						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600396  
**DATE** : 12.02.2026  
**REQ No** : 1032600657  
**REQ TITLE** : Repair, Calibration and cert  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MASTER CALIBRATOR ONLY. (NO OIL MEDIUM TO BE USED)</p> <p>11.#FOR PMP71 PT CALIBRATION SHOULD BE DONE THROUGH THE FIELD CARE SOFTWARE.</p> <p>12.#PT SHOULD BE VERIFY BY APPLYING LINEAR PRESSURE 0%, 2 5%, 50%, 70% &amp; 100% DURING THE CALIBRATION AND MAINTAIN THE ACCURACY AS PER THE MANUFACTURER RECOMMENDATION.</p> <p>13.#AFTER THE SUCCESSFUL CALIBRATION PT SPAN ADJUSTMENT SCREWS SHOULD BE SEALED.</p> <p>14.#ACCURACY SHOULD BE MAINTAINED AS PER THE P.T MANUFACTURER RECOMMENDATION.</p> <p>15.#CALIBRATION CERTIFICATE TO BE PROVIDED FOR EACH P.T AFTER THE CALIBRATION.</p> <p>16.#CALIBRATION DETAILS WITH DUE DATE LABEL/STICKER TO BE FIXED ON EACH P.T.</p> <p>17.#AFTER THE CALIBRATION ALL P.T FUNCTIONS NEED TO BE CHECKED AND LOGGED AS PER THE PT MEASURING SCALE/RANGE.</p> <p>18.#DU</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600396  
**DATE** : 12.02.2026  
**REQ No** : 1032600657  
**REQ TITLE** : Repair, Calibration and cert  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RING THE CALIBRATION IF THE PT FOUNDS MAJOR DEFECTIVE CONTRACTOR HAS TO INFORM TO DEWA &amp; RETURNED BACK WITHIN 02 WORKING FROM THERECE</p> <p>IVING DATE WITH A REPORT.19.#IF THE PT REQUIRES DURING THE CALIBRATION SMALL ITEM LIKE CONNECTORS, TERMINAL BLOCK AND LEGS ETC. COMP</p> <p>ANY HAS TO REPLACE FREE OF CHARGE WITH NO ADDITIONAL COST TO DEWA.20.#THE PRESSURE TRANSMITTERS (PT) ARE OF VARIOUS MAKE OF ENDRESS+H</p> <p>AUSER, KROHNE AND SIEMENS AND OF VARIOUS RANGES -1 TO 4, -1 TO 10, -1 TO 16 &amp; -1 TO 40 BAR.21.#THE COMPANY SHALL PROVIDE A CHECKLIST</p> <p>FOR THE CALIBRATION ACTIVITIES OF WHICH IS DULY APPROVED BY THE DEWA ENGINEER. NOTE- FOR ANY CLARIFICATION PLEASE CONTACT MR. ABHILASH BABU ON 052-9172571.</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2332600396
<b>DATE</b>	: 12.02.2026
<b>REQ No</b>	: 1032600657
<b>REQ TITLE</b>	: Repair, Calibration and cert
<b>DELIVERY LOCATION</b>	
<b>CLOSING DATE</b>	: 18.02.2026
<b>CLOSING TIME</b>	: 10:00:00

### **SPECIAL NOTES / INSTRUCTIONS:**

Repair, Calibration and certification of pressure transmitter at DEWA water network by ISO 9000 Party for Zone -1.

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2332600396
<b>DATE</b>	: 12.02.2026
<b>REQ No</b>	: 1032600657
<b>REQ TITLE</b>	: Repair, Calibration and cert
<b>DELIVERY LOCATION</b>	
<b>CLOSING DATE</b>	: 18.02.2026
<b>CLOSING TIME</b>	: 10:00:00

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**