

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION ,OUTSOURCING WORK L II STATION, JEBEL ALI POWER STATIONNAME OF WORK : REMOVAL AND RE FIXING OF LINER PLATES AND INSULATION FORTHE FOLLOWING AREAS TO CARRY OUT THE INSPECTION OF FLOW GRID BOTTOMSUPPORT OF HRSG 81FLOW GRID BOT TOM SUPPORT. SIZE (2.2M WIDTHX7.2M LENGTH) 3MM THICK PLATEREMOVAL AND REFIXING.1.#FLOW GRID BOTTOM SUPPORT INSULATION REMOVAL AND RE FIXING SIZE (2.2MWIDTHX7.2M LENGTH) 7 LAYERS OF INSULATION THICKNESS 50MMPERIOD OF WORK: 05 DAYS DURING SHUT DOWN OF HRSG.SCOPE OF WORK:.#TO GET A PTW, HWP CONTRACTOR HAS TO SUBMIT RISK ASSESSMENT FORMS ANDMETHOD STATEMENT).#CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY ANDSAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.#IF WORKING ENVIRONMENT IS</p>	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SAFE PROCEED THE FOLLO            WING STEPS.#A SAFETY MEETING WILL BE HELD            TO EVALUATE THE RISK INVOLVED INMETHODS TO            BE USED. RISK ASSESSMENT AND TOOL BOX TALK            TO B            E GIVEN TO THEEMPLOYEES.#MOBILIZE THE            LABOR, EQUIPMENT, TOOLS, ETC. ON 24 HRS.            NOTICE PERIOD.#DEWA WILL PROVIDE THE            SCAFFOLDING IF            REQUIRED.#CUTTING OF THE NUT (M12) AND            REMOVE THE LINER PLATE THICKNESS 3MMFROM            THE DESIGNATED AREA. DUCT BURNER AREA.            (2.2M WIDTHX            7.2M LENGTH) #3MM THICK PLATE            REMOVAL.#REMOVE THE OLD            INSULATION/CERAMIC BLANKET FROM THE            DESIGNATED AREASIZE (2.2M WIDTHX7.2M LENG            TH) 7 LAYERS OF INSULATION THICKNESS            50MM.#CLEAN/RETHREADING/REPLACEMENT OF            STUDS SIZE 12MM MATERAIL 321H            IFREQUIRE.#INSPECTION OF            THE BOTTOM SUPPORTS.( INSPECTION WILL BE            DONE BY DEWA)#INSULATION 7 LAYERS TO BE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FIXED AND ALL LAYERS TO BE OVERLAP  WITHEACH OTHER  .#RE FIXING OF LINER PLATE AND TACK WELD THE  STUD WITH NUT. MATERIALWILL BE PROVIDE BY  DEWA.#ENSURE SMOOTH OPERATION OF THE  BOILER  AND SUBMIT FULL REPAIRINGREPORTS TO DEWA  WITH WARRANTY FOR ONE  YEAR...#HOUSEKEEPING AND DISPOSAL OF WASTE  FROM THE JOB TO BE DONE B  EFORESITE CLEARANCE.#INSPECTION AND  APPROVAL FROM DEWA  PERSONNEL.#DE-MOBILIZATION AND SITE  CLEARANCE.#SCAFFOLDING AND INSULATION U  NDER DEWA SCOPE.#PREVIOUS EXPERIENCE PO  # TO BE PROVIDED FOR THE SAME TYPE OF JOB  FROMDEWA OR ANY OTHER WELL-KNOWN  COMPANY.#WORK C  OMPLETION REPORT TO BE SUBMITTED TO  DEWA.#WORK WILL BE CARRY OUT DURING HRSG  OVERHAULING FROM OCT-2020  TOMARCH-2020.GENERAL TERMS &amp;  CONDITIONS1.#THE CONTRACTOR SHALL VISIT</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMIT HIS BID. #THE CONTRACTOR SHALL SUBMIT THE SCHEDULE OF WORK AND THE PERIOD FOR WORK SO THAT THE WORK SHALL COME WELL WITHIN THE ALLOTTED OUTAGE PERIOD. THE SCHEDULE SHALL BE APPROVED BY DEWA BEFORE COMMENCEMENT OF WORK. #THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATED PLACES AS PER DEWA ENVIRONMENTAL POLICY OF HAZARDOUS WASTE DISPOSAL. #ALL DEWA SAFETY &amp; ENVIRONMENT POLICY, RULES AND REGULATION SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR'S ENGINEER SHOULD BE FAMILIAR WITH SAFETY R</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REGULATIONS WHILE WORKING IN AHAZARDOUS AREA.5.#THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/ SCHEDULE REQUIREMENT. CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE ATSITE THROUGHOUT THE PERIOD OF WORK.6.#THE CONTRACTOR SHOULD APPLY FOR THE PERMIT TO WORK WELL IN ADVANCEAND THIS REQUEST SHALL BE FOLLOWED WITH METHOD STATEMENT, RISKASSESSMENT AS ATTACHMENTS7.#ENTRY PERMITS FOR THE STAFF/WORKERS SHOULD BE APPLIED WITH PASSPORTCOPIES HAVING VALID VISA. PERSONS, WHOSE NAMES ARE NOT AVAILABLE IN THELIST, WILL NOT BE ALLOWED TO ENTER THE POWERHOUSE8.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE ASAFE WORKING CONDITION.9.#ENTRY PERMITS FOR THE VEHICLE SHOULD BE APPLIED WITH COPIES OFVEHICLE REGISTRATION.10.#ALL THE PERSONS SHOULD</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WEAR THE UNIFORM, SAFETY SHOES AND HELMET WHILE AT WORK.11.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWA ENGINEER IN-CHARGE ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.12.#TOOLBOX TALKS AND RISK ASSESSMENTS SHOULD BE GIVEN TO THE WORKMEN BY THEIR SUPERVISOR BEFORE START OF WORK.13.#DEWA ENGINEER-IN-CHARGE SHALL BE UPDATED THE WORK PROGRESS ON A REGULAR BASIS.14.#CONTRACTOR SHOULD GET HOT WORK PERMIT FROM DEWA ENGINEER-IN-CHARGE ON DAILY BASIS AND PROVIDE TBT AND RA ACCORDINGLY.PARTY SHOULD COMPLY THE SA 8000 STANDARD AS PER DEWA</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TERMS AND CONDITION						
2		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION ,OUTSOURCING WORK L II STATION, JEBEL ALI POWER STATIONNAME OF WORK : REMOVAL AND RE FIXING OF LINER PLATES AND INSULATION FORTHE FOLLOWING AREAS TO CARRY OUT THE INSPECTION OF FLOW GRID BOTTOMSUPPORT OF HRSG 841.#FLOW GRID BOTTOM SUPPORT. SIZE (2.2M WIDTHX7.2M LENGTH) 3MM THICKPLATE REMOVAL AND REFIXING.2.#FLOW GRID BOTTOM SUPPORT INSULATION REMOVAL AND REFIXING SIZE (2.2MWIDTHX7.2M LENGTH) 7 LAYERS OF INSULATION THICKNESS 50MMPERIOD OF WORK: 05 DAYS DURING SHUT DOWN OF HRSG.SCOPE OF WORK:.#TO GET A PTW, HWP CONTRACTOR HAS TO SUBMIT RISK ASSESSMENT FORMS ANDMETHOD STATEMENT)-#CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY ANDSAFETY INSPECTION TO ASSESS THE WORKING</p>	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENVIRONMENT.#IF WORKING ENVIRONMENT IS SAFE PROCEED THE FOLLOWING STEPS.#A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOL BOX TALK TO BE GIVEN TO THEEMPLOYEES.#MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. ON 24 HRS. NOTICE PERIOD.#DEWA WILL PROVIDE THE SCAFFOLDING IF REQUIRED.#CUTTING OF THE NUT (M12) AND REMOVE THE LINER PLATE THICKNESS 3MMFROM THE DESIGNATED AREA. DUCT BURNER AREA. (2.2M WID THX7.2M LENGTH) #3MM THICK PLATE REMOVAL.#REMOVE THE OLD INSULATION/CERAMIC BLANKET FROM THE DESIGNATED AREASIZE (2.2M WIDTHX7.2M LENGTH) 7 LAYERS OF INSULATION THICKNESS 50MM.#CLEAN/RETHREADING/REPLACEMENT OF STUDS SIZE 12MM MATERAIL 321H IFREQUIRE.#INSPECTION OF THE BOTTOM SUPPORTS.( INSPECTION WILL</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BE DONE BY DEWA).#INSULATION 7 LAYERS TO BE FIXED AND ALL LAYERS TO BE OVERLAP WITHEACH OTHER.#RE FIXING OF LINER PLATE AND TACK WELD THE STUD WITH NUT. MATERIAL WILL BE PROVIDED BY DEWA.#ENSURE SMOOTH OPERATION OF THE BOILER AND SUBMIT FULL REPAIRING REPORTS TO DEWA WITH WARRANTY FOR ONE YEAR...#HOUSEKEEPING AND DISPOSAL OF WASTE FROM THE JOB TO BE DONE BEFORE SITE CLEARANCE.#INSPECTION AND APPROVAL FROM DEWA PERSONNEL.#DE-MOBILIZATION AND SITE CLEARANCE.#SCAFFOLDING AND INSULATION UNDER DEWA SCOPE.#PREVIOUS EXPERIENCE PO # TO BE PROVIDED FOR THE SAME TYPE OF JOB FROM DEWA OR ANY OTHER WELL-KNOWN COMPANY.#WORK COMPLETION REPORT TO BE SUBMITTED TO DEWA.#WORK WILL BE CARRY OUT DURING HRSG OVERHAULING FROM OCT-2020 TO MARCH-2020.GENERAL TERM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>S &amp; CONDITIONS1.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES ETC., BEFORE HE SUBMIT HIS BID2.#THE CONTRACTOR SHALL SUBMIT THE SCHEDULE OF WORK AND THE PERIOD FORWORK SO THAT THE WORK SHALL COME WELL WITHIN THE ALLOTTED OUTAGE PERIOD.THE SCHEDULE SHALL BE APPROVED BY DEWA BEFORE COMMENCEMENT OF WORK3.#THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS AND THECONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TODesignated PLACES AS PER DEWA ENVIRONMENTAL POLICY OF HAZARDOUS WASTEDISPOSAL..4.#ALL DEWA SAFETY &amp; ENVIRONMENT POLICY, RULES AND REGULATION SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#ENGINEER SHOULD BE FAMILIAR</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA.5.#THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/ SCHEDULE REQUIREMENT. CONTRACTOR'S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK.6.#THE CONTRACTOR SHOULD APPLY FOR THE PERMIT TO WORK WELL IN ADVANCE AND THIS REQUEST SHALL BE FOLLOWED WITH METHOD STATEMENT, RISK ASSESSMENT AS ATTACHMENTS 7.#ENTRY PERMITS FOR THE STAFF/WORKERS SHOULD BE APPLIED WITH PASSPORT COPIES HAVING VALID VISA. PERSONS, WHOSE NAMES ARE NOT AVAILABLE IN THE LIST, WILL NOT BE ALLOWED TO ENTER THE POWERHOUSE 8.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION .9.#ENTRY PERMITS FOR THE VEHICLE SHOULD BE APPLIED WITH COPIES OF VEHICLE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REGISTRATION.10.#ALL THE PERSONS SHOULD WEAR THE UNIFORM, SAFETY SHOES AND HELMETWHILE AT WORK.11.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BYDEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWAENGINEER IN-CHARGE ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FORTHE CLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.12.#TOOLBOX TALKS AND RISK ASSESSMENTS SHOULD BE GIVEN TO THE WORKMENBY THEIR SUPERVISOR BEFORE START OF WORK.13.#DEWA ENGINEER-IN-CHARGE SHALL BE UP DATED THE WORK PROGRESS ON AREGULAR BASIS.14.#CONTRACTOR SHOULD GET HOT WORK PERMIT FROM DEWA ENGINEER-IN-CHARGEON DAILY BASIS AND PROVIDE TBT AND RA ACCORDINGLY.PARTY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHOULD COMPLY THE SA 8000 STANDARD AS PER DEWA TERMS AND CONDITION						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

**SPECIAL NOTES / INSTRUCTIONS:**

REMOVAL AND RE FIXING OF LINER PLATES AND INSULATION FOR THE FOLLOWING AREAS TO CARRY OUT THE INSPECTION OF FLOW GRID BOTTOM SUPPORT OF HRSG 81 and 84. (2 NO) AT L-2 STATION

For more details contact Arunkumar.sethuraman@dewa.gov.ae 04-322-6104

**STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600504  
**DATE** : 23.02.2026  
**REQ No** : 1032600863  
**REQ TITLE** : REMOVAL AND RE FIXING OF  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.02.2026  
**CLOSING TIME** : 10:00:00

connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements  
The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**