

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>COMPLETE OVERHAULING OF BOOSTER PUMP FOR JA HABAB PH2 PUMPING STATION.PUMP DETAILS: EQUIPMENT NO. 50437328, TORISHIMA PUMP MODEL: DV L-250,HEAD-140M, FLOW-263L/S, RPM-1475, 630KW.SCOPE OF WORKTHE FOLLOWING OUTLINES THE MANDATORY AND OPTIONAL SCOPE OF WORK FOR THEOV ERHAUL OF BOOSTER PUMPS AND THEIR ACCESSORIES AT THE BOOSTER PUMPINGSTATION.1.0 MANDATORY SCOPE OF WORK:A) THE CONTRACTOR IS RESPONSIBLE FOR TRANSPORTING THE PUMP ASSEMBLY TOAND FROM THE DEWA SITE TO THEIR WORKSHOP. DEWA WILL NOT PROVIDETRANSPORTATION. FOR LOADING AND UNLOADING, THE CONTRACTOR MAY USE DEWA#SOVERHEAD CRANE AT THE PUMPING STATION, WITH PROPER COORDINATION WITHDEWA REPRESENTATIVE S. B) REPLACEMENT OF THE MECHANICAL SEAL, COUPLINGBUSH RENEWAL, GLAND PACKING RENEWAL, AND BEARING REPLACEMENT</p>	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ASREQUIRED. C) OVERHA ULING OF THE PUMP (REFER TO ANNEXURE I FOR MANDATORYAND ANNEXURE II FOR OPTIONAL WORK). D) EXTERNAL PAINTING OF THE PUMP. E)RECTIFIC ATION OF ANY ISSUES THAT ARISE AFTER INSTALLATION/LOAD TESTING.THIS SHALL BE DONE ON SITE IF POSSIBLE, AND IF NOT, THE CONTRACTOR IS RESPONSIBLE IN COLLECTING THE PUMP AND MOVED IT BACK TO THEIR FACILITY.F) IF ANY PART IS FOUND DEFECTIVE, THE CONTRACTOR IS RESPONSI BLE FORREPAIRING OR REPLACING IT. DEWA WILL PROVIDE AVAILABLE SPARES. IF ANYSPARE PARTS ARE UNAVAILABLE, THE CONTRACTOR MUST ARRANGE THEM AND SUBMITTHE COST FOR DEWA APPROVAL BEFORE PLACING AN ORDER. G) ONCE THE PUMP ISFULLY ASSEMBLED, THE PUMP MUST BE PRESSURE HY DRO TESTED IN THECONTRACTOR FACILITY TO MAKE SURE THE PUMP IS WELL ASSEMBLED AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THAT THERE ARE NO LEAKS. 2.0 REQUIREMENTS PRIOR TO QUOTATION SUBMISSION: A) THE CONTRACTOR MUST VISIT THE SITE TO FAMILIARIZE THEMSELVES WITH THE SCOPE OF WORK AND POTENTIAL COMPLEXITIES BEFORE SUBMITTING A QUOTATION. B) DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL CHARGES BEYOND THE AGREED RATES OR PRICES DURING OR AFTER THE EXECUTION OF THE WORK. C) THE CONTRACTOR WILL BE PROVIDED WITH AN EQUIPMENT SHUTDOWN SCHEDULE IN COORDINATION WITH THE OPERATIONS & MAINTENANCE DEPARTMENT OF THE WATER DIVISION. D) A TIME SCHEDULE OR BAR CHART SHOWING EACH ACTIVITY MUST BE SUBMITTED. E) UPON COMPLETION, AN INSPECTION CHECKLIST AND QUALITY PROCEDURE DOCUMENTATION, WHERE APPLICABLE, MUST BE SUBMITTED. F) THE CONTRACTOR IS RESPONSIBLE FOR SITE SUPERVISION, COORDINATION</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF FIELDACTIVITIES, AND THE SUPPLY OF REQUIRED TECHNICIANS, TOOLS, EQUIPMENT,AND RESOURC ES NECESSARY TO EXECUTE THE CONTRACT.3.0 TAKEOVER:UPON COMPLETION OF ALL WORK WITHIN THE SCOPE OF THE CONTRACT, THECONTRACTOR MUST N OTIFY DEWA IN WRITING. A CERTIFICATE OF COMPLETION WILLBE ISSUED AFTER A FINAL INSPECTION, CONFIRMING THAT THE WORK HAS BEENACCEPTED AND TAKEN OVER BY DEWA FOLLOWING THE NECESSARY CONDITIONMONITORING CHECKS.4.0 WARRANTY:A) ALL WORK WILL CARRY A WARRANTY OF 8,000 H OURS OF OPERATION OR ONEYEAR, WHICHEVER COMES FIRST. B) THE WARRANTY WILL TAKE EFFECT FROM THEDATE OF DEWA'S OFFICIAL TAKEOVER OF TH E COMPLETED JOB. C) IF ANY DEFECTSARE IDENTIFIED DURING THE WARRANTY PERIOD, THE CONTRACTOR MUST RECTIFYTHEM WITHIN THE TIMEFRAME SE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>T BY DEWA WITHOUT ADDITIONAL COST ORCOMPENSATION.5.0 DOCUMENTATION:UPON SATISFACTORY COMPLETION OF THE WORK AND HANDOVER, THE CONTRA CTORMUST SUBMIT THE FOLLOWING DOCUMENTS TO DEWA: #INITIAL INSPECTION REPORT (MENTIONING THE REQUIRED SPARES ANDREQUIRED ACTIONS).#JOB COMPLETION REPORT (INCLUDING ALL OVERHAULING ACTIONS DONE) WITHINONE WEEK OF DELIVERY.#SERVICE ENTRY APPLICATION ATTACHING THE JOB COMPLETION REPORTIMMEDIATELY ONCE THE REPORT IS SIGNED BY DEWA REPRESENTATIVE.#INCLUDING ALL PROPER PHOTOS, EQUIPMENT SERIAL NUMBER , AND EQUIPMENTTAGGING.#REQUISITION FOR SPARE PARTS PLANNING BASED ON THE CURRENT CONDITIONOF THE EQUIPMENTANNEXURE I # DETAILED MAN DATORY SCOPE OF WORK FOR BOOSTER PUMP OVERHAUL1.#DISMANTLING: THE CONTRACTOR SHALL DISMANTLE THE PUMP ACCORDING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TODEWA ENGINEER#S INSTRUCTIONS. SKILLED WORKMANSHIP AND CARE MUST BEAPPLIED DURING REMOVAL.2.#OVERHAULING: THE CONTRACTOR SHALL DISMANTLE THE ROTATING ASSEMBLY INTHEIR WORKSHOP AND RECORD ALL FINDINGS, INCLUDING PHOTOGRAPHS OFDETERIORATED COMPONENTS. THE SHAFT MUST BE INSPECTED FOR STRAIGHTNESS,AND WORN AREAS SHOULD BE RECONDITIONED. IMPELLER, BEARINGS, MECHANICALSEAL, GLAND SLEEVE, AND WEAR RINGS MUST BE THOROUGHLY CHECKED ANDREPLACED IF NECESSARY. ALL PARTS FOUND DEFECTIVE MUST BE REPAIRED ORREPLACED, WITH AVAILABLE SPARES SUPPLIED BY DEWA.</p> <p>IF SPARES AREUNAVAILABLE, THE CONTRACTOR MUST ARRANGE THEM AND SEEK APPROVAL FROMDEWA FOR ADDITIONAL COSTS. THE PUMP CASING MUST BE CLEANED AND INSPECTEDFOR DAMAGE, AND ANY NECESSARY REPAIRS MUST BE CARRIED OUT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>USINGSANDBLASTING AND FOOD-GRADE EPOXY COATING.3.#AS SEMBLY: REASSEMBLY OF THE EQUIPMENT MUST FOLLOW STANDARDPROCEDURES, ENSURING THE PROPER FIT AND CLEARANCES. THE ROTOR ASSEMBLYSHOULD BE DYNAMICALLY BALANCED PER ISO 1940/1 STANDARDS. A DETAILEDRECORD OF ALL ACTIVITIES MUST BE MAINTAINED, AND ANY DEVIATIONS FROM SE TVALUES WILL BE DETERMINED BY DEWA.4.#CONSUMABLES & ACCESSORIES: MANUFACTURING OF MECHANICAL SEAL COOLINGPIPE FITTINGS, SHAFT LOCK N UTS, LOCK WASHERS, DOWEL PINS, BEARINGSPACERS, HOLDING DOWN BOLTS, AND VARIOUS GASKETS, INCLUDING THE SUPPLYOF O-RINGS.ANNEXURE II # OPTIONAL MACHINING WORKS1.#IMPELLER MACHINING: THIS INCLUDES GRIT BLASTING AND NON-DESTRUCTIVETESTING (NDT) TO IDENTIFY CRACKS, SKI MMING THE WEAR RING AREAS, ANDFITTING NEW</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RINGS.2.#SHAFT MACHINING: THE SHAFT WILL UNDERGO CHROME PLATING ON BEARINGSEATING AREAS AND MECHANICAL SEAL SEATING AREAS, ALONG WITH METALREBUILDING AND STRAIGHTENING (UP TO A 4-THOU MAXIMUM BEND).3.#BEARING HOUSING MACHINING: MACHINING AND RESLEEVEING OF BOTH DE ANDNDE BEARING HOUSING BORES.4.#MECHANICAL SEAL FACE: MACHINING AND REPAIRING OF THE PUMP# S TOP ANDBOTTOM CASING HALVES AT THE MECHANICAL SEAL FACE.5.#PUMP CASINGS: SKIMMING AND GROOVING OF SUCTION AND DISCHARGE FLANGESON THE PUMP CASING.MACHINING WORKS MUST COMPLY WITH THE LATEST STANDARDS, AND PRIORAPPROVAL FROM THE DEWA ENGINEER IS REQUIRED BEFORE COMMENCING ANYMACHINING TASKS. ANY DAMAGES DONE ON ANY PROVIDED SPARES FROM DEWA, THECONTRACTOR IS HELD RESPONSIBLE IN REPLACING THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DAMAGED MATERIAL AT NOADDITIONAL COST TO DEWA.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
2		ITEM-00001	MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING WITH COMPLETE PUMP ASSEMBLY FOR JA HABAB PH2 TORISHIMA PUMP.SCOPE OF WORK1.#MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING: THE CONTRACTOR WILL MACHINE AND ASSEMBLE THE PUMP CASE WEAR RING, USING THE MATERIAL PROVIDED BY DEWA.2.#COMPLIANCE WITH SPECIFICATIONS: MATERIAL AND DIMENSIONS MUST STRICTLY FOLLOW THE PROVIDED SAMPLE.3.#ROTOR ASSEMBLY TESTING: AFTER INSTALLING THE CASE WEAR RING, THE ROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING.4.#PAYMENT TERMS: PAYMENTS WILL BE PROCESSED UPON APPROVAL FROM THE DEWA ENGINEER.5.#WARRANTY: A ONE-YEAR	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WARRANTY WILL APPLY FOLLOWING THE INSTALLATION AND SUCCESSFUL TESTING OF THE PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THE CONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NO ADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
3		ITEM-00001	MACHINING & ASSEMBLY OF PUMP IMPELLER WEAR RING WITH COMPLETE PUMP ASSEMBLY FOR JA HABAB PH2 TORISHIMA PUMP. SCOPE OF WORK 1.#MACHINING AND ASSEMBLY OF PUMP IMPELLER WEAR RING: THE CONTRACTOR WILL MACHINE AND ASSEMBLE THE PUMP IMPELLER WEAR RING, USING THE MATERIAL PROVIDED BY DEWA. 2.#COMPLIANCE WITH SPECIFICATIONS: MATERIAL AND DIMENSIONS	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MUST STRICTLY FOLLOW THE PROVIDED SAMPLE.3.#ROTOR ASSEMBLY TESTING: AFTER INSTALLING THE IMPELLER WEAR RING, THE ROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING.4.#PAYMENT TERMS: PAYMENTS WILL BE PROCESSED UPON APPROVAL FROM THE DEWA ENGINEER.5.#WARRANTY: A ONE-YEAR WARRANTY WILL APPLY FOLLOWING THE INSTALLATION AND SUCCESSFUL TESTING OF THE PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THE CONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NO ADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THE HOSE ORIGINALLY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
4		ITEM-00001	MACHINING AND ASSEMBLY OF SHAFT SLEEVES	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR JA HABAB PH2 TORISHIMA PUMPSCOPE OF WORK:1.#MACHINING: MACHINE THE SHAFT SLEEVES ACCORDI NG TO THE SPECIFIEDDIMENSIONS PROVIDED BY DEWA.2.#ASSEMBLY: ASSEMBLE THE SHAFT SLEEVES ONTO THE PUMP'S ROTOR AS PERTHE REQUIRED STAN DARDS.3.#TESTING: PERFORM A COMPREHENSIVE TEST ON THE ROTOR ASSEMBLY TOENSURE THE PROPER FITTING AND ALIGNMENT OF THE SHAFT SLEEVES. 4.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THECONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATE RIALS AT NOADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAMESPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.</p>						
5		ITEM-00001	MACHINING AND REBUILDING OF SHAFT FOR JA	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HABAB PH2 TORISHIMA PUMPSCOPE OF WORK:1.#SHAFT REBUILDING AND MACHINING: REBUILD AND MACHIN E THE PUMP SHAFTON BOTH THE DRIVE END (DE) AND NON-DRIVE END (NDE), FOCUSING ON THE MECHANICAL SEAL AND BEARING AREAS.2.#ASSEMBLY AND TESTING: REASSEMBLE THE PUMP AND ROTOR, FOLLOWED BY THOROUGH TESTING TO ENSURE PROPER FUNCTIONALITY.3.#CONTRACTOR RESPONSIBILITY: THE CONTRACTOR WILL ASSUME FULL RESPONSIBILITY FOR ANY ERRORS OR MISHANDLING DURING THE PROCESS. ALL NECESSARY CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
6		ITEM-00001	MODIFICATION OF MECHANICAL SEAL COOLING LINE FOR JA HABAB PH2 TORISHIMA PUMPSCOPE OF WORK:1.#FABRICATION AND MODIFICATION: FABRICATE	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OR MODIFY THE MECHANICALSEAL COOLING LINE TO MEET THE SPECIFIC REQUIREMENTS OF THE PUMP.2.#ASSEMBLY AND TESTING: ASSEMBLE THE COOLIN G LINE TO THE PUMP ROTORASSEMBLY, ENSURING IT ADHERES TO THE ORIGINAL DESIGN SPECIFICATIONS.TEST THE COOLING LINE THOROUGHLY TO CONFIRM THERE ARE NO ISSUES ORLEAKS.3.#CONTRACTOR RESPONSIBILITY: THE CONTRACTOR WILL BE FULLY RESPONSIBLEFOR ANY ERRORS OR MISHANDLING DURING THE MODIFICATION OR ASSEMBLYPROCESS. ALL NECESSARY CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST.KINDLY CONTACT MR. NOOR (04 -3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.						
7		ITEM-00001	FULL BLASTING AND RECOATING OF JA HABAB PH2 TORISHIMA PUMPSPECIFICATION FOR INTERNAL COATING OF PUMPS AND VALV THESE PUMPS AND VALVES ARE UTILIZED IN WATER BOOSTER PUMPING	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STATIONS,HANDLING POTABLE WATER WITH TEMPERATURES UP TO 50°C. WHILE THE WATER ISTYPICALLY CLEAN, OCCASIONAL SAND OR SOLIDS MAY BE PRESENT IN THE STREAMFROM THE PIPELINE. THE PUMPS HAVE BEEN IN OPERATION SINCE THE STATION'S COMMISSIONING.SCOPE OF WORK1.#COLLECTION AND TRANSPORTATION: THE CONTRACTOR IS RESPONSIBLE FORCOLLECTING THE PUMP CASING USING A SUITABLE PICKUP OR CRANE-MOUNTEDTRUCK TO TRANSPORT IT TO DEWA'S WORKSHOP. THE CONTRACTOR MUST ENSURETHE USE OF APPROPRIATE LIFTING SLINGS/BELTS WITH SUFFICIENT LOADCAPACITY FOR SAFE LOADING AND UNLOADING.2.#SURFACE PREPARATION: BEFORE APPLYING ANY COATING, THE CONTRACTORMUST PERFORM SURFACE PREPARATION USING SAND OR GRIT BLASTING, OR OTHERSUITABLE MECHANICAL METHODS TO REMOVE RUST AND LOOSE MATER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IALS. AFTERTHE BLASTING, DEWA ENGINEERS MUST INSPECT THE SURFACE BEFORE COATING.ALL MACHINED SURFACES AND CRITICAL AREAS MUST BE ADE QUATELY PROTECTEDDURING SANDBLASTING TO AVOID DAMAGE. CLEAR PHOTOS MUST BE TAKEN AND BEATTACHED IN THE COMPLETION REPORT.3.#REBUILDING ERODED/PITTED SURFACES: THE CONTRACTOR MUST RESTOREERODED SURFACES USING A SUITABLE COMPOSITE MATERIAL BEFORE APPLYING ANYCOATING . THE COMPOSITE MATERIAL MUST HAVE THE FOLLOWING PROPERTIES:O#SUITABLE FOR CONTINUOUS IMMERSION IN VARIOUS CHEMICALS (E.G., FERRICCHLORIDE, HYDROCHLORIC ACID, SULFURIC ACID, SODIUM HYDROXIDE, AMMONIUMHYDROXIDE) AT 21°C.O#MUST PASS THE ASTM C868 CORROSION TEST FOR DEMINERALIZED WATERIMMERSION AT 43°C FOR AT LEAST SIX MONTHS.O#ADHESION (ASTM D1002) GREATER THAN 183 KG/CM² (2,600 PSI).O#MEET OR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>E XCEED COMPRESSIVE, TENSILE, AND FLEXURAL STRENGTH STANDARDS.ENVIRONMENTAL CONDITIONS DURING SURFACE PREPARATION, APPLICATION, ANDCUR ING MUST BE MONITORED TO ENSURE PROPER EXECUTION.4.#INTERNAL AND EXTERNAL COATING:O#APPLY CERAMIC-REINFORCED COMPOSITE MATERIALS FOR THE FINAL COATINGAFTER SURFACE PREPARATION AND REBUILDING.O#THE COMPOSITE MUST WITHSTAND CONTINUOUS IMMERSION IN CHEMICALS ANDPASS THE ASTM B117 SALT FOG AND ASTM G8 CATHODIC DISBANDMENT TESTS.O#THE COATING MUST BE 800-1000 MICRONS THICK AND FINISHED WITH ASMOOTH , ABRASION-RESISTANT GLASS-LIKE SURFACE.O#THE COMPOSITE MATERIAL MUST BE AUTHORIZED FOR USDA INCIDENTAL FOODCONTACT APPLICATIONS AND HOLD POTABLE WATER CERTIFICATION FROM WRAS OREQUIVALENT AUTHORITIES.O#EXTERNAL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COATING SHOULD BE AN EPOXY COATING, 300-400 MICRONS THICK, IN BLUE COLOR FOR BOTH PUMPS AND VALVES.5.#WARRANTY: THE SUPPLIER MUST PROVIDE A 24-MONTH SERVICE WARRANTY AGAINST ANY DEFECTS IN THE COATING. IF THE COATING FAILS WITHIN THIS PERIOD, THE SUPPLIER WILL RECOAT THE EQUIPMENT FREE OF CHARGE.6.#METHOD STATEMENT: THE SUPPLIER MUST SUBMIT A DETAILED METHOD STATEMENT FOR THE COATING PROCESS, INCLUDING MATERIAL SPECIFICATIONS, FOR REVIEW AND APPROVAL.7.#INSPECTION: PRIOR TO DELIVERY, THE COATING WORK MUST BE INSPECTED BY DEWA ENGINEERS AT THE SUPPLIER'S WORKSHOP FOR FINAL ACCEPTANCE. THE CONTRACTOR MUST PROVIDE ALL NECESSARY INSPECTION TOOLS.8.#REPORTS AND DOCUMENTATION: UPON DELIVERY, THE CONTRACTOR MUST SUBMIT THE FOLLOWING:</p> <p>0#MATERIAL DATA SHEETS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BEFORE AND AFTER COATING.O#WRAS CERTIFICATION FOR COATING MATERIALS.O#ALL RELEVANT TEST REPOR TS.O#PROPER COMPLETION REPORT INCLUDING THE INTERNAL CONDITION BEFORE ANDAFTER THE BLASTING AND THE COATING.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.						
8		ITEM-00002	COMPLETE OVERHAULING OF BOOSTER PUMP FOR JA HABAB PH3 PUMPING STATION.PUMP DETAILS: EQUIPMENT NO. 50437341, TORISHIMA PUMP MODEL: DV L-250, HEAD-140M, FLOW-263L/S, RPM-1475,630KW.SCOPE OF WORKTHE FOLLOWING OUTLINES THE MANDATORY AND OPTIONAL SCOPE OF WORK FOR THEOV ERHAUL OF BOOSTER PUMPS AND THEIR ACCESSORIES AT THE BOOSTER PUMPINGSTATION.1.0 MANDATORY SCOPE OF WORK:A) THE CONTRACTOR IS RESPONS IBLE FOR TRANSPORTING THE PUMP ASSEMBLY TOAND FROM THE DEWA SITE TO THEIR	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORKSHOP. DEWA WILL NOT PROVIDETRANSPORTATION. FOR LOADING AND UNLOADING, THE CONTRACTOR MAY USE DEWA#SOVERHEAD CRANE AT THE PUMPING STATION, WITH PROPER COORDINATION WITHDEWA REPRESENTATIVE</p> <p>S. B) REPLACEMENT OF THE MECHANICAL SEAL, COUPLINGBUSH RENEWAL, GLAND PACKING RENEWAL, AND BEARING REPLACEMENT ASREQUIRED. C) OVERHA</p> <p>ULING OF THE PUMP (REFER TO ANNEXURE I FOR MANDATORYAND ANNEXURE II FOR OPTIONAL WORK). D) EXTERNAL PAINTING OF THE PUMP. E)RECTIFIC</p> <p>ATION OF ANY ISSUES THAT ARISE AFTER INSTALLATION/LOAD TESTING.THIS SHALL BE DONE ON SITE IF POSSIBLE, AND IF NOT, THE CONTRACTOR IS</p> <p>RESPONSIBLE IN COLLECTING THE PUMP AND MOVED IT BACK TO THEIR FACILITY.F) IF ANY PART IS FOUND DEFECTIVE, THE CONTRACTOR IS RESPONSIB</p> <p>LE FORREPAIRING OR REPLACING IT. DEWA WILL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROVIDE AVAILABLE SPARES. IF ANY SPARE PARTS ARE UNAVAILABLE, THE CONTRACTOR MUST ARRANGE THEM AND SUBMIT THE COST FOR DEWA APPROVAL BEFORE PLACING AN ORDER. G) ONCE THE PUMP IS FULLY ASSEMBLED, THE PUMP MUST BE PRESSURE HYDRO TESTED IN THE CONTRACTOR FACILITY TO MAKE SURE THE PUMP IS WELL ASSEMBLED AND THAT THERE ARE NO LEAKS. 2.0 REQUIREMENTS PRIOR TO QUOTATION SUBMISSION: A) THE CONTRACTOR MUST VISIT THE SITE TO FAMILIARIZE THEMSELVES WITH THE SCOPE OF WORK AND POTENTIAL COMPLEXITIES BEFORE SUBMITTING A QUOTATION. B) DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL CHARGES BEYOND THE AGREED RATES OR PRICES DURING OR AFTER THE EXECUTION OF THE WORK. C) THE CONTRACTOR WILL BE PROVIDED WITH AN EQUIPMENT SHUTDOWN SCHEDULE IN COORDINATION WITH THE OPERAT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IONS & MAINTENANCE DEPARTMENT OF THE WATERDIVISION. D) A TIME SCHEDULE OR BAR CHART SHOWING EACH ACTIVITY MUST BESUBMITTED. E) UPON COMPLETION, AN INSPECTION CHECKLIST AND QUALITYPROCEDURE DOCUMENTATION, WHERE APPLICABLE, MUST BE SUBMITTED. F) THECONTRACTOR IS RES PONSIBLE FOR SITE SUPERVISION, COORDINATION OF FIELDACTIVITIES, AND THE SUPPLY OF REQUIRED TECHNICIANS, TOOLS, EQUIPMENT,AND RESOURC ES NECESSARY TO EXECUTE THE CONTRACT.3.0 TAKEOVER:UPON COMPLETION OF ALL WORK WITHIN THE SCOPE OF THE CONTRACT, THECONTRACTOR MUST N OTIFY DEWA IN WRITING. A CERTIFICATE OF COMPLETION WILLBE ISSUED AFTER A FINAL INSPECTION, CONFIRMING THAT THE WORK HAS BEENACCEPTED AND TAKEN OVER BY DEWA FOLLOWING THE NECESSARY CONDITIONMONITORING CHECKS.4.0 WARRANTY:A) ALL WORK WILL CARRY A</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WARRANTY OF 8,000 HOURS OF OPERATION OR ONEYEAR, WHICHEVER COMES FIRST. B) THE WARRANTY WILL TAKE EFFECT FROM THE DATE OF DEWA'S OFFICIAL TAKEOVER OF THE COMPLETED JOB. C) IF ANY DEFECTS ARE IDENTIFIED DURING THE WARRANTY PERIOD, THE CONTRACTOR MUST RECTIFY THEM WITHIN THE TIMEFRAME SET BY DEWA WITHOUT ADDITIONAL COST OR COMPENSATION. 5.0 DOCUMENTATION: UPON SATISFACTORY COMPLETION OF THE WORK AND HANDOVER, THE CONTRACTOR MUST SUBMIT THE FOLLOWING DOCUMENTS TO DEWA: #INITIAL INSPECTION REPORT (MENTIONING THE REQUIRED SPARES AND REQUIRED ACTIONS). #JOB COMPLETION REPORT (INCLUDING ALL OVERHAULING ACTIONS DONE) WITHIN ONE WEEK OF DELIVERY. #SERVICE ENTRY APPLICATION ATTACHING THE JOB COMPLETION REPORT IMMEDIATELY ONCE THE REPORT IS SIGNED BY DEWA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REPRESENTATIVE-#INCLUDING ALL PROPER PHOTOS, EQUIPMENT SERIAL NUMBER , AND EQUIPMENTTAGGING-#REQUISITION FOR SPARE PARTS PLANNING BASED ON THE CURRENT CONDITIONOF THE EQUIPMENTANNEXURE I # DETAILED MAN</p> <p>DATORY SCOPE OF WORK FOR BOOSTER PUMP OVERHAUL1.#DISMANTLING: THE CONTRACTOR SHALL DISMANTLE THE PUMP ACCORDING TODewa ENGINEER#S IN STRUCTIONS. SKILLED WORKMANSHIP AND CARE MUST BEAPPLIED DURING REMOVAL.2.#OVERHAULING: THE CONTRACTOR SHALL DISMANTLE THE ROTATING A SSEMBLY INTHEIR WORKSHOP AND RECORD ALL FINDINGS, INCLUDING PHOTOGRAPHS OFDETERIORATED COMPONENTS. THE SHAFT MUST BE INSPECTED FOR S TRAIGHTNESS,AND WORN AREAS SHOULD BE RECONDITIONED. IMPELLER, BEARINGS, MECHANICALSEAL, GLAND SLEEVE, AND WEAR RINGS MUST BE THOROUGHLY CHECKED ANDREPLACED IF NECESSARY. ALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PARTS FOUND DEFECTIVE MUST BE REPAIRED ORREPLACED, WITH AVAILABLE SPARES SUPPLIED BY DEWA.</p> <p>IF SPARES AREUNAVAILABLE, THE CONTRACTOR MUST ARRANGE THEM AND SEEK APPROVAL FROMDEWA FOR ADDITIONAL COSTS. THE PUMP CASING MUST BE</p> <p>CLEANED AND INSPECTEDFOR DAMAGE, AND ANY NECESSARY REPAIRS MUST BE CARRIED OUT USINGSANDBLASTING AND FOOD-GRADE EPOXY COATING.3.#AS</p> <p>SEMBLY: REASSEMBLY OF THE EQUIPMENT MUST FOLLOW STANDARDPROCEDURES, ENSURING THE PROPER FIT AND CLEARANCES. THE ROTOR ASSEMBLYSHOULD</p> <p>BE DYNAMICALLY BALANCED PER ISO 1940/1 STANDARDS. A DETAILEDRECORD OF ALL ACTIVITIES MUST BE MAINTAINED, AND ANY DEVIATIONS FROM SE</p> <p>TVALUES WILL BE DETERMINED BY DEWA.4.#CONSUMABLES & ACCESSORIES: MANUFACTURING OF MECHANICAL SEAL COOLINGPIPE FITTINGS, SHAFT LOCK N</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>UTS, LOCK WASHERS, DOWEL PINS, BEARINGSPACERS, HOLDING DOWN BOLTS, AND VARIOUS GASKETS, INCLUDING THE SUPPLYOF O-RINGS.ANNEXURE II #</p> <p>OPTIONAL MACHINING WORKS1.#IMPELLER MACHINING: THIS INCLUDES GRIT BLASTING AND NON-DESTRUCTIVETESTING (NDT) TO IDENTIFY CRACKS, SKI</p> <p>MMING THE WEAR RING AREAS, ANDFITTING NEW RINGS.2.#SHAFT MACHINING: THE SHAFT WILL UNDERGO CHROME PLATING ON BEARINGSEATING AREAS AN</p> <p>D MECHANICAL SEAL SEATING AREAS, ALONG WITH METALREBUILDING AND STRAIGHTENING (UP TO A 4-THOU MAXIMUM BEND).3.#BEARING HOUSING MACHI</p> <p>NING: MACHINING AND RESLEEVEING OF BOTH DE ANDNDE BEARING HOUSING BORES.4.#MECHANICAL SEAL FACE: MACHINING AND REPAIRING OF THE PUMP#</p> <p>S TOP ANDBOTTOM CASING HALVES AT THE MECHANICAL SEAL FACE.5.#PUMP CASINGS: SKIMMING AND GROOVING OF SUCTION AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DISCHARGE FLANGES ON THE PUMP CASING. MACHINING WORKS MUST COMPLY WITH THE LATEST STANDARDS, AND PRIOR APPROVAL FROM THE DEWA ENGINEER IS REQUIRED BEFORE COMMENCING ANY MACHINING TASKS. ANY DAMAGES DONE ON ANY PROVIDED SPARES FROM DEWA, THE CONTRACTOR IS HELD RESPONSIBLE IN REPLACING THE DAMAGED MATERIAL AT NO ADDITIONAL COST TO DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
9		ITEM-00002	MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING WITH COMPLETE PUMP ASSEMBLY FOR JA HABAB PH3 TORISHIMA PUMP. SCOPE OF WORK 1. #MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING: THE CONTRACTOR WILL MACHINE AND ASSEMBLE THE PUMP CASE WEAR RING, USING THE MATERIAL PROVIDED BY DEWA. 2. #COMPLIANCE WITH SPECIFICATIONS:	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MATERIAL AND DIMENSIONS MUST STRICTLY FOLLOW THE PROVIDED SAMPLE.3.#ROTOR ASSEMBLY TESTING: AFTER INSTALLING THE CASE WEAR RING, THE ROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING.4.#PAYMENT TERMS: PAYMENTS WILL BE PROCESSED UPON APPROVAL FROM THE DEWA ENGINEER.5.#WARRANTY: A ONE-YEAR WARRANTY WILL APPLY FOLLOWING THE INSTALLATION AND SUCCESSFUL TESTING OF THE PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THE CONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NO ADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.</p>						
10		ITEM-00002	MACHINING & ASSEMBLY OF PUMP IMPELLER	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WEAR RING WITH COMPLETE PUMPASSEMBLY FOR JA HABAB PH3 TORISHIMA PUMP.SCOPE OF WORK1.#MACHINING AND ASSEMBLY OF PUMP IMPELLER WEAR RING: THE CONTRACTORWILL MACHINE AND ASSEMBLE THE PUMP IMPELLER WEAR RING, USING THEMATERIAL PROVIDED BY DEWA.2.#COMPLIANCE WITH SPECIFICATIONS: MATERIAL AND DIMENSIONS MUSTSTRICTLY FOLLOW THE PROVIDED SAMPLE.3.#ROTOR ASSEMBLY TESTING: AFTER INSTALLING THE IMPELLER WEAR RING, THEROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING.4.#PAYMENT TERMS: PAYMENTS WILL BE PROCESSED UPON APPROVAL FROM THEDEWA ENGINEER.5.#WARRANTY: A ONE-YEAR WARRANTY WILL APPLY FOLLOWING THE INSTALLATIONAND SUCCESSFUL TESTING OF THE PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THECONTRACTOR WILL BE HEL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			D RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NOADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAMESPECIFICATIONS AS T HOSE ORIGINALLY SUPPLIED BY DEWA.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.						
11		ITEM-00002	MACHINING AND ASSEMBLY OF SHAFT SLEEVES FOR JA HABAB PH3 TORISHIMA PUMPSCOPE OF WORK:1.#MACHINING: MACHINE THE SHAFT SLEEVES ACCORDI NG TO THE SPECIFIEDDIMENSIONS PROVIDED BY DEWA.2.#ASSEMBLY: ASSEMBLE THE SHAFT SLEEVES ONTO THE PUMP'S ROTOR AS PERTHE REQUIRED STAN DARDS.3.#TESTING: PERFORM A COMPREHENSIVE TEST ON THE ROTOR ASSEMBLY TOENSURE THE PROPER FITTING AND ALIGNMENT OF THE SHAFT SLEEVES. 4.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THECONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NEW MATERIALS AT NO ADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
12		ITEM-00002	MACHINING AND REBUILDING OF SHAFT FOR JAHABAB PH3 TORISHIMA PUMPSCOPE OF WORK: 1.#SHAFT REBUILDING AND MACHINING: REBUILD AND MACHINE THE PUMP SHAFT ON BOTH THE DRIVE END (DE) AND NON-DRIVE END (NDE), FOCUSING ON THE MECHANICAL SEAL AND BEARING AREAS. 2.#ASSEMBLY AND TESTING: REASSEMBLE THE PUMP AND ROTOR, FOLLOWED BY THOROUGH TESTING TO ENSURE PROPER FUNCTIONALITY. 3.#CONTRACTOR RESPONSIBILITY: THE CONTRACTOR WILL ASSUME FULL RESPONSIBILITY FOR ANY ERRORS OR MISHANDLING DURING THE PROCESS.	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ALLNECESSARY CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
13		ITEM-00002	MODIFICATION OF MECHANICAL SEAL COOLING LINE FOR JA HABAB PH3 TORISHIMAPUMPSCOPE OF WORK:1.#FABRICATION AND MODIFICATION: FABRICATE OR MODIFY THE MECHANICALSEAL COOLING LINE TO MEET THE SPECIFIC REQUIREMENTS OF THE PUMP.2.#ASSEMBLY AND TESTING: ASSEMBLE THE COOLIN G LINE TO THE PUMP ROTORASSEMBLY, ENSURING IT ADHERES TO THE ORIGINAL DESIGN SPECIFICATIONS.TEST THE COOLING LINE THOROUGHLY TO CONFIRM THERE ARE NO ISSUES ORLEAKS.3.#CONTRACTOR RESPONSIBILITY: THE CONTRACTOR WILL BE FULLY RESPONSIBLEFOR ANY ERRORS OR MISHANDLING DURING THE MODIFICATION OR ASSEMBLYPROCESS. ALL NECESSARY	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST.KINDLY CONTACT MR. NOOR (04 -3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.						
14		ITEM-00002	FULL BLASTING AND RECOATING OF JA HABAB PH3 TORISHIMA PUMPSPECIFICATION FOR INTERNAL COATING OF PUMPS AND VALV THESE PUMPS AND VALVES ARE UTILIZED IN WATER BOOSTER PUMPING STATIONS,HANDLING POTABLE WATER WITH TEMPERATURES UP TO 50°C. WHILE THE WATER ISTYPICALLY CLEAN, OCCASIONAL SAND OR SOLIDS MAY BE PRESENT IN THE STREAMFROM THE PIPELINE. THE PUMPS HAVE BEEN IN OPERATION SINCE THE STATION'SCOMMISSIONING.SCOPE OF WORK1.#COLLECTION AND TRANSPORTATION: THE CONTRACTOR IS RESPONSIBLE FORCOLLECTING THE PUMP CASING USING A SUITABLE PICKUP OR CRANE-MOUNTEDTRUCK TO TRANSPORT IT TO DEWA'S WORKSHOP. THE CONTRACTOR MUST ENSURETHE USE OF	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>APPROPRIATE LIFTING SLIN GS/BELTS WITH SUFFICIENT LOADCAPACITY FOR SAFE LOADING AND UNLOADING.2.#SURFACE PREPARATION: BEFORE APPLYING ANY COATING, THE CONTRA CTORMUST PERFORM SURFACE PREPARATION USING SAND OR GRIT BLASTING, OR OTHERSUITABLE MECHANICAL METHODS TO REMOVE RUST AND LOOSE MATER IALS. AFTERTHE BLASTING, DEWA ENGINEERS MUST INSPECT THE SURFACE BEFORE COATING.ALL MACHINED SURFACES AND CRITICAL AREAS MUST BE ADE QUATELY PROTECTEDDURING SANDBLASTING TO AVOID DAMAGE. CLEAR PHOTOS MUST BE TAKEN AND BEATTACHED IN THE COMPLETION REPORT.3.#REBUILDI NG ERODED/PITTED SURFACES: THE CONTRACTOR MUST RESTOREERODED SURFACES USING A SUITABLE COMPOSITE MATERIAL BEFORE APPLYING ANYCOATING . THE COMPOSITE MATERIAL MUST HAVE THE FOLLOWING PROPERTIES:O#SUITABLE FOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTINUOUS IMMERSION IN VARIOUS CHEMICALS (E.G., FERRICCHLORIDE, HYDROCHLORIC ACID, SULFURIC ACID, SODIUM HYDROXIDE, AMMONIUMHYDROXIDE) AT 21°C.O#MUST PASS THE ASTM C868 CORROSION TEST FOR DEMINERALIZED WATERIMMERSION AT 43°C FOR AT LEAST SIX MONTHS.O#ADHESION (ASTM D1002) GREATER THAN 183 KG/CM² (2,600 PSI).O#MEET OR EXCEED COMPRESSIVE, TENSILE, AND FLEXURAL STRENGTH STANDARDS.ENVIRONMENTAL CONDITIONS DURING SURFACE PREPARATION, APPLICATION, ANDCURRING MUST BE MONITORED TO ENSURE PROPER EXECUTION.4.#INTERNAL AND EXTERNAL COATING:O#APPLY CERAMIC-REINFORCED COMPOSITE MATERIALS FOR THE FINAL COATINGAFTER SURFACE PREPARATION AND REBUILDING.O#THE COMPOSITE MUST WITHSTAND CONTINUOUS IMMERSION IN CHEMICALS ANDPASS THE ASTM B117 SALT FOG AND ASTM G8</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CATHODIC DISBANDMENT TESTS.O#THE COATING MUST BE 800-1000 MICRONS THICK AND FINISHED WITH ASMOOTH , ABRASION-RESISTANT GLASS-LIKE SURFACE.O#THE COMPOSITE MATERIAL MUST BE AUTHORIZED FOR USDA INCIDENTAL FOODCONTACT APPLICATIONS AND HOLD POTABLE WATER CERTIFICATION FROM WRAS OREQUIVALENT AUTHORITIES.O#EXTERNAL COATING SHOULD BE AN EPOXY COATING, 300-400 MICRONS THICK,IN BLUE COLOR FOR BOTH PUMPS AND VALVES.5.#WARRANTY: THE SUPPLIER MUST PROVIDE A 24-MONTH SERVICE WARRANTYAGAINST ANY DEFECTS IN THE COATING. IF THE COATING FAILS WITHIN THISPERIOD, THE SUPPLIER WILL RECOAT THE EQUIPMENT FREE OF CHARGE.6.#METHOD STATEMENT: T HE SUPPLIER MUST SUBMIT A DETAILED METHODSTATEMENT FOR THE COATING PROCESS, INCLUDING MATERIAL SPECIFICATIONS,FOR REVIEW AND APPROVA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			L.7.#INSPECTION: PRIOR TO DELIVERY, THE COATING WORK MUST BE INSPECTED BYDEWA ENGINEERS AT THE SUPPLIER'S WORKSHOP FOR FINAL ACCEPTANCE. THECONTRACTOR MUST PROVIDE ALL NECESSARY INSPECTION TOOLS.8.#REPORTS AND DOCUMENTATION: UPON DELIVERY, THE CONTRACTOR MUST SUBMIT THE FOLLOWING:O#MATERIAL DATA SHEETS BEFORE AND AFTER COATING.O#WRAS CERTIFICATION FOR COATING MATERIALS.O#ALL RELEVANT TEST REPORTS.O#PROPER COMPLETION REPORT INCLUDING THE INTERNAL CONDITION BEFORE ANDAFTER THE BLASTING AND THE COATING.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.						
15		ITEM-00003	COMPLETE OVERHAULING OF BOOSTER PUMP FOR NAJMA PH3 PUMPING STATION. PUMPDDETAILS: EQUIPMENT NO. 50270338, WEIR PUMP MODEL: SDA 400/50 0 B, HEAD-140M, FLOW-263L/S,	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RPM-1475,630KW.SCOPE OF WORKTHE FOLLOWING OUTLINES THE MANDATORY AND OPTIONAL SCOPE OF WORK FOR THEOVER HAUL OF BOOSTER PUMPS AND THEIR ACCESSORIES AT THE BOOSTER PUMPINGSTATION.1.0 MANDATORY SCOPE OF WORK:A) THE CONTRACTOR IS RESPONSIB LE FOR TRANSPORTING THE PUMP ASSEMBLY TOAND FROM THE DEWA SITE TO THEIR WORKSHOP. DEWA WILL NOT PROVIDETRANSPORTATION. FOR LOADING A ND UNLOADING, THE CONTRACTOR MAY USE DEWA#SOVERHEAD CRANE AT THE PUMPING STATION, WITH PROPER COORDINATION WITHDEWA REPRESENTATIVES.</p> <p>B) REPLACEMENT OF THE MECHANICAL SEAL, COUPLINGBUSH RENEWAL, GLAND PACKING RENEWAL, AND BEARING REPLACEMENT ASREQUIRED. C) OVERHAUL ING OF THE PUMP (REFER TO ANNEXURE I FOR MANDATORYAND ANNEXURE II FOR OPTIONAL WORK). D) EXTERNAL PAINTING OF THE PUMP. E)RECTIFICAT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ION OF ANY ISSUES THAT ARISE AFTER INSTALLATION/LOAD TESTING.THIS SHALL BE DONE ON SITE IF POSSIBLE, AND IF NOT, THE CONTRACTOR IS RESPONSIBLE IN COLLECTING THE PUMP AND MOVING IT BACK TO THEIR FACILITY.F) IF ANY PART IS FOUND DEFECTIVE, THE CONTRACTOR IS RESPONSIBLE FOR REPAIRING OR REPLACING IT. DEWA WILL PROVIDE AVAILABLE SPARES. IF ANY SPARE PARTS ARE UNAVAILABLE, THE CONTRACTOR MUST ARRANGE TO OBTAIN THEM AND SUBMIT THE COST FOR DEWA APPROVAL BEFORE PLACING AN ORDER. G) ONCE THE PUMP IS FULLY ASSEMBLED, THE PUMP MUST BE TESTED IN THE CONTRACTOR FACILITY TO MAKE SURE THE PUMP IS WELL ASSEMBLED AND THAT THERE ARE NO LEAKS.2.0 REQUIREMENTS PRIOR TO QUOTATION SUBMISSION:A) THE CONTRACTOR MUST VISIT THE SITE TO FAMILIARIZE THEMSELVES WITH THE SCOPE OF WORK AND POTENTIAL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COMPLEXITIES BE FORE SUBMITTING A QUOTATION.B) DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL CHARGES BEYOND THEAGREED RATES OR PRICES DURING OR AFT ER THE EXECUTION OF THE WORK. C) THECONTRACTOR WILL BE PROVIDED WITH AN EQUIPMENT SHUTDOWN SCHEDULE INCOORDINATION WITH THE OPERATIO NS & MAINTENANCE DEPARTMENT OF THE WATERDIVISION. D) A TIME SCHEDULE OR BAR CHART SHOWING EACH ACTIVITY MUST BESUBMITTED. E) UPON CO MPLETION, AN INSPECTION CHECKLIST AND QUALITYPROCEDURE DOCUMENTATION, WHERE APPLICABLE, MUST BE SUBMITTED. F) THECONTRACTOR IS RESPO NSIBLE FOR SITE SUPERVISION, COORDINATION OF FIELDACTIVITIES, AND THE SUPPLY OF REQUIRED TECHNICIANS, TOOLS, EQUIPMENT,AND RESOURCES NECESSARY TO EXECUTE THE CONTRACT.3.0 TAKEOVER:UPON COMPLETION OF ALL WORK</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WITHIN THE SCOPE OF THE CONTRACT, THE CONTRACTOR MUST NOTIFY DEWA IN WRITING. A CERTIFICATE OF COMPLETION WILL BE ISSUED AFTER A FINAL INSPECTION, CONFIRMING THAT THE WORK HAS BEEN ACCEPTED AND TAKEN OVER BY DEWA FOLLOWING THE NECESSARY CONDITION MONITORING CHECKS. 4.0 WARRANTY: A) ALL WORK WILL CARRY A WARRANTY OF 8,000 HOURS OF OPERATION OR ONE YEAR, WHICHEVER COMES FIRST. B) THE WARRANTY WILL TAKE EFFECT FROM THE DATE OF DEWA'S OFFICIAL TAKEOVER OF THE COMPLETED JOB. C) IF ANY DEFECTS ARE IDENTIFIED DURING THE WARRANTY PERIOD, THE CONTRACTOR MUST RECTIFY THEM WITHIN THE TIMEFRAME SET BY DEWA WITHOUT ADDITIONAL COST OR COMPENSATION. 5.0 DOCUMENTATION: UPON SATISFACTORY COMPLETION OF THE WORK AND HANDOVER, THE CONTRACTOR MUST SUBMIT THE FOLLOWING DOCUMENTS TO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DEWA: #INITIAL INSPECTION REPORT (MENTIONING THE REQUIRED SPARES AND REQUIRED ACTIONS) #JOB COMPLETION REPORT (INCLUDING ALL OVERHAULING ACTIONS DONE) WITHIN ONE WEEK OF DELIVERY #SERVICE ENTRY APPLICATION ATTACHING THE JOB COMPLETION REPORT IMMEDIATELY ONCE THE REPORT IS SIGNED BY DEWA REPRESENTATIVE #INCLUDING ALL PROPER PHOTOS, EQUIPMENT SERIAL NUMBER, AND EQUIPMENT TAGGING #REQUISITION FOR SPARE PARTS PLANNING BASED ON THE CURRENT CONDITION OF THE EQUIPMENT ANNEXURE I # DETAILED MANDATORY SCOPE OF WORK FOR BOOSTER PUMP OVERHAUL 1. #DISMANTLING: THE CONTRACTOR SHALL DISMANTLE THE PUMP ACCORDING TO DEWA ENGINEER'S INSTRUCTIONS. SKILLED WORKMANSHIP AND CARE MUST BE APPLIED DURING REMOVAL. 2. #OVERHAULING: THE CONTRACTOR SHALL DISMANTLE THE ROTATING ASS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EMBLY INTHEIR WORKSHOP AND RECORD ALL FINDINGS, INCLUDING PHOTOGRAPHS OFDETERIORATED COMPONENTS. THE SHAFT MUST BE INSPECTED FOR STR AIGHTNESS,AND WORN AREAS SHOULD BE RECONDITIONED. IMPELLER, BEARINGS, MECHANICALSEAL, GLAND SLEEVE, AND WEAR RINGS MUST BE THOROUGHLY CHECKED ANDREPLACED IF NECESSARY. ALL PARTS FOUND DEFECTIVE MUST BE REPAIRED ORREPLACED, WITH AVAILABLE SPARES SUPPLIED BY DEWA. I F SPARES AREUNAVAILABLE, THE CONTRACTOR MUST ARRANGE THEM AND SEEK APPROVAL FROMDEWA FOR ADDITIONAL COSTS. THE PUMP CASING MUST BE CLEANED AND INSPECTEDFOR DAMAGE, AND ANY NECESSARY REPAIRS MUST BE CARRIED OUT USINGSANDBLASTING AND FOOD-GRADE EPOXY COATING.3.#ASSE</p> <p>MBLY: REASSEMBLY OF THE EQUIPMENT MUST FOLLOW STANDARDPROCEDURES, ENSURING THE PROPER FIT AND CLEARANCES. THE ROTOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ASSEMBLY SHOULD BE DYNAMICALLY BALANCED PER ISO 1940/1 STANDARDS. A DETAILED RECORD OF ALL ACTIVITIES MUST BE MAINTAINED, AND ANY DEVIATIONS FROM SET VALUES WILL BE DETERMINED BY DEWA.4.#CONSUMABLES & ACCESSORIES: MANUFACTURING OF MECHANICAL SEAL COOLING PIPE FITTINGS, SHAFT LOCK NUTS, LOCK WASHERS, DOWEL PINS, BEARING SPACERS, HOLDING DOWN BOLTS, AND VARIOUS GASKETS, INCLUDING THE SUPPLY OF O-RINGS. ANNEXURE II # OPTIONAL MACHINING WORKS 1.#IMPELLER MACHINING: THIS INCLUDES GRIT BLASTING AND NON-DESTRUCTIVE TESTING (NDT) TO IDENTIFY CRACKS, SKIMMING THE WEAR RING AREAS, AND FITTING NEW RINGS. 2.#SHAFT MACHINING: THE SHAFT WILL UNDERGO CHROME PLATING ON BEARING SEATING AREAS AND MECHANICAL SEAL SEATING AREAS, ALONG WITH METAL REBUILDING AND STRAIGHTENING (UP TO A</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>4-THOU MAXIMUM BEND).3.#BEARING HOUSING MACHINI NG: MACHINING AND RESLEEVEING OF BOTH DE ANDNDE BEARING HOUSING BORES.4.#MECHANICAL SEAL FACE: MACHINING AND REPAIRING OF THE PUMP#S TOP ANDBOTTOM CASING HALVES AT THE MECHANICAL SEAL FACE.5.#PUMP CASINGS: SKIMMING AND GROOVING OF SUCTION AND DISCHARGE FLANGESON TH E PUMP CASING.MACHINING WORKS MUST COMPLY WITH THE LATEST STANDARDS, AND PRIORAPPROVAL FROM THE DEWA ENGINEER IS REQUIRED BEFORE COM MENCING ANYMACHINING TASKS. ANY DAMAGES DONE ON ANY PROVIDED SPARES FROM DEWA, THECONTRACTOR IS HELD RESPONSIBLE IN REPLACING THE DA MAGED MATERIAL AT NOADDITIONAL COST TO DEWA.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATIO N.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
16		ITEM-00003	MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING WITH COMPLETE PUMPASSEMBLY FOR NAJMA PH3 WEIR PUMP.SCOPE OF WORK1.#MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING: THE CONTRACTOR WILLMACHINE AND ASSEMBLE THE PUMP CASE WEAR RING, USING THE MATERIALPROVIDED BY DEWA.2.#COMPLIANCE WITH SPECIFICATIONS: MATERIAL AND DIMENSIONS MUSTSTRICTLY FOLLOW THE PROVIDED SAMPLE.3.#ROTOR ASSEMBLY TESTING: AFTER INST ALLING THE CASE WEAR RING, THEROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING.4.#PAYMENT TERMS: PAYMENTS WILL BE PR OCESED UPON APPROVAL FROM THEDEWA ENGINEER.5.#WARRANTY: A ONE-YEAR WARRANTY WILL APPLY FOLLOWING THE INSTALLATIONAND SUCCESSFUL TES TING OF THE PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THECONTRACTOR WILL BE HELD	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NOADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
17		ITEM-00003	MACHINING & ASSEMBLY OF PUMP IMPELLER WEAR RING WITH COMPLETE PUMP ASSEMBLY FOR NAJMA PH3 WEIR PUMP. SCOPE OF WORK 1. #MACHINING AND ASSEMBLY OF PUMP IMPELLER WEAR RING: THE CONTRACTOR WILL MACHINE AND ASSEMBLE THE PUMP IMPELLER WEAR RING, USING THE MATERIAL PROVIDED BY DEWA. 2. #COMPLIANCE WITH SPECIFICATIONS: MATERIAL AND DIMENSIONS MUST STRICTLY FOLLOW THE PROVIDED SAMPLE. 3. #ROTOR ASSEMBLY TESTING: AFTER INSTALLING THE IMPELLER WEAR RING, THE ROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING. 4. #PAYMENT	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TERMS: PAYME NTS WILL BE PROCESSED UPON APPROVAL FROM THEDEWA ENGINEER.5.#WARRANTY: A ONE-YEAR WARRANTY WILL APPLY FOLLOWING THE INSTALLATIONAND SUCCESSFUL TESTING OF THE PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THECONTRACTOR WILL BE HELD RESPON SIBLE AND MUST PROVIDE NEW MATERIALS AT NOADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAMESPECIFICATIONS AS THOSE ORI GINALLY SUPPLIED BY DEWA.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.</p>						
18		ITEM-00003	<p>MACHINING AND ASSEMBLY OF SHAFT SLEEVES FOR NAJMA PH3 WEIR PUMPSCOPE OF WORK:1.#MACHINING: MACHINE THE SHAFT SLEEVES ACCORDING TO TH E SPECIFIEDDIMENSIONS PROVIDED BY DEWA.2.#ASSEMBLY: ASSEMBLE THE SHAFT</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SLEEVES ONTO THE PUMP'S ROTOR AS PER THE REQUIRED STANDARDS.3. #TESTING: PERFORM A COMPREHENSIVE TEST ON THE ROTOR ASSEMBLY TO ENSURE THE PROPER FITTING AND ALIGNMENT OF THE SHAFT SLEEVES.4.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THE CONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NO ADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.</p>						
19		ITEM-00003	<p>MACHINING AND REBUILDING OF SHAFT FOR NAJMA PH3 WEIR PUMP. SCOPE OF WORK: 1.#SHAFT REBUILDING AND MACHINING: REBUILD AND MACHINE THE PUMP SHAFT ON BOTH THE DRIVE END (DE) AND NON-DRIVE END (NDE), FOCUSING ON</p>	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE MECHANICAL SEAL AND BEARING AREAS.2.#ASSEMBLY AND TESTING : REASSEMBLE THE PUMP AND ROTOR, FOLLOWED BY THOROUGH TESTING TO ENSURE PROPER FUNCTIONALITY.3.#CONTRACTOR RESPONSIBILITY: THE CONTRACTOR WILL ASSUME FULL RESPONSIBILITY FOR ANY ERRORS OR MISHANDLING DURING THE PROCESS. ALL NECESSARY CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
20		ITEM-00003	MODIFICATION OF MECHANICAL SEAL COOLING LINE FOR NAJMA PH3 WEIR PUMP. SCOPE OF WORK: 1.#FABRICATION AND MODIFICATION: FABRICATE OR MODIFY THE MECHANICAL SEAL COOLING LINE TO MEET THE SPECIFIC REQUIREMENTS OF THE PUMP. 2.#ASSEMBLY AND TESTING: ASSEMBLE THE COOLING LINE TO THE PUMP ROTOR ASSEMBLY, ENSURING IT ADHERES TO THE ORIGINAL DESIGN	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SPECIFICATIONS.TEST THE COOLING LINE THOROUGHLY TO CONFIRM THE RE ARE NO ISSUES ORLEAKS.3.#CONTRACTOR RESPONSIBILITY: THE CONTRACTOR WILL BE FULLY RESPONSIBLEFOR ANY ERRORS OR MISHANDLING DURING THE MODIFICATION OR ASSEMBLYPROCESS. ALL NECESSARY CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST.KINDLY CONTACT MR. NOOR (04-322943 9 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.						
21		ITEM-00003	FULL BLASTING AND RECOATING OF NAJMA PH3 WEIR PUMPSPECIFICATION FOR INTERNAL COATING OF PUMPS AND VALVESTHESE PUMPS AND VALVES ARE U TILIZED IN WATER BOOSTER PUMPING STATIONS,HANDLING POTABLE WATER WITH TEMPERATURES UP TO 50°C. WHILE THE WATER ISTYPICALLY CLEAN, OC CASIONAL SAND OR SOLIDS MAY BE PRESENT IN THE STREAMFROM THE PIPELINE. THE PUMPS HAVE BEEN IN OPERATION SINCE THE	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STATION'S COMMISSIONING. SCOPE OF WORK 1. #COLLECTION AND TRANSPORTATION: THE CONTRACTOR IS RESPONSIBLE FOR COLLECTING THE PUMP CASING USING A SUITABLE PICKUP OR CRANE-MOUNTED TRUCK TO TRANSPORT IT TO DEWA'S WORKSHOP. THE CONTRACTOR MUST ENSURE THE USE OF APPROPRIATE LIFTING SLINGS/BELTS WITH SUFFICIENT LOAD CAPACITY FOR SAFE LOADING AND UNLOADING. 2. #SURFACE PREPARATION: BEFORE APPLYING ANY COATING, THE CONTRACTOR MUST PERFORM SURFACE PREPARATION USING SAND OR GRIT BLASTING, OR OTHER SUITABLE MECHANICAL METHODS TO REMOVE RUST AND LOOSE MATERIALS. AFTER THE BLASTING, DEWA ENGINEERS MUST INSPECT THE SURFACE BEFORE COATING. ALL MACHINED SURFACES AND CRITICAL AREAS MUST BE ADEQUATELY PROTECTED DURING SANDBLASTING TO AVOID DAMAGE. CLEAR PHOTOS MUST BE TAKEN AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BEATTACHED IN THE COMPLETION REPORT.3.#REBUILDING ERODE D/PITTED SURFACES: THE CONTRACTOR MUST RESTOREERODED SURFACES USING A SUITABLE COMPOSITE MATERIAL BEFORE APPLYING ANYCOATING. THE CO MPOSITE MATERIAL MUST HAVE THE FOLLOWING PROPERTIES:O#SUITABLE FOR CONTINUOUS IMMERSION IN VARIOUS CHEMICALS (E.G., FERRICCHLORIDE, HYDROCHLORIC ACID, SULFURIC ACID, SODIUM HYDROXIDE, AMMONIUMHYDROXIDE) AT 21°C.O#MUST PASS THE ASTM C868 CORROSION TEST FOR DEMINERALIZED WATERIMMERSION AT 43°C FOR AT LEAST SIX MONTHS.O#ADHESION (ASTM D1002) GREATER THAN 183 KG/CM² (2,600 PSI).O#MEET OR EXCEED CO MPRESSIVE, TENSILE, AND FLEXURAL STRENGTH STANDARDS.ENVIRONMENTAL CONDITIONS DURING SURFACE PREPARATION, APPLICATION, ANDCURING MUST BE MONITORED TO ENSURE PROPER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EXECUTION.4.#INTERNAL AND EXTERNAL COATING:O#APPLY CERAMIC-REINFORCED COMPOSITE MATERIALS FOR THE FINAL COATINGAFTER SURFACE PREPARATION AND REBUILDING.O#THE COMPOSITE MUST WITHSTAND CONTINUOUS IMMERSION IN CHEMICALS ANDPASS THE ASTM B117 SALT FOG AND ASTM G8 CATHODIC DISBANDMENT TESTS.O#THE COATING MUST BE 800-1000 MICRONS THICK AND FINISHED WITH ASMOOTH, ABRASION-RESISTANT GLASS-LIKE SURFACE.O#THE COMPOSITE MATERIAL MUST BE AUTHORIZED FOR USDA INCIDENTAL FOODCONTACT APPLICATIONS AND HOLD PO TABLE WATER CERTIFICATION FROM WRAS OREQUIVALENT AUTHORITIES.O#EXTERNAL COATING SHOULD BE AN EPOXY COATING, 300-400 MICRONS THICK,IN BLUE COLOR FOR BOTH PUMPS AND VALVES.5.#WARRANTY: THE SUPPLIER MUST PROVIDE A 24-MONTH SERVICE WARRANTYAGAINST ANY DEFECTS IN THE C</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OATING. IF THE COATING FAILS WITHIN THISPERIOD, THE SUPPLIER WILL RECOAT THE EQUIPMENT FREE OF CHARGE.6.#METHOD STATEMENT: THE SUPPLIER MUST SUBMIT A DETAILED METHODSTATEMENT FOR THE COATING PROCESS, INCLUDING MATERIAL SPECIFICATIONS, FOR REVIEW AND APPROVAL.7.#INS PECTION: PRIOR TO DELIVERY, THE COATING WORK MUST BE INSPECTED BYDEWA ENGINEERS AT THE SUPPLIER'S WORKSHOP FOR FINAL ACCEPTANCE. THE CONTRACTOR MUST PROVIDE ALL NECESSARY INSPECTION TOOLS.8.#REPORTS AND DOCUMENTATION: UPON DELIVERY, THE CONTRACTOR MUST SUBMITTHE FOLLOWING:O#MATERIAL DATA SHEETS BEFORE AND AFTER COATING.O#WRAS CERTIFICATION FOR COATING MATERIALS.O#ALL RELEVANT TEST REPORTS.O#PRO PER COMPLETION REPORT INCLUDING THE INTERNAL CONDITION BEFORE ANDAFTER THE BLASTING AND THE COATING.KINDLY CONTACT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MR. NOOR (04-3229 439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
22		ITEM-00004	COMPLETE OVERHAULING OF BOOSTER PUMP FOR NAJMA PH4 PUMPING STATION. PUMP DETAILS: EQUIPMENT NO. 50269451, AVERSA PUMP MODEL: NDS-450-400-400, HEAD-140M, FLOW-263L/S, RPM-1475,630KW. SCOPE OF WORK THE FOLLOWING OUTLINES THE MANDATORY AND OPTIONAL SCOPE OF WORK FOR THE OVERHAUL OF BOOSTER PUMPS AND THEIR ACCESSORIES AT THE BOOSTER PUMPING STATION. 1.0 MANDATORY SCOPE OF WORK: A) THE CONTRACTOR IS RESPONSIBLE FOR TRANSPORTING THE PUMP ASSEMBLY TO AND FROM THE DEWA SITE TO THEIR WORKSHOP. DEWA WILL NOT PROVIDE TRANSPORTATION. FOR LOADING AND UNLOADING, THE CONTRACTOR MAY USE DEWA'S OVERHEAD CRANE AT THE PUMPING STATION, WITH PROPER COORDINATION WITH DEWA REPRESENTATIVE	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VES. B) REPLACEMENT OF THE MECHANICAL SEAL, COUPLINGBUSH RENEWAL, GLAND PACKING RENEWAL, AND BEARING REPLACEMENT ASREQUIRED. C) OVER HAULING OF THE PUMP (REFER TO ANNEXURE I FOR MANDATORYAND ANNEXURE II FOR OPTIONAL WORK). D) EXTERNAL PAINTING OF THE PUMP. E)RECTIFICATION OF ANY ISSUES THAT ARISE AFTER INSTALLATION/LOAD TESTING.THIS SHALL BE DONE ON SITE IF POSSIBLE, AND IF NOT, THE CONTRACTOR ISRESPONSIBLE IN COLLECTING THE PUMP AND MOVED IT BACK TO THEIR FACILITY.F) IF ANY PART IS FOUND DEFECTIVE, THE CONTRACTOR IS RESPON SIBLE FORREPAIRING OR REPLACING IT. DEWA WILL PROVIDE AVAILABLE SPARES. IF ANYSPARE PARTS ARE UNAVAILABLE, THE CONTRACTOR MUST ARRAN GE THEM AND SUBMITTHE COST FOR DEWA APPROVAL BEFORE PLACING AN ORDER. G) ONCE THE PUMP ISFULLY ASSEMBLED, THE PUMP MUST</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BE PRESSURE HYDRO TESTED IN THECONTRACTOR FACILITY TO MAKE SURE THE PUMP IS WELL ASSEMBLED AND THAT THERE ARE NO LEAKS.2.0 REQUIREMENTS PRIOR TO QUOTATION SUBMISSION:A) THE CONTRACTOR MUST VISIT THE SITE TO FAMILIARIZE THEMSELVES WITH THE SCOPE OF WORK AND POTENTIAL COMPLEXITIE S BEFORE SUBMITTING A QUOTATION.B) DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL CHARGES BEYOND THE AGREED RATES OR PRICES DURING OR AFTER THE EXECUTION OF THE WORK. C) THE CONTRACTOR WILL BE PROVIDED WITH AN EQUIPMENT SHUTDOWN SCHEDULE IN COORDINATION WITH THE OPER ATIONS & MAINTENANCE DEPARTMENT OF THE WATER DIVISION. D) A TIME SCHEDULE OR BAR CHART SHOWING EACH ACTIVITY MUST BE SUBMITTED. E) UPO N COMPLETION, AN INSPECTION CHECKLIST AND QUALITY PROCEDURE DOCUMENTATION, WHERE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>APPLICABLE, MUST BE SUBMITTED. F) THE CONTRACTOR IS RESPONSIBLE FOR SITE SUPERVISION, COORDINATION OF FIELD ACTIVITIES, AND THE SUPPLY OF REQUIRED TECHNICIANS, TOOLS, EQUIPMENT, AND RESOURCES NECESSARY TO EXECUTE THE CONTRACT. 3.0 TAKEOVER: UPON COMPLETION OF ALL WORK WITHIN THE SCOPE OF THE CONTRACT, THE CONTRACTOR MUST NOTIFY DEWA IN WRITING. A CERTIFICATE OF COMPLETION WILL BE ISSUED AFTER A FINAL INSPECTION, CONFIRMING THAT THE WORK HAS BEEN ACCEPTED AND TAKEN OVER BY DEWA FOLLOWING THE NECESSARY CONDITION MONITORING CHECKS. 4.0 WARRANTY: A) ALL WORK WILL CARRY A WARRANTY OF 8,000 HOURS OF OPERATION OR ONE YEAR, WHICHEVER COMES FIRST. B) THE WARRANTY WILL TAKE EFFECT FROM THE DATE OF DEWA'S OFFICIAL TAKEOVER OF THE COMPLETED JOB. C) IF ANY DEFECTS ARE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IDENTIFIED DURING THE WARRANTY PERIOD, THE CONTRACTOR MUST RECTIFY THEM WITHIN THE TIMEFRAME SET BY DEWA WITHOUT ADDITIONAL COST OR COMPENSATION.5.0 DOCUMENTATION:UPON SATISFACTORY COMPLETION OF THE WORK AND HANDOVER, THE CONTRACTOR MUST SUBMIT THE FOLLOWING DOCUMENTS TO DEWA: #INITIAL INSPECTION REPORT (MENTIONING THE REQUIRED SPARES AND REQUIRED ACTIONS)-# JOB COMPLETION REPORT (INCLUDING ALL OVERHAULING ACTIONS DONE) WITHIN ONE WEEK OF DELIVERY.#SERVICE ENTRY APPLICATION ATTACHING THE JOB COMPLETION REPORT IMMEDIATELY ONCE THE REPORT IS SIGNED BY DEWA REPRESENTATIVE.#INCLUDING ALL PROPER PHOTOS, EQUIPMENT SERIAL NUMBER, AND EQUIPMENT TAGGING.#REQUISITION FOR SPARE PARTS PLANNING BASED ON THE CURRENT CONDITION OF THE EQUIPMENT ANNEXURE I # DETAILED M</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MANDATORY SCOPE OF WORK FOR BOOSTER PUMP OVERHAUL1.#DISMANTLING: THE CONTRACTOR SHALL DISMANTLE THE PUMP ACCORDING TO DEWA ENGINEER#S INSTRUCTIONS. SKILLED WORKMANSHIP AND CARE MUST BE APPLIED DURING REMOVAL.2.#OVERHAULING: THE CONTRACTOR SHALL DISMANTLE THE ROTATING ASSEMBLY IN THEIR WORKSHOP AND RECORD ALL FINDINGS, INCLUDING PHOTOGRAPHS OF DETERIORATED COMPONENTS. THE SHAFT MUST BE INSPECTED FOR STRAIGHTNESS, AND WORN AREAS SHOULD BE RECONDITIONED. IMPELLER, BEARINGS, MECHANICAL SEAL, GLAND SLEEVE, AND WEAR RINGS MUST BE THOROUGHLY CHECKED AND REPLACED IF NECESSARY. ALL PARTS FOUND DEFECTIVE MUST BE REPAIRED OR REPLACED, WITH AVAILABLE SPARES SUPPLIED BY DEW</p> <p>A. IF SPARES ARE UNAVAILABLE, THE CONTRACTOR MUST ARRANGE THEM AND SEEK APPROVAL FROM DEWA FOR ADDITIONAL COSTS.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE PUMP CASING MUST BE CLEANED AND INSPECTED FOR DAMAGE, AND ANY NECESSARY REPAIRS MUST BE CARRIED OUT USING SANDBLASTING AND FOOD-GRADE EPOXY COATING.3.#</p> <p>ASSEMBLY: REASSEMBLY OF THE EQUIPMENT MUST FOLLOW STANDARD PROCEDURES, ENSURING THE PROPER FIT AND CLEARANCES. THE ROTOR ASSEMBLY SHOULD BE DYNAMICALLY BALANCED PER ISO 1940/1 STANDARDS. A DETAILED RECORD OF ALL ACTIVITIES MUST BE MAINTAINED, AND ANY DEVIATIONS FROM SET VALUES WILL BE DETERMINED BY DEWA.4.#</p> <p>CONSUMABLES & ACCESSORIES: MANUFACTURING OF MECHANICAL SEAL COOLING PIPE FITTINGS, SHAFT LOCK NUTS, LOCK WASHERS, DOWEL PINS, BEARING SPACERS, HOLDING DOWN BOLTS, AND VARIOUS GASKETS, INCLUDING THE SUPPLY OF O-RINGS. ANNEXURE II</p> <p># OPTIONAL MACHINING WORKS1.#</p> <p>IMPELLER MACHINING: THIS INCLUDES GRIT BLASTING AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NON-DESTRUCTIVETESTING (NDT) TO IDENTIFY CRACKS, S KIMMING THE WEAR RING AREAS, ANDFITTING NEW RINGS.2.#SHAFT MACHINING: THE SHAFT WILL UNDERGO CHROME PLATING ON BEARINGSEATING AREAS AND MECHANICAL SEAL SEATING AREAS, ALONG WITH METALREBUILDING AND STRAIGHTENING (UP TO A 4-THOU MAXIMUM BEND).3.#BEARING HOUSING MAC HINING: MACHINING AND RESLEEVEING OF BOTH DE ANDNDE BEARING HOUSING BORES.4.#MECHANICAL SEAL FACE: MACHINING AND REPAIRING OF THE PUM P#S TOP ANDBOTTOM CASING HALVES AT THE MECHANICAL SEAL FACE.5.#PUMP CASINGS: SKIMMING AND GROOVING OF SUCTION AND DISCHARGE FLANGESO N THE PUMP CASING.MACHINING WORKS MUST COMPLY WITH THE LATEST STANDARDS, AND PRIORAPPROVAL FROM THE DEWA ENGINEER IS REQUIRED BEFORE COMMENCING ANYMACHINING TASKS. ANY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DAMAGES DONE ON ANY PROVIDED SPARES FROM DEWA, THE CONTRACTOR IS HELD RESPONSIBLE IN REPLACING THE DAMAGED MATERIAL AT NO ADDITIONAL COST TO DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
23		ITEM-00004	MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING WITH COMPLETE PUMP ASSEMBLY FOR NAJMA PH4 AVERSA PUMP. SCOPE OF WORK 1. #MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING: THE CONTRACTOR WILL MACHINE AND ASSEMBLE THE PUMP CASE WEAR RING, USING THE MATERIAL PROVIDED BY DEWA. 2. #COMPLIANCE WITH SPECIFICATIONS: MATERIAL AND DIMENSIONS MUST STRICTLY FOLLOW THE PROVIDED SAMPLE. 3. #ROTOR ASSEMBLY TESTING: AFTER INSTALLING THE CASE WEAR RING, THE ROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING. 4. #PAYMENT TERMS:	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PAYMENTS WILL BE PROCESSED UPON APPROVAL FROM THE DEWA ENGINEER.5.#WARRANTY: A ONE-YEAR WARRANTY WILL APPLY FOLLOWING THE INSTALLATION AND SUCCESSFUL TESTING OF THE PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THE CONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NO ADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.</p>						
24		ITEM-00004	<p>MACHINING & ASSEMBLY OF PUMP IMPELLER WEAR RING WITH COMPLETE PUMP ASSEMBLY FOR NAJMA PH4 AVERSA PUMP. SCOPE OF WORK 1.#MACHINING AND ASSEMBLY OF PUMP IMPELLER WEAR RING: THE CONTRACTOR WILL MACHINE AND ASSEMBLE THE PUMP IMPELLER WEAR RING, USING THE MATERIAL</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROVIDED BY DEWA.2.#COMPLIANCE WITH SPECIFICATIONS: MATERIAL AND DIMENSIONS MUSTSTRICTLY FOLLOW THE PROVIDED SAMPLE.3.#ROTOR ASSEMBLY TESTING : AFTER INSTALLING THE IMPELLER WEAR RING, THEROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING.4.#PAYMENT TERMS: PAY MENTS WILL BE PROCESSED UPON APPROVAL FROM THEDEWA ENGINEER.5.#WARRANTY: A ONE-YEAR WARRANTY WILL APPLY FOLLOWING THE INSTALLATIONAN D SUCCESSFUL TESTING OF THE PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THECONTRACTOR WILL BE HELD RESP ONSIBLE AND MUST PROVIDE NEW MATERIALS AT NOADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAMESPECIFICATIONS AS THOSE O RIGINALLY SUPPLIED BY DEWA.KINDLY CONTACT MR. NOOR (04-3229439 //</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
25		ITEM-00004	<p>MACHINING AND ASSEMBLY OF SHAFT SLEEVES FOR NAJMA PH4 AVERSA PUMPSCOPE OF WORK:1.#MACHINING: MACHINE THE SHAFT SLEEVES ACCORDING TO THE SPECIFIED DIMENSIONS PROVIDED BY DEWA.2.#ASSEMBLY: ASSEMBLE THE SHAFT SLEEVES ONTO THE PUMP'S ROTOR AS PER THE REQUIRED STANDARDS.</p> <p>3.#TESTING: PERFORM A COMPREHENSIVE TEST ON THE ROTOR ASSEMBLY TO ENSURE THE PROPER FITTING AND ALIGNMENT OF THE SHAFT SLEEVES.4.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THE CONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NO ADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 //</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
26		ITEM-00004	MACHINING AND REBUILDING OF SHAFT FOR NAJMA PH4 AVERSA PUMPSCOPE OF WORK:1.#SHAFT REBUILDING AND MACHINING: REBUILD AND MACHINE THE PUMP SHAFT ON BOTH THE DRIVE END (DE) AND NON-DRIVE END (NDE), FOCUSING ON THE MECHANICAL SEAL AND BEARING AREAS.2.#ASSEMBLY AND TESTING: REASSEMBLE THE PUMP AND ROTOR, FOLLOWED BY THOROUGH TESTING TO ENSURE PROPER FUNCTIONALITY.3.#CONTRACTOR RESPONSIBILITY: THE CONTRACTOR WILL ASSUME FULL RESPONSIBILITY FOR ANY ERRORS OR MISHANDLING DURING THE PROCESS. ALL NECESSARY CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.	1	SET				
27		ITEM-00004	MODIFICATION OF MECHANICAL SEAL COOLING LINE FOR NAJMA PH4 AVERSA PUMPSCOPE OF	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORK:1.#FABRICATION AND MODIFICATION: FABRICATE OR MODIFY THE MECHANICAL SEAL COOLING LINE TO MEET THE SPECIFIC REQUIREMENTS OF THE PUMP.2.#ASSEMBLY AND TESTING: ASSEMBLE THE COOLING LINE TO THE PUMP ROTOR ASSEMBLY, ENSURING IT ADHERES TO THE ORIGINAL DESIGN SPECIFICATIONS. TEST THE COOLING LINE THOROUGHLY TO CONFIRM THERE ARE NO ISSUES OR LEAKS.3.#CONTRACTOR RESPONSIBILITY: THE CONTRACTOR WILL BE FULLY RESPONSIBLE FOR ANY ERRORS OR MISHANDLING DURING THE MODIFICATION OR ASSEMBLY PROCESS. ALL NECESSARY CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST. KINDLY CONTACT MR. NOOR (04-3229 439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.</p>						
28		ITEM-00004	FULL BLASTING AND RECOATING OF NAJMA PH4 AVERSA PUMP SPECIFICATION FOR INTERNAL COATING OF PUMPS AND VALVES THESE PUMPS	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND VALVES ARE UTILIZED IN WATER BOOSTER PUMPING STATIONS,HANDLING POTABLE WATER WITH TEMPERATURES UP TO 50°C. WHILE THE WATER ISTYPICALLY CLEAN, OCCASIONAL SAND OR SOLIDS MAY BE PRESENT IN THE STREAMFROM THE PIPELINE. THE PUMPS HAVE BEEN IN OPERATION SINCE THE STATION'SCOMMISS IONING.SCOPE OF WORK1.#COLLECTION AND TRANSPORTATION: THE CONTRACTOR IS RESPONSIBLE FORCOLLECTING THE PUMP CASING USING A SUITABLE PICKUP OR CRANE-MOUNTEDTRUCK TO TRANSPORT IT TO DEWA'S WORKSHOP. THE CONTRACTOR MUST ENSURETHE USE OF APPROPRIATE LIFTING SLINGS/BELTS WITH SUFFICIENT LOADCAPACITY FOR SAFE LOADING AND UNLOADING.2.#SURFACE PREPARATION: BEFORE APPLYING ANY COATING, THE CONTRACTORMUST PERFORM SURFACE PREPARATION USING SAND OR GRIT BLASTING, OR OTHERSUITABLE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MECHANICAL METHODS TO REMOVE RUST AND LOOSE MATERIALS. AFTER THE BLASTING, DEWA ENGINEERS MUST INSPECT THE SURFACE BEFORE COATING. ALL MACHINED SURFACES AND CRITICAL AREAS MUST BE ADEQUATELY PROTECTED DURING SANDBLASTING TO AVOID DAMAGE. CLEAR PHOTOS MUST BE TAKEN AND BE ATTACHED IN THE COMPLETION REPORT. 3. #REBUILDING ERODED/PITTED SURFACES: THE CONTRACTOR MUST RESTORE ERODED SURFACES USING A SUITABLE COMPOSITE MATERIAL BEFORE APPLYING ANY COATING. THE COMPOSITE MATERIAL MUST HAVE THE FOLLOWING PROPERTIES: O# SUITABLE FOR CONTINUOUS IMMERSION IN VARIOUS CHEMICALS (E.G., FERRIC CHLORIDE, HYDROCHLORIC ACID, SULFURIC ACID, SODIUM HYDROXIDE, AMMONIUM HYDROXIDE) AT 21°C. O# MUST PASS THE ASTM C868 CORROSION TEST FOR DEMINERALIZED WATER IMMERSION AT 43°C FOR AT LEAST</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SIX MONTHS.O#ADHESION (ASTM D1002) GREATER THAN 183 KG/CM² (2,600 PSI).O#MEET OR EXCEED COMPRESSIVE, TENSILE, AND FLEXURAL STRENGTH STANDARDS.ENVIRONMENTAL CONDITIONS DURING SURFACE PREPARATION, APPLICATION, ANDCURING MUST BE MONITORED TO ENSURE PROPER EXECUTION.4.#INTERNAL AND EXTERNAL COATING:O#APPLY CERAMIC-REINFORCED COMPOSITE MATERIALS FOR THE FINAL COATINGAFTER SURFACE PREPARATION AND REBUILDING.O#THE COMPOSITE MUST WITHSTAND CONTINUOUS IMMERSION IN CHEMICALS ANDPASS THE ASTM B117 SALT FOG AND ASTM G8 CATHODIC DISBANDMENT TESTS.O#THE COATING MUST BE 800-1000 MICRONS THICK AND FINISHED WITH A SMOOTH, ABRA SION-RESISTANT GLASS-LIKE SURFACE.O#THE COMPOSITE MATERIAL MUST BE AUTHORIZED FOR USDA INCIDENTAL FOODCONTACT APPLICATIONS AND HOLD POTABLE WATER CERTIFICATION FROM WRAS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OREQUIVALENT AUTHORITIES.O#EXTERNAL COATING SHOULD BE AN EPOXY COATING, 300-400 MICRONS THICK, IN BLUE COLOR FOR BOTH PUMPS AND VALVES.5.#WARRANTY: THE SUPPLIER MUST PROVIDE A 24-MONTH SERVICE WARRANTYAGAINST ANY DEFECTS IN THE COATING. IF THE COATING FAILS WITHIN THISPERIOD, THE SUPPLIER WILL RECOAT THE EQUIPMENT FREE OF CHARGE.6.#METHOD STATEMENT: THE SUPPLIER MUST SUBMIT A DETAILED METHODSTATEMENT FOR THE COATING PROCESS, INCLUDING MATERIAL SPECIFICATIONS,FOR REVIEW AND APPROVAL.7.#INSPECTION: PRIOR TO DELIVERY, THE COATING WORK MUST BE INSPECTED BYDEWA ENGINEERS AT THE SUPPLIER'S WORKSHOP FOR FINAL ACCEPTANCE. THE CONTRACTOR MUST PROVIDE ALL NECESSARY INSPECTION TOOLS.8.#REPORTS AND DOCUMENTATION: UPON DELIVERY, THE CONTRACTOR MUST SUBMITTHE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOLLOWING:O#MATERIAL DATA SHEETS BEFORE AND AFTER COATING.O#WRAS CERTIFICATION FOR COATING MATERIALS.O#ALL RELEVANT TEST REPORTS.O#P ROPER COMPLETION REPORT INCLUDING THE INTERNAL CONDITION BEFORE ANDAFTER THE BLASTING AND THE COATING.KINDLY CONTACT MR. NOOR (04-32 29439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.</p>						
29		ITEM-00005	<p>COMPLETE OVERHAULING OF BOOSTER PUMP FOR NAD ALSHEBA PUMPING STATION.PUMP DETAILS: EQUIPMENT NO. 50353407, CLYDE UNION PUMP MODEL: : SDK 400/600, HEAD-140M, FLOW-263L/S,RPM-1475, 630KW.SCOPE OF WORKTHE FOLLOWING OUTLINES THE MANDATORY AND OPTIONAL SCOPE OF WORK FO R THEOVERHAUL OF BOOSTER PUMPS AND THEIR ACCESSORIES AT THE BOOSTER PUMPINGSTATION.1.0 MANDATORY SCOPE OF WORK:A) THE CONTRACTOR IS RESPONSIBLE FOR TRANSPORTING THE PUMP</p>	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ASSEMBLY TO AND FROM THE DEWA SITE TO THEIR WORKSHOP. DEWA WILL NOT PROVIDE TRANSPORTATION. FOR LOADING AND UNLOADING, THE CONTRACTOR MAY USE DEWA'S OVERHEAD CRANE AT THE PUMPING STATION, WITH PROPER COORDINATION WITH DEWA REPRESENTATIVES. B) REPLACEMENT OF THE MECHANICAL SEAL, COUPLING BUSH RENEWAL, GLAND PACKING RENEWAL, AND BEARING REPLACEMENT AS REQUIRED. C) OVERHAULING OF THE PUMP (REFER TO ANNEXURE I FOR MANDATORY AND ANNEXURE II FOR OPTIONAL WORK). D) EXTERNAL PAINTING OF THE PUMP. E) RECTIFICATION OF ANY ISSUES THAT ARISE AFTER INSTALLATION/LOAD TESTING. THIS SHALL BE DONE ON SITE IF POSSIBLE, AND IF NOT, THE CONTRACTOR IS RESPONSIBLE IN COLLECTING THE PUMP AND MOVING IT BACK TO THEIR FACILITY. F) IF ANY PART IS FOUND DEFECTIVE, THE CONTRACTOR IS RESPONSIBLE.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RESPONSIBLE FORREPAIRING OR REPLACING IT. DEWA WILL PROVIDE AVAILABLE SPARES. IF ANYSPARE PARTS ARE UNAVAILABLE, THE CONTRACTOR MUST ARRANGE THEM AND SUBMITTHE COST FOR DEWA APPROVAL BEFORE PLACING AN ORDER. G) ONCE THE PUMP ISFULLY ASSEMBLED, THE PUMP MUST BE PRES SURE HYDRO TESTED IN THECONTRACTOR FACILITY TO MAKE SURE THE PUMP IS WELL ASSEMBLED AND THATTHERE ARE NO LEAKS.2.0 REQUIREMENTS PRIO R TO QUOTATION SUBMISSION:A) THE CONTRACTOR MUST VISIT THE SITE TO FAMILIARIZE THEMSELVES WITH THESCOPE OF WORK AND POTENTIAL COMPLE XITIES BEFORE SUBMITTING A QUOTATION.B) DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL CHARGES BEYOND THEAGREED RATES OR PRICES DUR I NG OR AFTER THE EXECUTION OF THE WORK. C) THECONTRACTOR WILL BE PROVIDED WITH AN EQUIPMENT SHUTDOWN SCHEDULE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INCOORDINATION WITH THE OPERATIONS & MAINTENANCE DEPARTMENT OF THE WATERDIVISION. D) A TIME SCHEDULE OR BAR CHART SHOWING EACH ACTIVITY MUST BESUBMITTED. E) UPON COMPLETION, AN INSPECTION CHECKLIST AND QUALITYPROCEDURE DOCUMENTATION, WHERE APPLICABLE, MUST BE SUBMITTED. F) THECONTRACTOR IS RESPONSIBLE FOR SITE SUPERVISION, COORDINATION OF FIELDACTIVITIES, AND THE SUPPLY OF REQUIRED TECHNICIANS, TOOLS, EQUIPMENT,AND RESOURCES NECESSARY TO EXECUTE THE CONTRACT.3.0 TAKEOVER:UPON COMPLETION OF ALL WORK WITHIN THE SCOPE OF THE CONTRACT, THECONTRACTOR MUST NOTIFY DEWA IN WRITING. A CERTIFICATE OF COMPLETION WILLBE ISSUED AFTER A FINAL INSPECTION, CONFIRMING THAT THE WORK HAS BEENA CCEPTED AND TAKEN OVER BY DEWA FOLLOWING THE NECESSARY CONDITIONMONITORING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CHECKS.4.0 WARRANTY:A) ALL WORK WILL CARRY A WARRANTY OF 8,000 HOURS OF OPERATION OR ONEYEAR, WHICHEVER COMES FIRST. B) THE WARRANTY WILL TAKE EFFECT FROM THE DATE OF DEWA'S OFFICIAL TAKEOVER OF THE COMPLETED JOB. C) IF ANY DEFECTS ARE IDENTIFIED DURING THE WARRANTY PERIOD, THE CONTRACTOR MUST RECTIFY THEM WITHIN THE TIME FRAME SET BY DEWA WITHOUT ADDITIONAL COST OR COMPENSATION.5.0 DOCUMENTATION:UPON SATISFACTORY COMPLETION OF THE WORK AND HANDOVER, THE CONTRACTOR MUST SUBMIT THE FOLLOWING DOCUMENTS TO DEWA: #INITIAL INSPECTION REPORT (MENTIONING THE REQUIRED SPARES AND REQUIRED ACTIONS) #JOB COMPLETION REPORT (INCLUDING ALL OVERHAULING ACTIONS DONE) WITHIN ONE WEEK OF DELIVERY.#SERVICE ENTRY APPLICATION ATTACHING THE JOB COMPLETION REPORT IMMEDIATELY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ONCE THE REPORT IS SIGNED BY DEWA REPRESENTATIVE.#INCLUDING ALL PROPER PHOTOS, EQUIPMENT SERIAL NUMBER, AND EQUIPMENTTAGGING.#REQUISITION FOR SPARE PARTS PLANNING BASED ON THE CURRENT CONDITIONOF THE EQUIPMENTANNEXURE I # DETAILED MANDATORY SCOPE OF WORK FOR BOOSTER PUMP OVERHAUL1.#DISMANTLING: THE CONTRACTOR SHALL DISMANTLE THE PUMP ACCORDING TO DEWA ENGINEER#S INSTRUCTIONS. SKILLED WORKMANSHIP AND CARE MUST BE APPLIED DURING REMOVAL.2.#OVERHAULING: THE CONTRACTOR SHALL DISMANTLE THE ROTATING ASSEMBLY IN THEIR WORKSHOP AND RECORD ALL FINDINGS, INCLUDING PHOTOGRAPHS OF DETERIORATED COMPONENTS. THE SHAFT MUST BE INSPECTED FOR STRAIGHTNESS, AND WORN AREAS SHOULD BE RECONDITIONED. IMPELLER, BEARINGS, MECHANICAL SEAL, GLAND SLEEVE, AND WEAR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RINGS MUST BE THOROUGHLY CHECKED AND REPLACED IF NECESSARY. ALL PARTS FOUND DEFECTIVE MUST BE REPAIRED OR REPLACED, WITH AVAILABLE SPARES SUPPLIED BY DEWA. IF SPARES ARE UNAVAILABLE, THE CONTRACTOR MUST ARRANGE THEM AND SEEK APPROVAL FROM DEWA FOR ADDITIONAL COSTS. THE PUMP CASING MUST BE CLEANED AND INSPECTED FOR DAMAGE, AND ANY NECESSARY REPAIRS MUST BE CARRIED OUT USING SAND BLASTING AND FOOD-GRADE EPOXY COATING.</p> <p>G.3.#ASSEMBLY: REASSEMBLY OF THE EQUIPMENT MUST FOLLOW STANDARD PROCEDURES, ENSURING THE PROPER FIT AND CLEARANCES. THE ROTOR ASSEMBLY SHOULD BE DYNAMICALLY BALANCED PER ISO 1940/1 STANDARDS. A DETAILED RECORD OF ALL ACTIVITIES MUST BE MAINTAINED, AND ANY DEVIATIONS FROM SET VALUES WILL BE DETERMINED BY DEWA.</p> <p>4.#CONSUMABLES & ACCESSORIES:</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MANUFACTURING OF MECHANICAL SEAL COOLINGPIPE FITTINGS, SHAFT LOCK NUTS, LOCK WASHERS, DOWEL PINS, BEARINGSPACERS, HOLDING DOWN BOLTS, AND VARIOUS GASKETS, INCLUDING THE SUPPLYOF O-RINGS.ANNEXU</p> <p>RE II # OPTIONAL MACHINING WORKS1.#IMPELLER MACHINING: THIS INCLUDES GRIT BLASTING AND NON-DESTRUCTIVETESTING (NDT) TO IDENTIFY CRACKS, SKIMMING THE WEAR RING AREAS, ANDFITTING NEW RINGS.2.#SHAFT MACHINING: THE SHAFT WILL UNDERGO CHROME PLATING ON BEARINGSEATING AREAS AND MECHANICAL SEAL SEATING AREAS, ALONG WITH METALREBUILDING AND STRAIGHTENING (UP TO A 4-THOU MAXIMUM BEND).3.#BEARING HOUSING MACHINING: MACHINING AND RESLEEVEING OF BOTH DE ANDNDE BEARING HOUSING BORES.4.#MECHANICAL SEAL FACE: MACHINING AND REPAIRING OF THE PUMP#S TOP ANDBOTTOM CASING HALVES AT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE MECHANICAL SEAL FACE.5.#PUMP CASINGS: SKIMMING AND GROOVING OF SUCTION AND DISCHARGE FLANGE ON THE PUMP CASING.MACHINING WORKS MUST COMPLY WITH THE LATEST STANDARDS, AND PRIOR APPROVAL FROM THE DEWA ENGINEER IS REQUIRED BEFORE COMMENCING ANY MACHINING TASKS. ANY DAMAGES DONE ON ANY PROVIDED SPARES FROM DEWA, THE CONTRACTOR IS HELD RESPONSIBLE IN REPLACING THE DAMAGED MATERIAL AT NO ADDITIONAL COST TO DEWA.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.</p>						
30		ITEM-00005	<p>MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING WITH COMPLETE PUMP ASSEMBLY FOR NAD ALSHEBA CLYDE UNION PUMP.SCOPE OF WORK1.#MACHINING AND ASSEMBLY OF PUMP CASE WEAR RING: THE CONTRACTOR WILL MACHINE AND ASSEMBLE THE PUMP CASE WEAR RING, USING THE</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MATERIAL PROVIDED BY DEWA.2.#COMPLIANCE WITH SPECIFICATIONS: MATERIAL AND DIMENSIONS MUST STRICTLY FOLLOW THE PROVIDED SAMPLE.3.#ROTOR ASSEMBLY TESTING: A FTER INSTALLING THE CASE WEAR RING, THE ROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING.4.#PAYMENT TERMS: PAYMENTS W ILL BE PROCESSED UPON APPROVAL FROM THE DEWA ENGINEER.5.#WARRANTY: A ONE-YEAR WARRANTY WILL APPLY FOLLOWING THE INSTALLATION AND SUCCESSFUL TESTING OF THE PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THE CONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NO ADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THOSE ORIGINAL LY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 //</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
31		ITEM-00005	<p>MACHINING & ASSEMBLY OF PUMP IMPELLER WEAR RING WITH COMPLETE PUMP ASSEMBLY FOR NAD ALSHEBA CLYDE UNION PUMP. SCOPE OF WORK 1. #MACHINING AND ASSEMBLY OF PUMP IMPELLER WEAR RING: THE CONTRACTOR WILL MACHINE AND ASSEMBLE THE PUMP IMPELLER WEAR RING, USING THE MATERIAL PROVIDED BY DEWA. 2. #COMPLIANCE WITH SPECIFICATIONS: MATERIAL AND DIMENSIONS MUST STRICTLY FOLLOW THE PROVIDED SAMPLE. 3. #ROTOR ASSEMBLY TESTING: AFTER INSTALLING THE IMPELLER WEAR RING, THE ROTOR ASSEMBLY MUST UNDERGO TESTING TO ENSURE PROPER FUNCTIONING. 4. #PAYMENT TERMS: PAYMENTS WILL BE PROCESSED UPON APPROVAL FROM THE DEWA ENGINEER. 5. #WARRANTY: A ONE-YEAR WARRANTY WILL APPLY FOLLOWING THE INSTALLATION AND SUCCESSFUL TESTING OF THE</p>	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PUMP.6.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THECONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NOADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAMESPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.						
32		ITEM-00005	MACHINING AND ASSEMBLY OF SHAFT SLEEVES FOR NAD ALSHEBA CLYDE UNION PUMPSCOPE OF WORK:1.#MACHINING: MACHINE THE SHAFT SLEEVES ACCORDING TO THE SPECIFIEDDIMENSIONS PROVIDED BY DEWA.2.#ASSEMBLY: ASSEMBLE THE SHAFT SLEEVES ONTO THE PUMP'S ROTOR AS PERTHE REQUIRED STANDARDS.3.#TESTING: PERFORM A COMPREHENSIVE TEST ON THE ROTOR ASSEMBLY TOENSURE THE PROPER FITTING AND ALIGNMENT OF THE SHAFT SLEEVES	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			.4.#RESPONSIBILITY FOR ERRORS: IN THE EVENT OF ANY MACHINING ERRORS, THE CONTRACTOR WILL BE HELD RESPONSIBLE AND MUST PROVIDE NEW MATERIALS AT NO ADDITIONAL COST. THESE REPLACEMENT MATERIALS MUST MEET THE SAME SPECIFICATIONS AS THOSE ORIGINALLY SUPPLIED BY DEWA. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.						
33		ITEM-00005	MACHINING AND REBUILDING OF SHAFT FOR NAD ALSHEBA CLYDE UNION PUMP SCOPE OF WORK: 1.#SHAFT REBUILDING AND MACHINING: REBUILD AND MACHINE THE PUMP SHAFT ON BOTH THE DRIVE END (DE) AND NON-DRIVE END (NDE), FOCUSING ON THE MECHANICAL SEAL AND BEARING AREAS. 2.#ASSEMBLY AND TESTING: REASSEMBLE THE PUMP AND ROTOR, FOLLOWED BY THOROUGH TESTING TO ENSURE PROPER FUNCTIONALITY. 3.#CONTRACTOR RESPONSIBILITY: T	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HE CONTRACTOR WILL ASSUME FULLRESPONSIBILITY FOR ANY ERRORS OR MISHANDLING DURING THE PROCESS. ALLNECESSARY CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.						
34		ITEM-00005	MODIFICATION OF MECHANICAL SEAL COOLING LINE FOR NAD ALSHEBA CLYDE UNIONPUMPSCOPE OF WORK:1.#FABRICATION AND MODIFICATION: FABRICATE OR MODIFY THE MECHANICALSEAL COOLING LINE TO MEET THE SPECIFIC REQUIREMENTS OF THE PUMP.2.#ASSEMBLY AND TESTING: ASSEMBLE THE COOLI NG LINE TO THE PUMP ROTORASSEMBLY, ENSURING IT ADHERES TO THE ORIGINAL DESIGN SPECIFICATIONS.TEST THE COOLING LINE THOROUGHLY TO CON FIRM THERE ARE NO ISSUES ORLEAKS.3.#CONTRACTOR RESPONSIBILITY: THE CONTRACTOR WILL BE FULLY RESPONSIBLEFOR	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANY ERRORS OR MISHANDLING DURING THE MODIFICATION OR ASSEMBLYPROCESS. ALL NECESSARY CORRECTIONS MUST BE MADE AT NO ADDITIONAL COST.KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FORFURTHER CLARIFICATION.						
35		ITEM-00005	FULL BLASTING AND RECOATING OF NAD ALSHEBA CLYDE UNION PUMPSPECIFICATION FOR INTERNAL COATING OF PUMPS AND VALVESTHESE PUMPS AND VALVES ARE UTILIZED IN WATER BOOSTER PUMPING STATIONS,HANDLING POTABLE WATER WITH TEMPERATURES UP TO 50°C. WHILE THE WATER ISTYPICALLY CLEAN, OCCASIONAL SAND OR SOLIDS MAY BE PRESENT IN THE STREAMFROM THE PIPELINE. THE PUMPS HAVE BEEN IN OPERATION SINCE THE STATION'S COMMISSIONING.SCOPE OF WORK1.#COLLECTION AND TRANSPORTATION: THE CONTRACTOR IS RESPONSIBLE FORCOLLECTING THE PUMP CASING USING A SUI	1	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TABLE PICKUP OR CRANE-MOUNTED TRUCK TO TRANSPORT IT TO DEWA'S WORKSHOP. THE CONTRACTOR MUST ENSURE THE USE OF APPROPRIATE LIFTING SLINGS/BELTS WITH SUFFICIENT LOAD CAPACITY FOR SAFE LOADING AND UNLOADING. 2. #SURFACE PREPARATION: BEFORE APPLYING ANY COATING, THE CONTRACTOR MUST PERFORM SURFACE PREPARATION USING SAND OR GRIT BLASTING, OR OTHER SUITABLE MECHANICAL METHODS TO REMOVE RUST AND LOOSE MATERIALS. AFTER THE BLASTING, DEWA ENGINEERS MUST INSPECT THE SURFACE BEFORE COATING. ALL MACHINED SURFACES AND CRITICAL AREAS MUST BE ADEQUATELY PROTECTED DURING SANDBLASTING TO AVOID DAMAGE. CLEAR PHOTOS MUST BE TAKEN AND BE ATTACHED IN THE COMPLETION REPORT. 3. #REBUILDING ERODED/PITTED SURFACES: THE CONTRACTOR MUST RESTORE ERODED SURFACES USING A SUITABLE COMPOSITE MATERIAL BEFORE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>APPLYING ANYCOATIN G. THE COMPOSITE MATERIAL MUST HAVE THE FOLLOWING PROPERTIES:O#SUITABLE FOR CONTINUOUS IMMERSION IN VARIOUS CHEMICALS (E.G., FERRICC HLORIDE, HYDROCHLORIC ACID, SULFURIC ACID, SODIUM HYDROXIDE, AMMONIUMHYDROXIDE) AT 21°C.O#MUST PASS THE ASTM C868 CORROSION TEST FOR DEMINERALIZED WATERIMMERSION AT 43°C FOR AT LEAST SIX MONTHS.O#ADHESION (ASTM D1002) GREATER THAN 183 KG/CM² (2,600 PSI).O#MEET OR EXCEED COMPRESSIVE, TENSILE, AND FLEXURAL STRENGTH STANDARDS.ENVIRONMENTAL CONDITIONS DURING SURFACE PREPARATION, APPLICATION, ANDCU RING MUST BE MONITORED TO ENSURE PROPER EXECUTION.4.#INTERNAL AND EXTERNAL COATING:O#APPLY CERAMIC-REINFORCED COMPOSITE MATERIALS FO R THE FINAL COATINGAFTER SURFACE PREPARATION AND REBUILDING.O#THE COMPOSITE MUST WITHSTAND CONTINUOUS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IMMERSION IN CHEMICALS ANDPASS THE ASTM B117 SALT FOG AND ASTM G8 CATHODIC DISBANDMENT TESTS.O#THE COATING MUST BE 800-1000 MICRONS THICK AND FINISHED WITH ASMOT H, ABRASION-RESISTANT GLASS-LIKE SURFACE.O#THE COMPOSITE MATERIAL MUST BE AUTHORIZED FOR USDA INCIDENTAL FOODCONTACT APPLICATIONS AN D HOLD POTABLE WATER CERTIFICATION FROM WRAS OREQUIVALENT AUTHORITIES.O#EXTERNAL COATING SHOULD BE AN EPOXY COATING, 300-400 MICRONS THICK,IN BLUE COLOR FOR BOTH PUMPS AND VALVES.5.#WARRANTY: THE SUPPLIER MUST PROVIDE A 24-MONTH SERVICE WARRANTYAGAINST ANY DEFECTS IN THE COATING. IF THE COATING FAILS WITHIN THISPERIOD, THE SUPPLIER WILL RECOAT THE EQUIPMENT FREE OF CHARGE.6.#METHOD STATEMENT: THE SUPPLIER MUST SUBMIT A DETAILED METHODSTATEMENT FOR THE COATING PROCESS,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INCLUDING MATERIAL SPECIFICATIONS, FOR REVIEW AND APPROVAL. 7.#INSPECTION: PRIOR TO DELIVERY, THE COATING WORK MUST BE INSPECTED BY DEWA ENGINEERS AT THE SUPPLIER'S WORKSHOP FOR FINAL ACCEPTANCE. THE CONTRACTOR MUST PROVIDE ALL NECESSARY INSPECTION TOOLS. 8.#REPORTS AND DOCUMENTATION: UPON DELIVERY, THE CONTRACTOR MUST SUBMIT THE FOLLOWING: 0#MATERIAL DATA SHEETS BEFORE AND AFTER COATING. 0#WRAS CERTIFICATION FOR COATING MATERIALS. 0#ALL RELEVANT TEST REPORTS. 0#PROPER COMPLETION REPORT INCLUDING THE INTERNAL CONDITION BEFORE AND AFTER THE BLASTING AND THE COATING. KINDLY CONTACT MR. NOOR (04-3229439 // MD.NOORUDDIN@DEWA.GOV.AE) FOR FURTHER CLARIFICATION.</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

Several pumps complete overhauling and recoating

1. JA Habab PH2 Torishima Pump
2. JA Habab PH3 Torishima Pump
3. Najma PH3 Weir Pump
4. Najma PH4 Aversa Pump
5. NAS Clyde Union Pump

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600588
DATE : 06.03.2026
REQ No : 1032601071
REQ TITLE : Several pumps complete overha
DELIVERY LOCATION
CLOSING DATE : 17.03.2026
CLOSING TIME : 10:00:00

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP