

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF TANK INTEGRITY ANALYSIS AT MSTATION, JEBEL ALI POWER STATION.1.#INTRODUCTION:INTEGRITY ANALYS IS, FITNESS FOR SERVICE ASSESSMENT, RLA AND CALIBRATIONOF DFO STORAGE TANK AT DEWA, JEBEL ALI. CONDUCT INTERNAL/EXTERNALINSPECTION A ND RECOMMEND NDE IN COMPLIANCE WITH API 653.BASED ON THE NDE FINDINGS, FITNESS-FOR-SERVICE ASSESSMENT SHALL BEPERFORMED AND RECOMMEN DATIONS FOR ANY REQUIRED REPAIRS, ALONG WITH ANINSPECTION AND TEST PLAN (ITP) AND APPLICABLE NDE PROCEDURES SHALL BESUBMITTED ACCORD INGLY.TANK SPECIFICATION:DFO STORAGE M TANKS NO. 3, KKS: 00EGB13BB001TANK SIZE: 38500 MM ID X 19585 MM HIGHTYPE OF TANK: CONE ROOF C YLINDRICALTANK CAPACITY (TOTAL): 22800 CU. MDESIGN CODE: API STD 650, 10TH EDITION DESIGN PRESSURE: ATMQUANTITY - 01</p>	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NOS2.#PERIOD OF WORK:03 DAYS3.#SCOPE OF WORK:3.1.#SCOPE OF WORK INCLUDES, BUT NOT LIMITED TO THE FOLLOWING3.1.1.#MOBILIZE THE API AUTHORIZED INSPECTOR WITH SUITABLE INSPECTION TOOLS, PPES AND CONSUMABLES WITHIN ONE DAY AFTER ORDER CONFIRMATION.3.1.2.#ALL EQUIPMENT NECESSARY TO EXECUTE INSPECTION AND MEASUREMENTS SHALL BE THE SCOPE OF CONTRACTOR.3.1.3.#CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.3.1.4.#CHECK AND ENSURE CONDITIONS ARE SUITABLE FOR CARRYING OUT WORK.3.1.5.#ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK IN ALL RESPECTS3.1.6.#IF WORKING ENVIRONMENT IS SAFE, PROCEED WITH THE FOLLOWING STEPS.3.1.7.#CARRY OUT INTEGRITY ASSESSMENT, RLA & FFS3.1.8.#COLLECT DATA ON ORIGINAL DESIGN AND FABRICATION PRACTICES,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE MATERIAL OF CONSTRUCTION, AND THE SERVICE HISTOR</p> <p>Y.3.1.9.#DEVELOP INTEGRITY MANAGEMENT PLAN (IMP)3.1.10.#PREPARE INSPECTION TEST PROTOCOL (ITP) TO IMPLEMENT IMP AND TO COLLECT NDE DATA ON PRESENT CONDITION OF THE ASSET UNDER SCOPE.3.1.11.#ITP SHALL HAVE NECESSARY INSPECTION-RELATED INFORMATION DETAILING ALL THE COMPONENTS/STRUCTURES WITHOUT ANY EXCEPTION, TO PLAN THE ACTIVITIES DURING SHUTDOWN INSPECTION.3.1.12.#A MARKUP DRAWING SHALL BE PREPARED SHOWING ALL THE CML LOCATIONS. A UNIQUE IDENTIFICATION MUST BE DEVELOPED FOR CMLS. COPIES OF EXISTING DRAWINGS SHALL BE USED TO MARK CML POINTS.3.1.13.#ALL NDE SHALL BE IN THE SCOPE OF CONTRACTOR ALONG WITH THEIR TEST EQUIPMENT, TOOLS, TACKLES, CONSUMABLES AND CERTIFIED PERSONNEL.COMPARISON AGAINST</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REQUIREMENTS PROVIDED IN THE DRAWINGS TO BE MADE BY THE CONTRACTOR.3.1.14.#CALIBRATION OF TANK BY EODR (ELECTRO OPTICAL DISTANCE RANGING)METHOD BY AUTHORIZED PARTY.3.2.#TANK EXTERNAL OUT OF SERVICE INSPECTION:3.2.1.#THE EXTERNAL INSPECTION MUST BE CONDUCTED BY AN AUTHORIZED APIINSPECTOR.3.2.2.#A COMPLETE VISUAL INSPECTION SHALL BE CARRIED OUT TO IDENTIFY ANY SURFACE DEFECT.3.2.3.#CHECK THE FOUNDATION, SHELL, ACCESSORIES AND ROOF.3.2.4.#THE OBSERVATIONS SHALL CONCENTRATE ON LEAKAGE FROM UNDER THE BOTTOM, SHELL SETTLEMENT, VERTICALITY, SHELL DEFORMATIONS (FLAT SPOTS,BUCKLES OR BULGES), ROOF CONDITION, CORROSION SPOTS ETC. AS PER API 6533.2.5.#THE OBSERVATIONS SHOULD INCLUDE THE CONDITION OF PAINT, SAFETY OF STAIRS, PLATFORMS AND HANDRAILS AND PROPER FU</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FUNCTIONING OF SERVICEEQUIPMENT.3.2.6.#INSPECTION AND MONITORING OF ALL LEAK DETECTION SYSTEMS,CATHODIC PROTECTION MONITORING EQUIPMEN T OR OTHER MONITORING OR WARNINGSYSTEMS WHICH MAY BE IN PLACE AT THE FACILITY.3.2.7.#WALL THICKNESS MEASUREMENT TO BE DONE FOR SHELL AND ROOF. ASUITABLE ULTRASONIC THICKNESS MEASUREMENT TECHNIQUE SHALL BE APPLIED.3.2.8.#IN THE EVENT OF SUSPECTED CRACKING IN WELDS OR OTHER AREAS OFTHE TANK, SUCH DEFECTS SHALL BE CONFIRMED USING AN APPROPRIATENON-DESTRUCTIVE TESTING (NDT) METHOD, SUCH AS RADIOGR APHC TESTING,ULTRASONIC TESTING, DYE PENETRANT TESTING, OR MAGNETIC PARTICLEEXAMINATION.3.2.9.#SURFACE CORROSION, WELD DEFECTS, OR COATING DETERIORATION TO ANEXTENT THAT COULD ADVERSELY AFFECT THE INTEGRITY OF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE TANK SHALL BE INSPECTED USING APPROPRIATE METHODS.</p> <p>3.2.10.#THE TANK SHELL/ROOF/BOTTOM SHALL BE INSPECTED FOR SIGNS OF DEFORMATION (FLAT SPOT, BUCKLE OR BULGE), LEAKAGE OR CORROSION OF BOTTOM EDGE AND SHELL PLATES.</p> <p>3.2.11.#STIFFENING RINGS INTENDED TO PREVENT BUCKLING RESULTING FROM WIND LOADS AND ELEVATED THERMAL STRESSES AT LOW AMBIENT (WINTER) TEMPERATURES SHALL ALSO BE INSPECTED.</p> <p>3.2.12.#IN THE EVENT THAT INDICATIONS OF CORROSION PENETRATING THE ROOF STRUCTURE ARE OBSERVED, ACCESS TO THE ROOF SHALL BE PROHIBITED, AND THE MATTER SHALL BE REFERRED TO DEWA FOR FURTHER DETERMINATION ON THE APPROPRIATE COURSE OF ACTION.</p> <p>3.2.13.#THE FOLLOWING ELEMENTS SHALL BE INSPECTED BUT NOT LIMITED TO BY AN APPROPRIATE METHOD TO ENSURE THAT THEY ARE IN GOOD</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONDITION:##STRUCTURES SUPPORTING AND REINFORCING THE TANK##MEANS OF ATTACHMENT TO TANK SYSTEM##ANY SERVICE EQUIPMENT LIKE LEVEL GAUGES, EARTH LUG, BREATHERS, HEATDETECTORS, STAIRS ETC.##DRAINS, TRENCHES, DRAIN COLLECTION PIT AND INTE RCEPTOR ETC.##FIREFIGHTING ACCESSORIES AND SYSTEM3.2.14.#CONNECTED PIPELINES AND BELLOWS SHALL ALSO BE INSPECTED FORPUNCTURE OR CRAC KS.3.2.15.#THE PROPER FUNCTIONING OF EXTERNAL EQUIPMENT SUCH AS VENTS,PRESSURE/VACUUM VALVES, FLAME ARRESTOR GAUGING DEVICES ANDWATER-DRAINING EQUIPMENT SHALL BE ESTABLISHED.3.2.16.#FLEXIBLE JOINTS AND FIXED HOSES AS PART OF THE FILLING AND/ORDISCHARGING SYSTEM SH ALL BE VISUALLY INSPECTED.3.2.17.#BOLTED FLANGES, CAPS TO VALVES AT BOTTOM OUTLETS SHALL BECHECKED FOR WORN THREADS AND DAMAGED GASK</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ETS.3.2.18.#ALL SERVICE EQUIPMENT INCLUDING ANY PERMANENTLY ATTACHED HOSES SHALL BE INSPECTED IN THE MOUNTED POSITION FOR CORRECT FUNCTIONING.3.2.19.#IN ADDITION TO A GENERAL INSPECTION OF THE STEELWORK PARTICULAR ATTENTION SHALL BE PAID TO: SUPPORTS TO TANK SHELL, INTERMEDIATE PLATFORMS AND HAND RAILING, CONCRETE PEDESTAL SUPPORTS FOR STAIRWAYS, THE CRACKS IN THE TANK CONCRETE FOUNDATION.3.2.20.#THE PART OF THE FOUNDATION WHICH PROJECTS BEYOND THE BASE OF THE TANK (THE SHOULDER) SHALL BE INSPECTED TO VERIFY THAT THE TANK BOTTOM SEALING IS IN GOOD CONDITION AS IT IS POSSIBLE THAT MINOR, EVEN SETTLEMENT OF A TANK WILL FORM A CHANNEL AROUND THE PERIPHERY OF THE TANK BOTTOM IN WHICH RAINWATER WILL COLLECT AND CAUSE SERIOUS CORROSION OF THE BOTTOM-TO-SHELL CONNECTION.3.2.21.#VERIFY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THAT THE SLOPE OF THE TANK CONCRETE FOUNDATION SHOULD BE ADEQUATE TO ENSURE PROPER DRAINAGE OF RAINWATER.3.2.22.#SHELL SETTLEMENT, VERTICALITY, SHELL DEFORMATIONS TO BE MEASURED3.2.23.#OUT-OF-SERVICE INSPECTION REPORT TO BE FILLED IN ADDITION AS PER API STANDARD.3.3.#TANK INTERNAL OUT OF SERVICE INSPECTION:3.3.1.#DETERMINING THE CONDITION AND INTEGRITY OF THE TANK BOTTOM.3.3.2.#THE AUTHORIZED API INSPECTOR WHO IS RESPONSIBLE FOR EVALUATION OF A TANK MUST CONDUCT A VISUAL INSPECTION AND ASSURE THE QUALITY.3.3.3.#A COMPLETE VISUAL INSPECTION SHALL BE PERFORMED TO IDENTIFY ANY SURFACE DEFECT AND SHALL TAKE ACCOUNT OF THE ORIGINAL SPECIFICATION.3.3.4.#THE INSPECTOR SHALL BE CAPABLE OF ASSESSING THE THICKNESS OF THE TANK BOTTOM, IN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COMBINATION WITH METHODS CAPABLE OF ASSESSING TANK BOTTOM INTEGRITY.3.3.5.#THE AUTHORIZED API INSPECTOR SHALL ENSURE THE COMPETENCE OF NONDESTRUCTIVE EXAMINATION (NDE) RESULTS BY SUITABLE METHODS.3</p> <p>.3.6.#ANY LINING OR COATING SHALL BE VISUALLY INSPECTED FOR INTEGRITY.IN PARTICULAR BONDING DEFECTS OR DELAMINATION SHALL BE IDENTIFIED AND RECORDED IN THE REPORT.3.3.7.#THE BOTTOM PLATE THICKNESS SHALL BE ASCERTAINED BY NON-DESTRUCTIVE TESTING LIKE ULTRASONIC TESTING, MAGNETIC FLUX LEAKAGE (MFL) TEST OR ANY OTHER SUITABLE APPROVED TECHNIQS.3.3.8.#GATHER THE DATA NECESSARY FOR THE MINIMUM BOTTOM AND SHELL THICKNESS ASSESSMENTS DETAIL.3.3.9.#THE DATA AND INFORMATION COLLECTED SHOULD BE SUFFICIENT TO EVALUATE THE THICKNESS, CORROSION RATE, AND INTEGRITY OF THE TANK</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BOTTOMAND ESTABLISH THE INTERNAL INSPECTION INTERVAL, BASED ON TANK BOTTOMTHICKNESS, CORROSION RATE, AND INTEGRITY, UTILIZING THE STANDARDMETHODS.3.3.10.#THE AUTHORIZED API INSPECTOR WHO IS RESPONSIBLE FOR EVALUATIONOF A TANK M UST ASSURE THE QUALITY AND COMPETENCE FOR THE INSPECTIONMETHOD.3.3.11.#THE TANK DRAIN PITS OR SUMPS PLATE THICKNESS, WELD JOINTS SHA LLBE INSPEC						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

TECHNICAL AND GENERAL SPECIFICATION OF TANK INTEGRITY ANALYSIS AT M

DFO-3TANK, JEBEL ALI POWER STATION.

CONTACT-anton.jacob@dewa.gov.ae

STANDARD TERMS & CONDITIONS

1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details,

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332600590
DATE	: 09.03.2026
REQ No	: 1032600982
REQ TITLE	: TECHNICAL AND GENERAL
DELIVERY LOCATION	
CLOSING DATE	: 13.03.2026
CLOSING TIME	: 10:00:00

requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.

2) Prices should be 'DDP' delivery duty paid at DEWA stores.

3) Quotation to be submitted only in local currency U.A.E Dirhams

4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.

5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.

7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:

a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.

b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.

c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

- commencement.
- d) DEWA reserves the right to withhold data from third parties if deemed sensitive.
- e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.
- 9) Liquidated Damages for PO total value in excess of AED 50,000:
If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.
- 10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.
- 11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.
- 12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.
- 13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600590
DATE : 09.03.2026
REQ No : 1032600982
REQ TITLE : TECHNICAL AND GENERAL
DELIVERY LOCATION
CLOSING DATE : 13.03.2026
CLOSING TIME : 10:00:00

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP