

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>OVERHAULING, REPAIRING &amp; COATING OF THE DN500 PN10 BUTTERFLY VALVE OFNAJMA PH3 PUMPING STATION.PLEASE CONTACT MR. NOOR (04-3229439)</p> <p>FOR FURTHER CLARIFICATIONS.1.0#SCOPE OF WORKTHE BUTTERFLY VALVE ARE NOT WORKING PROPERLY FOR WHICH DEWA INTENDED TOOUTSOURCE THE REP</p> <p>AIRING &amp; COATING JOB IN LOCAL REPUTED CONTRACTOR.#DETAILS OF THE BUTTERFLY VALVE:#MAKE: ###ERHARD.#NOMINAL DIAMETER:#DN500.#PRESSURE RATING:#PN10#SCOPE OF WORKSA.#REPAIRING/OVERHAULING OF THE COMPLETE BUTTERFLY VALVE.#REPLACEMENT OF THE ALL DEFECTIVE SPARES LIKE O-RING, SHAFT KEY ETC.C.#REPLACEMENT OF SEALING RING &amp; BUSH, IF INDEED REQUIRES.D.#TRUENESS CHECK OF DRIVE SHAFT &amp; SHORT SHAFT, I F REQUIRES REPAIRINGOF THE SHAFTSE.#REPAIRING &amp; OVERHAULING OF GEARBOX AND REPLACEMENT OF THE</p>	1	SET				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NECESSARY SPARES, IF DEEMED TO BE REPLACED.F.#FUNCTIONAL &amp; PRESSURE TEST OF BUTTERFLY VALVE AT CONTRACTOR PREMISES.G.#OPERATIONAL TEST OF THE BUTTERFLY VALVE INSTALLED AT DEWA PIPELINE.2.0#PRIOR TO SUBMISSION OF QUOTATION, THE FOLLOWING SHALL BE DETERMINED CAREFULLY:A.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPES, COMPLEXITIES, ETC., BEFORE SUBMITTING THE QUOTATION.B.#DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES /PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED.C.# THE CONTRACTOR SHOULD SUBMIT THE TIME SCHEDULE /BAR CHART INDICATING EACH ACTIVITY.D.#ON COMPLETION OF THE WORK, THE INSPECTION CHECKLIST OF QUALITY PROCEDURES, WHERE APPLICABLE SHOULD BE FILLED IN AND SUBMITTED.4.0#TAKE OVER ON COMPLETION OF</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ALL WORK WITHIN THE SCOPE OF THE CONTRACT, FORACCEPTANCE OF THE MAINTENANCE WORK, CONTRACTOR SHALL NOTIFY DEWA INWRITING. A CERTIFICATE OF COMPLETION WILL BE ISSUED BY DEWA ON FINALINSPECTION ONLY WHEN THE CONTRACT WORK IS DEEMED TO HAVE BEEN TAKEN OVERBY DEWA AFTER NECESSARY CONDITION MONITORING CHECKS WHEREVER &amp; WHENEVERREQUIRED.5.0#WARRANTYA.#ALL THE WORK CARRIED OUT SHALL CARRY A WARRANTY FOR 8000 HOURS OFOPERATION OR 1 YEAR WHICHEVER IS EARLIER.B.#THE GUARANTEE WILL TAKE EFFECT FROM THE DATE OF TAKEOVER BY DEWA OFTHE JOB CARRIED OUT BY THE CONTRACTOR.C.#WHEN A DEFECT IS NOTICED DURING THE PERIOD OF WARRANTY, THECONTRACTOR MUST RECTIFY THE DEFECT WITHIN A REASONABLE AMOUNT OF TIMEFIXED BY DEWA WITHIN NO CLAIM OR COMPENSATION.6.0#DOCUMENTS:#ON</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SATISFACTORY COMPLETION OF THE WORK &amp; HANDING OVER, THE CONTRACTOR SHOULD SUBMIT THE FOLLOWING TO DEWA.                    ##A.#INSPECTION REPORT.B.#REPAIR/ACTION REPORT.C.#METHOD STATEMENT OF THE REPAIRING WORKS.D.#PHOTOS OF PARTS OF THE VALVE BEFORE/AFTER REPAIRING.E.#ALL TEST REPORTS.SPECIFICATION FOR INTERNAL COATING OF VALVE1.1#SURFACE PREPARATIONBEFORE APPLYING ANY COATING, THE CONTRACTOR HAS TO DO NECESSARY SURFACEPREPARATION BY SAND OR GRIT BLASTING OR ANY OTHER SUITABLE MECHANICALSYSTEM TO REMOVE ALL RUST &amp; LOOSE MATERIALS. AFTER SAND BLASTING THECONTRACTOR HAS TO INTIMATE DEWA ENGINEER FOR INSPECTION OF THE SURFACEBEFORE APPLYING ANY COATING. DURING SANDBLASTING IT IS REQUIRED TOPROTECT ALL MACHINED SURFACE, SEAT AREA AND ALL OTHER CRITICAL AREAS ANDPARTS FROM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DAMAGE BY SUITABLE METHOD.BUILDUP/ FILLING OF ERRODED/PITTED SURFACE THE SUPPLIER HAS TO BUILDUP ERODED SURFACE BY SUITABLE COMPOSITEMATERIALS UP TO ORIGINAL LEVEL BEFORE APPLYING ANY COATING. THECOMPOSITE MATERIAL SHALL HAVE THE FOLLOWING PROPERTIES:.#THE CURRIED COMPOSITE MUST BE SUITABLE FOR CONTINUOUS IMMERSION INTHE FOLLOWING CHEMICALS AT 21 0C (70 0F): FERRIC CHLORIDE, 10%HYDROCHLORIC ACID, 10% SULFURIC ACID, 5% NITRIC ACID, 50% SODIUMHYDROXIDE AND 28% AMMONIUM HYDROXIDE.# THE COMPOSITE SHALL SHOW NO BLISTERS WHEN EXPOSED TO DE-MINERALIZEDWATER IN AN ASTM C 868 CORROSION TEST AT 43 0C (110 0 F) FOR A MI NIMUMPERIOD OF 6 MONTHS.#ADHESION OF THE COMPOSITE PER ASTM D1002 SHALL BE GREATER THAN 183KG/CM2 (2,600 PSI).#THE CURVED COMPOSITE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MUST MEET OR EXCEED THE FOLLOWING PHYSICAL REQUIREMENTS: COMPRESSIVE STRENGTH (ASTM D 695) 914 KG/CM2 (13,000 PSI). TENSILE STRENGTH (ASTM D 638) 431 KG/CM2 (6,136 PSI) FLEXURAL STRENGTH (ASTM D 790) 620 KG/CM2 (8,800 PSI) FLEXURAL MODULUS (ASTM D 790) 6.9 X 104 KG/C M2 (9.87 X 105 PSI). DURING THE PHASES OF SURFACE PREPARATION, APPLICATION, AND CURING, ENVIRONMENTAL CONDITIONS WILL REQUIRE CAREFUL MONITORING AND MAY REQUIRE SUPPLEMENTAL CONTROLS. CRITICAL AREAS OF CONCERN ARE RELATIVE HUMIDITY, DEW POINT, SURFACE TEMPERATURE OF THE SUBSTRATE, AND AIR PURITY. CONTRACTOR SHALL CARRY OUT ALL THE PROCEDURES IN A CONTROLLED ENVIRONMENT IN ACCORDANCE WITH THE LATEST STANDARDS AND PROCEDURES. FINAL INTERNAL COATING AFTER SURFACE PREPARATION AND FILLING UP THE ERODED SURFACE IT IS REQUIRED</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TO APPLY THE CERAMIC REINFORCED COMPOSITE MATERIALS FOR FINAL COATING. THE COMPOSITE COATING MATERIALS SHALL HAVE FOLLOWING PROPERTIES: #THE CURED COMPOSITE MUST BE SUITABLE FOR CONTINUOUS IMMERSION IN THE FOLLOWING CHEMICALS AT 210C(700F): FERRIC CHLORIDE, 10% HYDROCHLORIC ACID, 10% SULFURIC ACID, 5% NITRIC ACID, 50% SODIUM HYDROXIDE AND 28% AMMONIUM HYDROXIDE. #THE COMPOSITE MUST EXCEED 10,000 HRS IN AN ASTM B 117 SALT FOG TEST (SCORED) WITH NO SIGNS OF UNDER FILM CORROSION AT THE SCORE. #THE COMPOSITE MUST PASS ASTM G 8 CATHODIC DISBAN DMENT TEST FOR NOT LESS THAN 60 DAYS. #THE COMPOSITE SHALL SHOW NO BLISTERS WHEN EXPOSED TO DEMINERALIZED WATER IN AN ASTM C 868 CORRO CELL TEST AT 430C (1100F) FOR A MINIMUM PERIOD OF 6 MONTHS. #ADHESION OF THE COMPOSITE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PER ASTM D 4541 SHALL BE GREATER THAN 140KG/CM            2 (2,000 PSI).#THE LINEAR CO-EFFICIENT OF THERMAL EXPANSION (ASTM C 531) SHALL NOT EXCEED 5.0 X 10-5 CM/CM/0C (2.8 X 10-5 IN/IN/0F).            #THICKNESS OF COATING 400-500 MICRONS.#SURFACE FINISHING OF THE COATING SHALL BE SMOOTH GLASS SURFACE FINISHED AND ABRASION RESISTANT            T.#THE CURED COMPOSITE MUST MEET OR EXCEED THE FOLLOWING            PHYSICAL REQUIREMENTS: COMPRESSIVE STRENGTH: (ASTM D 695) 844 KG/CM2 (12,000 PSI) TENSILE STRENGTH: (ASTM D 638) 240 KG/CM2 (3,420 PSI) FLEXURAL STRENGTH: (ASTM D 790) 562 KG/CM2 (8,000 PSI).#THE COMPOSITE SHALL BE AUTHORIZED FOR USDA APPLICATION FOR INCIDENTAL FOOD CONTACT.#THE COMPOSITE IS REQUIRED TO HAVE POTABLE WATER CERTIFICATION FROM INTERNATIONAL/LOCAL AUTHORITIES, WRAS (WATER REGULATORY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ADVISORY SOCIETY). EXTERNAL COATING  EPOXY POWDER COATING  G IN BLUE COLOUR AT LEAST 300-400  MICRON THICK FOR THE VALVES. ALL NECESSARY  SURFACES PREPARATIONS TO BE DONE BEFORE  COATING. WARRANTY  THE SUPPLIER HAS TO PROVIDE AT LEAST 24  MONTHS OF SERVICE WARRANTY AGAINST ANY  DAMAGE/ DEFECTS FOR THE COATING. IF THE  COATING  G IS FOUND TO FAIL WITHIN THIS PERIOD THE  SUPPLIER HAS TO RECOAT THE EQUIPMENT AT  FREE OF CHARGE TO DEWA. METHOD  STATEMENT THE SUPPLIER  HAS TO PROVIDE METHOD STATEMENT OF  COATING AND MATERIAL DETAILS ALONG WITH  THEIR OFFER FOR TECHNICAL EVALUATION AND  APPROVAL. INSPECTI  ON AT SITE BEFORE DELIVERY OF COATED  VALVES, THE COATING WORKS TO BE INSPECTED  BY DEWA ENGINEER AT SUPPLIER WORKSHOP FOR  FINAL ACCEPTA  NCE. CONTRACTOR SHALL PROVIDE WITH ALL</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REQUIRED NECESSARY INSPECTION TOOLS AS REQUIRED ON SITE. REPORTS & DOCUMENTS DURING DELIVERY THE FOLLOWING DOCUMENTS TO BE SUBMITTED. 1.#MATERIAL DATA SHEET. 2.#PHOTO OF NEEDLE VALVE BEFORE AND AFTER COATING. 3.#WARAS CERTIFICATE FOR COATING MATERIALS. 4.#ALL TEST REPORTS.						
2		ITEM-00002	LINE BORING & REPLACEMENT OF SHAFT SLEEVES OF THE DN500 PN10 BUTTERFLY VALVE OF NAJMA PH3 PUMPING STATION. CONTACT MR. NOOR (04-3229439) FOR FURTHER CLARIFICATION. SCOPE OF WORKS: 1. LINE BORING ON THE VALVE SLEEVES AREAS AND INSTALLATION OF NEWSLEEVES ON THE BOTH END OF THE VALVE. 2. ASSEMBLY OF THE COMPLETE VALVE. 3. HYDRO TESTING OF THE VALVE. 4. WARRANTY 2 YEARS	1	SET				
3		ITEM-00003	MACHINING & REPLACEMENT OF RETAINING RING OF THE DN500 PN10 BUTTERFLY VALVE OF NAJMA PH3 PUMPING STATION. CONTACT MR. NOOR	1	SET				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			(04-3229439) FOR FURTHER CLARIFICATIONSCOPE OF WORKS:1. MACHINING AND REPLACEMENT OF THE VALVE RETAINING RING.2. ASSEMBLY OF THE COMPLETE VALVE3 . HYDRO TESTING OF THE VALVE4. WARRANTY 2YEARS						
4		ITEM-00004	MACHINING & REPLACEMENT OF SEAT RING OF THE DN500 PN10 BUTTERFLY VALVEOFNAJMA PH3 PUMPING STATION.CONTACT MR. NOOR (04-3229439) FOR FURTHER CLARIFICATIONSCOPE OF WORKS:1. MACHINING AND REPLACEMENT OF THE VALVE SEAT RING (SS316L).2. ASSEMBLY OF THE COMPLETE VALVE 3. HYDRO TESTING OF THE VALVE4. WARRANTY 2YEARS	1	SET				

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

**SPECIAL NOTES / INSTRUCTIONS:**

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

Overhauling, Repairing <> Coating of the DN500 PN10 Butterfly Valve  
of of Najma Ph3 Pumping Station.

### STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider

**MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.**

**Page12 of 15**

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2332600799
<b>DATE</b>	: 02.04.2026
<b>REQ No</b>	: 1032601348
<b>REQ TITLE</b>	: Overhauling, Repairing & Coat
<b>DELIVERY LOCATION</b>	
<b>CLOSING DATE</b>	: 08.04.2026
<b>CLOSING TIME</b>	: 10:00:00

shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

### 8) Data Privacy, Security and Sharing:

- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- DEWA reserves the right to withhold data from third parties if deemed sensitive.
- Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

### 9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332600799  
**DATE** : 02.04.2026  
**REQ No** : 1032601348  
**REQ TITLE** : Overhauling, Repairing & Coat  
**DELIVERY LOCATION**  
**CLOSING DATE** : 08.04.2026  
**CLOSING TIME** : 10:00:00

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**