

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION :
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>DECOMMISSIONING AND REPLACEMENT OF EXISTING 07 NOS EUROSAFE,UK MAKE MOTORIZED DRY SECTIONAL VALVES IN SAADAST 132 KV SUBSTATION.SCOPE OF WORK INCLUDES REPLACEMENT OF EXISTING 07 NOS EUROSAFE ,UK MAKEMOTORIZED DRY SECTIONAL VALVES WITH DESIGN , SUPPLY, INSTALLATION AND TESTING & COMMISSIONING OF NEW, APPROVED SINORIX ,DENMARK MAKECOMPATIBLE UNITS AND FULL INTEGRATION WITH THE SUBSTATION'S FIRE PROTECTION, MONITORING, AND CONTROL SYSTEMS.1. SCOPE OF WORK1.1 PRE-EXECUTION ACTIVITIES.#CONDUCT A SITE SURVEY TO VERIFY EXISTING VALVE SPECIFICATIONS, PIPE SIZES, CONTROL WIRING, AND INSTALLATION CONSTRAINTS.#REVIEW EXISTING AS-BUILT DRAWINGS AND COORDINATE WITH THE DEWA END USER MAINTENANCE TEAM.#SUBMIT MATERIAL SUBMITTAL FOR DEWA APPROVAL.#SUBMIT HYDRAULIC CALCULATION</p>	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION :
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND RFC DRAWINGS FOR DEWA APPROVAL.#PREPARE METHOD STATEMENTS, RISK ASSESSMENTS, AND WORK PERMITS FORAPPROVAL.1.2 SUPPLY OF MATERIALS & EQUIPMENTTHE CON TRACTOR SHALL SUPPLY:#NEW MOTORIZED DRY SECTIONAL VALVES SINORIX ,DENMARK MAKE[SIZE:01 INCH,QTY -07 NOS].#ACTUATORS, CONTROL MODUL ES, AND ACCESSORIES COMPATIBLE WITH EXISTINGSYSTEM LOGIC.#REQUIRED FITTINGS, FLANGES, GASKETS, SUPPORTS, AND HARDWARE.#ELECTRICAL WIRING, CONDUITS, JUNCTION BOXES, AND TERMINATIONS ASNEEDED.#CONSUMABLES, TOOLS, AND LIFTING EQUIPMENT.ALL SUPPLIED MATERIALS MUST BE:#VDS APPROVED AND MATERIAL SUBMITTAL TO BE APPROVED BY DEWA .#COMPLIANT WITH PROJECT SPECIFICATIONS AND LOCAL FIRE PROTECTIONST ANDARDS1.3 . REMOVAL OF EXISTING MOTORIZED DRY SECTIONAL VALVES.#QTY TO BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DECOMMISSIONED SHALL BE 1.5 INCH -4 NOS AND 1 INCH -03 N</p> <p>OS.#DISCONNECT ELECTRICAL WIRING, CONTROL CABLES, AND COMMUNICATIONLINES.#REMOVE EXISTING EUROSAFE MAKE MOTORIZED DRY SECTIONAL VALVES WITHOUTDAMAGING ADJACENT PIPING OR EQUIPMENT.#HAND OVER THE REMOVED VALVES TO DEWA2. INSTALLATION OF NEW MOTORIZED DRY SECTIONAL VALVES.#INSTALLATION SHALL BE CARRIED OUT BY OEM APPROVED /CERTIFIED ENGINEEROR CONTRACTOR WITH EXPERIENCE IN SIMILAR HP WATER MIST SYSTEM IN DEWA.#INSTALL NEW MOTORIZED DRY SECTIONAL VALVES IN THE SAME OR APPROVEDMODIFIED CONFIGURATION.#APPROPRIATE FITTINGS SHALL BE USED TO MATCH THE DIFFERENCE IN DIMENSION.#ENSURE PROPER ALIGNMENT, SUPPORT, AND SEALING OF ALL PIPECONNECTIONS.#INSTALL AND TERMINATE ACTUATOR WIRING, CONTROL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CABLES, AND COMMUNICATION INTERFACES. #INTEGRATE NEW VALVES WITH THE FIRE ALARM PANEL, SCADA, OR BMS AS APPLICABLE. #LABEL ALL VALVES, WIRING, AND COMPONENTS ACCORDING TO FACILITY STANDARDS. 3. TESTING & COMMISSIONING #PERFORM MECHANICAL INTEGRITY CHECKS (LEAK TESTS, TORQUE CHECKS, ALIGNMENT VERIFICATION). #CONDUCT ELECTRICAL AND FUNCTIONAL TESTS, INCLUDING: O#VALVE OPEN/CLOSE OPERATION #REMOTE CONTROL AND FEEDBACK SIGNAL #FAIL-SAFE OPERATION #ALARM AND SUPERVISORY SIGNAL VERIFICATION #DISCHARGE TEST TO BE CARRIED OUT AND DEWA OUTAGE SCHEDULE TO BE FOLLOWED. #ALL THE TESTING ACTIVITIES SHALL BE WITNESSED BY DEWA ENGINEER. #SUBMIT COMMISSIONING SAT REPORTS AND UPDATED AS-BUILT DOCUMENTATION. 4. DELIVERABLES #APPROVED METHOD STATEMENT AND RISK ASSESSMENT. #M</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ATERIAL SUBMITTALS AND MANUFACTURER DATASHEETS.#TEST AND COMMISSIONING REPORTS.#UPDATED AS-BUILT DRAWINGS.#02 YEAR WARRANTY CERTIFICATES FOR SUPPLIED MATERIALS AND INSTALLATION.#OPERATIONAL TRAINING FOR END USER MAINTENANCE STAFF5. CONTRACTOR RESPONSIBILITIES.#ENSURE COMPLIANCE WITH ALL SAFETY, REGULATORY, AND DEWA QHS REQUIREMENTS.#PROVIDE QUALIFIED TECHNICIANS AND CERTIFIED PERSONNEL FOR THE WORK.#MAINTAIN HOUSEKEEPING AND SAFE WORKING CONDITIONS THROUGHOUT THE PROJECT.#COORDINATE SHUTDOWNS AND OUTAGES WITH THE DEWA.#PROTECT EXISTING EQUIPMENT AND RESTORE ANY DISTURBED AREAS.6. EXCLUSIONS UNLESS SPECIFICALLY STATED OTHERWISE, THE FOLLOWING ARE EXCLUDED:#REPLACEMENT OF UNRELATED FIRE PROTECTION SYSTEM COMPONENTS.#MAJOR PIPE REROUTING BEYOND WHAT IS REQUIRED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FOR VALVE INSTALLATION.#CIVIL WORKS OR STRUCTURAL MODIFICATIONS NOT DIRECTLY RELATED TO VALVEREPLACEMENT.#SCADA MODIFICATIONS BEYOND BASIC INTEGRATION. N.7. PROJECT DURATION THE CONTRACTOR SHALL PROPOSE A DETAILED SCHEDULE INCLUDING:#MOBILIZATION#SHUTDOWN COORDINATION#VALVE REPLACEMENT ACTIVITIES#TESTING AND COMMISSIONING#DEMOBILIZATION THE SCHEDULE MUST MINIMIZE OPERATIONAL DISRUPTION AND BE APPROVED PRIOR TO EXECUTION. THE ENTIRE PROJECT SHALL BE COMPLETED WITHIN 06 MONTHS FROM DATE OF ISSUANCE OF PO, EXCLUSION ON OUTAGE RELATED DISCHARGE TEST WHICH SHALL FOLLOW DEWA OUTAGE SCHEDULE.FOR TECHNICAL QUERIES CONTACT MR.VISHNU VIJAY (MOB:0509463644) OR ANEEZHUSSAIN (MOB:055 9660850)						
2		ITEM-00001	DECOMMISSIONING AND REPLACEMENT OF	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EXISTING 07 NOS EUROSAFE,UK MAKE MOTORIZED DRY SECTIONAL VALVES IN SAADAST 132 KV SUBSTATION.SCO PE OF WORK INCLUDES REPLACEMENT OF EXISTING 07 NOS EUROSAFE ,UK MAKEMOTORIZED DRY SECTIONAL VALVES WITH DESIGN , SUPPLY, INSTALLATI ON ANDTESTING & COMMISSIONING OF NEW, APPROVED SINORIX ,DENMARK MAKECOMPATIBLE UNITS AND FULL INTEGRATION WITH THE SUBSTATION#S FIR EPROTECTION, MONITORING, AND CONTROL SYSTEMS.1. SCOPE OF WORK1.1 PRE#EXECUTION ACTIVITIES.#CONDUCT A SITE SURVEY TO VERIFY EXISTING VALVE SPECIFICATIONS, PIPESIZES, CONTROL WIRING, AND INSTALLATION CONSTRAINTS.#REVIEW EXISTING AS-BUILT DRAWINGS AND COORDINATE WIT H THE DEWA ENDUSER MAINTENANCE TEAM.#SUBMIT MATERIAL SUBMITTAL FOR DEWA APPROVAL.#SUBMIT HYDRAULIC CALCULATION AND RFC DRAWINGS FOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DEWA APPROVAL.#PREPARE METHOD STATEMENTS, RISK ASSESSMENTS, AND WORK PERMITS FORAPPROVAL.1.2 SUPPLY OF MATERIALS & EQUIPMENTTHE CONTRACTOR SHALL SUPPLY:#NEW MOTORIZED DRY SECTIONAL VALVES SINORIX ,DENMARK MAKE[SIZE:01 INCH,QTY -07 NOS].#ACTUATORS, CONTROL MODULES, AND ACCESSORIES COMPATIBLE WITH EXISTINGSYSTEM LOGIC.#REQUIRED FITTINGS, FLANGES, GASKETS, SUPPORTS, AND HARDWARE.#ELECTRICAL WIRING, CONDUITS, JUNCTION BOXES, AND TERMINATIONS ASNEEDED.#CONSUMABLES, TOOLS, AND LIFTING EQUIPMENT.ALL SUPPLIED MATERIALS MUST BE:#VDS APPROVED AND MATERIAL SUBMITTAL TO BE APPROVED BY DEWA .#COMPLIANT WITH PROJECT SPECIFICATIONS AND LOCAL FIRE PROTECTIONSTANDARDS1.3 . REMOVAL OF EXISTING MOTORIZED DRY SECTIONAL VALVES.#QTY TO BE DECOMMISSIONED SHALL BE 1.5 INCH -4 NOS AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			1 INCH -03 N OS.#DISCONNECT ELECTRICAL WIRING, CONTROL CABLES, AND COMMUNICATIONLINES.#REMOVE EXISTING EUROSAFE MAKE MOTORIZED DRY SECTIONAL VALVES WITHOUTDAMAGING ADJACENT PIPING OR EQUIPMENT.#HAND OVER THE REMOVED VALVES TO DEWA2. INSTALLATION OF NEW MOTORIZED DRY SECTIONAL VALVES.#INSTALLATION SHALL BE CARRIED OUT BY OEM APPROVED /CERTIFIED ENGINEEROR CONTRACTOR WITH EXPERIENCE IN SIMILAR HP WATER MIST SYSTEM IN DEWA.#INSTALL NEW MOTORIZED DRY SECTIONAL VALVES IN THE SAME OR APPROVEDMODIFIED CONFIGURATION.#APPROPRIATE FITTINGS SHALL BE USED TO MATCH THE DIFFERENCE IN DIMENSION.#ENSURE PROPER ALIGNMENT, SUPPORT, AND SEALING OF ALL PIPECONNECTIONS.#INSTALL AND TERMINATE ACTUATOR WIRING, CONTROL CABLES, AND COMMUNICATION						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INTERFACES.#INTEGRATE NEW VALVES WITH THE FIRE ALARM PANEL, SCADA, OR BMS ASAPPLICABLE.#LABEL ALL VALVES, WIRING, AND COMPONENTS ACCORDING TO FACILITYSTANDARDS.3. TESTING & COMMISSIONING.#PERFORM MECHANICAL INTEGRITY CHECKS (LEAK TESTS, TORQUE CHECKS,ALIGNMENT VERIFICATION).#CONDUCT ELECTRICAL AND FUNCTIONAL TESTS, INCLUDING:O#VALVE OPEN/CLOSE OPERATIONO#REMOTE CONTROL AND FEEDBACK SIGNALSO#FAIL-SAFE OPERATIONO#ALARM AND SUPERVISORY SIGNAL VERIFICATION.#DISCHARGE TEST TO BE CARRIED OUT AND DEWA OUTAGE SCHEDULE TO BE FOLLOWED.#ALL THE TESTING ACTIVITIES SHALL BE WITNESSED BY DEWA ENGINEER.#SUBMIT COMMISSIONING SAT REPORTS AND UPDATED AS-BUILT DOCUMENTATION.4. DELIVERABLES.#APPROVED METHOD STATEMENT AND RISK ASSESSMENT.#MATERIAL SUBMITTALS AND MANUFACTURER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DATASHEETS.#TEST AND COMMISSIONING REPORTS.#UPDATED AS-BUILT DRAWINGS.#02 YEAR WARRANTY CERTIFICATES FOR SUPPLIED MATERIALS ANDINSTALLATION.#OPERATIONAL TRAINING FOR END USER MAINTENANCE STAFF5. CONTRACTOR RESPONSIBILITIES.#ENSURE COMPLIANCE WITH ALL SAFETY, REGULATORY, AND DEWA QHSREQUIREMENTS.#PROVIDE QUALIFIED TECHNICIANS AND CERTIFIED PERSONNEL FOR THE WORK.#MAINTAIN HOUSEKEEPING AND SAFE WORKING CONDITIONS THROUGHOUT THEPROJECT.#COORDINATE SHUTDOWNS AND OUTAGES WITH THE DEWA.#PROTECT EXISTING EQUIPMENT AND RESTORE ANY DISTURBED AREAS.6. EXCLUSIONSUNLESS SPECIFICALLY STATED OTHERWISE, THE FOLLOWING ARE EXCLUDED:#REPLACEMENT OF UNRELATED FIRE PROTECTION SYSTEM COMPONENTS.#MAJOR PIPE REROUTING BEYOND WHAT IS REQUIRED FOR VALVE INSTALLAT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ION.#CIVIL WORKS OR STRUCTURAL MODIFICATIONS NOT DIRECTLY RELATED TO VALVEREPLACEMENT.#SCADA MODIFICATIONS BEYOND BASIC INTEGRATIO N.7. PROJECT DURATIONTHE CONTRACTOR SHALL PROPOSE A DETAILED SCHEDULE INCLUDING:#MOBILIZATION#SHUTDOWN COORDINATION#VALVE REPLACE MENT ACTIVITIES#TESTING AND COMMISSIONING#DEMOBILIZATIONTHE SCHEDULE MUST MINIMIZE OPERATIONAL DISRUPTION AND BE APPROVED PRIORTO EXECUTION. THE ENTIRE PROJECT SHALL BE COMPLETED WITHIN 06 MONTHSFROM DATE OF ISSUANCE OF PO, EXCLUSION ON OUTAGE RELATED DISCHARGE TESTWHICH SHALL FOLLOW DEWA OUTAGE SCHEDULE.FOR TECHNICAL QUERIES CONTACT MR.VISHNU VIJAY (MOB:0509463644) OR ANEEZHUSSAIN (MOB:055 9660850)						
3		ITEM-00001	DECOMMISSIONING AND REPLACEMENT OF EXISTING 07 NOS EUROSAFE,UK MAKE	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION :
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MOTORIZED DRY SECTIONAL VALVES IN SAADAST 132 KV SUBSTATION.SCOPE OF WORK INCLUDES REPLACEMENT OF EXISTING 07 NOS EUROSAFE ,UK MAKEMOTORIZED DRY SECTIONAL VALVES WITH DESIGN , SUPPLY, INSTALLATION AND TESTING & COMMISSIONING OF NEW, APPROVED SINORIX ,DENMARK MAKECOMPATIBLE UNITS AND FULL INTEGRATION WITH THE SUBSTATION'S FIRE PROTECTION, MONITORING, AND CONTROL SYSTEMS.1. SCOPE OF WORK1.1 PRE-EXECUTION ACTIVITIES.#CONDUCT A SITE SURVEY TO VERIFY EXISTING VALVE SPECIFICATIONS, PIPE SIZES, CONTROL WIRING, AND INSTALLATION CONSTRAINTS.#REVIEW EXISTING AS-BUILT DRAWINGS AND COORDINATE WITH THE DEWA END USER MAINTENANCE TEAM.#SUBMIT MATERIAL SUBMITTAL FOR DEWA APPROVAL.#SUBMIT HYDRAULIC CALCULATION AND RFC DRAWINGS FOR DEWA APPROVAL.#PREPARE METHOD</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION :
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STATEMENTS, RISK ASSESSMENTS, AND WORK PERMITS FOR APPROVAL. 1.2 SUPPLY OF MATERIALS & EQUIPMENT THE CONTRACTOR SHALL SUPPLY: #NEW MOTORIZED DRY SECTIONAL VALVES SINORIX, DENMARK MAKE [SIZE: 01 INCH, QTY -07 NOS]. #ACTUATORS, CONTROL MODULES, AND ACCESSORIES COMPATIBLE WITH EXISTING SYSTEM LOGIC. #REQUIRED FITTINGS, FLANGES, GASKETS, SUPPORTS, AND HARDWARE. #ELECTRICAL WIRING, CONDUITS, JUNCTION BOXES, AND TERMINATIONS AS NEEDED. #CONSUMABLES, TOOLS, AND LIFTING EQUIPMENT. ALL SUPPLIED MATERIALS MUST BE: #VDS APPROVED AND MATERIAL SUBMITTAL TO BE APPROVED BY DEWA. #COMPLIANT WITH PROJECT SPECIFICATIONS AND LOCAL FIRE PROTECTION STANDARDS. 1.3. REMOVAL OF EXISTING MOTORIZED DRY SECTIONAL VALVES #QTY TO BE DECOMMISSIONED SHALL BE 1.5 INCH -4 NOS AND 1 INCH -03 NOS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OS.#DISCONNECT ELECTRICAL WIRING, CONTROL CABLES, AND COMMUNICATIONLINES.#REMOVE EXISTING EUROSAFE MAKE MOTORIZED DRY SECTIONAL VALVES WITHOUTDAMAGING ADJACENT PIPING OR EQUIPMENT.#HAND OVER THE REMOVED VALVES TO DEWA2. INSTALLATION OF NEW MOTORIZED DRY SECTIONAL VALVES.#INSTALLATION SHALL BE CARRIED OUT BY OEM APPROVED /CERTIFIED ENGINEEROR CONTRACTOR WITH EXPERIENCE IN SIMILAR HP WATER MIST SYSTEM IN DEWA.#INSTALL NEW MOTORIZED DRY SECTIONAL VALVES IN THE SAME OR APPROVEDMODIFIED CONFIGURATION.#APPROPRIATE FITTINGS SHALL BE USED TO MATCH THE DIFFERENCE IN DIMENSION.#ENSURE PROPER ALIGNMENT, SUPPORT, AND SEALING OF ALL PIPECONNECTIONS.#INSTALL AND TERMINATE ACTUATOR WIRING, CONTROL CABLES, ANDCOMMUNICATION INTERFACES.#INTEGRATE NEW VALVES WITH THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FIRE ALARM PANEL, SCADA, OR BMS AS APPLICABLE. # LABEL ALL VALVES, WIRING, AND COMPONENTS ACCORDING TO FACILITY STANDARDS. 3. TESTING & COMMISSIONING # PERFORM MECHANICAL INTEGRITY CHECKS (LEAK TESTS, TORQUE CHECKS, ALIGNMENT VERIFICATION). # CONDUCT ELECTRICAL AND FUNCTIONAL TESTS, INCLUDING: O# VALVE OPEN/CLOSE OPERATION # REMOTE CONTROL AND FEEDBACK SIGNAL # FAIL-SAFE OPERATION # ALARM AND SUPERVISORY SIGNAL VERIFICATION. # DISCHARGE TEST TO BE CARRIED OUT AND DEWA OUTAGE SCHEDULE TO BE FOLLOWED. # ALL THE TESTING ACTIVITIES SHALL BE WITNESSED BY DEWA ENGINEER. # SUBMIT COMMISSIONING SAT REPORTS AND UPDATED AS-BUILT DOCUMENTATION. 4. DELIVERABLES # APPROVED METHOD STATEMENT AND RISK ASSESSMENT. # MATERIAL SUBMITTALS AND MANUFACTURER DATA SHEETS. # TEST AND COMMISSIONING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REPORTS.#UPDATED AS-BUILT DRAWINGS.#02 YEAR WARRANTY CERTIFIC ATES FOR SUPPLIED MATERIALS ANDINSTALLATION.#OPERATIONAL TRAINING FOR END USER MAINTENANCE STAFF5. CONTRACTOR RESPONSIBILITIES.#ENS URE COMPLIANCE WITH ALL SAFETY, REGULATORY, AND DEWA QHSEREQUIREMENTS.#PROVIDE QUALIFIED TECHNICIANS AND CERTIFIED PERSONNEL FOR TH E WORK.#MAINTAIN HOUSEKEEPING AND SAFE WORKING CONDITIONS THROUGHOUT THEPROJECT.#COORDINATE SHUTDOWNS AND OUTAGES WITH THE DEWA.# PROTECT EXISTING EQUIPMENT AND RESTORE ANY DISTURBED AREAS.6. EXCLUSIONSUNLESS SPECIFICALLY STATED OTHERWISE, THE FOLLOWING ARE EXCL UDED:#REPLACEMENT OF UNRELATED FIRE PROTECTION SYSTEM COMPONENTS.#MAJOR PIPE REROUTING BEYOND WHAT IS REQUIRED FOR VALVE INSTALLAT ION.#CIVIL WORKS OR STRUCTURAL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION :
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MODIFICATIONS NOT DIRECTLY RELATED TO VALVEREPLACEMENT.#SCADA MODIFICATIONS BEYOND BASIC INTEGRATIO</p> <p>N.7. PROJECT DURATIONTHE CONTRACTOR SHALL PROPOSE A DETAILED SCHEDULE INCLUDING:#MOBILIZATION#SHUTDOWN COORDINATION#VALVE REPLACE MENT ACTIVITIES#TESTING AND COMMISSIONING#DEMOBILIZATIONTHE SCHEDULE MUST MINIMIZE OPERATIONAL DISRUPTION AND BE APPROVED PRIORTO EXECUTION. THE ENTIRE PROJECT SHALL BE COMPLETED WITHIN 06 MONTHSFROM DATE OF ISSUANCE OF PO, EXCLUSION ON OUTAGE RELATED DISCHARGE TESTWHICH SHALL FOLLOW DEWA OUTAGE SCHEDULE.FOR TECHNICAL QUERIES CONTACT MR.VISHNU VIJAY (MOB:0509463644) OR ANEEZHUSSAIN (MOB:055 9660850)</p>						
4		ITEM-00001	DECOMMISSIONING AND REPLACEMENT OF EXISTING 07 NOS EUROSAFE,UK MAKE MOTORIZED DRY SECTIONAL VALVES IN SAADAST	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION :
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>132 KV SUBSTATION.SCOPE OF WORK INCLUDES REPLACEMENT OF EXISTING 07 NOS EUROSAFE ,UK MAKEMOTORIZED DRY SECTIONAL VALVES WITH DESIGN , SUPPLY, INSTALLATION AND TESTING & COMMISSIONING OF NEW, APPROVED SINORIX ,DENMARK MAKECOMPATIBLE UNITS AND FULL INTEGRATION WITH THE SUBSTATION'S FIRE PROTECTION, MONITORING, AND CONTROL SYSTEMS.1. SCOPE OF WORK1.1 PRE-EXECUTION ACTIVITIES.#CONDUCT A SITE SURVEY TO VERIFY EXISTING VALVE SPECIFICATIONS, PIPE SIZES, CONTROL WIRING, AND INSTALLATION CONSTRAINTS.#REVIEW EXISTING AS-BUILT DRAWINGS AND COORDINATE WITH THE DEWA END USER MAINTENANCE TEAM.#SUBMIT MATERIAL SUBMITTAL FOR DEWA APPROVAL.#SUBMIT HYDRAULIC CALCULATION AND RFC DRAWINGS FOR DEWA APPROVAL.#PREPARE METHOD STATEMENTS, RISK ASSESSMENTS, AND WORK</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION :
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PERMITS FOR APPROVAL.1.2 SUPPLY OF MATERIALS & EQUIPMENT THE CONTRACTOR SHALL SUPPLY: #NEW MOTORIZED DRY SECTIONAL VALVES SINORIX ,DENMARK MAKE [SIZE:01 INCH,QTY -07 NOS] #ACTUATORS, CONTROL MODULES, AND ACCESSORIES COMPATIBLE WITH EXISTING SYSTEM LOGIC. #REQUIRED FITTINGS, FLANGES, GASKETS, SUPPORTS, AND HARDWARE. #ELECTRICAL WIRING, CONDUITS, JUNCTION BOXES, AND TERMINATIONS AS NEEDED. #CONSUMABLES, TOOLS, AND LIFTING EQUIPMENT. ALL SUPPLIED MATERIALS MUST BE: #VDS APPROVED AND MATERIAL SUBMITTAL TO BE APPROVED BY DEWA. #COMPLIANT WITH PROJECT SPECIFICATIONS AND LOCAL FIRE PROTECTION STANDARDS</p> <p>1.3 . REMOVAL OF EXISTING MOTORIZED DRY SECTIONAL VALVES #QTY TO BE DECOMMISSIONED SHALL BE 1.5 INCH -4 NOS AND 1 INCH -03 NOS #DISCONNECT ELECTRICAL WIRING, CONTROL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectional Valves
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CABLES, AND COMMUNICATION LINES. #REMOVE EXISTING EUROSAFE MAKE MOTORIZED DRY SECTIONAL VALVES WITHOUT DAMAGING ADJACENT PIPING OR EQUIPMENT. #HAND OVER THE REMOVED VALVES TO DEWA2. INSTALLATION OF NEW MOTORIZED DRY SECTIONAL VALVES #INSTALLATION SHALL BE CARRIED OUT BY OEM APPROVED /CERTIFIED ENGINEER OR CONTRACTOR WITH EXPERIENCE IN SIMILAR HP WATER MIST SYSTEM IN DEWA. #INSTALL NEW MOTORIZED DRY SECTIONAL VALVES IN THE SAME OR APPROVED MODIFIED CONFIGURATION. #APPROPRIATE FITTINGS SHALL BE USED TO MATCH THE DIFFERENCE IN DIMENSION. #ENSURE PROPER ALIGNMENT, SUPPORT, AND SEALING OF ALL PIPE CONNECTIONS. #INSTALL AND TERMINATE ACTUATOR WIRING, CONTROL CABLES, AND COMMUNICATION INTERFACES. #INTEGRATE NEW VALVES WITH THE FIRE ALARM PANEL, SCADA, OR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BMS AS APPLICABLE. # LABEL ALL VALVES, WIRING, AND COMPONENTS ACCORDING TO FACILITY STANDARDS. 3. TESTING & COMMISSIONING # PERFORM MECHANICAL INTEGRITY CHECKS (LEAK TESTS, TORQUE CHECKS, ALIGNMENT VERIFICATION). # CONDUCT ELECTRICAL AND FUNCTIONAL TESTS, INCLUDING: O# VALVE OPEN/CLOSE OPERATION # REMOTE CONTROL AND FEEDBACK SIGNAL # FAIL-SAFE OPERATION # ALARM AND SUPERVISORY SIGNAL VERIFICATION. # DISCHARGE TEST TO BE CARRIED OUT AND DEWA OUTAGE SCHEDULE TO BE FOLLOWED. # ALL THE TESTING ACTIVITIES SHALL BE WITNESSED BY DEWA ENGINEER. # SUBMIT COMMISSIONING SAT REPORTS AND UPDATED AS-BUILT DOCUMENTATION. 4. DELIVERABLES # APPROVED METHOD STATEMENT AND RISK ASSESSMENT. # MATERIAL SUBMITTALS AND MANUFACTURER DATA SHEETS. # TEST AND COMMISSIONING REPORTS. # UPDATED AS-BUILT DRAWINGS. # 02</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>YEAR WARRANTY CERTIFICATES FOR SUPPLIED MATERIALS AND INSTALLATION. #OPERATIONAL TRAINING FOR END USER MAINTENANCE STAFF 5. CONTRACTOR RESPONSIBILITIES. #ENSURE COMPLIANCE WITH ALL SAFETY, REGULATORY, AND DEWA QHS REQUIREMENTS. #PROVIDE QUALIFIED TECHNICIANS AND CERTIFIED PERSONNEL FOR THE WORK. #MAINTAIN HOUSEKEEPING AND SAFE WORKING CONDITIONS THROUGHOUT THE PROJECT. #COORDINATE SHUTDOWNS AND OUTAGES WITH THE DEWA. #PROTECT EXISTING EQUIPMENT AND RESTORE ANY DISTURBED AREAS. 6. EXCLUSIONS UNLESS SPECIFICALLY STATED OTHERWISE, THE FOLLOWING ARE EXCLUDED: #REPLACEMENT OF UNRELATED FIRE PROTECTION SYSTEM COMPONENTS. #MAJOR PIPE REROUTING BEYOND WHAT IS REQUIRED FOR VALVE INSTALLATION. #CIVIL WORKS OR STRUCTURAL MODIFICATIONS NOT DIRECTLY RELATED TO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VALVEREPLACEMENT.#SCADA MODIFICATIONS BEYOND BASIC INTEGRATIO N.7. PROJECT DURATIONTHE CONTRACTOR SHALL PROPOSE A DETAILED SCHEDULE INCLUDING:#MOBILIZATION#SHUTDOWN COORDINATION#VALVE REPLACE MENT ACTIVITIES.#TESTING AND COMMISSIONING.#DEMOBILIZATIONTHE SCHEDULE MUST MINIMIZE OPERATIONAL DISRUPTION AND BE APPROVED PRIORTO EXECUTION. THE ENTIRE PROJECT SHALL BE COMPLETED WITHIN 06 MONTHSFROM DATE OF ISSUANCE OF PO, EXCLUSION ON OUTAGE RELATED DISCHARGE TESTWHICH SHALL FOLLOW DEWA OUTAGE SCHEDULE.FOR TECHNICAL QUERIES CONTACT MR.VISHNU VIJAY (MOB:0509463644) OR ANEEZHUSSAIN (MOB:055 9660850)</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Eurosafe Motorized Dry Sectional Valves

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332600864
DATE	: 10.04.2026
REQ No	: 1032601405
REQ TITLE	: Eurosafe Motorized Dry Sectio
DELIVERY LOCATION	
CLOSING DATE	: 16.04.2026
CLOSING TIME	: 10:00:00

For technical queries Contact Mr.Vishnu Vijay (Mob:0509463644) or Aneez Hussain (Mob:0559660850)

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectio
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:

- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- DEWA reserves the right to withhold data from third parties if deemed sensitive.
- Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement,

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Section
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600864
DATE : 10.04.2026
REQ No : 1032601405
REQ TITLE : Eurosafe Motorized Dry Sectio
DELIVERY LOCATION
CLOSING DATE : 16.04.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP