

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600994
DATE : 24.04.2026
REQ No : 1032601418
REQ TITLE : Fume Extractor System for Lab
DELIVERY LOCATION
CLOSING DATE : 30.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL SPECIFICATION FOR FUME EXTRACTOR SYSTEM FOR LABORATORY1. SCOPE THE CONTRACTOR SHALL DESIGN, SUPPLY, INSTALL, TEST, AND COMMISSION A FLEXIBLE ARM TYPE LOCAL FUME EXTRACTION SYSTEM#AT DEWA OIL LABORATORY AT WARSAN, DUBAI. THE SYSTEM SHALL BE ENGINEERED TO EFFECTIVELY CAPTURE AND EXTRACT HAZARDOUS FUMES AT SOURCE FROM LABORATORY TEST EQUIPMENT, ENSURING A SAFE AND COMPLIANT WORKING ENVIRONMENT. THE SCOPE INCLUDES ALL MECHANICAL, ELECTRICAL, AND CONTROL COMPONENTS REQUIRED FOR A FULLY OPERATIONAL SYSTEM. 2. DELIVERABLES 2.1#EXTRACTION ARMS:#QUANTITY: 6 NOS. OF FLEXIBLE EXTRACTION ARMS FOR LOCAL FUME EXTRACTION.#TYPE: LABORATORY EXTRACTION ARM - 3 JOINTS TYPE.#AIRFLOW: BETWEEN 120 AND 150 M³/H-UNITS FOR EACH ARM EACH ARM EQUIPPED WITH MOTORIZED DAMPERS UNIT & AIR FLOW ALARM</p>	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600994
DATE : 24.04.2026
REQ No : 1032601418
REQ TITLE : Fume Extractor System for Lab
DELIVERY LOCATION
CLOSING DATE : 30.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DEVICE(FOR OPTIMAL SUCTION EFFICIENCY) WITH AUDIBLE & VISUAL ALARM.#ROTATION: 360° ROTATION, HANDED POSITIONING, CAN SIMPLY PUSH, PULL,AND PIVOT THE ARM TO THE EXACT SPOT ACCORDING TO NEED.#ARM MATERIAL: STANDARD ALUMINUM WITH THREE JOINTS, ALL VERTICAL DROPSFROM CEILING/WALLS MUST BE OF CORROSION RESISTANCE SS.#ARM LENGTH (A + B + C): 1500MM.#ARM DIAMETER: 75MM.#SUCTION: DOME HOOD # PP : 4 NOS. FLAT SCREEN HOOD FOR TABLE ANDBENCH WORK: 2 NOS.TRANSPARENT, MOVABLE POSITION TO VERTICAL/ANGLED/HORIZONTAL AS REQUIRED;TEMP RANGE 0#C TO 80#C, STANDARD SIZE.#MOUNTING: CEILING/WALL WITH BRACKETS 6 NOS (4 NOS. CEILINGS MOUNTED,2 NOS. WALL MOUNTED).#(ALL SUCTION ARMS SHOULD BE EQUIPPED WITH MOTORIZED DAMPERS (LOCALLYCONTROLLED) TO ENSURE PROPER AIR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600994
DATE : 24.04.2026
REQ No : 1032601418
REQ TITLE : Fume Extractor System for Lab
DELIVERY LOCATION
CLOSING DATE : 30.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BALANCING WITHIN THE LABORATORY, SO IT SHOULD BE 6 NOS.)#THE EXHAUST AIR FROM ALL SUCTION POINTS SHOULD BE FILTERED (ACTIVE CARBON FILTER) TO MAINTAIN SAFE AND CLEAN DISCHARGE.#INSTALLATION: INSTALLATION OF FLEXIBLE ARMS TYPE LOCAL FUME EXTRACTORS INCLUDING ALL MECHANICAL AND ELECTRICAL WORK.2.2#BLOWER UNITS:#SUPPLY AND INSTALLATION OF 3 NOS. OF BLOWER/ EXTRACTION FAN UNITS, WHICH WILL BE MOUNTED ON THE EXTERNAL WALL OF THE LAB. 2 NOS. EXTRACTOR ON ARM CONNECTED TO ONE BLOWER / EXTRACTION FAN.#EXHAUST FAN, 220V, SINGLE PHASE,2.3 DUCTING SYSTEM:#SUPPLY AND INSTALLATION OF PVC DUCT. MATERIAL UPVC, BASED ON THE REQUIREMENTS (APPROX -60 METER LENGTH)2.4 ELECTRICAL WORKS:#SUPPLY AND INSTALLATION OF ELECTRICAL WIRING, BACK BOX, FACEPLATE, CONDUIT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600994
DATE : 24.04.2026
REQ No : 1032601418
REQ TITLE : Fume Extractor System for Lab
DELIVERY LOCATION
CLOSING DATE : 30.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REQUIRED FOR THE SUPPLIED EXTRACTOR SYSTEM.2.5 FILTRATION SYSTEM:·#PRE-FILTER (G4 OR EQUIVALENT) ·#ACTIVATED CARBON FILTER2.6 CONTROL & MONITORING:·#DIGITAL DISPLAY PANEL WITH:O#FAN STATUS MONITORINGO#REAL-TIME ENVIRONMENTAL DAT A.#INTEGRATED ALARM SYSTEM3. PERFORMANCE.#CONSISTENT AIRFLOW FOR EVERY EXTRACTOR ARM.#EFFECTIVELY REMOVES LABORATORY FUMES AND VAPO RS.#BLOWER FANS SHOULD NOT BE LOUDER THAN 60 DB WHEN RUNNING.#SYSTEM TO OPERATE CONTINUOUSLY UNDER LABORATORY CONDITIONS4. MATERIA LS.#ARMS AND DUCTS ARE CORROSION RESISTANT AND CHEMICAL RESISTANT.#DURABLE FANS CONSTRUCTION AND RESIST CORROSION.#EASY TO CLEAN SU RFACES.5. LAYOUT REFERENCE.#CONTRACTOR SHALL SUBMIT DETAILED LAYOUT DRAWINGS FOR APPROVAL PRIORTO INSTALLATION.#LAYOUT DRAWINGS SHA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600994
DATE : 24.04.2026
REQ No : 1032601418
REQ TITLE : Fume Extractor System for Lab
DELIVERY LOCATION
CLOSING DATE : 30.04.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LL BE BASED ON THE ACTUAL LABORATORY ARRANGEMENTS AND APPROVED EQUIPMENT POSITIONS. #ALL COMPONENTS (ARMS, DUCTS, BLOWERS, ELECTRICAL POINTS) MUST BE CLEARLY INDICATED. 6. SAFETY. #COMPLIANCE WITH LABORATORY VENTILATION STANDARDS. #EMERGENCY CONTROLS AVAILABLE. #SAFE DISCHARGE OF EXHAUST AIR. 7. DOCUMENTATION & TRAINING. #MANUALS FOR OPERATION AND MAINTENANCE/CLEANING PROVIDED. #TRAINING FOR LAB STAFF SHOULD BE INCLUDED AFTER INSTALLATION. 8. WARRANTY & MAINTENANCE. #SUPPORT AND MAINTENANCE SHALL BE PROVIDED FOR 2 YEARS AFTER DATE OF COMMISSIONING. #INCLUDES REPAIR/REPLACEMENT OF FAULTY COMPONENTS CONTACT PERSON: ROHAN DSOUZA CONTACT NUMBER: 04-3228301 / 050-4993 497 CONTACT PERSON: MUKESH NAIR CONTACT NUMBER: 050-3557271</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600994
DATE : 24.04.2026
REQ No : 1032601418
REQ TITLE : Fume Extractor System for Lab
DELIVERY LOCATION
CLOSING DATE : 30.04.2026
CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Fume Extractor System for Lab

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page6 of 9

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332600994
DATE	: 24.04.2026
REQ No	: 1032601418
REQ TITLE	: Fume Extractor System for Lab
DELIVERY LOCATION	
CLOSING DATE	: 30.04.2026
CLOSING TIME	: 10:00:00

the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:

- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- DEWA reserves the right to withhold data from third parties if deemed sensitive.
- Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement,

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600994
DATE : 24.04.2026
REQ No : 1032601418
REQ TITLE : Fume Extractor System for Lab
DELIVERY LOCATION
CLOSING DATE : 30.04.2026
CLOSING TIME : 10:00:00

the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332600994
DATE : 24.04.2026
REQ No : 1032601418
REQ TITLE : Fume Extractor System for Lab
DELIVERY LOCATION
CLOSING DATE : 30.04.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP