

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATIONS -OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#AUXILIARY BOILER#76 & 77 AIR & FLU E GAS EXPANSION JOINTREPLACEMENT WORK#PERIOD OF WORK:#8 CALENDAR DAYS DURING SHUTDOWNSCOPE OF WORK:#AUXILIARY BOILER#76 & 77#SL NO#D ESIGNATION#SERVICE#MEDIUM#EXPANSION JOINT DUCT DIMENSIONS#TYPE#QTY#1#E103E203#AUX BOILER 76 & 77 RAPH AIR OUTLET#AIR#8200 X 3200 X 3 00 MM#FABRIC#2#####.#TH E CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES, ERECTION PROCEDURES ETC., BEFORE HE SUBMITS HIS BID.#PARTY SHALL CONSIDER TWO MOBILIZATION TO COMPLETE THIS JOB DURINGAUXILIARY BOILER#76 & 77-UNIT SHUTDOWN (FROM MAY TO OCTOBER 2026).#THE</p>	2	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE AT ALL TIME. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#). #PREPARATORY WORK, IF ANY, SHALL BE CARRIED OUT BY THE PARTY BEFORE START OF WORK UPON INFORMATION FROM DEWA. #SUBMIT DETAILED SCHEDULE, RISK ASSESSMENT, CRANE REQUIREMENT, CRANE CAPACITY, LIFTING PLAN, AND METHOD STATEMENT OF THE WORK IN ADVANCE TO DEWA. #CHECK AND ENSURE THAT SITE CONDITIONS ARE SUITABLE FOR CARRYING OUT WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #UPON RECEIVING THE PO, CONTRACTOR SHALL INSPECT THE NEW EXPANSION JOINT DIMENSIONS WITH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EXISTING/ INSTALLED EXPANSION JOINT AND INFORMDEWA I F THERE ARE ANY CHANGES. MINOR MODIFICATIONS REQUIRED TOACCOMMODATE THE EXPANSION JOINT SHALL BE UNDER CONTRACTOR SCOPE.#A SAFETY M EETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE GIVEN TO THEEMPLOYEES .#PARTY SHOULD MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELYAFTER DEWA NOTIFICATION. THE PARTY SHALL BE READY TO START THE WORK WITHONE-DAY ADVANCE NOTIFICATION.#ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND THE TEST CERTIFICATETO BE PROVIDED TO DEWA. .#PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALIDSCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING.#EXISTING BELLOW REMOVAL WORK SHALL START ONLY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AFTER SUCCESSFUL VERIFICATION OF THE SUITABILITY OF NEW BELLOW. #REMOVE THE PROTECTION MESH BY REMOVING THE CORRUGATED ALUMINIUM CLADDING SHEET FROM SIDWAYS OF THE EXPANSION JOINT. KEEP IT IN A SAFE MANNER TO REUSE THE SAME. #MARK THE BACKUP BAR WITH IDENTIFICATION NUMBERS AND REMOVE THE BOLTS TO UNFASTEN THE EXPANSION JOINT. #CONTRACTOR SHALL NOT DAMAGE ANY NUTS AND BOLTS DURING REMOVAL. REMOVED NUTS AND BOLTS SHALL BE LUBRICATED AND SHALL KEEP IN SAFE CUSTODY TO RE-USE. #CLEAN AND THOROUGHLY INSPECT THE BELLOW DUCT, FLANGES AND BAFFLE FOR ANY DAMAGES. #MINOR DAMAGE FOUND IN THE BELLOW DUCT, FLANGES AND FLOW LINER SHALL BE RECTIFIED BY THE CONTRACTOR (CONSIDERING 1 FABRICATOR AND 1 WELDER FOR TWO DAYS/EACH EXPANSION JOINT). #FLOW LINER CORNERS SHOULD BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MODIFIED TO ACCOMMODATE THE NEWEXPANSION JOINT AND TO ALLOW THE FREE MOVEMENT OF EXPANSION JOINTWITHOUT HITTING THE FLOW LINER CORNE RS.#REMOVE THE OLD GASKET FROM THE FLANGES AND BETWEEN THE FLOW LINER ANDFLANGE GASKET. FLOW LINER SHALL BE PROPERLY SECURED WHILE REMOVING THEEXISTING EXPANSION JOINT AND DURING INSTALLATION OF GASKET.#INSTALL NEW GASKET BETWEEN FLANGE AND FLOW LINER.#AFTER JO INT INSPECTION WITH DEWA AND AFTER GETTING CLEARANCE FOR NEWBELLOW INSTALLATION, SHIFT THE NEW BELLOW TO THE WORK LOCATION.#INSTALL NEW EXPANSION JOINT OVER THE DUCT AS PER THE DRAWING AND BYMATCHING THE CORNERS.#INSTALLATION OF THE BACKUP BARS AND FASTENING WIT H BOLTS.#JOINING THE EXPANSION JOINT IN PRESENCE OF DEWA SUPERVISOR AS PER OEMJOINING PROCEDURE.#TORQUE TIGHTENING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF THE BOLTS AS PER OEM/DEWA RECOMMENDATION.#INSTALL THE MESH OVER THE EXPANSION JOINT AND SECURE IT BETWEEN THECLADDING SHEETS.#OLD BELLOW SHALL CU T INTO PIECES, PACK IN RED POLYETHENE BAGSPROPERLY AND SHALL SHIFT TO THE DESIGNATED AREA (GROUND FLOOR WHEREVEHICLE ACCESS IS AVAIL ABLE) AS INSTRUCTED BY DEWA.#EXTRA PRECAUTIONS SHALL BE TAKEN DURING EXECUTION OF THE WORK NOT TODAMAGE ANY NEARBY EQUIPMENT AND FLA NGE FACES.#REMOVAL OF ALL SCRAPS FROM WORKPLACE AND DISPOSAL AS PER DEWAENGINEER INSTRUCTION.#HOT TIGHTENING OF THE BOLTS AFTER UNI T COMES IN SERVICE.#JOB COMPLETION ACCEPTANCE IS SUBJECTED TO DEWA PERSONNEL INSPECTIONAND VERIFICATION.DEWA WILL ARRANGE TO PERFORM THERMOGRAPHY INSPECTION AFTER EXPANSIONJOINT REPLACEMENT AND IF THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TEMPERATURE FOUND MORE THAN THE DESIGNATEDVALUE, IT WILL NOT BE ACCEPTABLE.#HOUSEKEEP THE AREA ON REGULAR BASIS AS OTHER CONTRACTORS MUST WORK INTHE SAME AREA.#CONTRACTOR SHALL BE READY TO CARRY OUT THE WORK IN DAY AND NIGHTSHIFTS (IF REQUIRED)#DE-MOBILIZATION AND SITE CLEARANCE.#PREVIOUS SIMILAR EXPERIENCE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY.#WORK COMPLETION REPORT INCLUDING ITP, RIGGING TOOL CERTIFICATES, RISKASSESSMENT, WARRANTY CERTIFICATE AND PHOTOS SHALL SUBMIT.CONTRACTOR SCOPE OF SUPPLY#TOOLS, TACKLES AND EQUIPMENT TO CARRY OUT THE JOB.#MANPOWER.#WELDING CONSUMABLES.#ITP & ERECTION PLAN.#IRON FOR BELLOW JOINTDEWA SCOPE.#NEW EXPANSION JOINT (WITHOUT HOLES)#SCAFFOLDING.#EXPANSION JOINT BOLTS AND NUTS (ONLY TO REPLACE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE DAMAGED QTY).#CRANE (ONLY IF ACCESSIBLE).#FORKLIFT.#POWER (POWER CABLES TO BE EXTENDED BY CONTRACTOR FROM THE POWERSOURCE TO THE REQUIRED LOCATION).#WATERWARRANTY.#A MINIMUM WARRANTY OF 24 MONTHS FOR WORKMANSHIP SHALL BE PROVIDED BYTHE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROM DEWA..#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY T HE DEFECT WITHIN SHORTPERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.GENERAL TERMS & CONDITIONSTECHNICAL SAFETY DU RING THE WORK:##CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANTPREMISES.##CONTRACTOR SHALL GIVE DAILY TOOL BO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>X TALK, RISK ASSESSMENT ANDDYNAMIC RISK ASSESSMENT TO THEIR STAFFS.#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THEAVAI</p> <p>LABILITY OF#LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORESTART OF ANY WORK.#CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE ISO</p> <p>LATIONS BEFORESTARTING OF ANY OVERHAULING WORK.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THEWORK. CONDUCT SIT</p> <p>E SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.#CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS.#CONT</p> <p>RACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB.#THE CONTRACTOR MUST ENGAGE A QUALIFIED S</p> <p>AFETY OFFICER TO ENSUREOBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE ATALL TIME. THE SAFETY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISKASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPEINCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING ATHEIGHT.#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THEWORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES AND ITMUST BE PRODUCE TO DEWA FOREMAN/ ENGINEER UPON REQUEST.#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THEWORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANYDELAY.#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			GRINDING/DRILLING/HEATING ETC..#DURING WELDING / CUTTING, ENSURE THAT WELDING SPARK / CUTTINGMATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETSSHALL BE USED DURING WELDING AND CUTTING WORK.#NO ANY HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT ANDWITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATIO						
2		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS -OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#AUXILIARY BOILER#76 & 77 AIR & FLU E GAS EXPANSION JOINTREPLACEMENT WORK#PERIOD OF WORK:#8 CALENDAR DAYS DURING SHUTDOWNSCOPE OF WORK:#AUXILIARY BOILER#76 & 77#SL NO#D ESIGNATION#SERVICE#MEDIUM#EXPANSION JOINT DUCT DIMENSIONS#TYPE#QTY#####2#E105E205#AUX BOILER 76 & 77 BOILER AIR INLET#AIR#14178 X 1100 X 800	2	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MM#FABRIC#2#####.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES, ERECTION PROCEDURES ETC., BEFORE HE SUBMITS HIS BID.#PARTY SHALL CONSIDER TWO MOBILIZATION TO COMPLETE THIS JOB DURINGAUXILIARY BOILER#76 & 77-UNIT SHUTDOWN (FROM MAY TO OCTOBER 2026).#THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ENSUREOBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE ATALL TIME. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISKASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#PREPARATORY WORK, IF ANY, SHALL BE CARRIED OUT BY THE PARTY BEFORESTART OF WORK UPON INFORMATION FROM DEWA.#SUBMIT DETAILED SCHEDULE, RISK ASSE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SSMENT, CRANE REQUIREMENT, CRANECAPACITY, LIFTING PLAN, AND METHOD STATEMENT OF THE WORK IN ADVANCE TODewa.#CHECK AND ENSURE THAT SITE CONDITIONS ARE SUITABLE FOR CARRYING OUTWORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.#UPON RECEIVING THE PO, CONTRACTOR SHALL INSPECT THE NEW EXPANSIONJOINT DIMENSIONS WITH EXISTING/ INSTALLED EXPANSION JOINT AND INFORMDEWA IF THERE ARE ANY CHANGES. MINOR MODIFICATIONS REQUIRED TOACCOMMODATE THE EXPANSION JOINT SHALL BE UNDER CONTRACTOR SCOPE.#A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE GIVEN TO THEEMPLOYEE.ES.#PARTY SHOULD MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELYAFTER DEWA NOTIFICATION. THE PARTY SHALL BE READY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TO START THE WORK WITH ONE-DAY ADVANCE NOTIFICATION. #ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND THE TEST CERTIFICATE TO BE PROVIDED TO DEWA</p> <p>A. #PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALID SCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING. #EXISTING</p> <p>B. BELLOW REMOVAL WORK SHALL START ONLY AFTER SUCCESSFUL VERIFICATION OF THE SUITABILITY OF NEW BELLOW. #REMOVE THE PROTECTION MESH BY REMOVING THE CORRUGATED ALUMINIUM CLADDING SHEET FROM SIDWAYS OF THE EXPANSION JOINT. KEEP IT IN A SAFE MANNER TO REUSE THE SAME. #MARK</p> <p>C. MARK THE BACKUP BAR WITH IDENTIFICATION NUMBERS AND REMOVE THE BOLTS TO UNFASTEN THE EXPANSION JOINT. #CONTRACTOR SHALL NOT DAMAGE ANY NUTS AND BOLTS DURING REMOVAL. REMOVED NUTS AND BOLTS SHALL BE LUBRICATED AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL KEEP IN SAFECUSTODY TO RE-USE.#CLEAN AND THOROUGHLY INSPECT THE BELLOW DUCT, FLANGES AND BAFFLE FOR ANY DAMAGES.#MINOR DAMAGE FOUND IN THE BELLOW DUCT, FLANGES AND FLOW LINER SHALL BE RECTIFIED BY THE CONTRACTOR(CONSIDERING 1 FABRICATOR AND 1 WELDER FOR TWO DAYS/EACH EXPANSION JOINT).#FLOW LINER CORNERS SHOULD BE MODIFIED TO ACCOMMODATE THE NEW EXPANSION JOINT AND TO ALLOW THE FREE MOVEMENT OF EXPANSION JOINT WITHOUT HITTING THE FLOW LINER CORNERS.#REMOVE THE OLD GASKET FROM THE FLANGES AND BETWEEN THE FLOW LINER AND FLANGE GASKET. FLOW LINER SHALL BE PROPERLY SECURED WHILE REMOVING THE EXISTING EXPANSION JOINT AND DURING INSTALLATION OF GASKET.#INSTALL NEW GASKET BETWEEN FLANGE AND FLOW LINER.#AFTER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>JOINT INSPECTION WITH DEWA AND AFTER GETTING CLEARANCE FOR NEWBELLOW INSTALLATION, SHIFT THE NEW BELLOW TO THE WORK LOCATION.#INSTA LL NEW EXPANSION JOINT OVER THE DUCT AS PER THE DRAWING AND BYMATCHING THE CORNERS.#INSTALLATION OF THE BACKUP BARS AND FASTENING W ITH BOLTS.#JOINING THE EXPANSION JOINT IN PRESENCE OF DEWA SUPERVISOR AS PER OEMJOINING PROCEDURE.#TORQUE TIGHTENING OF THE BOLTS A S PER OEM/DEWA RECOMMENDATION.#INSTALL THE MESH OVER THE EXPANSION JOINT AND SECURE IT BETWEEN THECLADDING SHEETS.#OLD BELLOW SHALL CUT INTO PIECES, PACK IN RED POLYETHENE BAGSPROPERLY AND SHALL SHIFT TO THE DESIGNATED AREA (GROUND FLOOR WHEREVEHICLE ACCESS IS AVA ILABLE) AS INSTRUCTED BY DEWA.#EXTRA PRECAUTIONS SHALL BE TAKEN DURING EXECUTION OF THE WORK NOT TODAMAGE ANY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NEARBY EQUIPMENT AND F LANGE FACES.#REMOVAL OF ALL SCRAPS FROM WORKPLACE AND DISPOSAL AS PER DEWAENGINEER INSTRUCTION.#HOT TIGHTENING OF THE BOLTS AFTER U NIT COMES IN SERVICE.#JOB COMPLETION ACCEPTANCE IS SUBJECTED TO DEWA PERSONNEL INSPECTIONAND VERIFICATION.DEWA WILL ARRANGE TO PERFO RM THERMOGRAPHY INSPECTION AFTER EXPANSIONJOINT REPLACEMENT AND IF THE TEMPERATURE FOUND MORE THAN THE DESIGNATEDVALUE, IT WILL NOT BE ACCEPTABLE.#HOUSEKEEP THE AREA ON REGULAR BASIS AS OTHER CONTRACTORS MUST WORK INTHE SAME AREA.#CONTRACTOR SHALL BE READY TO CA RRY OUT THE WORK IN DAY AND NIGHTSHIFTS (IF REQUIRED).#DE-MOBILIZATION AND SITE CLEARANCE.#PREVIOUS SIMILAR EXPERIENCE PO # TO BE P ROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY.#WORK COMPLETION</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REPORT INCLUDING ITP, RIGGING TOOL CERTIFICATES, RISKASSESSMENT, WARRANTY CERTIFICATE AND PHOTOS SHALL SUBMIT.CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES AND EQUIPMENT TO CARRY OUT THE JOB.#MANPOWE R.#WELDING CONSUMABLES.#ITP & ERECTION PLAN.#IRON FOR BELLOW JOINTDEWA SCOPE.#NEW EXPANSION JOINT (WITHOUT HOLES).#SCAFFOLDING.#EXPA NSION JOINT BOLTS AND NUTS (ONLY TO REPLACE THE DAMAGED QTY).#CRANE (ONLY IF ACCESSIBLE).#FORKLIFT.#POWER (POWER CABLES TO BE EXTEND ED BY CONTRACTOR FROM THE POWERSOURCE TO THE REQUIRED LOCATION).#WATERWARRANTY.#A MINIMUM WARRANTY OF 24 MONTHS FOR WORKMANSHIP SHAL L BE PROVIDED BYTHE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROM DEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>D OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORT PERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER. GENERAL TERMS & CONDITIONS TECHNICAL SAFETY DURING THE WORK: ## CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANT PREMISES. ## CONTRACTOR SHALL GIVE DAILY TOOL BOX TALK, RISK ASSESSMENT AND DYNAMIC RISK ASSESSMENT TO THEIR STAFFS. ## CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THE AVAILABILITY OF # LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORE START OF ANY WORK. ## CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE SOLUTIONS BEFORE STARTING OF ANY OVERHAULING WORK. ## THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THEWORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.#CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS.#CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB.#THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ENSUREOBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE ATALL TIME. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISKASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPEINCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING ATHEIGHT.#ONLY TESTED AND CERTIFIED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RIGGING TOOLS SHALL BE USED DURING THEWORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES AND ITMUST BE PRODUCE TO DEWA FOREMAN/ ENGINEER UPON REQUEST.#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THEWORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANYDELAY.#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/ GRINDING/DRILLING/HEATING ETC.#DURING WELDING / CUTTING, ENSURE THAT WELDING SPARK / CUTTINGMATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETSSHALL BE USED DURING WELDING AND CUTTING WORK.#NO ANY HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT ANDWITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCAT</p>						
3		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>-OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#AUXILIARY BOILER#76 & 77 AIR & FLU E GAS EXPANSION JOINTREPLACEMENT WORK#PERIOD OF WORK:#8 CALENDAR DAYS DURING SHUTDOWNSCOPE OF WORK:#AUXILIARY BOILER#76 & 77#SL NO#D ESIGNATION#SERVICE#MEDIUM#EXPANSION JOINT DUCT DIMENSIONS#TYPE#QTY#####3#E158#A UX BOILER 76 FLUE GAS COMMON INLET TO GIF # FLUE GAS#2400 X2400 X 400MM#FABRIC#1#####.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES, ERECTION PROCEDURES ETC., BEFORE HE SUBMITS HIS BID.#PARTY SHALL C ONSIDER TWO MOBILIZATION TO COMPLETE THIS JOB DURINGAUXILIARY BOILER#76 & 77-UNIT SHUTDOWN (FROM MAY TO OCTOBER 2026).#THE CONTRACT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE AT ALL TIME. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#). #PREPARATORY WORK, IF ANY, SHALL BE CARRIED OUT BY THE PARTY BEFORE START OF WORK UPON INFORMATION FROM DEWA. #SUBMIT DETAILED SCHEDULE, RISK ASSESSMENT, CRANE REQUIREMENT, CRANE CAPACITY, LIFTING PLAN, AND METHOD STATEMENT OF THE WORK IN ADVANCE TO DEWA. #CHECK AND ENSURE THAT SITE CONDITIONS ARE SUITABLE FOR CARRYING OUT WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #UPON RECEIVING THE PO, CONTRACTOR SHALL INSPECT THE NEW EXPANSION JOINT DIMENSIONS WITH EXISTING/ INSTALLED EXPANSION JOINT AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INFO RMDEWA IF THERE ARE ANY CHANGES. MINOR MODIFICATIONS REQUIRED TOACCOMMODATE THE EXPANSION JOINT SHALL BE UNDER CONTRACTOR SCOPE.#A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE GIVEN TO THEE MPLOYEES.#PARTY SHOULD MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELYAFTER DEWA NOTIFICATION. THE PARTY SHALL BE READY TO S TART THE WORK WITHONE-DAY ADVANCE NOTIFICATION.#ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND THE TEST CERTIFICATETO BE PROVIDED TO DEWA.#PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALIDSCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING.#E XISTING BELLOW REMOVAL WORK SHALL START ONLY AFTER SUCCESSFULVERIFICATION OF THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SUITABILITY OF NEW BELLOW.#REMOVE THE PROTECTION MESH BY REMOVING THE CORRUGATED ALUMINIUMCLADDING SHEET FROM SIDEWAYS OF THE EXPANSION JOINT. KEEP IT IN A SAFEMANNER TO REUSE THE SAME.#MARK THE BACKUP BAR WITH IDENTIFICATION NUMBERS AND REMOVE THE BOLTS TO UNFASTEN THE EXPANSION JOINT.#CONTRACTOR SHALL NOT DAMAGE ANY NUTS AND BOLTS DURING REMOVAL.REMOVED NUTS AND BOLTS SHALL BE LUBRICATED AND SHALL KEEP IN SAFE CUSTODY TO RE-USE.#CLEAN AND THOROUGHLY INSPECT THE BELLOW DUCT, FLANGES AND BAFFLE FOR ANY DAMAGES.#MINOR DAMAGE FOUND IN THE BELLOW DUCT, FLANGES AND FLOW LINE SHALL BE RECTIFIED BY THE CONTRACTOR(CONSIDERING 1 FABRICATOR AND 1 WELDER FOR TWO DAYS/EACH EXPANSION JOINT).#FLOW LINER CORNERS SHOULD BE MODIFIED TO ACCOMMODATE THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NEW EXPANSION JOINT AND TO ALLOW THE FREE MOVEMENT OF EXPANSION JOINT WITHOUT HITTING THE FLOW LINER CORNERS. #REMOVE THE OLD GASKET FROM THE FLANGES AND BETWEEN THE FLOW LINER AND FLANGE GASKET. FLOW LINER SHALL BE PROPERLY SECURED WHILE REMOVING THE EXISTING EXPANSION JOINT AND DURING INSTALLATION OF GASKET. #INSTALL NEW GASKET BETWEEN FLANGE AND FLOW LINER. #AFTER JOINT INSPECTION WITH DEWA AND AFTER GETTING CLEARANCE FOR NEW BELLOW INSTALLATION, SHIFT THE NEW BELLOW TO THE WORK LOCATION. #INSTALL NEW EXPANSION JOINT OVER THE DUCT AS PER THE DRAWING AND BY MATCHING THE CORNERS. #INSTALLATION OF THE BACKUP BARS AND FASTENING WITH BOLTS. #JOINING THE EXPANSION JOINT IN PRESENCE OF DEWA SUPERVISOR AS PER OEM JOINING PROCEDURE. #TORQUE TIGHTENING OF THE B</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OLTS AS PER OEM/DEWA RECOMMENDATION.#INSTALL THE MESH OVER THE EXPANSION JOINT AND SECURE IT BETWEEN THECLADDING SHEETS.#OLD BELLOW SHALL CUT INTO PIECES, PACK IN RED POLYETHENE BAGSPROPERLY AND SHALL SHIFT TO THE DESIGNATED AREA (GROUND FLOOR WHEREVEHICLE ACCESS IS AVAILABLE) AS INSTRUCTED BY DEWA.#EXTRA PRECAUTIONS SHALL BE TAKEN DURING EXECUTION OF THE WORK NOT TODAMAGE ANY NEARBY EQUIPMENT AND FLANGE FACES.#REMOVAL OF ALL SCRAPS FROM WORKPLACE AND DISPOSAL AS PER DEWAENGINEER INSTRUCTION.#HOT TIGHTENING OF THE BOLTS A FTER UNIT COMES IN SERVICE.#JOB COMPLETION ACCEPTANCE IS SUBJECTED TO DEWA PERSONNEL INSPECTIONAND VERIFICATION.DEWA WILL ARRANGE TO PERFORM THERMOGRAPHY INSPECTION AFTER EXPANSIONJOINT REPLACEMENT AND IF THE TEMPERATURE FOUND MORE THAN THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DESIGNATEDVALUE, IT WIL L NOT BE ACCEPTABLE.#HOUSEKEEP THE AREA ON REGULAR BASIS AS OTHER CONTRACTORS MUST WORK INTHE SAME AREA.#CONTRACTOR SHALL BE READY TO CARRY OUT THE WORK IN DAY AND NIGHTSHIFTS (IF REQUIRED).#DE-MOBILIZATION AND SITE CLEARANCE.#PREVIOUS SIMILAR EXPERIENCE PO # T O BE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY.#WORK COMPLETION REPORT INCLUDING ITP, RIGGING TOOL CERTIFICATES, RISKASSESS MENT, WARRANTY CERTIFICATE AND PHOTOS SHALL SUBMIT.CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES AND EQUIPMENT TO CARRY OUT THE JOB.#M ANPOWER.#WELDING CONSUMABLES.#ITP & ERECTION PLAN.#IRON FOR BELLOW JOINTDEWA SCOPE.#NEW EXPANSION JOINT (WITHOUT HOLES).#SCAFFOLDING .#EXPANSION JOINT BOLTS AND NUTS (ONLY TO REPLACE THE DAMAGED QTY).#CRANE (ONLY IF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ACCESSIBLE).#FORKLIFT.#POWER (POWER CABLES TO BE EXTENDED BY CONTRACTOR FROM THE POWERSOURCE TO THE REQUIRED LOCATION).#WATERWARRANTY.#A MINIMUM WARRANTY OF 24 MONTHS FOR WORKMANSHIP SHALL BE PROVIDED BYTHE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROM DEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORTPERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.GENERAL TERMS & CONDITIONS TECHNICAL SAFETY DURING THE WORK:##CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANTPREMISES.##CONTRACTOR SHALL GIVE DAILY TOOL BOX TALK, RISK ASSESSMENT ANDDYNAMIC</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RISK ASSESSMENT TO THEIR STAFFS.#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THEAVAILABILITY OF#LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORESTART OF ANY WORK.#CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE ISOLATIONS BEFORESTARTING OF ANY OVERHAULING WORK.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THEWORK. CON DUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.#CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASI S.#CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB.#THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ENSUREOBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE ATALL TIME. THE SAFETY SUPERVISOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL KEEP ALL RECORDS (TBT, RISKASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPEINCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING ATHEIGHT.#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THEWORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES AND ITMUST BE PRODUCE TO DEWA FOREMAN/ ENGINEER UPON REQUEST.#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THEWORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANYDELAY.#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/ GRINDING/DRILLING/HEATING ETC.#DURING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WELDING / CUTTING, ENSURE THAT WELDING SPARK / CUTTING MATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETS SHALL BE USED DURING WELDING AND CUTTING WORK. #NO ANY HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT AND WITHOUT FIRE EXTINGUISHER NEAR THE WORK						
4		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS -OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#AUXILIARY BOILER#76 & 77 AIR & FLUE GAS EXPANSION JOINT REPLACEMENT WORK#PERIOD OF WORK:#8 CALENDAR DAYS DURING SHUTDOWN SCOPE OF WORK:#AUXILIARY BOILER#76 & 77#SL NO#DESCRIPTION#SERVICE#MEDIUM#EXPANSION JOINT DUCT DIMENSIONS#TYPE#QTY#4#E251#AUX BOILER 77 ECONOMISER OUTLET#FLUE GAS#13278 X 2500 X 800MM#FABRIC#1#.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES, ERECTION PROCEDURES ETC., BEFORE HE SUBMITS HIS BID. #PARTY SHALL CONSIDER TWO MOBILIZATION TO COMPLETE THIS JOB DURING AUXILIARY BOILER #76 & 77-UNIT SHUTDOWN (FROM MAY TO OCTOBER 2026). #THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE AT ALL TIME. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS). #PREPARATORY WORK, IF ANY, SHALL BE CARRIED OUT BY THE PARTY BEFORE START OF WORK UPON INFORMATION FROM DEWA. #SUBMIT DETAILED SCHEDULE, RISK ASSESSMENT, CRANE REQUIREMENT, CRANE CAPACITY, LIFTING PLAN, AND METHOD</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STATEMENT OF THE WORK IN ADVANCE TODEWA.#CHECK AND ENSURE THAT SITE CONDITIONS ARE SUITABLE FOR CARRYING OUTWORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.#UPON RECEIVING THE PO, CONTRACTOR SHA LL INSPECT THE NEW EXPANSIONJOINT DIMENSIONS WITH EXISTING/ INSTALLED EXPANSION JOINT AND INFORMDEWA IF THERE ARE ANY CHANGES. MINOR MODIFICATIONS REQUIRED TOACCOMMODATE THE EXPANSION JOINT SHALL BE UNDER CONTRACTOR SCOPE.#A SAFETY MEETING WILL BE HELD TO EVALUAT E THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE GIVEN TO THEEMPLOYEES.#PARTY SHOULD MOBILIZE THE L ABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELYAFTER DEWA NOTIFICATION. THE PARTY SHALL BE READY TO START THE WORK WITHONE-DAY ADVANCE NOTI</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FICATION.#ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND THE TEST CERTIFICATE TO BE PROVIDED TO DEWA.#PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALID SCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING.#EXISTING BELLOW REMOVAL WORK SHALL START ONLY AFTER SUCCESSFUL VERIFICATION OF THE SUITABILITY OF NEW BELLOW.#REMOVE THE PROTECTION MESH BY REMOVING THE CORRUGATED ALUMINIUM CLADDING SHEET FROM SIDEWAYS OF THE EXPANSION JOINT. KEEP IT IN A SAFE MANNER TO REUSE THE SAME.#MARK THE BACKUP BAR WITH IDENTIFICATION NUMBERS AND REMOVE THE BOLTS TO UNFASTEN THE EXPANSION JOINT.#CONTRACTOR SHALL NOT DAMAGE ANY NUTS AND BOLTS DURING REMOVAL. REMOVED NUTS AND BOLTS SHALL BE LUBRICATED AND SHALL KEEP IN SAFE CUSTODY TO RE-USE.#CLEAN AND THOROUGHLY INSPECT THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BELLOW DUCT, FLANGES AND BAFFLE FOR ANY DAMAGES. #MINOR DAMAGE FOUND IN THE BELLOW DUCT, FLANGES AND FLOW LINER SHALL BE RECTIFIED BY THE CONTRACTOR (CONSIDERING 1 FABRICATOR AND 1 WELDER FOR TWO DAYS/EACH EXPANSION JOINT). #FLOW LINER CORNERS SHOULD BE MODIFIED TO ACCOMMODATE THE NEW EXPANSION JOINT AND TO ALLOW THE FREE MOVEMENT OF EXPANSION JOINT WITHOUT HITTING THE FLOW LINER CORNERS. #REMOVE THE OLD GASKET FROM THE FLANGES AND BETWEEN THE FLOW LINER AND FLANGE GASKET. FLOW LINER SHALL BE PROPERLY SECURED WHILE REMOVING THE EXISTING EXPANSION JOINT AND DURING INSTALLATION OF GASKET. #INSTALL NEW GASKET BETWEEN FLANGE AND FLOW LINER. #AFTER JOINT INSPECTION WITH DEWA AND AFTER GETTING CLEARANCE FOR NEW BELLOW INSTALLATION, SHIFT THE NEW BELLOW TO THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORK LOCATION.#INSTALL NEW EXPANSION JOINT OVER THE DUCT AS PER THE DRAWING AND BYMATCHING THE CORNERS.#INSTALLATION OF THE BACKUP BARS AND FASTENING WITH BOLTS.#JOINING THE EXPANSION JOINT IN PRESENCE OF DEWA SUPERVISOR AS PER OEMJOINING PROCEDURE.#TORQUE TIGHTENING OF THE BOLTS AS PER OEM/DEWA RECOMMENDATION.#I NSTALL THE MESH OVER THE EXPANSION JOINT AND SECURE IT BETWEEN THECLADDING SHEETS.#OLD BELLOW SHALL CUT INTO PIECES, PACK IN RED POL YETHENE BAGSPROPERLY AND SHALL SHIFT TO THE DESIGNATED AREA (GROUND FLOOR WHEREVEHICLE ACCESS IS AVAILABLE) AS INSTRUCTED BY DEWA.#E XTRA PRECAUTIONS SHALL BE TAKEN DURING EXECUTION OF THE WORK NOT TODAMAGE ANY NEARBY EQUIPMENT AND FLANGE FACES.#REMOVAL OF ALL SCR APS FROM WORKPLACE AND DISPOSAL AS PER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEWAENGINEER INSTRUCTION.#HOT TIGHTENING OF THE BOLTS AFTER UNIT COMES IN SERVICE.#JOB COMPLETION ACCEPTANCE IS SUBJECTED TO DEWA PERSONNEL INSPECTIONAND VERIFICATION.DEWA WILL ARRANGE TO PERFORM THERMOGRAPHY INSPECTION AFTER EXPANSIONJOINT REPLACEMENT AND IF THE TEMPERATURE FOUND MORE THAN THE DESIGNATEDVALUE, IT WILL NOT BE ACCEPTABLE.#HOUSEKEEP THE AREA ON REGULAR BASIS AS OTHER CONTRACTORS MUST WORK INTHE SAME AREA.#CONTRACTOR SHALL BE READY TO CARRY OUT THE WORK IN DAY AND NIGH TSHIFTS (IF REQUIRED).#DE-MOBILIZATION AND SITE CLEARANCE.#PREVIOUS SIMILAR EXPERIENCE PO # TO BE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY.#WORK COMPLETION REPORT INCLUDING ITP, RIGGING TOOL CERTIFICATES, RISKASSESSMENT, WARRANTY CERTIFICATE AND PHOTOS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL SUBMIT.CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES AND EQUIPMENT TO CARRY OUT THE JOB.#MANPOWER.#WELDING CONSUMABLES.#ITP & ER ECTION PLAN.#IRON FOR BELLOW JOINTDEWA SCOPE.#NEW EXPANSION JOINT (WITHOUT HOLES).#SCAFFOLDING.#EXPANSION JOINT BOLTS AND NUTS (ONLY TO REPLACE THE DAMAGED QTY).#CRANE (ONLY IF ACCESSIBLE).#FORKLIFT.#POWER (POWER CABLES TO BE EXTENDED BY CONTRACTOR FROM THE POWERS OURCE TO THE REQUIRED LOCATION).#WATERWARRANTY.#A MINIMUM WARRANTY OF 24 MONTHS FOR WORKMANSHIP SHALL BE PROVIDED BYTHE CONTRACTOR S TARTING FROM THE DATE OF FINAL CLEARANCE FROM DEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHORTPERIOD W ITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.GENERAL TERMS & CONDITIONSTECHNICAL SAFETY DURING THE WORK:##CONTRACTOR ST AFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANTPREMISES.##CONTRACTOR SHALL GIVE DAILY TOOL BOX TALK, RISK ASSESSMENT ANDDYN AMIC RISK ASSESSMENT TO THEIR STAFFS.##CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THEAVAILABILITY OF#LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORESTART OF ANY WORK.##CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE ISOLATIONS BEFORESTARTING OF ANY OVERHAULING WORK.##THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THEWORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.##CONTRACTOR SHALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS.#CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB.#THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE AT ALL TIME. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPE INCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING AT HEIGHT.#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THE WORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES AND IT MUST BE PRODUCED TO DEWA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FOREMAN/ ENGINEER UPON REQUEST.#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THE WORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANY DELAY.#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKE WELDING/ CUTTING/ GRINDING/ DRILLING/ HEATING ETC.#DURING WELDING / CUTTING, ENSURE THAT WELDING SPARK / CUTTING MATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETS SHALL BE USED DURING WELDING AND CUTTING WORK.#NO ANY HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT AND WITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATION.#DAILY CONFINED SPACE WORK PERM						
5		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS - OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#AUXILIARY BOILER#76 & 77 AIR & FLU	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>E GAS EXPANSION JOINTREPLACEMENT WORK#PERIOD OF WORK:#8 CALENDAR DAYS DURING SHUTDOWNSCOPE OF WORK:#AUXILIARY BOILER#76 & 77#SL NO#D ESIGNATION#SERVICE#MEDIUM#EXPANSION JOINT DUCT DIMENSIONS#TYPE#QTY#5#E211#AUX BOILER 77 BURNER HOT AIR INLET#AIR#2574 X 2220 X 300 M M#FABRIC#1#.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPL EXITIES, SAFETYMEASURES, ERECTION PROCEDURES ETC., BEFORE HE SUBMITS HIS BID.#PARTY SHALL CONSIDER TWO MOBILIZATION TO COMPLETE THI S JOB DURINGAUXILIARY BOILER#76 & 77-UNIT SHUTDOWN (FROM MAY TO OCTOBER 2026).#THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICE R TO ENSUREOBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE ATALL TIME. THE SAFETY SUPERVISOR SHALL KEEP ALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RECOR DS (TBT, RISKASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#PREPARATORY WORK, IF ANY, SHALL BE CARRIED OUT BY THE PARTY BEFORE START OF WORK UPON INFORMATION FROM DEWA.#SUBMIT DETAILED SCHEDULE, RISK ASSESSMENT, CRANE REQUIREMENT, CRANE CA PACITY, LIFTING PLAN, AND METHOD STATEMENT OF THE WORK IN ADVANCE TO DEWA.#CHECK AND ENSURE THAT SITE CONDITIONS ARE SUITABLE FOR CA RRYING OUTWORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.#UPON RECEIVING THE PO, CONTRACTOR SHALL INSPECT THE NEW EXPANSION JOINT DIMENSIONS WITH EXISTING/ INSTALLED EXPANSION JOINT AND INFORM DEWA IF THERE ARE ANY CHANGES. MINOR M ODIFICATIONS REQUIRED TO ACCOMMODATE THE EXPANSION JOINT SHALL BE UNDER CONTRACTOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SCOPE.#A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE GIVEN TO THEEMPLOYEES.#PARTY SHOULD MOBILIZE THE LAB OR, EQUIPMENT, TOOLS, ETC. IMMEDIATELYAFTER DEWA NOTIFICATION. THE PARTY SHALL BE READY TO START THE WORK WITHONE-DAY ADVANCE NOTIFI CATION.#ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND THE TEST CERTIFICATETO BE PROVIDED TO DEWA.#PARTY SHALL VERIFY THAT SCAFFO LDS ARE SAFE TO WORK AND VALIDSCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING.#EXISTING BELLOW REMOVAL WORK SHALL START ONLY AFTER SUCCESSFULVERIFICATION OF THE SUITABILITY OF NEW BELLOW.#REMOVE THE PROTECTION MESH BY REMOVING THE CORRUGATED ALUMINIUM CLADDING SHEET FROM SIDEWAYS OF THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EXPANSION JOINT. KEEP IT IN A SAFEMANNER TO REUSE THE SAME. #MARK THE BACKUP BAR WITH IDENTIFICATION NUMBERS AND REMOVE THE BOLTSTO UNFASTEN THE EXPANSION JOINT. #CONTRACTOR SHALL NOT DAMAGE ANY NUTS AND BOLTS DURING REMOVAL. REMOVED NUTS AND BOLTS SHALL BE LUBRICATED AND SHALL KEEP IN SAFECUSTODY TO RE-USE. #CLEAN AND THOROUGHLY INSPECT THE BELLOW DUCT, FLANGES AND BAFFLE FORANY DAMAGES. #MINOR DAMAGE FOUND IN THE BELLOW DUCT, FLANGES AND FLOW LINER SHALLBE RECTIFIED BY THE CONTRACTOR(CONSIDERING 1 FABRICATOR AND 1 WELDER FOR TWO DAYS/EACH EXPANSIONJOINT). #FLOW LINER CORNERS SHOULD BE MODIFIED TO ACCOMMODATE THE NEW EXPANSION JOINT AND TO ALLOW THE FREE MOVEMENT OF EXPANSION JOINTWITHOUT HITTING THE FLOW LINER CORNERS. #REMOVE THE OLD GASKET FROM</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE FLANGES AND BETWEEN THE FLOW LINER AND FLANGE GASKET. FLOW LINER SHALL BE PROPERLY SECURED WHILE REMOVING THE EXISTING EXPANSION JOINT AND DURING INSTALLATION OF GASKET. #INSTALL NEW GASKET BETWEEN FLANGE AND FLOW LINER. #AFTER JOINT INSPECTION WITH DEWA AND AFTER GETTING CLEARANCE FOR NEW BELLOW INSTALLATION, SHIFT THE NEW BELLOW TO THE WORK LOCATION. #INSTALL NEW EXPANSION JOINT OVER THE DUCT AS PER THE DRAWING AND BY MATCHING THE CORNERS. #INSTALLATION OF THE BACKUP BARS AND FASTENING WITH BOLTS. #JOINING THE EXPANSION JOINT IN PRESENCE OF DEWA SUPERVISOR AS PER OEM JOINING PROCEDURE. #TORQUE TIGHTENING OF THE BOLTS AS PER OEM/DEWA RECOMMENDATION. #INSTALL ALL THE MESH OVER THE EXPANSION JOINT AND SECURE IT BETWEEN THE CLADDING SHEETS. #OLD BELLOW SHALL CUT INTO PIECES, PACK IN RED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>POLYE THESE BAGS PROPERLY AND SHALL SHIFT TO THE DESIGNATED AREA (GROUND FLOOR WHERE VEHICLE ACCESS IS AVAILABLE) AS INSTRUCTED BY DEWA.#EXT RA PRECAUTIONS SHALL BE TAKEN DURING EXECUTION OF THE WORK NOT TO DAMAGE ANY NEARBY EQUIPMENT AND FLANGE FACES.#REMOVAL OF ALL SCRAP S FROM WORKPLACE AND DISPOSAL AS PER DEWA ENGINEER INSTRUCTION.#HOT TIGHTENING OF THE BOLTS AFTER UNIT COMES IN SERVICE.#JOB COMPLETE ON ACCEPTANCE IS SUBJECT TO DEWA PERSONNEL INSPECTION AND VERIFICATION.DEWA WILL ARRANGE TO PERFORM THERMOGRAPHY INSPECTION AFTER EXPANSION JOINT REPLACEMENT AND IF THE TEMPERATURE FOUND MORE THAN THE DESIGNATED VALUE, IT WILL NOT BE ACCEPTABLE.#HOUSEKEEP THE AREA ON REGULAR BASIS AS OTHER CONTRACTORS MUST WORK IN THE SAME AREA.#CONTRACTOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL BE READY TO CARRY OUT THE WORK IN DAY AND NIGHTS HIPTS (IF REQUIRED).#DE-MOBILIZATION AND SITE CLEARANCE.#PREVIOUS SIMILAR EXPERIENCE PO # TO BE PROVIDED FROM DEWA OR ANYOTHER WELL -KNOWN COMPANY.#WORK COMPLETION REPORT INCLUDING ITP, RIGGING TOOL CERTIFICATES, RISKASSESSMENT, WARRANTY CERTIFICATE AND PHOTOS SH ALL SUBMIT.CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES AND EQUIPMENT TO CARRY OUT THE JOB.#MANPOWER.#WELDING CONSUMABLES.#ITP & EREC TION PLAN.#IRON FOR BELLOW JOINTDEWA SCOPE.#NEW EXPANSION JOINT (WITHOUT HOLES).#SCAFFOLDING.#EXPANSION JOINT BOLTS AND NUTS (ONLY T O REPLACE THE DAMAGED QTY).#CRANE (ONLY IF ACCESSIBLE).#FORKLIFT.#POWER (POWER CABLES TO BE EXTENDED BY CONTRACTOR FROM THE POWERSOU RCE TO THE REQUIRED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LOCATION).#WATERWARRANTY.#A MINIMUM WARRANTY OF 24 MONTHS FOR WORKMANSHIP SHALL BE PROVIDED BYTHE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROM DEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN TH IS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORTPERIOD WIT HOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.GENERAL TERMS & CONDITIONSTECHNICAL SAFETY DURING THE WORK:##CONTRACTOR STAF F MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANTPREMISES.##CONTRACTOR SHALL GIVE DAILY TOOL BOX TALK, RISK ASSESSMENT ANDDYNAM IC RISK ASSESSMENT TO THEIR STAFFS.#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THEAVAILABILITY OF#LINE CLEARANCE (LC)</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND PERMIT TO WORK (PTW) BEFORE START OF ANY WORK. #CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE ISOLATIONS BEFORE STARTING OF ANY OVERHAULING WORK. #THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS. #CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB. #THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE AT ALL TIME. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS). #CONTRACTOR STAFF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPE INCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC. #CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING AT HEIGHT. #ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THE WORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATE AND IT MUST BE PRODUCED TO DEWA FOREMAN/ ENGINEER UPON REQUEST. #CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THE WORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANY DELAY. #DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKE WELDING/ CUTTING/ GRINDING/ DRILLING/ HEATING ETC. #DURING WELDING / CUTTING, ENSURE THAT WELDING SPARK / CUTTING MATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ADEQUATE FIRE BLANKETSSHALL BE USED DURING WELDING AND CUTTING WORK.#NO ANY HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT ANDWITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATION.#DAILY CONFINED SPACE WORK PERMIT						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

AUX BOILER 76 AND 77 EXPANSION BELLOWS REPLACEMENT L-1-MMD-MBR.Note : Scope of work for any clarification please contact Mr. Nadeem Anjum 04 32260770551338462 nadeem.ahmad@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601080
DATE	: 05.05.2026
REQ No	: 1032602050
REQ TITLE	: 1-1032602050 AUX BOILER 76
DELIVERY LOCATION	
CLOSING DATE	: 11.05.2026
CLOSING TIME	: 10:00:00

4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.

5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.

7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:

a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.

b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.

c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.

d) DEWA reserves the right to withhold data from third parties if deemed sensitive.

e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.

f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.

g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601080
DATE : 05.05.2026
REQ No : 1032602050
REQ TITLE : 1-1032602050 AUX BOILER 76
DELIVERY LOCATION
CLOSING DATE : 11.05.2026
CLOSING TIME : 10:00:00

compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP