

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>INTEGRITY INSPECTIONS OF WHRB 53 AT #K# STATION, JEBEL ALI</p> <p>TECHNICAL SPECIFICATIONS</p> <p>1.#INTRODUCTION:1.1.#DUBAI ELECTRICITY &amp; WATER AUTHORITY (DEWA) IS THE OWNER AND OPERATOR OF 11,529 MW OF ELECTRICITY GENERATION AND 495 MGD OF DESALINATED WATER PRODUCTION PLANTS AND OWNS AND OPERATES ALL TRANSMISSION AND DISTRIBUTION NETWORKS IN THE EMIRATES OF DUBAI.1.2.#DEWA GENERATE POWER USING NATURAL GAS (NG) AND / OR FUEL OILS (DFO AND / OR MFO) DELIVERED TO EITHER BOILERS AND OR GAS TURBINES. P2 STATIONS COMPRISE OF 16 WHRB'S (HEAT RECOVERY STEAM GENERATORS/BOILERS), 16 GTS (GAS TURBINES), 7 AUX BOILERS AND 9 STEAM TURBINES.1.3.#GENERATION DIVISION OF DEWA OPERATES AND PROVIDES MAINTENANCE, REPAIR AND OVERHAUL SERVICES FOR POWER GENERATION AND WATER PRODUCTION PLANTS IN DEWA. SAFETY,</p>	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AVAILABILITY, RELIABILITY AND COST HAVE ALWAYS BEEN THE MOST IMPORTANT PRIORITIES IN DEWA.1.4.#IN DEWA, K STATION COMPRISES OF THREE WHRBS AND ALL ARE MANUFACTURED BY M/S ALSTOM POWER.1.5.#DEWA INTENDS TO APPOINT A COMPETENT BOILER OEM / BOILER INSPECTION AGENCY HAVING A LEGAL STANDING AS PER LOCAL REGULATIONS, THE CAPABILITY AND EXTENSIVE PAST EXPERIENCE IN BOILER INTEGRITY ASSESSMENT TO CARRY OUT INTEGRITY ASSESSMENT OF THREE WHRBS IN #K STATION# IN COMPLIANCE TO EIAC #RQ-1B-004, ASME BPVC SECTION I AND SECTION VIII.2.#PHYSICAL BOUNDARY:2.1.#PHYSICAL BOUNDARY OF THIS TENDER FOR THE FOLLOWING TWO WHRBS SHALL INCLUDE BUT NOT LIMITED TO THE PRESSURE/ NON-PRESSURE COMPONENTS SUCH AS BOILER PRESSURE PARTS, BOILER PROPER PIPING#, BOILER EXTERNAL PIPING#,</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ATTEMPERATORS / DESUPERHEATERS, ISOLATION VALVES PROVIDED AT THE END OF AGREED BOUNDARY LINE, BOILER AND PIPING HANGERS, SUPPORTS &amp; RESTRAINTS AND BOILER SUPPORT STRUCTURES. 2.2. #COMPONENTS / AREA COVERED IN DUBAI MUNICIPALITY REGULATION EIAC#RQ-1B-004, ASME BPVC SECTION I, SECTION VIII AND OR THE PRESSURE BOUNDARY AS PER THE ORIGINAL CODE OF CONSTRUCTION AS EXPLAINED IN #SCOPE OF WORK# AND ELSEWHERE IN THIS TENDER DOCUMENT SHALL ALSO BE A PART OF PHYSICAL BOUNDARY. STATION#K#UNIT#WHRB 53#NO OF UNITS#1#OEM#M/S ALSTOM POWER#COMMISSIONING#APRIL. 2003 WHRB 53#TYPE OF BOILER#NATURAL CIRCULATION, HORIZONTAL GAS FLOW DESIGN WITH SINGLE STAGE SUPPLEMENTARY FIRING#RATED OUTPUT#484 T/H HP STEAM #PRE/TEMP#70 BARA # 535°C HP STEAM #3.#SCOPE OF WORK: THE MAIN</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OBJECTIVE OF THIS TENDER IS TO ACCOMPLISH THE FOLLOWING:3.1.#THE SCOPE OF WORKS UNDER THIS CONTRACT IS TO CARRY OUT INTEGRITYASSESSMENT FOR THREE WHRBS IN K STATION.3.2.#INTEGRITY ASSESSMENT OF BOILERS IN COMPLIANCE TO LOCAL REGULATIONS IAC #RQ-1B-004, ASME BPVC SECTION - 1, SECTION VIII AND / OR THEPRESSURE BOUNDARY AS PER THE ORIGINAL CODE OF CONSTRUCTION WITHOUT ANYAMBIGUITY.3.3.#TO ENSURE THE INTEGRITY OF BOILER BY CERTIFYING THE PRESSUREBOUNDARIES OF BOILERS ARE FREE FROM FLAWS OR TO REPORT ACTUAL CONDITIONOF BOILER INCLUDING REMEDIAL ACTION REQUIRED TO CERTIFY THE BOILERS ASPER THE LOCAL REGULATIONS REQUIREMENT AND INTERNATIONAL STANDARD.3.4.#IF FLAWS ARE IDENTIFIED DURING INSPECTIONS, DETERMINE THE DAMAGEMECANISM AND CALCULATE HOW LONG THE COMPONENTS CONTAINING FLAWS CAN</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BEOPERATED SAFELY.3.5.#ESTABLISH BASELINE DATA FOR BOILER PRESSURE COMPONENTS.3.6.#DETERMINE FUTURE INSPECTION REGIME.3.7.#TO PROVIDE SERVICES OF EXPERIENCED AND CERTIFIED INSPECTORS.3.8.#ALL EQUIPMENT NECESSARY TO EXECUTE INSPECTI ON AND MEASUREMENTSHALL BE THE SCOPE OF CONTRACTOR.3.9.#THE CONTRACTOR SHALL COMPLY WITH LOCAL REGULATION EIAC #RQ-1B-004,API 570, A PI 571, API 579, BS 7910, EPRI, ASME &amp; CODES AND STANDARD ASAPPLICABLE.3.10.#INTEGRITY INSPECTION OF #PRESSURE EQUIPMENT / SYSTEMS# SHALLINCLUDE BUT NOT LIMITED TO THE FOLLOWING:3.10.1.#IDENTIFICATION OF ALL CRITICAL COMPONENTS AND AREAS3.10.2.#DETAILED VISUAL INS PECTION OF ALL STRUCTURAL, STACKS,FOUNDATIONS AND CRITICAL COMPONENTS.3.10.3.#CHECKING OF TOLERANCES FOR WEAR LIMIT FOR CRITICAL COM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PONENTS;3.10.4.#CHECKING FOR CORROSION3.10.5.#NON-DESTRUCTIVE EXAMINATION (NDE) FOR THE CRITICAL OR HIGHSTRESS AREAS OF THE PRESSURE EQUIPMENT SUCH AS CONNECTIONS, WELDMENTS,AND HEAT AFFECTED ZONES FOR EVIDENCE OF CRACKING OR OTHER DEFECT3.11.#CONTRACTOR SHALL CARRY OUT INTEGRITY ASSESSMENT, RLA &amp; FFSACCORDING TO THE FOLLOWINGS3.11.1.#DESKTOP STUDY:3.11.1.1.#IDENTIFICATION OF ALL THE REQUIRED COMPONENTS AND AREAS INTHE BOILER FOR INTEGRITY TEST.3.11.1.2.#COLLECTION OF ORIGINAL DATA REGARDING ORIGINAL DESIGN ANDCONSTRUCTION DOCUMENTS, BOILER ORIGINAL NAMEPLATE DETAIL, THE MATERIALOF CONSTRUCTION, SERVICE HISTORY AND THE PROCESS CONDITIONS.3.11.1.3.#DEVELOP INTEGRITY MANAGEMENT PLAN (IMP)3.11.1.4.#PREPARE INSPECTION TEST</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROTOCOL (ITP) TO IMPLEMENT IMP AND TO COLLECT NDE DATA ON PRESENT CONDITION OF THE ASSETS UNDER SCOPE.3.11.1.5.#ITP SHALL HAVE NECESSARY INSPECTION-RELATED INFORMATION DETAILING FOR ALL THE COMPONENTS/STRUCTURES LIKE COMPONENT NAME / AREA, DIMENSIONS / SIZE, MATERIAL OF CONSTRUCTION, OPERATING PARAMETER DAMAGE MECHANISM LOOKING FOR, INSPECTION TECHNIQUE TO BE USED WITHOUT ANY EXCEPTION AND ANY SPECIAL REQUIREMENT.3.11.1.6.#A MARKUP DRAWING SHALL BE PREPARED SHOWING ALL THE CML LOCATIONS. A UNIQUE IDENTIFICATION HAS TO BE DEVELOPED FOR CMLS. COPY OF EXISTING ISOMETRIC DRAWINGS SHALL BE USED TO MARK CML POINTS. IF ISOMETRIC DRAWINGS ARE NOT AVAILABLE, A LEGIBLE SKETCH SHALL BE PREPARED FOR CML MARKING BY THE CONTRACTOR.3.11.1.7.#DETERMINE CRITICAL COMPONENTS IN THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>UNIT FOR DESTRUCTIVE &amp;NON-DESTRUCTIVE TESTS3.11.1.8.#ESTABLISH INSPECTION PLAN AND INTEGRATE THE ACTIVITIES ALONGWITH DEWA ANNUAL OVERHAUL INSPECTION PLAN OF THE BOILER.3.11.1.9.#VERIFICATION OF MANUFACTURER#S NAMEPLATE.3.11.1.10.#REVIEWING CONSTRUCTION CERTIFICATE, DRAWINGS ANDCONSTRUCTION INSPECTION RECORDS.3.11.1.11.#REVIEWING REPAIRS AND/OR ALTERATIONS CARRIED OUT SO FAR ANDREVIEW OF THOSE RECORDS INCLUDING PAST PERIODIC INSPECTION RECORDS.3.11.1.12.#EXTERNAL VISUAL EXAMINATION (HOT SURVEY) OF THE SPECIFIEDCOMPONENTS, COLLECTING DATA SUCH AS NAMEPLATE INFORMATION, CHECKINGNOISE LEVEL/ VIBRATIONS AND DOCUMENT THE PRESENT CONDITION OF THEEQUIPMENT AS OBSERVED. THIS WILL INCLUDE, BUT NOT LIMITED TO NOTING ALLHANGER POSITIONS AND CONDITION</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>S ON STEAM, CONDENSATE, FEED WATER PIPING,ETC.3.11.1.13.#INSPECTION OF HANGERS AND SUPPORTS HOT CONDITIONS.3.11.1.14.#REVIEWING CALIBRATION RECORDS OF GAUGES AND EQUIPMENT USEDIN THE BOILER3.11.1.15.#VISUAL EXAMINATION OF CONCRETE FOUNDATIONS AND BOTTOM FLOORFOR C RACKS AND SETTLEMENT.3.11.1.16.#VISUAL SURVEY FOR VIBRATION OF THE STRUCTURES.3.11.1.17.#REVIEWING BOILER FEED WATER, STEAM AND CONDENSATE TREATMENTRECORDS/ ANALYSIS.3.11.1.18.#INSPECTION OF WATER LEVEL GAUGES, CLEANLINESS OF GLASS,BLOW-DOWN ARRANGEMENTS.3.11.1.19 .#VALVES VISUAL INSPECTION FOR ANY LEAKAGES/ PASSING.3.11.1.20.#SUBMIT FAILURE MECHANISM &amp; TEST METHODOLOGIES FOR DEWAAPPROVAL PRIOR TO IMPLEMENT ACTION OF THE INSPECTION/TEST PLAN FOR ALLTHE EQUIPMENT#S.3.11.1.21.#IMPLEMENT INSPECTION</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>METHODOLOGIES.3.11.1.22.#CON  TRACTOR SHALL FORECAST EQUIPMENT FAILURE  OR BREAK DOWN ATPRESENT CONDITION OR  EXPECTED DUE TO AGEING OR  DETERIORATION.3.11.1.23.#REV  IEW &amp; EVALUATION OF EMISSIONS LIKE NOX &amp; CO  ETC. ANDRECOMMENDATION IN CASE OF ANY  ABNORMAL CONDITIONS (IF  ANY).3.11.1.24.#CONTRACTOR  SHALL CLEARLY IDENTIFY ROOT CAUSE OF  DEFECT IFOTHER THAN DETERIORATION OR  AGEING (AS REQUIRED) AND ENSURE ALL  THENEEEDED DATA ARE OB  TAINED DURING OUTAGE.3.11.2.#ON SITE NDT  DATA COLLECTION:3.11.2.1.#ALL THE PLANNED  INSPECTIONS SHALL BE DONE WITHIN  THESCHEDULED PER  IOD OF OUTAGE (TENTATIVELY 12 DAYS FOR EACH  BOILERINCLUDING SHUTDOWN, COOLING AND  BOILER DRAINING.)3.11.2.2.#CONDITION  MONITORING LO  CATION (CML) MARKING SHALL BE DONE ONTHE  PLACE WHERE NDE DATA WILL BE COLLECTED</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND ALL THE CML SHALL HAVE UNIQUE IDENTIFICATION NUMBER.3.11.2.3.#WHEREVER PRACTICALLY POSSIBLE, THE MARKING AT SITE SHALL BE PERMANENT TYPE FOR FUTURE REFERENCE.3.11.2.4.#ALL METALLOGRAPHIC TESTS, DESTRUCTIVE & NONDESTRUCTIVE TESTS(MAGNETIC PARTICLE EXAMINATION, ULTRASONIC EXAMINATION, RADIOGRAPHIC EXAMINATION (IF REQUIRED),						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### **SPECIAL NOTES / INSTRUCTIONS:**

Integrity inspection of WHRB 53 at K Station, Jabel Ali ( 2026 -2027) Please contact Mr. Kaliyamoorathi; 052 -9126916 for any further information.

### **STANDARD TERMS & CONDITIONS**

1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2332601155
<b>DATE</b>	: 11.05.2026
<b>REQ No</b>	: 1032602059
<b>REQ TITLE</b>	: 1032602059 Integrity inspection
<b>DELIVERY LOCATION</b>	
<b>CLOSING DATE</b>	: 15.05.2026
<b>CLOSING TIME</b>	: 10:00:00

- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.
- 8) Data Privacy, Security and Sharing:
  - a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
  - b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
  - c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
  - d) DEWA reserves the right to withhold data from third parties if deemed sensitive.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

<b>RFQ NUMBER</b>	: 2332601155
<b>DATE</b>	: 11.05.2026
<b>REQ No</b>	: 1032602059
<b>REQ TITLE</b>	: 1032602059 Integrity inspection
<b>DELIVERY LOCATION</b>	
<b>CLOSING DATE</b>	: 15.05.2026
<b>CLOSING TIME</b>	: 10:00:00

- e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.
- 9) Liquidated Damages for PO total value in excess of AED 50,000:  
If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.
- 10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.
- 11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.
- 12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.
- 13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.
- 14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601155  
**DATE** : 11.05.2026  
**REQ No** : 1032602059  
**REQ TITLE** : 1032602059 Integrity inspection  
**DELIVERY LOCATION**  
**CLOSING DATE** : 15.05.2026  
**CLOSING TIME** : 10:00:00

extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**