

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF WORK AT K STN, JEBEL ALI POWERSTATION.1.#TITLE: WHRB 51&52 TUBES /HEADERS INSPECTION CAP CUTTING , WELDINGAND BORESCOPE INSPECTION.2.#QUANTITY: INSPECTION CAP WILL BE CUT ON HEADERS BY DEWA FOR ACCESS.MAXIMUM NUMBER OF ACCESSIBLE TUBES AND HEADERS SECTION SHALL BEINSPECTED BY BORESCOPE. REFER BELOW LOCATION DETAILSS.NO#UNIT#LOCATION#MATERIAL.#QTY#1#WHRB 5 1#HPLTSH 1#A 335 P22#3#2#WHRB 51#HPLTSH 2#A 335 P22#6#3#WHRB 51#HPHTSH #A 335 P91#6#4#WHRB 51#HP EVAPORATOR#A 106 GR.B#12#5#WHRB 51# HP ECONOMIZER 1#A 106 GR.B#18#6#WHRB 51#HP ECONOMIZER 2#A 106 GR.B#18#7#WHRB 52#HPLTSH 1#A 335 P22#3#8#WHRB 52#HPLTSH 2#A 335 P22#6# 9#WHRB 52#HPHTSH #A 335 P91#6#10#WHRB 52#HP EVAPORATOR#A 106 GR.B#12#11#WHRB</p>	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			52#HP ECONOMIZER 1#A 106 GR.B#18#12#WHRB 52#HP ECONOMIZ ER 2#A 106 GR.B#18#3.#DURATION: 05 DAY4.#SCOPE OF WORK:4.1.#MOBILIZE TEAM/EQUIPMENT WITHIN 01 DAYS OF ADVANCE NOTICE.4.2.#SUBMIT FOL LOWING DOCUMENTS TO OBTAIN PTW,4.2.1.#METHOD STATEMENT4.2.2.#RISK ASSESSMENT OF THE WORK4.2.3.#TOOLBOX TALK REPORT.4.3.#OBTAIN PTW ((PERMIT TO WORK), LC (LINE CLEARANCE) & CONFINE SPACEENTRY PERMIT FROM DEWA.4.4.#CONDUCT SITE SURVEY AND SAFETY INSPECTION, TO ASSESS THE WORKINGENVIRONMENT.4.5.#BEFORE START OF WORK ENSURE AREA IS CORRECTLY SECURED AND SAFE TOWORK ON IN ALL RESPECTS, REPORT IF ANY ISSUE / OBSERVATION TO DEWAENGINEER.4.6.#IDENTIFY AND CUT INSPECTION NOZZLES CAPS ON ALL RELEVANT HEADERSTO ALLOW ACCESS FOR INTERN AL INSPECTION OF TUBES AND HEADERS. SAME						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENDCAP SHALL BE REUSED.4.7.#OPEN DOWNCOMER FLANGES TO ALLOW ACCESS FOR INTERNAL INSPECTION OFHEADERS.4.8.#OPEN ATTEMPERATOR FOR HP DESUPERHEATER4.9.#IF THE WORKING ENVIRONMENT IS SAFE, PROCEED WITH THE BORESCOPEINSPECTION.4 .10.#ASSESS THE INTERNAL CONDITIONS OF TUBES & HEADERS. ARTICULATINGBOREScope SHALL BE USED TO IDENTIFY ANY SCABBING, PITTING, SCALE BUILDUP, CORROSION, LAYER FORMATION, OVERHEATING AND ANY OTHER SIGNIFICANTFINDINGS. MAXIMUM NUMBER OF ACCESSIBLE TUBES TO BE INSPECTED ON EACHHEADER CHECK DE-SUPER HEATER NOZZLE CONDITION BY BORESCOPE. REINSTATEALL HEADER INSPECTION NOZZLES CAPS WHICH HAVE BEEN REMOVED. ALL WELDINGTO BE CARRIED OUT AS PER CLASS APPROVED WELDING PROCEDURES4.11.#IN CASE OF ANY SIGNIFICANT INSPECTION FINDING, S</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AME SHALL BE BROUGHT TO THE NOTICE OF DEWA.4.12.#UPON WORK COMPLETION, DETAILED INSPECTION REPORT SHALL SUBMIT.REPORT SHALL INCLUDE HEADER/TUBE IDENTIFICATION DETAILS, PHOTOS, VIDEOS,FINDINGS, RECOMMENDATIONS AND ALL SUPPORTING DOCUMENTS.4.13.#DIGITAL COPIES OF THE PHOTOS, VIDEOS, INSPECTION FINDINGS ANDREPORT SHALL SUBMIT THROUGH CLOUD/CD4.14.#DEWA SCOPE IS ONLY SCAFFOLDING IF REQUIRED5.#BORESCOPE EQUIPMENT DETAILS:5.1.#THE BORESCOPE SHOULD BE EQUIPPED WITH ARTICULATION AND HIGH-ENDINDUSTRIAL VIDEO SYSTEMS WITH PROPER MONITORS. THE BORESCOPE SHOULD HAVE THE FACILITY / SYSTEMS TO GET EXCELLENT QUALITY IMAGE, DETAILED INFORMATION ABOUT A NON-CONFORMITY LIKE INDICATIONS, DISCOLORATIONS,PITTING, SCABBING, SCALE BUILD UP AND OXYGEN CORROSION ETC. THE PROBESHOULD BE WATER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROOF, FLEXIBLE W HIGH SHOULD TURN UP TO 360°, SUITABLE TO ACCESS TO HEADERS & TUBES, LENGTH OF CABLE SHOULD BE 30 M, RESULTS RECORDABLE, DUAL OR EXTRA MONITOR, AND HIGH QUALITY OF RECORDING.6.#GENERAL TERMS & CONDITIONS:6.1.#THE CONTRACTOR SHALL VISIT THE SITE AND BE FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, MATERIAL REQUIREMENT, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE SUBMITTING THE BID.6.2 .#THE CONTRACTOR SHALL HAVE THE PREVIOUS EXPERIENCE FOR HRSG TUBES & HEADERS BORESCOPE INSPECTION IN DEWA OR WITH WELL-KNOWN COMPANY IN UAE.6.3.#THE CONTRACTOR SHALL SUBMIT THE SCHEDULE OF WORK AND THE PERIOD FOR WORK SO THAT THE WORK SHALL COME WELL WITHIN THE ALLO TTED OUTAGE PERIOD. THE SCHEDULE SHALL BE APPROVED BY DEWA BEFORE COMMENCEMENT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OFWORK6.4.#THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS AND THECONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TODESIGNATED PLACES AS PER DEWA ENVIRONMENTAL POLICY OF HAZARDOUS WASTEDISPOSAL.6.5.#ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATION SHALLBE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THECONTRACTOR#S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILEWORKING IN A HAZARDOUS AREA. 6.6.#THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PERQUALITY / SCHEDULE REQUIREMENT. CONTRACTOR#S SUPERVISOR SHALL BEAVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK.6.7.#THE CONTRACTOR SHOULD APPLY FOR THE PERMIT TO WORK WELL IN ADVANCEAND THIS REQUEST SHALL BE FOLLOWED WITH METHOD STATEMENT,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RISKASSESSMENT AS ATTACHMENTS6.8.#ENTRY PERMITS FOR THE STAFF/WORKERS SHOULD BE APPLIED WITH PASSPORT COPIES HAVING VALID VISA. PERSONS, WHOSE NAMES ARE NOT AVAILABLE IN THE LIST, WILL NOT BE ALLOWED TO ENTER THE POWERHOUSE6</p> <p>.9.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.6.10.#ENTRY PERMITS FOR THE VEHICLE SHOULD BE APPLIED WITH COPIES OF VEHICLE REGISTRATION.6.11.#ALL THE PERSONS SHOULD WEAR THE UNIFORM, SAFETY SHOES AND HELMET WHILE AT WORK</p> <p>K.6.12.#TOOLBOX TALKS AND RISK ASSESSMENTS SHOULD BE GIVEN TO THE WORKMEN BY THEIR SUPERVISOR BEFORE START OF WORK.6.13.#DEWA ENGINEER-IN-CHARGE SHALL BE UPDATED THE WORK PROGRESS ON A REGULAR BASIS.6.14.#CONTRACTOR SHALL COMPLY THE SA 8000 STANDARD AS PER DEWA TERM</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SAND CONDITIONS.6.15.#SAFETY OFFICER BY THE CONTRACTOR IS REQUIRED AT SITE.6.16.#EATING, RESTING AND SLEEPING IS NOT ALLOWED IN THE PLANT SITE.6.17.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BYDEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWAENGINEER ON DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THECLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.						
2		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF WORK AT K STN, JEBEL ALI POWERSTATION.1.#TITLE: WHRB 51&52 TUBES /HEADERS INSPECTION CAP CUTTING , WELDINGAND BORESCOPE INSPECTION.2.#QUANTITY: INSPECTION CAP WILL BE CUT ON HEADERS BY DEWA FOR ACCESS.MAXIMUM NUMBER OF ACCESSIBLE TUBES AND HEADERS SECTION SHALL BEINSPECTED BY BORESCOPE. REFER BELOW	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			LOCATION DETAILSS.NO#UNIT#LOCATION#MATERIAL.#QTY#1# WHRB 5 1#HPLTSH 1#A 335 P22#3#2#WHRB 51#HPLTSH 2#A 335 P22#6#3#WHRB 51#HPHTSH #A 335 P91#6#4#WHRB 51#HP EVAPORATOR#A 106 GR.B#12#5#WHRB 51# HP ECONOMIZER 1#A 106 GR.B#18#6#WHRB 51#HP ECONOMIZER 2#A 106 GR.B#18#7#WHRB 52#HPLTSH 1#A 335 P22#3#8#WHRB 52#HPLTSH 2#A 335 P22#6# 9#WHRB 52#HPHTSH #A 335 P91#6#10#WHRB 52#HP EVAPORATOR#A 106 GR.B#12#11#WHRB 52#HP ECONOMIZER 1#A 106 GR.B#18#12#WHRB 52#HP ECONOMIZ ER 2#A 106 GR.B#18#3.#DURATION: 05 DAY4.#SCOPE OF WORK:4.1.#MOBILIZE TEAM/EQUIPMENT WITHIN 01 DAYS OF ADVANCE NOTICE.4.2.#SUBMIT FOL LOWING DOCUMENTS TO OBTAIN PTW,4.2.1.#METHOD STATEMENT4.2.2.#RISK ASSESSMENT OF THE WORK4.2.3.#TOOLBOX TALK REPORT.4.3.#OBTAIN PTW (

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PERMIT TO WORK), LC (LINE CLEARANCE) & CONFINE SPACEENTRY PERMIT FROM DEWA.4.4.#CONDUCT SITE SURVEY AND SAFETY INSPECTION, TO ASSESS THE WORKINGENVIRONMENT.4.5.#BEFORE START OF WORK ENSURE AREA IS CORRECTLY SECURED AND SAFE TOWORK ON IN ALL RESPECTS, REPORT IF ANY ISSUE / OBSERVATION TO DEWAENGINEER.4.6.#IDENTIFY AND CUT INSPECTION NOZZLES CAPS ON ALL RELEVANT HEADERSTO ALLOW ACCESS FOR INTERNAL INSPECTION OF TUBES AND HEADERS. SAME ENDCAP SHALL BE REUSED.4.7.#OPEN DOWNCOMER FLANGES TO ALLOW ACCESS FOR INTERNAL INSPECTION OFHEADERS.4.8.#OPEN ATTEMPERATOR FOR HP DESUPERHEATER4.9.#IF THE WORKING ENVIRONMENT IS SAFE, PROCEED WITH THE BORESCOPEINSPECTION.4.10.#ASSESS THE INTERNAL CONDITIONS OF TUBES & HEADERS. ARTICULATINGBOREScope SHALL BE USED TO IDENTIFY ANY SCABBING,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PITTING, SCALE BUILDUP, CORROSION, LAYER FORMATION, OVERHEATING AND ANY OTHER SIGNIFICANT FINDINGS. MAXIMUM NUMBER OF ACCESSIBLE TUBES TO BE INSPEC TED ON EACH HEADER CHECK DE-SUPER HEATER NOZZLE CONDITION BY BORESCOPE. REINSTATE ALL HEADER INSPECTION NOZZLES CAPS WHICH HAVE BEEN REMOVED. ALL WELDING TO BE CARRIED OUT AS PER CLASS APPROVED WELDING PROCEDURES 4.11.#IN CASE OF ANY SIGNIFICANT INSPECTION FINDING, S AME SHALL BE BROUGHT TO THE NOTICE OF DEWA.4.12.#UPON WORK COMPLETION, DETAILED INSPECTION REPORT SHALL SUBMIT.REPORT SHALL INCLUDE H EADER/TUBE IDENTIFICATION DETAILS, PHOTOS, VIDEOS, FINDINGS, RECOMMENDATIONS AND ALL SUPPORTING DOCUMENTS.4.13.#DIGITAL COPIES OF THE PHOTOS, VIDEOS, INSPECTION FINDINGS AND REPORT SHALL SUBMIT THROUGH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CLOUD/CD4.14.#DEWA SCOPE IS ONLY SCAFFOLDING IF REQUIRED5.#BORES COPE EQUIPMENT DETAILS:5.1.#THE BORESCOPE SHOULD BE EQUIPPED WITH ARTICULATION AND HIGH-ENDINDUSTRIAL VIDEO SYSTEMS WITH PROPER MONITORS. THE BORESCOPE SHOULD HAVE THE FACILITY / SYSTEMS TO GET EXCELLENT QUALITY IMAGE, DETAILED INFORMATION ABOUT A NON-CONFORMITY LIKE INDICATIONS, DISCOLORATIONS, PITTING, SCABBING, SCALE BUILD UP AND OXYGEN CORROSION ETC. THE PROBESHOULD BE WATER PROOF, FLEXIBLE WHICH SHOULD TURN UP TO 360°, SUITABLE TO ACCESS TO HEADERS & TUBES, LENGTH OF CABLE SHOULD BE 30 M, RESULTS RECORDABLE, DUAL OR EXTRA MONITOR, AND HIGH QUALITY OF RECORDING.6.#GENERAL TERMS & CONDITIONS:6.1.#THE CONTRACTOR SHALL VISIT THE SITE AND BE FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MATERIAL REQUIREMENT, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE SUBMITTING THE BID.6.2</p> <p>.#THE CONTRACTOR SHALL HAVE THE PREVIOUS EXPERIENCE FOR HRSG TUBES & HEADERS BORESCOPE INSPECTION IN DEWA OR WITH WELL-KNOWN COMPANY IN UAE.6.3.#THE CONTRACTOR SHALL SUBMIT THE SCHEDULE OF WORK AND THE PERIOD FOR WORK SO THAT THE WORK SHALL COME WELL WITHIN THE ALLOTTED OUTAGE PERIOD. THE SCHEDULE SHALL BE APPROVED BY DEWA BEFORE COMMENCEMENT OF WORK.6.4.#THE CONTRACTOR SHALL ENSURE HOUSEKEEPING ON A DAILY BASIS AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATED PLACES AS PER DEWA ENVIRONMENTAL POLICY OF HAZARDOUS WASTE DISPOSAL.6.5.#ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATION SHALL BE FOLLOWED AT WORK SITE DUR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ING THE EXECUTION OF THE WORK. THECONTRACTOR#S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILEWORKING IN A HAZARDOUS AREA. 6.6.#THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PERQUALITY / SCHEDULE REQUIREMENT. CONTRACTOR#S SUPERVISOR SHALL BEAVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK.6.7.#THE CONTRACTOR SHOULD APPLY FOR THE PERMIT TO WORK WELL IN ADVANCEAND THIS REQUEST SHALL BE FOLLOWED WITH METHOD STATEMENT, RISKASSESSMENT AS ATTACHMENTS6.8.#ENTRY PERMITS FOR THE STAFF/WORKERS SHOULD BE APPLIED WITH PASSPORT COPIES HAVING VALID VISA. PERSONS, WHOSE NAMES ARE NOTAVAILABLE IN THE LIST, WILL NOT BE ALLOWED TO ENTER THE POWERHOUSE6.9.#THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.6.10.#ENTRY PERMITS FOR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE VEHICLE SHOULD BE APPLIED WITH COPIES OF VEHICLE REGISTRATION. 6.11.#ALL THE PERSONS SHOULD WEAR THE UNIFORM, SAFETY SHOES AND HELMET WHILE AT WORK. 6.12.#TOOLBOX TALKS AND RISK ASSESSMENTS SHOULD BE GIVEN TO THE WORKMEN BY THEIR SUPERVISOR BEFORE START OF WORK. 6.13.#DEWA ENGINEER IN-CHARGE SHALL BE UPDATED THE WORK PROGRESS ON A REGULAR BASIS. 6.14.#CONTRACTOR SHALL COMPLY THE SA 8000 STANDARD AS PER DEWA TERMS AND CONDITIONS. 6.15.#SAFETY OFFICER BY THE CONTRACTOR IS REQUIRED AT SITE. 6.16.#EATING, RESTING AND SLEEPING IS NOT ALLOWED IN THE PLANT SITE. 6.17.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWA ENGINEER ON DAILY BASIS. THIS DOCUMENT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THEM OUT ON COMPLETION OF THE JOB.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

WHRB 51<(>&<)>52 Tubes /Headers inspection cap cutting , welding and Borescope inspection
 Contact person : Kaliyamoorthi: Ph-0529126916

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.

7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:

a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.

b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.

c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.

d) DEWA reserves the right to withhold data from third parties if deemed sensitive.

e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.

f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.

g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601168
DATE : 14.05.2026
REQ No : 1032602196
REQ TITLE : WHRB 51&52 Tubes /Headers
DELIVERY LOCATION
CLOSING DATE : 20.05.2026
CLOSING TIME : 10:00:00

guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP