

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>SUPPLY AND REPLACEMENT OF SPX MARLEY COOLING TOWER PVC INFILLS ANDDRIFT ELIMINATORS AT HEAD OFFICE.#SCOPE OF WORKS:#THE CONTRACTOR IS REQUIRED TO QUOTE LUMP SUM PRICE FOR THE SUPPLY ANDREPLACEMENT OF THE EXISTING COOLING TOWERS -3 NOS PVC INFILLS ANDELIMINATORS.#</p> <p>THE SCOPE COVERS THE REMOVAL OF THE OUTDATED COMPONENTS, SUPPLY OF NEWPVC INFILLS AND ELIMINATORS, INSTALLATION, TESTING, AND COMMIS SIONING OFTHE NEW COMPONENTS TO ENSURE OPTIMAL PERFORMANCE OF THE COOLING TOWERSYSTEM.#THE CONTRACTOR SHALL PROVIDE ALL NECESSARY MA TERIALS, EQUIPMENT, ANDLABOUR REQUIRED FOR THE COMPLETE REPLACEMENT OF THE EXISTING PVC INFILLSAND ELIMINATORS IN THE COOLING TOWERS , INCLUDING THE FOLLOWINGACTIVITIES:#SUPPLY OF NEW PVC INFILLS AND ELIMINATORS.#REMOVAL OF EXISTING INFILLS</p>	3	JOB				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AND ELIMINATORS.#INSTALL ATION OF NEW INFILLS AND ELIMINATORS.#PERFORMANCE TESTING AND SYSTEM VERIFICATION.#DISPOSAL OF OLD COMPONENTS AND SITE RESTORATION.# REPORTING AND DOCUMENTATION OF COMPLETED WORK.#CONTRACTOR TO REPLACE THE EXISTING GASKETS FOR ALL COOLING TOWERSACCESS DOORS.#CONTRA CTOR TO DO LEAK REPAIR OF ALL THE COLD-WATER BASINS AS PER SITEREQUIREMENT.#DURING REPLACEMENT OF PVC INFILLS CONTRACTOR TO CLEAN AL L COOLINGTOWERS HOT WATER BASIN & COLD WATER BASIN AND SURROUNDING AREA AS WELL.#CONTRACTOR TO SUPPLY CHEMICALS FOR CLEANING OF INNE R SIDE OF THECOOLING TOWERS INCLUDING BRANCH PIPES AND NOZZLES.#DURING ACTIVITIES CONTRACTOR TO PROVIDE MORE MANPOWER TO CARRY OUTMA INTENANCE AND TO BE COMPLETED AS PER THE DEWA SCHEDULE.#ALL THE MATERIALS IN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>GENERAL WILL CONFORM AS PER LATEST STANDARDS AND SHALL BE SUBMITTED TO DEWA FOR ENGINEERS APPROVAL. DEWA-CONFIDENTIAL## THE CONTRACTOR IS REQUIRED TO TAKE ALL PRECAUTION. SO AS NOT, DAMAGE ANY OF THE EXISTING EQUIPMENT/ STRUCTURE ETC## ALL MAINTENANCE ACTIVITIES SHALL BE PERFORMED IN PRESENCE/SUPERVISION OF COMPETENT SUPERVISOR.## CONTRACTOR SHOULD SUBMIT MATERIAL SUBMITTAL, METHOD OF STATEMENT, RISK ASSESSMENT AND ACTION PLAN TO DEWA'S ENGINEER APPROVAL BEFORE CARRYING OUT THE INSTALLATION.## ALL MAINTENANCE ACTIVITIES SHALL BE PERFORMED IN PRESENCE/SUPERVISION OF CONTRACTOR'S COMPETENT SUPERVISOR.## THE CONTRACTOR SHALL DEPLOY THE SKILLED TECHNICIANS FOR CARRY OUT THE WORKS## CONTRACTORS TO BE SUBMITTED THEIR OWN CH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ECK LIST FOR CORRECTIVEMAINTENANCE FOR DEWA#S SUPERVISOR VERIFICATION AND RECORD##CONTRACTORS TO SUBMIT REQUIRE CONSUMABLE ITEMS TO COMPLETE CORRECTIVEMAINTENANCE FOR DEWA#S SUPERVISOR VERIFICATION AND RECORD.##FOLLOW THE MANUFACTURER GUIDELINES FOR REPAIRING/MODIFICATION OFEQUIPMENT.##CONTRACTOR TO PROVIDE US MATERIAL SUBMITTAL, METHOD OF STATEMENT,RISK ASSESSMENT AND PLANNER AS WELL.##TESTING AND COMMISSIONING SHALL BE COMPLETED AS PER EXISTING SITEREQUIREMENTS AND MANUFACTURES RECOMMENDATION##THE JOB EXECUTION SHALL BE CARRIED OUT IN THE TIMING ASSIGNED BY THEDEWA ENGINEER##IN CASE OF UN-SATISFACTORY PERFORMANCE, THE LPO WILL BE CANCELLEDGIVING 15 DAYS# NOTICE##CONTACT PERSON FOR SITE VISIT MR. MOHIDEEN: 055 3810513, 04 3227879(MOHIDEEN.ESMAIL@DEWA.GOV.AE).PVC</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INFILLS MATERIAL S PECIFICATIONS:##THE INFILLS SHALL BE MADE FROM HIGH-QUALITY, CORROSION-RESISTANT PVCOR EQUIVALENT MATERIAL WITH UV RESISTANCE.##THE MATERIAL SHOULD BE CAPABLE OF WITHSTANDING HIGH TEMPERATURES,EXPOSURE TO CHEMICALS, AND ENVIRONMENTAL CONDITIONS TYPICAL FOR COOLING TOWER APPLICATIONS.##INFILLS SHALL BE DESIGNED TO FACILITATE MAXIMUM HEAT EXCHANGEEFFICIENCY AND WATER DISTRIBUTION.##THE INFILL DESIGN SHOULD MAXIMIZE WATER AND AIR CONTACT AREA TOIMPROVE HEAT TRANSFER.##THE INFILLS SHALL BE OF THE COUNTERFLOW TYPE OR CROSSFLOW TYPE, BASEDON THE EXISTING SYSTEM DESIGN.DEWA-CONFIDENTIAL##THE THICKNESS OF THE INFILL SHALL BE DESIGNED TO MAINTAIN STRUCTURALINTEGRITY UNDER OPERATIONAL LOADS AND CHEMICAL EXPOSURE.##THE INFILLS SHALL MEET OR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EXCEED THE COOLING TOWER MANUFACTURER#SDESIGN SPECIFICATIONS FOR HEAT TRANSFER, AIR DISTRIBUTION, AND WATERDISTRIBUTION.##THE INFILLS SHALL PROVIDE MINIMAL RESISTANCE TO AIRFLOW TO ENSURE EFFICIENT OPERATION.MODEL NO:MAKE: SPX MARLEY (CROSS FLOW COOLING TOWER)MODEL NUMBER: NC8401-M-13000INFILLS SYSTEM DETAILS:##IN PP, PROVIDING AN EXTENDED EXCHANGE SURFACE, GOOD RESISTANCE TO TEMPERATURE (70 °C CONTINUOUS), HIGH EFFICIENCY EXTENDED SURFACE, EASY MAINTENANCE, HIGH RESISTANCE TO CHEMICALS, OPERATION RANGE UP TO 100°C UPON REQUEST (OPTION).PVC ELIMINATORS MATERIAL SPECIFICATIONS:##THE ELIMINATORS SHALL BE MADE OF DURABLE, UV-STABILIZED PVC OR EQUIVALENT MATERIAL.##THE MATERIAL SHALL BE RESISTANT TO CORROSION, CHEMICAL DETERIORATION, AND DEGRADATION FROM</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>UV EXPOSURE.##ELIMINATORS SHOULD BE DESIGNED TO REDUCE WATER CARRYOVER (DRIFT) FROMTHE COOLING TOWER WHILE MAINTAINING LOW AIRFLOW RESISTANCE.##THE ELIMINATORS MUST EFFECTIVELY SEPARATE WATER DROPLETS FROM THE AIRSTREAM, REDUCING WATER CARRYOVER AND IMPROVING THE OVERALL EFFICIENCY OFTHE COOLING TOWER.##THE DESIGN MUST PROVIDE ADEQUATE RESISTANCE TO WIND AND WATER FLOWWHILE PREVENTING EXCESSIVE PRESSURE DROP.DRIFT ELIMINATORS:##HIGHLY EFFICIENT, THEY PREVENT THE WATER FROM BEING SPRAYED OUT OFTHE TOWER AND ARE EASILY REMOVABLE.##THESE DRIFT ELIMINATORS ARE MADE OF CORRUGATED PVC BLADE. DRIFT ISMAXIMUM 0.01 % FROM WATER FLOW IN RECIRCULATION.DEWA-CONFIDENTIALINSTALLATION REQUIREMENTS FOR REMOVAL OF EXISTING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COMPONENTS:##CAREFULLY DISMANTLE AND REMOVE THE EXISTING PVC INFILLS AND ELIMINATORS WITHOUT CAUSING DAMAGE TO OTHER COOLING TOWER COMPONENTS.##THE CONTRACTOR SHALL ENSURE THAT ALL REMOVAL ACTIVITIES ARE CARRIED OUT WITH MINIMAL DISRUPTION TO THE COOLING TOWER'S OPERATION.##ALL REMOVED COMPONENTS MUST BE DISPOSED OF PROPERLY IN ACCORDANCE WITH ENVIRONMENTAL AND SITE REGULATIONS. INSTALLATION OF NEW COMPONENTS:##THE NEW PVC INFILLS AND ELIMINATORS SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTALLATION INSTRUCTIONS AND THE COOLING TOWER MANUFACTURER'S SPECIFICATIONS.##ENSURE PROPER ALIGNMENT AND FITTING OF THE INFILLS AND ELIMINATORS, ENSURING SECURE ATTACHMENT TO THE COOLING TOWER'S STRUCTURAL FRAMEWORK.##ALL COMPONENTS SHOULD BE TESTED FOR PROPER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FIT AND FUNCTION BEFORE FINAL INSTALLATION.##THE CONTRACTOR SHALL ENSURE THAT THE NEW COMPONENTS DO NOT INTERFERE WITH THE COOLING TOWER'S PERFORMANCE AND THAT ALL AIR AND WATER DISTRIBUTION SYSTEMS ARE OPTIMIZED.##ENSURE ALL MOUNTING AND SEALING MATERIALS USED ARE COMPATIBLE WITH PVC COMPONENTS AND CAPABLE OF WITHSTANDING THE OPERATING ENVIRONMENT (HIGH HUMIDITY, CHEMICALS, ETC.).##THE USE OF CORROSION-RESISTANT FASTENERS, SEALS, AND ADHESIVES IS REQUIRED.##ALL INFILLS AND ELIMINATORS SHALL BE SECURELY MOUNTED AND ALIGNED WITH PROPER SPACING TO AVOID AIR OR WATER DISTRIBUTION INEFFICIENCIES.</p> <p>TESTING AND COMMISSIONING:##AFTER THE INSTALLATION OF THE NEW PVC INFILLS AND ELIMINATORS, CONDUCT A PERFORMANCE TEST TO ENSURE THAT THE COOLING TOWER IS OPERATING WITHIN THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REQUIRED PERFORMANCE PARAMETERS (WATER FLOW, AIR DISTRIBUTION, COOLING CAPACITY, ETC.).##MEA</p> <p>SURE THE AIR AND WATER FLOW, TEMPERATURE DIFFERENTIALS, AND OTHER RELEVANT PARAMETERS TO ENSURE THE NEW COMPONENTS ARE FUNCTIONING AS DESIGNED.##THE CONTRACTOR MUST ENSURE THAT THE COOLING TOWER#S PERFORMANCE AFTER THE REPLACEMENT MEETS THE DESIGN SPECIFICATIONS AND OPERATES EFFICIENTLY DEWA-CONFIDENTIAL##VERIFY THAT THE COOLING TOWER OPERATES WITH MINIMAL VIBRATION, NOISE, AND AIR/WATER LEAKS AFTER INSTALLATION.##CHECK THAT THE COOLING TOWER SYSTEM MAINTAINS OPTIMAL PERFORMANCE, WITH NO ISSUES OF WATER CARRYOVER (DRIFT), UNEVEN DISTRIBUTION, OR REDUCED HEAT EXCHANGE EFFICIENCY.##GENERAL CONDITION & MOBILIZATION AT SITE OF THE CONTRACT:##ALL THE MATERIALS IN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			GENERAL WILL BE AS PER LATEST STANDARD AND SAMESHALL BE SUBMITTED FOR DEWA ENGINEERS APPROVAL.##THE CONTRACTOR IS REQUIRED TO TAKE A LL PRECAUTION AS PER HEALTH &SAFETY PROCEDURE, SO AS NOT DAMAGE ANY OF THE EXISTINGEQUIPMENT/STRUCTURE ETC.##SHOULD WE EXPERIENCE A BREAKDOWN IN ANY OF EQUIPMENT/SYSTEM AT ANYTIME OF THE DAY OR NIGHT, YOU WILL RESPOND TO OUR REQUEST WITH YOUR 24HOURS						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Supply and Replacement of SPX MARLEY Cooling Tower PVC Infills and Drift

Eliminators at Head office.

AS PER ATTACHED SOW

Contact : Mohideen / 553810513

Site Visit Date <(>&<)> Time: 05/06/2026

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

Payment Terms: After completion of work

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8) Data Privacy, Security and Sharing:

- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- DEWA reserves the right to withhold data from third parties if deemed sensitive.
- Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601283
DATE : 01.06.2026
REQ No : 1032602384
REQ TITLE : Supply and Replacement of SPX
DELIVERY LOCATION
CLOSING DATE : 05.06.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP