

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>COMPLETE JOB SCOPE: MOBILIZATION & CHARGES OF EQUIPMENT'S & SPECIALISTS AND REPORTING AFTER TEST AS PER BELOW TECHNICAL SPECIFICATION</p> <p>S -1.#MATERIAL & METHODS:1.1#PRINCIPLE:THE BLOWER-DOOR TESTING IS CARRIED OUT ACCORDING TO THE #DIN EN 13829# /#NFPA 850# / #NFPA 20</p> <p>01# (EDITION 2008, ANNEX C).IN NFPA 2001 (EDITION 2008 / ANNEX C) A METHOD IS DESCRIBED TO EVALUATE FIRE EXTINGUISHING SYSTEMS BASED ON A DOOR FAN TEST. THE CALCULATION METHOD MAKES IT POSSIBLE TO PREDICT THE TIME FOR THE CONCENTRATION TO FALL TO A GIVEN PERCENTAGE C ONCENTRATION. THIS PROCEDURE PROVIDES A WORST-CASE LEAKAGE ESTIMATE THAT IS VERY USEFUL FOR ENCLOSURES WITH COMPLEX HIDDEN LEAKS, BUT IT WILL GENERALLY REQUIRE MORE SEALING THAN IS NECESSARY TO PASS A DISCHARGE TEST. IN THIS PROJECT ONLY THE DOOR-FAN-TEST WITH</p>	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LEAKAGE CALCULATIONS ARE TO BE PERFORMED.2.1.1#DOOR-FAN-TEST:DOOR FAN TESTS ARE USED TO EXAMINE THE AIR TIGHTNESS OF CONSTRUCTION ENVELOPES/ GT ENCLOSURE. IN ORDER TO ACHIEVE THIS FOR THE TESTED ENVELOPES, A FLOW FAN CREATES A LOCAL DIFFERENTIAL PRESSURE REFERENCED AGAINST A AMBIENT AIR PRESSURE. THE DOOR-FAN-TEST-EQUIPMENT CONSISTS OF A FLOW FAN AND A FLEXIBLE FRAME CONSTRUCTION SET WHICH IS INSTALLED AIR TIGHTLY INTO A DOOR. BY USING SPEED CONTROL, THE FLOW RATE CREATED BY THE FAN CAN BE ADAPTED AT A VARIABLE RANGE. THE DIFFERENTIAL PRESSURE IS MEASURED AUTOMATICALLY BY A COMPUTER-CONTROLLED PRESSURE GAUGE (APT: AUTOMATED PERFORMANCE TESTING) WITH EIGHT CHANNELS. ACCORDING TO NFPA2001 THE PRESSURE DIFFERENCE SHOULD BE SET TO MINIMIZE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENVIRONMENTALFACTORS, SUCH AS WIND PRESSURE (USUALLY 10 PA). AN ADDITIONAL TEST POINTAT 50 PA (IF POSSIBLE) IS REQUIRED TO CALCULATE THE FLOW EXPONENT.THE FINAL VALUE FOR THE LEAKAGE CHARACTERISTI CS N AND K1 (ACCORDING TONFPA 2001) IS DETERMINED BY USING ORDINARY LEAST SQUARES REGRESSIONOBTAINED UNDER BOTH A POSITIVE AND NEGAT IVE PRESSURE. BASED ON THELEAKAGE CHARACTERISTICS THE EQUIVALENT LEAKAGE AREA (EQLA) CAN BECALCULATED. EQLA IS DEFINED BY CANADIAN R ESEARCHERS AT THE CANADIANNATIONAL RESEARCH COUNCIL AS THE AREA OF A SHARP EDGED ORIFICE (A SHARPROUND HOLE CUT IN A THIN PLATE) THA T WOULD LEAK THE SAME AMOUNT OF AIRAS THE BUILDING DOES AT A PRESSURE OF 10 PASCALS (CAN/CGSB-149.10-M86).EQLA IS NOT ESSENTIAL TO C ALCULATE RETENTION TIME BUT A</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>QUALITYPARAMETER FOR ENCLOSURE ENVELOPES. THE ACCURACY OF THE PROCEDURE CAN BESET AT 10%.THE FIRST STEP OF THE BLOWER DOOR TEST IS A VISUAL INSPECTION OF THEACOUSTIC ENCLOSURE TO BE TESTED. SCOPE OF THIS INSPECTION IS TO IDENTIFYEVIDE NT LEAKAGE AREAS TO PERMIT THE CLIENT TO CLOSE THEM BEFORE STARTINGOF THE TEST.TO CARRY OUT THE MEASUREMENT A CALIBRATED PRESSURE GA UGE (BLOWER WITHPRESSURE GAUGE) IS INSERTED INTO AN OUTER DOOR OF THE ACOUSTICENCLOSURE. ALL FURTHER OPENINGS SUCH AS EXTERNAL DOORS AND FLAPS, HAVETO BE CLOSED IN ACCORDANCE WITH REGULATIONS.DURING THIS TESTING AIR IS CONTINUOUSLY SUCKED OUT OF THE EN-CLOSURE(NEG ATIVE PRESSURE) OR LET INTO THE ENCLOSURE (OVERPRESSURE) USING ABLOWER SO THAT A NEGATIVE PRESSURE OR AN OVERPRESSURE IS PRODUCED.TH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>E PRESSURE MEASURING SENSORS OF THE MEASURING SYSTEM REGISTER THEEXTERNAL AND INTERNAL PRESSURE AS WELL AS THE INCOMING AIR VOLUME, WHICHTHE BLOWER PRODUCES. IN CASE THE ENCLOSURE HAS LEAKS THE EXISTING AIRFLOWS IN IT ARE LOCALIZED AND QUANTIFIED BY FOG OR AN AIR VELOCITYMEASURING DEVICE.FOR FURTHER LOCALIZATION OF LEAKS A FOG GENERATOR PRODUCES ARTIFICIALFOG WITHIN THE ROOM, WHICH IS PRESSED OUTWARD THROUGH LEAKS OF THEENCLOSURE. THIS PROCESS MAKES LEAKS VISIBLE.#2.1.2#PREPARATION:BEFORE STARTING THE TEST, ALL DOORS AND W INDOWS AND OPENINGS IN THEENCLOSURE ENVELOPE ARE SET TO THE STATE THEY WOULD BE DURING THE HOLDTIME. THE OBJECTS WERE PREPARED AS FO LLOWS:§#CLOSE THE FLAPSS§#SWITCH OF VENTILATION-SYSTEMS§#VISUAL INSPECTION OF THE OBJECT TO FIND TEMPORARY LEAKAGES</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SUCH ASCABLE PENE TRATIONSTHE PREPARATION OF THE OBJECTS TO BE VERIFIED BY THE CLIENT.1.2#LEAKAGE DEDUCTION:TO DETERMINE THE MAIN LEAKAGES, THE WHOLE ENCLOSURE IS SET UNDERNEGATIVE PRESSURE. IN THIS CASE AIR FROM OUTSIDE STREAMS THROUGH THELEAKAGES IN THE ENCLOSURE AND CAN BE DETEC TED.1.3#STANDARDS AND QUALITY ASSURANCE:§#NFPA 2001 "STANDARD ON CLEAN AGENT FIRE EXTINGUISHING SYSTEMS" 2012EDITION (APPENDIX C ENC LOSURE INTEGRITY PROCEDURE), EDITED BY NATIONALFIRE PROTECTION ASSOCIATION (NFPA); JUNE 2011.§#CAN/CGSB-149.10-M86, DETERMINATION OF THE AIRTIGHTNESS OF BUILDINGENVELOPES BY THE FAN DEPRESSURIZATION METHOD, EDITED BY CANADIAN GENERALSTANDARDS BOARD (CGSB); DECEMBE R 1986§#THE QUALITY ASSURANCE REFERS TO DIN EN ISO 17025.4.#TECHNICAL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REPORTS:-#CONTRACTOR HAS TO SUBMIT PRELIMINARY REPORT WITHIN 2 (TWO) DAYS OF THE TEST FOLLOWED BY FINAL REPORT WITHIN 15 (FIFTEEN) DAYS. JOBCOMPLETION CERTIFICATE IS TO BE SUBMITTED ALONG WITH THE FINAL REPORT.FOR CONTACT: NAZAR (050-2806076) NAZAR.BAKHSH@DEWA.GOV.AE BUTI(0562240401) BUTI.ALSHAMSI@DEWA.GOV.AE						
2		ITEM-00001	COMPLETE JOB SCOPE: MOBILIZATION & CHARGES OF EQUIPMENT'S & SPECIALISTS AND REPORTING AFTER TEST AS PER BELOW TECHNICAL SPECIFICATION S -1.#MATERIAL & METHODS:1.1#PRINCIPLE:THE BLOWER-DOOR TESTING IS CARRIED OUT ACCORDING TO THE #DIN EN 13829#/#NFPA 850#/#NFPA 20 01# (EDITION 2008, ANNEX C).IN NFPA 2001 (EDITION 2008 / ANNEX C) A METHOD IS DESCRIBED TO EVALUATE FIRE EXTINGUISHING SYSTEMS BASED ON A DOOR FAN TEST. THE CALCULATION METHOD MAKES IT POSSIBLE TO PREDICT THE TIME FOR	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE CONCENTRATION TO FALL TO A GIVEN PERCENTAGE C ONCENTRATION. THIS PROCEDURE PROVIDES A WORST-CASE LEAKAGE ESTIMATE THAT IS VERY USEFUL FOR ENCLOSURES WITH COMPLEX HIDDEN LEAKS, BUT IT WILL GENERALLY REQUIRE MORE SEALING THAN IS NECESSARY TO PASS A DISCHARGE TEST. IN THIS PROJECT ONLY THE DOOR-FAN-TEST WITH LEAKAGE CALCULATIONS ARE TO BE PERFORMED. 2.1.1 #DOOR-FAN-TEST: DOOR FAN TESTS ARE USED TO EXAMINE THE AIR TIGHTNESS OF CONSTRUCTION ENVELOPES/ GT ENCLOSURE. IN ORDER TO ACHIEVE THIS FOR THE TESTED ENVELOPES, A FLOW FAN CREATES A LOCAL DIFFERENTIAL PRESSURE REFERENCED AGAINST A AMBIENT AIR PRESSURE. THE DOOR-FAN-TEST-EQUIPMENT CONSISTS OF A FLOW FAN AND A FLEXIBLE FRAME CONSTRUCTION SET WHICH IS INSTALLED AIR TIGHTLY INTO A DOOR. BY USING SPEED CONTROL,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE FLOW RATE CREATED BY THE FAN CAN BE ADAPTED AT A VARIABLE RANGE. THE DIFFERENTIAL PRESSURE IS MEASURED AUTOMATICALLY BY A COMPUTER-CONTROLLED PRESSURE GAUGE (APT: AUTOMATED PERFORMANCE TESTING) WITH EIGHT CHANNELS. ACCORDING TO NFPA 2001 THE PRESSURE DIFFERENCE SHOULD BE SET TO MINIMIZE ENVIRONMENTAL FACTORS, SUCH AS WIND PRESSURE (USUALLY 10 PA). AN ADDITIONAL TEST POINT AT 50 PA (IF POSSIBLE) IS REQUIRED TO CALCULATE THE FLOW EXPONENT. THE FINAL VALUE FOR THE LEAKAGE CHARACTERISTICS (CS N AND K1 (ACCORDING TO NFPA 2001) IS DETERMINED BY USING ORDINARY LEAST SQUARES REGRESSION OBTAINED UNDER BOTH A POSITIVE AND NEGATIVE PRESSURE. BASED ON THE LEAKAGE CHARACTERISTICS THE EQUIVALENT LEAKAGE AREA (EQLA) CAN BE CALCULATED. EQLA IS DEFINED BY CANADIAN R</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ESEARCHERS AT THE CANADIANNATIONAL RESEARCH COUNCIL AS THE AREA OF A SHARP EDGED ORIFICE (A SHARPROUND HOLE CUT IN A THIN PLATE) THA T WOULD LEAK THE SAME AMOUNT OF AIRAS THE BUILDING DOES AT A PRESSURE OF 10 PASCALS (CAN/CGSB-149.10-M86).EQLA IS NOT ESSENTIAL TO C ALCULATE RETENTION TIME BUT A QUALITYPARAMETER FOR ENCLOSURE ENVELOPES. THE ACCURACY OF THE PROCEDURE CAN BESET AT 10%.THE FIRST STE P OF THE BLOWER DOOR TEST IS A VISUAL INSPECTION OF THEACOUSTIC ENCLOSURE TO BE TESTED. SCOPE OF THIS INSPECTION IS TO IDENTIFYEVIDE NT LEAKAGE AREAS TO PERMIT THE CLIENT TO CLOSE THEM BEFORE STARTINGOF THE TEST.TO CARRY OUT THE MEASUREMENT A CALIBRATED PRESSURE GA UGE (BLOWER WITHPRESSURE GAUGE) IS INSERTED INTO AN OUTER DOOR OF THE ACOUSTICENCLOSURE. ALL FURTHER OPENINGS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SUCH AS EXTERNAL DOORS AND FLAPS, HAVETO BE CLOSED IN ACCORDANCE WITH REGULATIONS.DURING THIS TESTING AIR IS CONTINUOUSLY SUCKED OUT OF THE EN-CLOSURE(NEGATIVE PRESSURE) OR LET INTO THE ENCLOSURE (OVERPRESSURE) USING ABLOWER SO THAT A NEGATIVE PRESSURE OR AN OVERPRESSURE IS PRODUCED.TH</p> <p>E PRESSURE MEASURING SENSORS OF THE MEASURING SYSTEM REGISTER THEEXTERNAL AND INTERNAL PRESSURE AS WELL AS THE INCOMING AIR VOLUME, WHICHTHE BLOWER PRODUCES. IN CASE THE ENCLOSURE HAS LEAKS THE EXISTING AIRFLOWS IN IT ARE LOCALIZED AND QUANTIFIED BY FOG OR AN AIR VELOCITYMEASURING DEVICE.FOR FURTHER LOCALIZATION OF LEAKS A FOG GENERATOR PRODUCES ARTIFICIALFOG WITHIN THE ROOM, WHICH IS PRESSED OUTWARD THROUGH LEAKS OF THEENCLOSURE. THIS PROCESS MAKES LEAKS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VISIBLE.#2.1.2#PREPARATION:BEFORE STARTING THE TEST, ALL DOORS AND WINDOW AND OPENINGS IN THE ENCLOSURE ENVELOPE ARE SET TO THE STATE THEY WOULD BE DURING THE HOLD TIME. THE OBJECTS WERE PREPARED AS FOLLOWS:1.#CLOSE THE FLAPS2.#SWITCH OF VENTILATION-SYSTEMS3.#VISUAL INSPECTION OF THE OBJECT TO FIND TEMPORARY LEAKAGES SUCH AS CABLE PENETRATION4.#THE PREPARATION OF THE OBJECTS TO BE VERIFIED BY THE CLIENT.1.2#LEAKAGE DEDUCTION:TO DETERMINE THE MAIN LEAKAGES, THE WHOLE ENCLOSURE IS SET UNDER NEGATIVE PRESSURE. IN THIS CASE AIR FROM OUTSIDE STREAMS THROUGH THE LEAKAGES IN THE ENCLOSURE AND CAN BE DETECTED.1.3#STANDARDS AND QUALITY ASSURANCE:1.#NFPA 2001 "STANDARD ON CLEAN AGENT FIRE EXTINGUISHING SYSTEMS" 2012 EDITION (APPENDIX C ENCLOSURE INTEGRITY PROCEDURE), EDITED BY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NATIONALFIRE PROTECTION ASSOCIATION (NFPA); JUNE 2011.§#CAN/CGSB-149.10-M86, DETERMINATION OF THE AIRTIGHTNESS OF BUILDINGENVELOPES BY THE FAN DEPRESSURIZATION METHOD, EDITED BY CANADIAN GENERALSTANDARDS BOARD (CGSB); DECEMBE R 1986§#THE QUALITY ASSURANCE REFERS TO DIN EN ISO 17025.4.#TECHNICAL REPORTS:.#CONTRACTOR HAS TO SUBMIT PRELIMINARY REPORT WITHIN 2 (TWO) DAYS OFTHE TEST FOLLOWED BY FINAL REPORT WITHIN 15 (FIFTEEN) DAYS. JOBCOMPLETION CERTIFICATE IS TO BE SUBMITTED ALONG WITH TH E FINAL REPORT.FOR CONTACT: NAZAR (050-2806076) NAZAR.BAKHSH@DEWA.GOV.AE BUTI(0562240401) BUTI.ALSHAMSI@DEWA.GOV.AE						
3		ITEM-00001	COMPLETE JOB SCOPE: MOBILIZATION & CHARGES OF EQUIPMENT'S & SPECIALISTSAND REPORTING AFTER TEST AS PER BELOW TECHNICAL SPECIFICATION S -1.#MATERIAL & METHODS:1.1#PRINCIPLE:THE	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BLOWER-DOOR TESTING IS CARRIED OUT ACCORDING TO THE #DIN EN 13829# /#NFPA 850# / #NFPA 20 01# (EDITION 2008, ANNEX C).IN NFPA 2001 (EDITION 2008 / ANNEX C) A METHOD IS DESCRIBED TO EVALUATEFIRE EXTINGUISHING SYSTEMS BASED ON A DOOR FAN TEST. THE CALCULATIONMETHOD MAKES IT POSSIBLE TO PREDICT THE TIME FOR THE CONCENTRATION TOFALL TO A GIVEN PERCENTAGE C ONCENTRATION. THIS PROCEDURE PROVIDES AWORST-CASE LEAKAGE ESTIMATE THAT IS VERY USEFUL FOR ENCLOSURES WITHCOMPLEX HIDDEN LEAKS, BUT IT WILL GENERALLY REQUIRE MORE SEALING THAN ISNECESSARY TO PASS A DISCHARGE TEST. IN THIS PROJECT ONLY THEDOOR-FAN-TEST WITH LEAKAGE CALCULATIONS ARE TO BE PERFORMED.2.1.1#DOOR-FAN-TEST:DOOR FAN TESTS ARE USED TO EXAMINE THE AIR TIGHTNESS OF CONSTRUCTIONENVELOPES/</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			GT ENCLOSURE. IN ORDER TO ACHIEVE THIS FOR THE TESTED ENVELOPES, A FLOW FAN CREATES A LOCAL DIFFERENTIAL PRESSURE REFERENCED AGAINST AMBIENT AIR PRESSURE. THE DOOR-FAN-TEST-EQUIPMENT CONSISTS OF A FLOW FAN AND A FLEXIBLE FRAME CONSTRUCTION SET WHICH IS INSTALLED AIR TIGHTLY INTO A DOOR. BY USING SPEED CONTROL, THE FLOW RATE CREATED BY THE FAN CAN BE ADAPTED AT A VARIABLE RANGE. THE DIFFERENTIAL PRESSURE IS MEASURED AUTOMATICALLY BY A COMPUTER-CONTROLLED PRESSURE GAUGE (APT: AUTOMATED PERFORMANCE TESTING) WITH EIGHT CHANNELS. ACCORDING TO NFPA2001 THE PRESSURE DIFFERENCE SHOULD BE SET TO MINIMIZE ENVIRONMENTAL FACTORS, SUCH AS WIND PRESSURE (USUALLY 10 PA). AN ADDITIONAL TEST POINT AT 50 PA (IF POSSIBLE) IS REQUIRED TO CALCULATE THE FLOW EXPONENT. THE FINAL VALUE FOR THE LEAKAGE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CHARACTERISTI CS N AND K1 (ACCORDING TONFPA 2001) IS DETERMINED BY USING ORDINARY LEAST SQUARES REGRESSIONOBTAINED UNDER BOTH A POSITIVE AND NEGAT IVE PRESSURE. BASED ON THELEAKAGE CHARACTERISTICS THE EQUIVALENT LEAKAGE AREA (EQLA) CAN BECALCULATED. EQLA IS DEFINED BY CANADIAN R ESEARCHERS AT THE CANADIANNATIONAL RESEARCH COUNCIL AS THE AREA OF A SHARP EDGED ORIFICE (A SHARPROUND HOLE CUT IN A THIN PLATE) THA T WOULD LEAK THE SAME AMOUNT OF AIRAS THE BUILDING DOES AT A PRESSURE OF 10 PASCALS (CAN/CGSB-149.10-M86).EQLA IS NOT ESSENTIAL TO C ALCULATE RETENTION TIME BUT A QUALITYPARAMETER FOR ENCLOSURE ENVELOPES. THE ACCURACY OF THE PROCEDURE CAN BESET AT 10%.THE FIRST STE P OF THE BLOWER DOOR TEST IS A VISUAL INSPECTION OF THEACOUSTIC ENCLOSURE TO BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TESTED. SCOPE OF THIS INSPECTION IS TO IDENTIFYEVIDE NT LEAKAGE AREAS TO PERMIT THE CLIENT TO CLOSE THEM BEFORE STARTINGOF THE TEST.TO CARRY OUT THE MEASUREMENT A CALIBRATED PRESSURE GA UGE (BLOWER WITHPRESSURE GAUGE) IS INSERTED INTO AN OUTER DOOR OF THE ACOUSTICENCLOSURE. ALL FURTHER OPENINGS SUCH AS EXTERNAL DOORS AND FLAPS, HAVETO BE CLOSED IN ACCORDANCE WITH REGULATIONS.DURING THIS TESTING AIR IS CONTINUOUSLY SUCKED OUT OF THE EN-CLOSURE(NEG ATIVE PRESSURE) OR LET INTO THE ENCLOSURE (OVERPRESSURE) USING ABLOWER SO THAT A NEGATIVE PRESSURE OR AN OVERPRESSURE IS PRODUCED.TH E PRESSURE MEASURING SENSORS OF THE MEASURING SYSTEM REGISTER THEEXTERNAL AND INTERNAL PRESSURE AS WELL AS THE INCOMING AIR VOLUME, WHICHTHE BLOWER PRODUCES. IN CASE THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENCLOSURE HAS LEAKS THE EXISTING AIRFLOWS IN IT ARE LOCALIZED AND QUANTIFIED BY FOG OR AN AIR VELOCITYMEASURING DEVICE.FOR FURTHER LOCALIZATION OF LEAKS A FOG GENERATOR PRODUCES ARTIFICIALFOG WITHIN THE ROOM, WHICH IS PRESSED OUTWARD THROUGH LEAKS OF THEENCLOSURE. THIS PROCESS MAKES LEAKS VISIBLE.#2.1.2#PREPARATION:BEFORE STARTING THE TEST, ALL DOORS AND W INDOWS AND OPENINGS IN THEENCLOSURE ENVELOPE ARE SET TO THE STATE THEY WOULD BE DURING THE HOLDTIME. THE OBJECTS WERE PREPARED AS FO LLOWS:\$#CLOSE THE FLAPSS#SWITCH OF VENTILATION-SYSTEMS\$#VISUAL INSPECTION OF THE OBJECT TO FIND TEMPORARY LEAKAGES SUCH ASCABLE PENE TRATIONSTHE PREPARATION OF THE OBJECTS TO BE VERIFIED BY THE CLIENT.1.2#LEAKAGE DEDUCTION:TO DETERMINE THE MAIN LEAKAGES, THE WHOLE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENCLOSURE IS SET UNDERNEGATIVE PRESSURE. IN THIS CASE AIR FROM OUTSIDE STREAMS THROUGH THELEAKAGES IN THE ENCLOSURE AND CAN BE DETEC</p> <p>TED.1.3#STANDARDS AND QUALITY ASSURANCE:§#NFPA 2001 "STANDARD ON CLEAN AGENT FIRE EXTINGUISHING SYSTEMS" 2012EDITION (APPENDIX C ENCLOSURE INTEGRITY PROCEDURE), EDITED BY NATIONALFIRE PROTECTION ASSOCIATION (NFPA); JUNE 2011.§#CAN/CGSB-149.10-M86, DETERMINATION OF THE AIRTIGHTNESS OF BUILDINGENVELOPES BY THE FAN DEPRESSURIZATION METHOD, EDITED BY CANADIAN GENERALSTANDARDS BOARD (CGSB); DECEMBE R 1986§#THE QUALITY ASSURANCE REFERS TO DIN EN ISO 17025.4.#TECHNICAL REPORTS:-#CONTRACTOR HAS TO SUBMIT PRELIMINARY REPORT WITHIN 2 (TWO) DAYS OFTHE TEST FOLLOWED BY FINAL REPORT WITHIN 15 (FIFTEEN) DAYS. JOBCOMPLETION CERTIFICATE IS TO BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUBMITTED ALONG WITH THE FINAL REPORT.FOR CONTACT: NAZAR (050-2806076) NAZAR.BAKHSH@DEWA.GOV.AE BUTI(0562240401) BUTI.ALSHAMSI@DEWA.GOV.AE						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Blow-door test for GT enclosure of K station unit GTK51 including equipment <(>&<)> specialist charges and reporting.

Job scheduled in 4th quarter of 2026

Contact:Nazar (050-2806076) nazar.bakhsh@dewa.gov.ae Buti (0562240401) buti.alshamsi@dewa.gov.ae

STANDARD TERMS & CONDITIONS

1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601332
DATE	: 05.06.2026
REQ No	: 1032600866
REQ TITLE	: Blow-door test for GT enclosu
DELIVERY LOCATION	
CLOSING DATE	: 11.06.2026
CLOSING TIME	: 10:00:00

- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.
- 8) Data Privacy, Security and Sharing:
 - a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
 - b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
 - c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
 - d) DEWA reserves the right to withhold data from third parties if deemed sensitive.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601332
DATE	: 05.06.2026
REQ No	: 1032600866
REQ TITLE	: Blow-door test for GT enclosu
DELIVERY LOCATION	
CLOSING DATE	: 11.06.2026
CLOSING TIME	: 10:00:00

- e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.
- 9) Liquidated Damages for PO total value in excess of AED 50,000:
If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.
- 10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.
- 11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.
- 12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.
- 13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.
- 14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601332
DATE : 05.06.2026
REQ No : 1032600866
REQ TITLE : Blow-door test for GT enclosu
DELIVERY LOCATION
CLOSING DATE : 11.06.2026
CLOSING TIME : 10:00:00

extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP