

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATION TITLE: M STATION DIVER DAMPER COUPLING BORE</p> <p>SCOPE INSPECTION A.# QUANTITY & DURATION:##06 (UNIT 11, 12, 21, 22, 31, 32)## DURATION # 01 DAY FOR EACH UNIT. B.# SCHEDULE## WORK TO BE CARRIED OUT DURING HRSG 11, 12, 21, 22, 31 & 32 OUTAGES BETWEEN OCT#2026 TO MAY#2027.##01 DAY OF ADVANCE NOTICE WILL BE PROVIDED BEFORE EACH SHUTDOWN C.# PRE-BID SITE INSPECTION:## THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED. D.# QUALIFICATION OF BIDDER:## THE</p>	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBSE.#SCOPE OF WORK:##MOBILIZE TECHNICIAN/EQUIPMENT WITHIN 01 DAY OF ADVANCE NOTICE</p> <p>##OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE).##SUBMIT THE FOLLOWING DOCUMENTS TO OBTAIN PTW,O#METHOD STATEMENTO#RISK ASSESSM ENT OF THE WORK.O#TOOLBOX TALK REPORT.##CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.##ENSURE PROPER I SOLATION OF THE SYSTEM AND CONFINED SPACE ENTRY PERMITIS AVAILABLE.##ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.##VERIFY THAT SCAFFOLDS ARE SAFE TO WORK WITH AND VALID SCAFFOLDINGTAGS ARE PROVIDED PRIOR TO USE.##IF THE WORKING ENVIRONM ENT IS SAFE, THEN THE CONTRACTOR CAN PROCEEDWITH THE FOLLOWING STEPS.##CARRY OUT BORESCOPE INSPECTION OF DD LHS & RHS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COUPLING THROU GHINSPECTION HOLES##INSPECTION HOLE DIAMETER IS AROUND 10 TO 15 MM (APPROX.)##RECORD HIGH RESOLUTION IMAGES AND VIDEO FOR DOCUMENTAT ION##MARK ANY CRACK DEFECTS AND MEASURE THE LENGTH OF THE CRACK (IF ANY)##ENSURE NO FOREIGN MATERIALS ARE LEFT INSIDE THE INSPECTION HOLES ORCOUPLING##SUBMIT REPORT INCLUDING PHOTOS & VIDEOS AND IDENTIFIED DEFECTS.##BOREScope EQUIPMENT SHALL HAVE VALID CALIBRATION CERTIFICATENOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES BROAD OUTLINE OF THETASK. THE BIDDER IS EXPECTED TO REVIEW THE ADEQUACY OF THE PROPOSEDScope OF WORKS TO CARRY OUT REQUIRED TASK AND ADD ANY ADDITIONAL WORKTHAT IS NEEDED FOR SATISFACTORY COMPLETION OF T HIS PROJECT.F.#GENERAL TERMS & CONDITIONS##THE CONTRACTOR SHALL HAVE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PREVIOUS WORK EXPERIENCE FOR THE SAME JOB##THE CONTRACTOR SHALL SUBMIT THE METHOD OF STATEMENT AND SCHEDULE UPONRECEIPT OF PO.##ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ONDEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED.##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES ETC., BEFORE SUBMITTING THE BID.##THE CONTRACTOR SHALL ENSURE DAILY HOUSEKEEPING, AND THE CONTRACTORSHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATEDPLACES.##ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA.##SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA.##THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT.##CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK.##DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICAL LAB / FIRE DEPARTMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDER THIS CONTRACT.##THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.##ALL THE CONTRACTOR STAFF SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.##ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ARED AT THE POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BYDEWA SECURITY. THE COPIES OF THESE DOCUMENTS SH</p> <p>ALL BE LODGED WITH DEWAENGINEER IN CHARGE ON A DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FORTHE CLEARANCE (GATE PASS) TO TAKE THE</p> <p>M OUT ON COMPLETION OF THE JOB.##SERVICE AIR, ELECTRICITY, AND WATER FOR WORK AT DEWA SITE. IT IS THERESPONSIBILITY OF THE CONTRACT</p> <p>OR TO HAVE HIS OWN ARRANGEMENT INEXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORKINCLUDING LIGHTING.</p>						
2		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATIONTITLE: M STATION DIVER DAMPER COUPLING BORE</p> <p>SCOPE INSPECTIONA.#QUANTITY & DURATION:##06 (UNIT 11, 12, 21, 22, 31, 32)##DURATION # 01 DAY FOR EACH UNIT.B.#SCHEDULE##WORK TO BE C</p>	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ARRIED OUT DURING HRSG 11, 12, 21, 22, 31 & 32 OUTAGESBETWEEN OCT#2026 TO MAY#2027.##01 DAY OF ADVANCE NOTICE WILL BE PROVIDED BEFOR E EACH SHUTDOWNC.#PRE-BID SITE INSPECTION:##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLYFAMILIAR WITH THE WORK SCOP E, PLANT ACCESS, FACILITIES, COMPLEXITIES,ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE SUBMITTING THE BID.DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES /PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED.D.#QUALIFICATION OF BIDDER:##THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBSE.#SCOPE OF WORK:##MOBILIZE TECHNICIAN/EQUIPMENT WITHIN 01 DAY OF ADVANCE NOTICE .##OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE).##SUBMIT THE FOLLOWING DOCUMENTS TO OBTAIN PTW,O#METHOD</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>STATEMENTO#RISK ASSESSM ENT OF THE WORK.O#TOOLBOX TALK REPORT.##CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.##ENSURE PROPER I SOLUTION OF THE SYSTEM AND CONFINED SPACE ENTRY PERMITIS AVAILABLE.##ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.##VERIFY THAT SCAFFOLDS ARE SAFE TO WORK WITH AND VALID SCAFFOLDINGTAGS ARE PROVIDED PRIOR TO USE.##IF THE WORKING ENVIRONM ENT IS SAFE, THEN THE CONTRACTOR CAN PROCEEDWITH THE FOLLOWING STEPS.##CARRY OUT BORESCOPE INSPECTION OF DD LHS & RHS COUPLING THROU GHINSPECTION HOLES##INSPECTION HOLE DIAMETER IS AROUND 10 TO 15 MM (APPROX.)##RECORD HIGH RESOLUTION IMAGES AND VIDEO FOR DOCUMENTAT ION##MARK ANY CRACK DEFECTS AND MEASURE THE LENGTH OF THE CRACK (IF ANY)##ENSURE NO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOREIGN MATERIALS ARE LEFT INSIDE THE INSPECTION HOLES OR COUPLING##SUBMIT REPORT INCLUDING PHOTOS & VIDEOS AND IDENTIFIED DEFECTS.##BOREScope EQUIPMENT SHALL HAVE VALID CALIBRATION CERTIFICATE NOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES BROAD OUTLINE OF THE TASK. THE BIDDER IS EXPECTED TO REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORKS TO CARRY OUT REQUIRED TASK AND ADD ANY ADDITIONAL WORK THAT IS NEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT.F.#GENERAL TERMS & CONDITIONS##THE CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SAME JOB##THE CONTRACTOR SHALL SUBMIT THE METHOD OF STATEMENT AND SCHEDULE UPON RECEIPT OF PO.##ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THIS EQUIPMENT SHOULD BE DULY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TESTED AND CERTIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED.##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE SUBMITTING THE BID.##THE CONTRACTOR SHALL ENSURE DAILY HOUSEKEEPING, AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATED PLACES.##ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR'S ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA.##SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA.##THE WORK</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PERQUALITY/SCHEDULE REQUIREMENT.##CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THEPERIOD OF WORK.##DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICALLAB / FIRE DEPARTMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDERTHIS CONTRACT.##THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.##ALL THE CONTRACTOR STAFF SHOULD WEAR ALL THE REQUIRED PPE WHILE ATWORK.##ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THE POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BYDEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL ALL BE LODGED WITH DEWAENGINEER IN CHARGE ON A DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE M OUT ON COMPLETION OF THE JOB.##SERVICE AIR, ELECTRICITY, AND WATER FOR WORK AT DEWA SITE. IT IS THERESPONSIBILITY OF THE CONTRACT OR TO HAVE HIS OWN ARRANGEMENT INEXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORKINCLUDING LIGHTING.						
3		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATIONTITLE: M STATION DIVER DAMPER COUPLING BORE SCOPE INSPECTIONA.#QUANTITY & DURATION:##06 (UNIT 11, 12, 21, 22, 31, 32)##DURATION # 01 DAY FOR EACH UNIT.B.#SCHEDULE##WORK TO BE C ARRIED OUT DURING HRSG 11, 12, 21, 22, 31 & 32 OUTAGESBETWEEN OCT#2026 TO MAY#2027.##01 DAY OF ADVANCE NOTICE WILL BE PROVIDED BEFOR E EACH SHUTDOWNC.#PRE-BID SITE INSPECTION:##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLYFAMILIAR	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WITH THE WORK SCOP E, PLANT ACCESS, FACILITIES, COMPLEXITIES,ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE SUBMITTING THE BID.DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES /PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED.D.#QUALIFICATION OF BIDDER:##THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBSE.#SCOPE OF WORK:##MOBILIZE TECHNICIAN/EQUIPMENT WITHIN 01 DAY OF ADVANCE NOTICE .##OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE).##SUBMIT THE FOLLOWING DOCUMENTS TO OBTAIN PTW,O#METHOD STATEMENTO#RISK ASSESSM ENT OF THE WORK.O#TOOLBOX TALK REPORT.##CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.##ENSURE PROPER I SOLUTION OF THE SYSTEM AND CONFINED SPACE ENTRY PERMITIS AVAILABLE.##ENSURE THE AREA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.##VERIFY THAT SCAFFOLDS ARE SAFE TO WORK WITH AND VALID SCAFFOLDINGTAGS ARE PROVIDED PRIOR TO USE.##IF THE WORKING ENVIRONM ENT IS SAFE, THEN THE CONTRACTOR CAN PROCEEDWITH THE FOLLOWING STEPS.##CARRY OUT BORESCOPE INSPECTION OF DD LHS & RHS COUPLING THROU GHINSPECTION HOLES##INSPECTION HOLE DIAMETER IS AROUND 10 TO 15 MM (APPROX.)##RECORD HIGH RESOLUTION IMAGES AND VIDEO FOR DOCUMENTAT ION##MARK ANY CRACK DEFECTS AND MEASURE THE LENGTH OF THE CRACK (IF ANY)##ENSURE NO FOREIGN MATERIALS ARE LEFT INSIDE THE INSPECTION HOLES ORCOUPLING##SUBMIT REPORT INCLUDING PHOTOS & VIDEOS AND IDENTIFIED DEFECTS.##BOREScope EQUIPMENT SHALL HAVE VALID CALIBRATION CERTIFICATENOTE: SCOPE OF WORK MENTIONED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HERE ONLY PROVIDES BROAD OUTLINE OF THE TASK. THE BIDDER IS EXPECTED TO REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORKS TO CARRY OUT REQUIRED TASK AND ADD ANY ADDITIONAL WORK THAT IS NEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT.</p> <p>GENERAL TERMS & CONDITIONS</p> <p>##THE CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SAME JOB##</p> <p>THE CONTRACTOR SHALL SUBMIT THE METHOD OF STATEMENT AND SCHEDULE UPON RECEIPT OF PO.</p> <p>##ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED.</p> <p>##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE SUBMITTING THE BID.##THE CONTRACTOR SHALL ENSURE DAILY HOUSEKEEPING, AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATED PLACES.##ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA.##SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA.##THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT.##CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK.##DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICAL LAB / FIRE DEPARTMENT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDER THIS CONTRACT.##THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.##ALL THE CONTRACTOR STAFF SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.##ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THE POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWA ENGINEER IN CHARGE ON A DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THE WORK OUT ON COMPLETION OF THE JOB.##SERVICE AIR, ELECTRICITY, AND WATER FOR WORK AT DEWA SITE. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT FOR EXTENDING THE ELECTRICITY AND WATER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			UTILITY TO HIS PLACES OF WORK INCLUDING LIGHTING.						
4		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATION TITLE: M STATION DIVER DAMPER COUPLING BORE</p> <p>SCOPE INSPECTION A.# QUANTITY & DURATION:##06 (UNIT 11, 12, 21, 22, 31, 32)## DURATION # 01 DAY FOR EACH UNIT. B.# SCHEDULE## WORK TO BE CARRIED OUT DURING HRSG 11, 12, 21, 22, 31 & 32 OUTAGES BETWEEN OCT#2026 TO MAY#2027.##01 DAY OF ADVANCE NOTICE WILL BE PROVIDED BEFORE EACH SHUTDOWN. C.# PRE-BID SITE INSPECTION:## THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE</p>	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EXECUTION OF WORK ORDERED.D.#QUALIFICATION OF BIDDER:##THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBSE.#SCOPE OF WORK:##MOBILIZE TECHNICIAN/EQUIPMENT WITHIN 01 DAY OF ADVANCE NOTICE .##OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE).##SUBMIT THE FOLLOWING DOCUMENTS TO OBTAIN PTW,O#METHOD STATEMENTO#RISK ASSESSM ENT OF THE WORK.O#TOOLBOX TALK REPORT.##CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.##ENSURE PROPER I SOLUTION OF THE SYSTEM AND CONFINED SPACE ENTRY PERMITIS AVAILABLE.##ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.##VERIFY THAT SCAFFOLDS ARE SAFE TO WORK WITH AND VALID SCAFFOLDINGTAGS ARE PROVIDED PRIOR TO USE.##IF THE WORKING ENVIRONM ENT IS SAFE, THEN THE CONTRACTOR CAN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROCEED WITH THE FOLLOWING STEPS.##CARRY OUT BORESCOPE INSPECTION OF DD LHS & RHS COUPLING THROU GHINSPECTION HOLES##INSPECTION HOLE DIAMETER IS AROUND 10 TO 15 MM (APPROX.)##RECORD HIGH RESOLUTION IMAGES AND VIDEO FOR DOCUMENTATION##MARK ANY CRACK DEFECTS AND MEASURE THE LENGTH OF THE CRACK (IF ANY)##ENSURE NO FOREIGN MATERIALS ARE LEFT INSIDE THE INSPECTION HOLES OR COUPLING##SUBMIT REPORT INCLUDING PHOTOS & VIDEOS AND IDENTIFIED DEFECTS.##BOREScope EQUIPMENT SHALL HAVE VALID CALIBRATION CERTIFICATE</p> <p>NOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES BROAD OUTLINE OF THE TASK. THE BIDDER IS EXPECTED TO REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORKS TO CARRY OUT REQUIRED TASK AND ADD ANY ADDITIONAL WORK THAT IS NEEDED FOR SATISFACTORY COMPLETION OF T</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HIS PROJECT.F.#GENERAL TERMS & CONDITIONS##THE CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SAME JOB##THE CONTRACTOR SHALL SUBMIT THE METHOD OF STATEMENT AND SCHEDULE UPONRECEIPT OF PO.##ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ONDEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED.##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES ETC., BEFORE SUBMITTING THE BID.##THE CONTRACTOR SHALL ENSURE DAILY HOUSEKEEPING, AND THE CONTRACTORSHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATEDPLACES.##ALL DEWA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SAFETY & ENVIR ONMENT POLICY, RULES AND REGULATIONS SHALL BEFOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#SENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN AHAZARDOUS AREA.##SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA.##THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PERQUALITY/SCHEDULE REQUIREMENT.##CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SIT E THROUGHOUT THEPERIOD OF WORK.##DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICALLAB / FIRE DEPARTMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDERTHIS CONTRACT.##THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE ASAFE WORKING CONDITION.##ALL THE CONTRACTOR STAFF SHOULD WEAR ALL THE REQUIRED PPE WHILE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ATWORK.##ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THE POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BYDEWA SECURITY. THE COPIES OF THESE DOCUMENTS SH ALL BE LODGED WITH DEWAENGINEER IN CHARGE ON A DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FORTHE CLEARANCE (GATE PASS) TO TAKE THE M OUT ON COMPLETION OF THE JOB.##SERVICE AIR, ELECTRICITY, AND WATER FOR WORK AT DEWA SITE. IT IS THERESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT INEXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORKINCLUDING LIGHTING.</p>						
5		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATIONTITLE: M STATION DIVER DAMPER COUPLING BORE SCOPE INSPECTIONA.#QUANTITY & DURATION:##06</p>	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>(UNIT 11, 12, 21, 22, 31, 32)##DURATION # 01 DAY FOR EACH UNIT.B.#SCHEDULE##WORK TO BE CARRIED OUT DURING HRSG 11, 12, 21, 22, 31 & 32 OUTAGESBETWEEN OCT#2026 TO MAY#2027.##01 DAY OF ADVANCE NOTICE WILL BE PROVIDED BEFOR</p> <p>E EACH SHUTDOWNC.#PRE-BID SITE INSPECTION:##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLYFAMILIAR WITH THE WORK SCOP</p> <p>E, PLANT ACCESS, FACILITIES, COMPLEXITIES,ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE SUBMITTING THE BID.DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES /PRICES DURING AND AFTER THE EXECUTION OF WORK</p> <p>ORDERED.D.#QUALIFICATION OF BIDDER:##THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBSE.#SCOPE OF WORK:##MOBILIZE TECHNICIAN/EQUIPMENT WITHIN 01 DAY OF ADVANCE NOTICE</p> <p>.##OBTAIN PTW (PERMIT TO WORK) / LC (LINE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CLEARANCE).##SUBMIT THE FOLLOWING DOCUMENTS TO OBTAIN PTW,O#METHOD STATEMENTO#RISK ASSESSMENT OF THE WORK.O#TOOLBOX TALK REPORT.##CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.##ENSURE PROPER ISOLATION OF THE SYSTEM AND CONFINED SPACE ENTRY PERMITIS AVAILABLE.##ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.##VERIFY THAT SCAFFOLDS ARE SAFE TO WORK WITH AND VALID SCAFFOLDINGTAGS ARE PROVIDED PRIOR TO USE.##IF THE WORKING ENVIRONM ENT IS SAFE, THEN THE CONTRACTOR CAN PROCEEDWITH THE FOLLOWING STEPS.##CARRY OUT BORESCOPE INSPECTION OF DD LHS & RHS COUPLING THROU GHINSPECTION HOLES##INSPECTION HOLE DIAMETER IS AROUND 10 TO 15 MM (APPROX.)##RECORD HIGH RESOLUTION IMAGES AND VIDEO FOR DOCUMENTAT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ION##MARK ANY CRACK DEFECTS AND MEASURE THE LENGTH OF THE CRACK (IF ANY)##ENSURE NO FOREIGN MATERIALS ARE LEFT INSIDE THE INSPECTION HOLES ORCOUPLING##SUBMIT REPORT INCLUDING PHOTOS & VIDEOS AND IDENTIFIED DEFECTS.##BOREScope EQUIPMENT SHALL HAVE VALID CALIBRATION CERTIFICATE NOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES BROAD OUTLINE OF THE TASK. THE BIDDER IS EXPECTED TO REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORKS TO CARRY OUT REQUIRED TASK AND ADD ANY ADDITIONAL WORK THAT IS NEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT.F.#GENERAL TERMS & CONDITIONS##THE CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SAME JOB##THE CONTRACTOR SHALL SUBMIT THE METHOD OF STATEMENT AND SCHEDULE UPON RECEIPT OF PO.##ALL TRANSPORTING AND REQUIRED EQUIPMENT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHOULD BE ARRANGED BY THE CONTRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED.##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE SUBMITTING THE BID.##THE CONTRACTOR SHALL ENSURE DAILY HOUSEKEEPING, AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATED PLACES.##ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA.##SCAFFOLDING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>IF REQUIRED SHALL BE ARRANGED BY DEWA.##THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PERQUALITY/SCHEDULE REQUIREMENT.##CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THEPERIOD OF WORK.##DEWA WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICALLAB / FIRE DEPARTMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDERTHIS CONTRACT.##THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE ASAFE WORKING CONDITION.##ALL THE CONTRACTOR STAFF SHOULD WEAR ALL THE REQUIRED PPE WHILE ATWORK.##ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THE POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BYDEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWAENGINEER IN CHARGE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ON A DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THE M OUT ON COMPLETION OF THE JOB.##SERVICE AIR, ELECTRICITY, AND WATER FOR WORK AT DEWA SITE. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT IN EXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORK INCLUDING LIGHTING.						
6		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M STATION, JEBELALI POWER STATION TITLE: M STATION DIVER DAMPER COUPLING BORE SCOPE INSPECTION A.#QUANTITY & DURATION:##06 (UNIT 11, 12, 21, 22, 31, 32)##DURATION # 01 DAY FOR EACH UNIT. B.#SCHEDULE##WORK TO BE CARRIED OUT DURING HRSG 11, 12, 21, 22, 31 & 32 OUTAGES BETWEEN OCT#2026 TO MAY#2027.##01 DAY OF ADVANCE NOTICE WILL BE PROVIDED BEFORE EACH SHUTDOWN C.#PRE-BID SITE	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSPECTION:##THE CONTRACTOR SHALL VISIT THE SITE AND MAKE THEMSELVES FULLYFAMILIAR WITH THE WORK SCOP E, PLANT ACCESS, FACILITIES, COMPLEXITIES,ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE SUBMITTING THE BID.DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES /PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED.D.#QUALIFICATION OF BIDDER:##THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBSE.#SCOPE OF WORK:##MOBILIZE TECHNICIAN/EQUIPMENT WITHIN 01 DAY OF ADVANCE NOTICE .##OBTAIN PTW (PERMIT TO WORK) / LC (LINE CLEARANCE).##SUBMIT THE FOLLOWING DOCUMENTS TO OBTAIN PTW,O#METHOD STATEMENTO#RISK ASSESSM ENT OF THE WORK.O#TOOLBOX TALK REPORT.##CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.##ENSURE PROPER I</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SOLUTION OF THE SYSTEM AND CONFINED SPACE ENTRY PERMITIS AVAILABLE.##ENSURE THE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.##VERIFY THAT SCAFFOLDS ARE SAFE TO WORK WITH AND VALID SCAFFOLDINGTAGS ARE PROVIDED PRIOR TO USE.##IF THE WORKING ENVIRONM ENT IS SAFE, THEN THE CONTRACTOR CAN PROCEEDWITH THE FOLLOWING STEPS.##CARRY OUT BORESCOPE INSPECTION OF DD LHS & RHS COUPLING THROU GHINSPECTION HOLES##INSPECTION HOLE DIAMETER IS AROUND 10 TO 15 MM (APPROX.)##RECORD HIGH RESOLUTION IMAGES AND VIDEO FOR DOCUMENTAT ION##MARK ANY CRACK DEFECTS AND MEASURE THE LENGTH OF THE CRACK (IF ANY)##ENSURE NO FOREIGN MATERIALS ARE LEFT INSIDE THE INSPECTION HOLES ORCOUPLING##SUBMIT REPORT INCLUDING PHOTOS & VIDEOS AND IDENTIFIED DEFECTS.##BORESCOPE EQUIPMENT SHALL HAVE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VALID CALIBRATION CERTIFICATE NOTE: SCOPE OF WORK MENTIONED HERE ONLY PROVIDES BROAD OUTLINE OF THE TASK. THE BIDDER IS EXPECTED TO REVIEW THE ADEQUACY OF THE PROPOSED SCOPE OF WORKS TO CARRY OUT REQUIRED TASK AND ADD ANY ADDITIONAL WORK THAT IS NEEDED FOR SATISFACTORY COMPLETION OF THIS PROJECT. F. #GENERAL TERMS & CONDITIONS ## THE CONTRACTOR SHALL HAVE PREVIOUS WORK EXPERIENCE FOR THE SAME JOB ## THE CONTRACTOR SHALL SUBMIT THE METHOD OF STATEMENT AND SCHEDULE UPON RECEIPT OF PO. ## ALL TRANSPORTING AND REQUIRED EQUIPMENT SHOULD BE ARRANGED BY THE CONTRACTOR. THIS EQUIPMENT SHOULD BE DULY TESTED AND CERTIFIED BY THE 3RD PARTY INSPECTION AGENCY AND THE CERTIFICATES SHOULD BE PRODUCED ON DEMAND. QUALIFIED MECHANICS SHOULD BE PROVIDED. ## THE CONTRACTOR SHALL VISIT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE SUBMITTING THE BID.##THE CONTRACTOR SHALL ENSURE DAILY HOUSEKEEPING, AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATED PLACES.##ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR#SENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA.##SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA.##THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT.##CONTRACTOR#S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT THE PERIOD OF WORK.##DEWA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WILL ARRANGE NECESSARY PTW / LC / HWP FROM OPERATION, CHEMICALLAB / FIRE DEPARTMENT CLEARANCES TO CARRY OUT THE SCOPE OF WORK UNDER THIS CONTRACT.##THE CONTRACTOR UPON RECEIVING THE WORK PERMIT SHALL FIRST ENSURE A SAFE WORKING CONDITION.##ALL THE CONTRACTOR STAFF SHOULD WEAR ALL THE REQUIRED PPE WHILE AT WORK.##ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT THE POWERSTATION SECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWA SECURITY. THE COPIES OF THESE DOCUMENTS SHALL BE LODGED WITH DEWA ENGINEER IN CHARGE ON A DAILY BASIS. THIS DOCUMENT WILL BE THE BASIS FOR THE CLEARANCE (GATE PASS) TO TAKE THE WORK OUT ON COMPLETION OF THE JOB.##SERVICE AIR, ELECTRICITY, AND WATER FOR WORK AT DEWA SITE. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OR TO HAVE HIS OWN ARRANGEMENT INEXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORK INCLUDING LIGHTING.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

M Station Diver Damper Coupling Borescope inspection

(Refer attached scope of work for details)

Contact : ashil.prabhakar@dewa.gov.ae / +971-4322-6179

STANDARD TERMS & CONDITIONS

1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.

2) Prices should be 'DDP' delivery duty paid at DEWA stores.

3) Quotation to be submitted only in local currency U.A.E Dirhams

4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601397
DATE	: 16.06.2026
REQ No	: 1032602558
REQ TITLE	: M Station Diver Damper Coupli
DELIVERY LOCATION	
CLOSING DATE	: 22.06.2026
CLOSING TIME	: 10:00:00

5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.

7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:

a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.

b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.

c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.

d) DEWA reserves the right to withhold data from third parties if deemed sensitive.

e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.

f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.

g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601397
DATE	: 16.06.2026
REQ No	: 1032602558
REQ TITLE	: M Station Diver Damper Coupli
DELIVERY LOCATION	
CLOSING DATE	: 22.06.2026
CLOSING TIME	: 10:00:00

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

- 10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.
- 11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.
- 12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.
- 13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.
- 14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.
- 15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601397
DATE : 16.06.2026
REQ No : 1032602558
REQ TITLE : M Station Diver Damper Coupli
DELIVERY LOCATION
CLOSING DATE : 22.06.2026
CLOSING TIME : 10:00:00

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP