

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M-STATION, JEBELALI POWER STATION1.#TITLE: M-STATION HRSG TUBE REPLACEMENT WORK (BY HARP SWING METHOD)2.#SPECIFICATION:##HEADER MATERIAL: SA106 # C##HEADER SIZE: 273 X 34 MM##TUBE MATERIAL: SA210-C##TUBE SIZE : 38.1 X 2.8 MM.3.#QUANTITY:##SERVICE LINE ITEM 1: - 1 EA. HARP SWING WITH ONE LEAKING BEND TUBEREPLACEMENT.##SERVICE LINE ITEM 2: - ADDITIONAL 1 EA. TUBE BEND REPLACEMENT ( INCASE OF ANY NEW LEAK FOUND DURING THE FINAL HYDROTEST )4.#WORK DURATION:TO BE COMPLETED IN 05 DAYS + 01 EXTRA DAY FOR SERVICE LINE ITEM NO. 2 INCASE REQUIRED5.#PRE-BID SITE INSPECTION:THE CONTRACTOR SHALL VISIT THE SITE AND INSPECT THE STEM AND BE FULLYFAMILIAR WITH THE WORK SCOPE, BEFORE SUBMITTING THE BID. DEWA WILL NOTACCEPT ANY CLAIM FOR EXTRAS B</p>	1	AU				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EYOND THE ORDER RATES / PRICES DURING ANDAFTER THE EXECUTION OF WORK.6.#CONTACT DETAILS FOR SITE VISIT.NIVAS BALAMURUGAN ANGUSAMY / NIVAS.ANGUSAMY@DEWA.GOV.AE / +971-4322-5609SHABBIR AHMAD ENULHAQUE SHABBIR.ENULHAQUE@DEWA.GOV.AE / +971-4322-59697.#QUALIFICATION OF BIDDER:THE BIDDER SHALL HAVE PROVEN EXPERIENCE FOR SIMILAR JOBS AND SHALLSUBMIT EVIDENCE (IF REQUIRED) THE BIDDER SHALL BE ASME #R# STAMPCERTI#CATE/DOCUMENTS HOLDER.8.#SCOPE OF WORK:##MOBILIZE MEN/EQUIPMENT.##SUBMIT METHOD STATEMENT, RISK ASSESSMENT OF THE WORK, TOOLBOX TALKREPORT PTW,##ENSURE HRSG IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.##ENSURE LC, CON#NED SPACE ENTRY PERMI T AND HOT WORK PERMIT AREAVAILABLE PRIOR TO STARTING THE WORK.##IDENTIFY THE LEAKING LOCATION ALONG WITH DEWA</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ENGINEERS.##ERECT SCAF            FOLDING FOR ACCESS TO REMOVE RHS/LHS SIDE            &amp; CENTRE CASINGBAF#E PLATES. (DEWA            SCOPE)##REMOVE RHS/LHS SIDE &amp; CENTRE            CASING GAS BAF#E P            LATES.##REMOVE ANTI-VIBRATION            SUPPORTS.##REMOVE LOWER HEADER            INSULATION PADS.##REMOVE SCAFFOLDING            (DEWA SCOPE)##REMOVE #OOR GAS BAF#            E PLATES.##CUT BOTTOM BUMPER GUIDES.##CUT            DRAIN LINES FOR HEADER NO. 09,10, 11 &amp; 12 (AS            REQUIRED TO PREPAREFOR HARP SWING AS PER            THE            LEAKING LOCATION).##SWING LOWER HEADERS            (DEPENDING ON LEAKING MODULE AND HEADER)            TOWARDSGT SIDE USING CHAIN BLOCKS TO MAKE            ACCESS F            OR NDT AND REPLACEMENT OF THELEAKING            TUBE.##PROVIDE TEMPORARY SUPPORT            BETWEEN CONSECUTIVE LOWER            HEADERS.##ALONG WITH DEWA IDENTIFY/M            ARK THE EXACT TUBE ON LOWER HEADER##CUT            AND REMOVE THE LEAKING TUBE(S)</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BEND(S).##COLLECT STRAIGHT TUBES FROM DEWA AND BEND IT AS PER OLD SAMPLE.##PREPARE THE WELD AREAS.##FIT UP THE TOP JOINT - NEW TUBE BEND TO EXISTING STRAIGHT TUBE (S).##WELD THE TUBE(S) BY GTAW BUTT WELD.##RT FOR THE WELD JOINT (DEWA SCOPE)##UPON SUCCESSFUL RT RESULT PROCEED FOR FIT UP BOTTOM JOINT - NEW TUBEBEND TO BOTTOM HEADER##WELD THE TUBE(S) BY GTAW #LLET WELDING AS PER WPS.##DPT FOR THE #LLET WELD JOINT (DEWA SCOPE)##UPON SUCCESSFUL DPT RESULT PROCEED FOR PWHT (DEWA SCOPE)##AFTER COMPLETION OF PWHT HEADER RESTORATION BY HARP SWING BACK TO ORIGINAL POSITION##WELD BACK 2-INCH DRAIN LINES##RT/DPT FOR DRAIN LINES (DEWA SCOPE)##WELD BACK THE #NS ON LOWER HEADERS (SUPPLY OF #NS PLATE IF REQUIRED IS UNDER CONTRACT OR SCOPE)##WELD THE INSULATION PAD STUDS ON LOWER HEADERS (SUPPLY OF STUDS &amp; NUTS</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>UNDER CONTRACTOR SCOPE)##WELD BACK            BOTTOM BUMPER GU            IDES.##DPT OF WELD JOINTS (DEWA            SCOPE)##HYDROTEST BY DEWA.##IN CASE OF ANY            NEW LEAK FOUND DURING THE HYDROTEST,            SERVICE LINE ITEM2 W            ILL BE APPLICABLE IE: HARP SWINGING AND 1 NO            OF LEAKING TUBE BENDREPLACEMENT AND            ASSOCIATED WORKS NEED TO BE EXECUTED            BASED ON THEL            EAKING LOCATION.##UPON SUCCESSFUL            HYDROTEST # #OOR PLATE            RESTORATION##SCAFFOLD ERECTION INSIDE            HARPY (DEWA)##REINSTALL THE SIDE AND            CENTRE BAF#E PLATES AND            ANTI-VIBRATIONSUPPORTS.##DPT OF WELD            JOINTS (DEWA SCOPE)##REMOVE SCAFFOLDING            (DEWA SCOPE).##RE#X INSULATION            PADS.##HOUSEKEEPING AND #OOR MANHOLE            CLOSING9.#CONTACTOR REQUIREMENT:##WORK            TO BE CARRIED OUT AROUND THE CLOCK IN DAY            AND NIGHT SHIF            TSWITHOUT ANY INTERRUPTION WITH ADEQUATE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>MANPOWER AND SUPERVISORS IN BOTHSHIFTS.##QUALI#ED JOB SUPERVISOR TO BE ASSIGNED FOR THE JOB .##QUALI#ED &amp; SKILLED FABRICATORS TO CARRY OUT ALL THE JOBS.##ALL WELDING IS TO BE CARRIED OUT BY QUALI#ED WELDERS AND AS PER WPSIN ACCORDANCE WITHREQUIREMENTS OF ASME CODE.##WPS, PQR &amp; WELDER QUALI#CATION CERTI#CATES TO BE SUBMITTED BEFORESTART OF WORK.##ALL TOOL S &amp; TACKLES ARE IN CONTRACTOR'S SCOPE.##VALID TEST CERTI#CATES OF ALL LIFTING TOOLS, ELECTRICAL TOOLS/CABLES,AND GAS CYLINDERS/HOSES TO BE SUBMITTED BEFORE START OF WORK.##VALID CALIBRATION CERTI#CATE FOR WELDING MACHINES TO BE SUBMITTEDBEFORE START OF WORK.##MTC FOR WELDING ELECTRODES, #LLER WIRES, INSULATION PAD STUDS,TUNGSTEN RODS AND ARGON GAS PURITYCERTI#CATE TO BE PROVIDED PRIOR TO START</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OF WORK.##HOUSEKEEPING AND WASTE SEGREGATION SHALL BE DONE AS PER DEWA RULES ON A DAILY BASIS.##HAZARDOUS &amp; NON-HAZARDOUS TO BE SEPARATED.10.#REPORTING:##FINAL COMPLETION REPORT WITH ALL THE REQUIRED PHOTOS TO BE SUBMITTED TO DEWA WITHIN 3 DAYS AFTER COMPLETION OF THE WORK COMPILED WITH ALL CALIBRATION CERTIFICATES, WELDER QUALIFICATION CERTIFICATES, WPS/PQR, MTCS AND 11.#WARRANTY:##THE WARRANTY PERIOD FOR THE WORK SHALL BE 01 YEAR FROM THE DATE OF COMPLETION OF WORK CERTIFIED BY DEWA.##IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN THE SHORTEST PERIOD.12.#DEWA SCOPE:##NDE/PWHT. (CONTRACTOR TO PROVIDE NDE SCHEDULE IN 01-DAY IN ADVANCE)##SUPPLY</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OF SPARES TUBE FOR REPLACEMENT.##FORKLIFT (CONTRACTOR TO PROVIDE REQUEST TO DEWA STATION ENGINEER01-DAY IN ADVANCE)##ELECTRICITY AND WATER (IT IS CONTRACTOR RESPONSIBILITY TO EXTEND THECONNECTION TO THE JOB AS PER SITE REQUIREMENTS)##REQUIRED GATE PASSES, HOLIDAY PERMIT, PT W/CSE AND HWP.##FOR GATE PASSES SUBMIT REQUEST 2 DAYS IN ADVANCE TOBOILER.P2@DEWA.GOV.AE / +971-4322-5912 AND KEEP CONCERNED STATION ENGINEERS IN CC.						
2		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK M-STATION, JEBELALI POWER STATION1.#TITLE: M-STATION HRSG TUBE REPLACEMENT W ORK (BY HARP SWING METHOD)2.#SPECIFICATION:##HEADER MATERIAL: SA106 # C##HEADER SIZE: 273 X 34 MM##TUBE MATERIAL: SA210-C##TUBE SIZE : 38.1 X 2.8 MM.3.#QUANTITY:##SERVICE LINE ITEM	1	AU				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>1: - 1 EA. HARP SWING WITH ONE LEAKING BEND TUBEREPLACEMENT.##SERVICE LINE ITEM 2: - ADDITIONAL 1 EA. TUBE BEND REPLACEMENT ( INCASE OF ANY NEW LEAK FOUND DURING THE FINAL HYDROTEST )4.#WORK DURATION:TO BE COMPLETED            IN 05 DAYS + 01 EXTRA DAY FOR SERVICE LINE ITEM NO. 2 INCASE REQUIRED5.#PRE-BID SITE INSPECTION:THE CONTRACTOR SHALL VISIT THE SITE AND INSPECT THE STEM AND BE FULLYFAMILIAR WITH THE WORK SCOPE, BEFORE SUBMITTING THE BID. DEWA WILL NOTACCEPT ANY CLAIM FOR EXTRAS B            EYOND THE ORDER RATES / PRICES DURING ANDAFTER THE EXECUTION OF WORK.6.#CONTACT DETAILS FOR SITE VISIT.NIVAS BALAMURUGAN ANGUSAMY /            NIVAS.ANGUSAMY@DEWA.GOV.AE /            +971-4322-5609SHABBIR AHMAD ENULHAQUE SHABBIR.ENULHAQUE@DEWA.GOV.AE /            +971-4322-59697.#QUALIFICATION OF BIDDER:THE BIDDER SHALL HAVE PROVEN</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>EXPERIENCE FOR SIMILAR JOBS AND SHALLSUBMIT EVIDENCE (IF REQUIRED) THE BIDDER SHALL BE ASME #R# STAMPCERTI#CATE/DOCUMENTS HOLDER.8.#SCOPE OF WORK:##MOBILIZE MEN/EQUIPMENT.##SUBMIT METHOD STATEMENT, RISK ASSESSMENT OF THE WORK, TOOLBOX TALKREPORT PTW,##ENSURE HRSG IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS.##ENSURE LC, CON#NED SPACE ENTRY PERMI T AND HOT WORK PERMIT AREAVAILABLE PRIOR TO STARTING THE WORK.##IDENTIFY THE LEAKING LOCATION ALONG WITH DEWA ENGINEERS.##ERECT SCAF FOLDING FOR ACCESS TO REMOVE RHS/LHS SIDE &amp; CENTRE CASINGBAF#E PLATES. (DEWA SCOPE)##REMOVE RHS/LHS SIDE &amp; CENTRE CASING GAS BAF#E P LATES.##REMOVE ANTI-VIBRATION SUPPORTS.##REMOVE LOWER HEADER INSULATION PADS.##REMOVE SCAFFOLDING (DEWA SCOPE)##REMOVE #OOR GAS BAF#</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>E PLATES.##CUT BOTTOM BUMPER GUIDES.##CUT DRAIN LINES FOR HEADER NO. 09,10, 11 &amp; 12 (AS REQUIRED TO PREPAREFOR HARP SWING AS PER THE LEAKING LOCATION).##SWING LOWER HEADERS (DEPENDING ON LEAKING MODULE AND HEADER) TOWARDSGT SIDE USING CHAIN BLOCKS TO MAKE ACCESS F OR NDT AND REPLACEMENT OF THELEAKING TUBE.##PROVIDE TEMPORARY SUPPORT BETWEEN CONSECUTIVE LOWER HEADERS.##ALONG WITH DEWA IDENTIFY/MARK THE EXACT TUBE ON LOWER HEADER##CUT AND REMOVE THE LEAKING TUBE(S) BEND(S).##COLLECT STRAIGHT TUBES FROM DEWA AND BEND IT AS PER OLD SAMPLE.##PREPARE THE WELD AREAS.##FIT UP THE TOP JOINT - NEW TUBE BEND TO EXISTING STRAIGHT TUBE (S).##WELD THE TUBE(S) BY GTAW BUTT WELD.##RT FOR THE WELD JOINT (DEWA SCOPE)##UPON SUCCESSFUL RT RESULT PROCEED FOR FIT UP BOTTOM JOINT - NEW TUBEBEND TO BOTTOM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>HEADER###WELD THE TUBE(S) BY GTAW #LLET WELDING AS PER WPS.##DPT FOR THE #LLET WELD JOINT (DEWA SCOPE)##UPON SUCCESSFUL DPT RESULT PROCEED FOR PWHT (DEWA SCOPE)##AFTER COMPLETION OF PWHT HEADER RESTORATION BY HARP SWING BACK TO ORIGINAL POSITION##WELD BACK 2-INCH DRAIN LINES##RT/DPT FOR DRAIN LINES (DEWA SCOPE)##WELD BACK THE #NS ON LOWER HEADERS (SUPPLY OF #NS PLATE IF REQUIRED IS UNDER CONTRACT OR SCOPE)##WELD THE INSULATION PAD STUDS ON LOWER HEADERS (SUPPLY OF STUDS &amp; NUTS UNDER CONTRACTOR SCOPE)##WELD BACK BOTTOM BUMPER GUIDES.##DPT OF WELD JOINTS (DEWA SCOPE)##HYDROTEST BY DEWA.##IN CASE OF ANY NEW LEAK FOUND DURING THE HYDROTEST, SERVICE LINE ITEM2 WILL BE APPLICABLE IE: HARP SWINGING AND 1 NO OF LEAKING TUBE BEND REPLACEMENT AND ASSOCIATED WORKS NEED TO BE EXECUTED</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BASED ON THE L  EAKING LOCATION.##UPON SUCCESSFUL  HYDROTEST # #OOR PLATE  RESTORATION##SCAFFOLD ERECTION INSIDE  HARPY (DEWA)##REINSTALL THE SIDE AND  CENTRE BAF#E PLATES AND  ANTI-VIBRATIONSUPPORTS.##DPT OF WELD  JOINTS (DEWA SCOPE)##REMOVE SCAFFOLDING  (DEWA SCOPE).##RE#X INSULATION  PADS.##HOUSEKEEPING AND #OOR MANHOLE  CLOSING9.#CONTACTOR REQUIREMENT:##WORK  TO BE CARRIED OUT AROUND THE CLOCK IN DAY  AND NIGHT SHIF  TSWITHOUT ANY INTERRUPTION WITH ADEQUATE  MANPOWER AND SUPERVISORS IN  BOTHSHIFTS.##QUALI#ED JOB SUPERVISOR TO BE  ASSIGNED FOR THE JOB  .##QUALI#ED &amp; SKILLED FABRICATORS TO CARRY  OUT ALL THE JOBS.##ALL WELDING IS TO BE  CARRIED OUT BY QUALI#ED WELDERS AND AS PER  WPSIN  ACCORDANCE WITHREQUIREMENTS OF ASME  CODE.##WPS, PQR &amp; WELDER QUALI#CATION</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CERTI#CATES TO BE SUBMITTED BEFORE START OF WORK.##ALL TOOL S &amp; TACKLES ARE IN CONTRACTOR'S SCOPE.##VALID TEST CERTI#CATES OF ALL LIFTING TOOLS, ELECTRICAL TOOLS/CABLES, AND GAS CYLINDERS/HOSES TO BE SUBMITTED BEFORE START OF WORK.##VALID CALIBRATION CERTI#CATE FOR WELDING MACHINES TO BE SUBMITTED BEFORE START OF WORK.##MTC FOR WELDING ELECTRODES, #LLER WIRES, INSULATION PAD STUDS, TUNGSTEN RODS AND ARGON GAS PURITY CERTI#CATE TO BE PROVIDED PRIOR TO START OF WORK.##HOUSEKEEPING AND WASTE SEGREGATION SHALL BE DONE AS PER DEWA RULES ON A DAILY BASIS.##HAZARDOUS &amp; NON-HAZARDOUS TO BE SEPARATED.10.#REPORTING:##FINAL COMPLETION REPORT WITH ALL THE REQUIRED PHOTOS TO BE SUBMITTED TO DEWA WITHIN 3 DAYS AFTER COMPLETION OF THE WORK COMPILED WITH ALL CALIBRATION</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CERTI#CATES, WELDER QUALI#CATION            CERTI#CATES, WPS/PQR,            MTCSAND11.#WARRANTY:##THE WARRANTY PERI            OD FOR THE WORK SHALL BE 01 YEAR FROM THE            DATE OFCOMPLETION OF WORKCERTI#ED BY            DEWA.##IN CASE OF ANY DAMAGE/DEFECT OF THE            WORK CARRI            ED OUT UNDER THISCONTRACT WITHIN THIS            WARRANTY PERIOD, THE CONTRACTOR SHALL            CARRY OUT THENECESSARY REPAIR WORK AND            RECTIFY THE DEFEC            T WITHIN THE SHORTEST PERIOD.12.#DEWA            SCOPE:##NDE/PWHT. (CONTRACTOR TO PROVIDE            NDE SCHEDULE IN 01-DAY IN ADVANCE)##SUPPLY            OF SPARES            TUBE FOR REPLACEMENT.##FORKLIFT            (CONTRACTOR TO PROVIDE REQUEST TO DEWA            STATION ENGINEER01-DAY IN            ADVANCE)##ELECTRICITY AND WATER (IT            IS CONTRACTOR RESPONSIBILITY TO EXTEND            THECONNECTION TO THE JOB AS PER SITE            REQUIREMENTS)##REQUIRED GATE PASSES,            HOLIDAY PERMIT, PT</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			W/CSE AND HWP.##FOR GATE PASSES SUBMIT REQUEST 2 DAYS IN ADVANCE TOBOILER.P2@DEWA.GOV.AE / +971-4322-5912 AND KEEP CONCERNED STATION ENGINEERS IN CC.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

**SPECIAL NOTES / INSTRUCTIONS:**

M-STATION HRSG TUBE REPLACEMENT WORK (BY HARP SWING METHOD)

(The bidder shall be ASME #R# Stamp certificate holder and have previous experience for the similar jobs).

Contact:nivas.angusamy@dewa.gov.ae (0503338429)

**STANDARD TERMS & CONDITIONS**

1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.

2) Prices should be 'DDP' delivery duty paid at DEWA stores.

**MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.**

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.
- 8)Data Privacy, Security and Sharing:
- a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- d) DEWA reserves the right to withhold data from third parties if deemed sensitive.
- e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332601521  
**DATE** : 24.06.2026  
**REQ No** : 1032602818  
**REQ TITLE** : M-STATION HRSG TUBE  
**DELIVERY LOCATION**  
**CLOSING DATE** : 30.06.2026  
**CLOSING TIME** : 10:00:00

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**