

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SCOPE OF WORK: AUX BOILER 87 DAMPER ACTUATORS & GEARBOXES INSPECTION,OVERHAUL AND TESTING OUTAGE DATE: 15.08.2026 (TENTATIVE) DURATION : 7 CALENDAR DAY EQUIPMENT/SYSTEM: AUX BOILER 87 DAMPER ACTUATORS AND ASSOCIATED GEARBOXES 1. OBJECTIVE TO CARRY OUT COMPLETE INSPECTION, DISMANTLING, REFURBISHMENT, REASSEMBLY, CALIBRATION, FUNCTIONAL TESTING, AND COMMISSIONING SUPPORT FOR AUX BOILER 87 DAMPER ACTUATORS AND ASSOCIATED GEARBOXES, ENSURING RELIABLE OPERATION, ACCURATE POSITIONING, PROPER TORQUE TRANSMISSION, AND COMPLIANCE WITH OEM RECOMMENDATIONS, DEWA REQUIREMENTS, APPLICABLE HSE RULES, AND QUALITY STANDARDS. 2. EQUIPMENT COVERED DSN#DESCRIPTION#KKS NO.#1#DAMPER DISCHARGE FD FAN A ACTUATOR#87HLA11AA001#2#DAMPER DISCHARGE	2	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FD FAN B ACTUATOR#87HLA12AA001#3#DAMPER AIR LINE TO BURNER BOX 1#87HLA21AA0 01#4#DAMPER AIR LINE TO BURNER BOX 2#87HLA22AA001#5#DAMPER AIR LINE TO BURNER BOX 3#87HLA23AA001#6#DAMPER SUCTION FGR FAN A#87HNF11A A001#7#DAMPER DISCHARGE FGR FAN A#87HNF11AA003#8#DAMPER SUCTION FGR FAN B#87HNF12AA001#9#DAMPER DISCHARGE FGR FAN B#87HNF12AA003#10# AUX BOILER STACK INLET DAMPER ACTUATOR#87HNA10AA001#11#FD FAN-A IGV ACTUATOR#87HLB11AA001#12#FD FAN-B IGV ACTUATOR#87HLB12AA001#3. S COPE OF WORK DETAILS3.1 PRE-OUTAGE ACTIVITIES.#CONDUCT SITE VISIT AND FAMILIARIZE WITH EQUIPMENT LOCATION, ACCESSREQUIREMENTS, LIFTI NG REQUIREMENTS, AND JOB-SPECIFIC SAFETY PRECAUTIONS.#COORDINATE WITH OPERATIONS AND I&C FOR EQUIPMENT ISOLATION,PERMISSIVE CLEARAN CES, PTW REQUIREMENTS, AND LOOP-CHECK						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>READINESS.#CONFIRM AVAILABILITY OF REQUIRED MANPOWER, TOOLS, LIFTING EQUIPMENT,SPARE PARTS, CONSUMABLES, CALIBRATED INSTRUMENTS, AND APPROVEDLUBRICANTS.3.2 DISMANTLING AND INSPECTION.#CHECK, RECORD AND MAINTAIN THE SAME TORQUE LIMIT AS EXISTING.#DISMANTLE ACTUATOR AND GEARBOX ASSEMBLIES IN A CONTROLLED MANNERAFTER CONFIRMING ISOLATION AND SAFE ACCESS.#INSPECT GEAR TRAIN, WORM GEARS, PLANETARY GEARS, BEARINGS, BUSHINGS,SHAFTS, COUPLINGS, KEYWAYS, SEALS, LIMIT SWITCHES, TORQUE SWITCHES , ANDACTUATOR MOTOR CONDITION.#CHECK FOR WEAR, CORROSION, ABNORMAL BACKLASH, MISALIGNMENT,MECHANICAL LOOSENESS, DAMAGED FASTENERS, OIL/GREASE CONTAMINATION, ANDSEALING DETERIORATION.#DPT FOR GEARBOX GEARS.#RECORD AS-FOUND CONDITION WITH PHOTOGRAPHS AND INSPECTIO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NOBSERVATIONS BEFORE CLEANING OR REPAIR.3.3 CLEANING.#REMOVE OLD GREASE, OIL RESIDUE, DUST, DEPOSITS, AND FOREIGN MATERIALFROM ACTUA TOR AND GEARBOX INTERNAL PARTS.#CLEAN COMPONENTS USING APPROVED SOLVENTS, LINT FREE CLOTHS, ANDSUITABLE CLEANING METHODS WITHOUT DA MAGING MACHINED SURFACES ORELECTRICAL PARTS.#PREPARE MATING SURFACES, COVERS, SEALS, AND FASTENERS PRIOR TOREASSEMBLY.3.4 REPAIR AN D REPLACEMENT.#REPLACE DEFECTIVE OR WORN PARTS SUCH AS BEARINGS, SEALS, SWITCHES,GEARS, FASTENERS, COUPLINGS, AND OTHER IDENTIFIED C OMPONENTS USINGOEM-RECOMMENDED OR DEWA-APPROVED SPARE PARTS.(SFOT REPAIR KIT ANDBEARING CONTRACTOR SCOPE-OTHERS SPARE DEWA SCOPE).#R EPAIR REUSABLE COMPONENTS WITHIN OEM TOLERANCES AND RESTORESERVICEABILITY AS APPLICABLE.#CORRECT ABNORMAL GEARBOX</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BACKLASH, RESTORE SEALING INTEGRITY, ANDENSURE FREE MOVEMENT OF MECHANICAL TRANSMISSION COMPONENTS.#REPORT ANY MAJOR DEFECT REQUIRING ADDITIONAL REP AIR, MACHINING,REPLACEMENT, OR ENGINEERING DECISION BEFORE PROCEEDING.3.5 REASSEMBLY.#REASSEMBLE ACTUATOR AND GEARBOX ASSEMBLIES AS PER OEM SEQUENCE ANDRECOMMENDED PRACTICES.#ENSURE CORRECT ALIGNMENT BETWEEN ACTUATOR, GEARBOX, COUPLING, ANDDAMPER SHAFT.#APPLY OE M-APPROVED LUBRICANTS, GREASE, OIL, AND SEALANTS SUITABLE FORTHE OPERATING ENVIRONMENT AND TEMPERATURE ZONE.#TIGHTEN FASTENERS, COU PLINGS, AND LOCKING ARRANGEMENTS TO THEAPPLICABLE TORQUE AND ENSURE PROPER MECHANICAL LOCKING.3.6 TESTING, CALIBRATION, AND SETTING. #CARRY OUT FUNCTIONAL OPEN/CLOSE OPERATION TEST FOR EACH ACTUATOR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ANDGEARBOX ASSEMBLY.#VERIFY TORQUE SWITCH OPERATION, LIMIT SWITCH OPERATION, END-POSITIONREPEATABILITY, AND STROKE DIRECTION.#PERFORM NO-LOAD AND LOADED CHECKS WHERE APPLICABLE, INCLUDINGOBSERVATI ON FOR ABNORMAL NOISE, VIBRATION, OVERHEATING, OR MECHANICALBINDING.#CALIBRATE OPEN/CLOSE LIMIT SWITCHES AND TORQUE SWITCH SETTINGS INCOORDINATION WITH I&C AND OPERATIONS.#VERIFY STROKE TIME AND ENSURE SETTINGS ARE ALIGNED WITH PLANTOPERATING REQUIREMENTS AND CO NTROL LOGIC INTERLOCKS.3.7 DOCUMENTATION AND REPORTING.#SUBMIT DETAILED INSPECTION REPORT INCLUDING AS-FOUND CONDITION,DEFECTS OBSER VED, CORRECTIVE ACTIONS, PARTS REPLACED, PHOTOGRAPHS, ANDRECOMMENDATIONS.#SUBMIT TEST AND CALIBRATION RECORDS FOR EACH ACTUATOR, IN CLUDINGLIMIT SWITCH SETTINGS, TORQUE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SWITCH SETTINGS, STROKE VERIFICATION, ANDFUNCTIONAL TEST RESULTS.#SUBMIT COMPLETION CERTIFICAT E CONFIRMING THAT THE WORK HAS BEENCOMPLETED IN ACCORDANCE WITH OEM RECOMMENDATIONS, DEWA REQUIREMENTS, ANDACCEPTED MAINTENANCE PRAC TICES.4. ACCEPTANCE CRITERIA.#ACTUATOR AND GEARBOX OPERATE SMOOTHLY ACROSS FULL STROKE WITHOUTABNORMAL NOISE, VIBRATION, OVERHEATING , OR MECHANICAL BINDING.#DAMPER ACHIEVES FULL OPEN AND FULL CLOSE POSITIONS WITH CORRECTINDICATION AND REPEATABLE POSITIONING.#TOR QUE AND LIMIT SWITCH SETTINGS ARE VERIFIED AND ALIGNED WITHOEM/PLANT REQUIREMENTS.#NO OIL/GREASE LEAKAGE, ABNORMAL BACKLASH, LOOSE COUPLING, SHAFTMISALIGNMENT, OR MECHANICAL LOOSENESS IS OBSERVED.#DCS/PLC FEEDBACK, COMMAND RESPONSE, INTERLOCKS, AND LOOP CHECKS A</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RECOMPLETED SATISFACTORILY.#FINAL OPERATION IS ACCEPTED BY DEWA MAINTENANCE, OPERATIONS, AND I&CREPRESENTATIVES, AS APPLICABLE.5. HSE AND QUALITY REQUIREMENTS.#COMPLY WITH DEWA HSE REQUIREMENTS, PTW SYSTEM, LOCK-OUT/TAG-OUTREQUIREMENTS, AND SITE SAFETY INSTRUCTIO NS.#CONDUCT TOOLBOX TALK AND JOB-SPECIFIC RISK ASSESSMENT BEFORE STARTINGWORK.#USE CERTIFIED LIFTING TOOLS, INSPECTED TACKLES, COM PETENT RIGGERS,AND SUITABLE LIFTING PLANS WHERE REQUIRED.#USE CALIBRATED INSTRUMENTS AND APPROVED TESTING EQUIPMENT FORINSPECTION, CALIBRATION, AND TESTING ACTIVITIES.#MAINTAIN PROPER HOUSEKEEPING, BARRICADING, ACCESS CONTROL, AND SAFESTORAGE OF DISMANTLED COMPO NENTS.#ENSURE ELECTRICAL ISOLATION AND VERIFICATION BEFORE WORKING ONACTUATOR MOTORS, LIMIT SWITCHES, TORQUE SWITCHES,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OR CONTROL W IRING.#DISPOSE OF USED GREASE, OIL, CLEANING MATERIALS, AND CONTAMINATEDWASTE AS PER APPLICABLE ENVIRONMENTAL REQUIREMENTS.#.6. WA RRANTY.#THE CONTRACTOR SHALL PROVIDE A MINIMUM ONE-YEAR WARRANTY FROM THEDATE OF WORK COMPLETION AND ACCEPTANCE.#THE WARRANTY SHALL COVER WORKMANSHIP, REPAIR QUALITY, REPLACED PARTSSUPPLIED BY THE CONTRACTOR, REASSEMBLY, CALIBRATION, AND TESTING-RELATEDDEFECTS.# THE CONTRACTOR SHALL ATTEND ANY WARRANTY DEFECT PROMPTLY WITHOUTADVERSELY AFFECTING PLANT OPERATION.						
2		ITEM-00001	SCOPE OF WORK: AUX BOILER 87 DAMPER ACTUATORS & GEARBOXES INSPECTION,OVERHAUL AND TESTINGOUTAGE DATE: 15.08.2026 (TENTATIVE)DURATION : 7 CALENDAR DAYSEQUIPMENT/SYSTEM: AUX BOILER 87 DAMPER ACTUATORS AND ASSOCIATEDGEARBOXES1. OBJECTIVETO CARRY	3	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OUT COMPLETE INSPECTIO N, DISMANTLING, REFURBISHMENT, REASSEMBLY, CALIBRATION, FUNCTIONAL TESTING, AND COMMISSIONING SUPPORT FOR AUX BOILER 87 DAMPER ACTUATO RS AND ASSOCIATED GEARBOXES, ENSURING RELIABLE OPERATION, ACCURATE POSITIONING, PROPER TORQUE TRANSMISSION, AND COMPLIANCE WITH OEM RE COMMENDATIONS, DEWA REQUIREMENTS, APPLICABLE HSE RULES, AND QUALITY STANDARDS. 2. EQUIPMENT COVERED SN# DESCRIPTION# KKS NO.#1# DAMPER DIS CHARGE FD FAN A ACTUATOR#87HLA11AA001#2# DAMPER DISCHARGE FD FAN B ACTUATOR#87HLA12AA001#3# DAMPER AIR LINE TO BURNER BOX 1#87HLA21AA0 01#4# DAMPER AIR LINE TO BURNER BOX 2#87HLA22AA001#5# DAMPER AIR LINE TO BURNER BOX 3#87HLA23AA001#6# DAMPER SUCTION FGR FAN A#87HNF11A A001#7# DAMPER DISCHARGE FGR FAN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			A#87HNF11AA003#8#DAMPER SUCTION FGR FAN B#87HNF12AA001#9#DAMPER DISCHARGE FGR FAN B#87HNF12AA003#10# AUX BOILER STACK INLET DAMPER ACTUATOR#87HNA10AA001#11#FD FAN-A IGV ACTUATOR#87HLB11AA001#12#FD FAN-B IGV ACTUATOR#87HLB12AA001#3. S COPE OF WORK DETAILS3.1 PRE-OUTAGE ACTIVITIES.#CONDUCT SITE VISIT AND FAMILIARIZE WITH EQUIPMENT LOCATION, ACCESSREQUIREMENTS, LIFTI NG REQUIREMENTS, AND JOB-SPECIFIC SAFETY PRECAUTIONS.#COORDINATE WITH OPERATIONS AND I&C FOR EQUIPMENT ISOLATION,PERMISSIVE CLEARAN CES, PTW REQUIREMENTS, AND LOOP-CHECK READINESS.#CONFIRM AVAILABILITY OF REQUIRED MANPOWER, TOOLS, LIFTING EQUIPMENT,SPARE PARTS, C ONSUMABLES, CALIBRATED INSTRUMENTS, AND APPROVEDLUBRICANTS.3.2 DISMANTLING AND INSPECTION.#CHECK, RECORD AND MAINTAIN THE SAME TORQU						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>E LIMIT AS EXISTING.#DISMANTLE ACTUATOR AND GEARBOX ASSEMBLIES IN A CONTROLLED MANNERAFTER CONFIRMING ISOLATION AND SAFE ACCESS.#IN SPECT GEAR TRAIN, WORM GEARS, PLANETARY GEARS, BEARINGS, BUSHINGS,SHAFTS, COUPLINGS, KEYWAYS, SEALS, LIMIT SWITCHES, TORQUE SWITCHES , ANDACTUATOR MOTOR CONDITION.#CHECK FOR WEAR, CORROSION, ABNORMAL BACKLASH, MISALIGNMENT,MECHANICAL LOOSENESS, DAMAGED FASTENERS, OIL/GREASE CONTAMINATION, ANDSEALING DETERIORATION.#DPT FOR GEARBOX GEARS.#RECORD AS-FOUND CONDITION WITH PHOTOGRAPHS AND INSPECTIO NOBSERVATIONS BEFORE CLEANING OR REPAIR.3.3 CLEANING.#REMOVE OLD GREASE, OIL RESIDUE, DUST, DEPOSITS, AND FOREIGN MATERIALFROM ACTUA TOR AND GEARBOX INTERNAL PARTS.#CLEAN COMPONENTS USING APPROVED SOLVENTS, LINT FREE CLOTHS, ANDSUITABLE CLEANING METHODS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WITHOUT DA MAGING MACHINED SURFACES ORELECTRICAL PARTS.#PREPARE MATING SURFACES, COVERS, SEALS, AND FASTENERS PRIOR TOREASSEMBLY.3.4 REPAIR AN D REPLACEMENT.#REPLACE DEFECTIVE OR WORN PARTS SUCH AS BEARINGS, SEALS, SWITCHES,GEARS, FASTENERS, COUPLINGS, AND OTHER IDENTIFIED C OMPONENTS USINGOEM-RECOMMENDED OR DEWA-APPROVED SPARE PARTS.(SFOT REPAIR KIT ANDBEARING CONTRACTOR SCOPE-OTHERS SPARE DEWA SCOPE).#R EPAIR REUSABLE COMPONENTS WITHIN OEM TOLERANCES AND RESTORESERVICEABILITY AS APPLICABLE.#CORRECT ABNORMAL GEARBOX BACKLASH, RESTORE SEALING INTEGRITY, ANDENSURE FREE MOVEMENT OF MECHANICAL TRANSMISSION COMPONENTS.#REPORT ANY MAJOR DEFECT REQUIRING ADDITIONAL REP AIR, MACHINING,REPLACEMENT, OR ENGINEERING DECISION BEFORE PROCEEDING.3.5</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REASSEMBLY.#REASSEMBLE ACTUATOR AND GEARBOX ASSEMBLIES AS PER OEM SEQUENCE ANDRECOMMENDED PRACTICES.#ENSURE CORRECT ALIGNMENT BETWEEN ACTUATOR, GEARBOX, COUPLING, ANDDAMPER SHAFT.#APPLY OE M-APPROVED LUBRICANTS, GREASE, OIL, AND SEALANTS SUITABLE FORTHE OPERATING ENVIRONMENT AND TEMPERATURE ZONE.#TIGHTEN FASTENERS, COU PLINGS, AND LOCKING ARRANGEMENTS TO THEAPPLICABLE TORQUE AND ENSURE PROPER MECHANICAL LOCKING.3.6 TESTING, CALIBRATION, AND SETTING.</p> <p>#CARRY OUT FUNCTIONAL OPEN/CLOSE OPERATION TEST FOR EACH ACTUATOR ANDGEARBOX ASSEMBLY.#VERIFY TORQUE SWITCH OPERATION, LIMIT SWITCH OPERATION, END-POSITIONREPEATABILITY, AND STROKE DIRECTION.#PERFORM NO-LOAD AND LOADED CHECKS WHERE APPLICABLE, INCLUDINGOBSERVATI ON FOR ABNORMAL NOISE, VIBRATION,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OVERHEATING, OR MECHANICAL BINDING. #CALIBRATE OPEN/CLOSE LIMIT SWITCHES AND TORQUE SWITCH SETTINGS INCOORDINATION WITH I&C AND OPERATIONS. #VERIFY STROKE TIME AND ENSURE SETTINGS ARE ALIGNED WITH PLANT OPERATING REQUIREMENTS AND CO NTROL LOGIC INTERLOCKS. 3.7 DOCUMENTATION AND REPORTING. #SUBMIT DETAILED INSPECTION REPORT INCLUDING AS-FOUND CONDITION, DEFECTS OBSER VED, CORRECTIVE ACTIONS, PARTS REPLACED, PHOTOGRAPHS, AND RECOMMENDATIONS. #SUBMIT TEST AND CALIBRATION RECORDS FOR EACH ACTUATOR, IN CLUDING LIMIT SWITCH SETTINGS, TORQUE SWITCH SETTINGS, STROKE VERIFICATION, AND FUNCTIONAL TEST RESULTS. #SUBMIT COMPLETION CERTIFICAT E CONFIRMING THAT THE WORK HAS BEEN COMPLETED IN ACCORDANCE WITH OEM RECOMMENDATIONS, DEWA REQUIREMENTS, AND ACCEPTED MAINTENANCE PRAC</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TICES.4. ACCEPTANCE CRITERIA.#ACTUATOR AND GEARBOX OPERATE SMOOTHLY ACROSS FULL STROKE WITHOUT ABNORMAL NOISE, VIBRATION, OVERHEATING , OR MECHANICAL BINDING.#DAMPER ACHIEVES FULL OPEN AND FULL CLOSE POSITIONS WITH CORRECT INDICATION AND REPEATABLE POSITIONING.#TOR QUE AND LIMIT SWITCH SETTINGS ARE VERIFIED AND ALIGNED WITH OEM/PLANT REQUIREMENTS.#NO OIL/GREASE LEAKAGE, ABNORMAL BACKLASH, LOOSE COUPLING, SHAFT MISALIGNMENT, OR MECHANICAL LOOSENESS IS OBSERVED.#DCS/PLC FEEDBACK, COMMAND RESPONSE, INTERLOCKS, AND LOOP CHECKS ARE COMPLETED SATISFACTORILY.#FINAL OPERATION IS ACCEPTED BY DEWA MAINTENANCE, OPERATIONS, AND I&C REPRESENTATIVES, AS APPLICABLE.5. HSE AND QUALITY REQUIREMENTS.#COMPLY WITH DEWA HSE REQUIREMENTS, PTW SYSTEM, LOCK-OUT/TAG-OUT REQUIREMENTS, AND SITE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SAFETY INSTRUCTIO NS.#CONDUCT TOOLBOX TALK AND JOB-SPECIFIC RISK ASSESSMENT BEFORE STARTINGWORK.#USE CERTIFIED LIFTING TOOLS, INSPECTED TACKLES, COM PETENT RIGGERS,AND SUITABLE LIFTING PLANS WHERE REQUIRED.#USE CALIBRATED INSTRUMENTS AND APPROVED TESTING EQUIPMENT FORINSPECTION, CALIBRATION, AND TESTING ACTIVITIES.#MAINTAIN PROPER HOUSEKEEPING, BARRICADING, ACCESS CONTROL, AND SAFESTORAGE OF DISMANTLED COMPO NENTS.#ENSURE ELECTRICAL ISOLATION AND VERIFICATION BEFORE WORKING ONACTUATOR MOTORS, LIMIT SWITCHES, TORQUE SWITCHES, OR CONTROL W IRING.#DISPOSE OF USED GREASE, OIL, CLEANING MATERIALS, AND CONTAMINATEDWASTE AS PER APPLICABLE ENVIRONMENTAL REQUIREMENTS.#.6. WA RRANTY.#THE CONTRACTOR SHALL PROVIDE A MINIMUM ONE-YEAR WARRANTY FROM THEDATE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OF WORK COMPLETION AND ACCEPTANCE.#THE WARRANTY SHALL COVER WORKMANSHIP, REPAIR QUALITY, REPLACED PARTSSUPPLIED BY THE CONTRACTOR, REASSEMBLY, CALIBRATION, AND TESTING-RELATEDDEFECTS.# THE CONTRACTOR SHALL ATTEND ANY WARRANTY DEFECT PROMPTLY WITHOUTADVERSELY AFFECTING PLANT OPERATION.						
3		ITEM-00001	SCOPE OF WORK: AUX BOILER 87 DAMPER ACTUATORS & GEARBOXES INSPECTION,OVERHAUL AND TESTINGOUTAGE DATE: 15.08.2026 (TENTATIVE)DURATION : 7 CALENDAR DAYSEQUIPMENT/SYSTEM: AUX BOILER 87 DAMPER ACTUATORS AND ASSOCIATEDGEARBOXES1. OBJECTIVETO CARRY OUT COMPLETE INSPECTIO N, DISMANTLING, REFURBISHMENT,REASSEMBLY, CALIBRATION, FUNCTIONAL TESTING, AND COMMISSIONING SUPPORTFOR AUX BOILER 87 DAMPER ACTUATO RS AND ASSOCIATED GEARBOXES, ENSURINGRELIABLE OPERATION, ACCURATE	2	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			POSITIONING, PROPER TORQUE TRANSMISSION, AND COMPLIANCE WITH OEM RE COMMENDATIONS, DEWA REQUIREMENTS, APPLICABLE HSE RULES, AND QUALITY STANDARDS. 2. EQUIPMENT COVERED SN# DESCRIPTION# KKS NO.#1# DAMPER DIS CHARGE FD FAN A ACTUATOR#87HLA11AA001#2# DAMPER DISCHARGE FD FAN B ACTUATOR#87HLA12AA001#3# DAMPER AIR LINE TO BURNER BOX 1#87HLA21AA0 01#4# DAMPER AIR LINE TO BURNER BOX 2#87HLA22AA001#5# DAMPER AIR LINE TO BURNER BOX 3#87HLA23AA001#6# DAMPER SUCTION FGR FAN A#87HNF11A A001#7# DAMPER DISCHARGE FGR FAN A#87HNF11AA003#8# DAMPER SUCTION FGR FAN B#87HNF12AA001#9# DAMPER DISCHARGE FGR FAN B#87HNF12AA003#10# AUX BOILER STACK INLET DAMPER ACTUATOR#87HNA10AA001#11# FD FAN-A IGV ACTUATOR#87HLB11AA001#12# FD FAN-B IGV ACTUATOR#87HLB12AA001#3. S						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COPE OF WORK DETAILS</p> <p>3.1 PRE-OUTAGE ACTIVITIES.#CONDUCT SITE VISIT AND FAMILIARIZE WITH EQUIPMENT LOCATION, ACCESSREQUIREMENTS, LIFTING REQUIREMENTS, AND JOB-SPECIFIC SAFETY PRECAUTIONS.#COORDINATE WITH OPERATIONS AND I&C FOR EQUIPMENT ISOLATION,PERMISSIVE CLEARANCES, PTW REQUIREMENTS, AND LOOP-CHECK READINESS.#CONFIRM AVAILABILITY OF REQUIRED MANPOWER, TOOLS, LIFTING EQUIPMENT,SPARE PARTS, CONSUMABLES, CALIBRATED INSTRUMENTS, AND APPROVEDLUBRICANTS.3.2 DISMANTLING AND INSPECTION.#CHECK, RECORD AND MAINTAIN THE SAME TORQUE LIMIT AS EXISTING.#DISMANTLE ACTUATOR AND GEARBOX ASSEMBLIES IN A CONTROLLED MANNERAFTER CONFIRMING ISOLATION AND SAFE ACCESS.#INSPECT GEAR TRAIN, WORM GEARS, PLANETARY GEARS, BEARINGS, BUSHINGS,SHAFTS, COUPLINGS, KEYWAYS, SEALS, LIMIT SWITCHES,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TORQUE SWITCHES , ANDACTUATOR MOTOR CONDITION.#CHECK FOR WEAR, CORROSION, ABNORMAL BACKLASH, MISALIGNMENT,MECHANICAL LOOSENESS, DAMAGED FASTENERS, OIL/GREASE CONTAMINATION, ANDSEALING DETERIORATION.#DPT FOR GEARBOX GEARS.#RECORD AS-FOUND CONDITION WITH PHOTOGRAPHS AND INSPECTIO NOBSERVATIONS BEFORE CLEANING OR REPAIR.3.3 CLEANING.#REMOVE OLD GREASE, OIL RESIDUE, DUST, DEPOSITS, AND FOREIGN MATERIALFROM ACTUA TOR AND GEARBOX INTERNAL PARTS.#CLEAN COMPONENTS USING APPROVED SOLVENTS, LINT FREE CLOTHS, ANDSUITABLE CLEANING METHODS WITHOUT DA MAGING MACHINED SURFACES ORELECTRICAL PARTS.#PREPARE MATING SURFACES, COVERS, SEALS, AND FASTENERS PRIOR TOREASSEMBLY.3.4 REPAIR AN D REPLACEMENT.#REPLACE DEFECTIVE OR WORN PARTS SUCH AS BEARINGS, SEALS,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SWITCHES,GEARS, FASTENERS, COUPLINGS, AND OTHER IDENTIFIED COMPONENTS USING OEM-RECOMMENDED OR DEWA-APPROVED SPARE PARTS.(SFOT REPAIR KIT AND BEARING CONTRACTOR SCOPE-OTHERS SPARE DEWA SCOPE).#R</p> <p>REPAIR REUSABLE COMPONENTS WITHIN OEM TOLERANCES AND RESTORE SERVICEABILITY AS APPLICABLE.#CORRECT ABNORMAL GEARBOX BACKLASH, RESTORE SEALING INTEGRITY, AND ENSURE FREE MOVEMENT OF MECHANICAL TRANSMISSION COMPONENTS.#REPORT ANY MAJOR DEFECT REQUIRING ADDITIONAL REPAIR, MACHINING, REPLACEMENT, OR ENGINEERING DECISION BEFORE PROCEEDING.3.5 REASSEMBLY.#REASSEMBLE ACTUATOR AND GEARBOX ASSEMBLIES AS PER OEM SEQUENCE AND RECOMMENDED PRACTICES.#ENSURE CORRECT ALIGNMENT BETWEEN ACTUATOR, GEARBOX, COUPLING, AND DAMPER SHAFT.#APPLY OEM-APPROVED LUBRICANTS, GREASE, OIL, AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SEALANTS SUITABLE FOR THE OPERATING ENVIRONMENT AND TEMPERATURE ZONE. #TIGHTEN FASTENERS, COUPLINGS, AND LOCKING ARRANGEMENTS TO THE APPLICABLE TORQUE AND ENSURE PROPER MECHANICAL LOCKING. 3.6 TESTING, CALIBRATION, AND SETTING.</p> <p>#CARRY OUT FUNCTIONAL OPEN/CLOSE OPERATION TEST FOR EACH ACTUATOR AND GEARBOX ASSEMBLY. #VERIFY TORQUE SWITCH OPERATION, LIMIT SWITCH OPERATION, END-POSITION REPEATABILITY, AND STROKE DIRECTION. #PERFORM NO-LOAD AND LOADED CHECKS WHERE APPLICABLE, INCLUDING OBSERVATION FOR ABNORMAL NOISE, VIBRATION, OVERHEATING, OR MECHANICAL BINDING. #CALIBRATE OPEN/CLOSE LIMIT SWITCHES AND TORQUE SWITCH SETTINGS IN COORDINATION WITH I&C AND OPERATIONS. #VERIFY STROKE TIME AND ENSURE SETTINGS ARE ALIGNED WITH PLANT OPERATING REQUIREMENTS AND CO</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONTROL LOGIC INTERLOCKS.3.7 DOCUMENTATION AND REPORTING.#SUBMIT DETAILED INSPECTION REPORT INCLUDING AS-FOUND CONDITION,DEFECTS OBSERVED, CORRECTIVE ACTIONS, PARTS REPLACED, PHOTOGRAPHS, ANDRECOMMENDATIONS.#SUBMIT TEST AND CALIBRATION RECORDS FOR EACH ACTUATOR, INCLUDINGLIMIT SWITCH SETTINGS, TORQUE SWITCH SETTINGS, STROKE VERIFICATION, ANDFUNCTIONAL TEST RESULTS.#SUBMIT COMPLETION CERTIFICATE CONFIRMING THAT THE WORK HAS BEENCOMPLETED IN ACCORDANCE WITH OEM RECOMMENDATIONS, DEWA REQUIREMENTS, ANDACCEPTED MAINTENANCE PRACTICES.4. ACCEPTANCE CRITERIA.#ACTUATOR AND GEARBOX OPERATE SMOOTHLY ACROSS FULL STROKE WITHOUTABNORMAL NOISE, VIBRATION, OVERHEATING , OR MECHANICAL BINDING.#DAMPER ACHIEVES FULL OPEN AND FULL CLOSE POSITIONS WITH CORRECTINDICATION AND REPEATABLE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			POSITIONING.#TOR QUE AND LIMIT SWITCH SETTINGS ARE VERIFIED AND ALIGNED WITH OEM/PLANT REQUIREMENTS.#NO OIL/GREASE LEAKAGE, ABNORMAL BACKLASH, LOOSE COUPLING, SHAFT MISALIGNMENT, OR MECHANICAL LOOSENESS IS OBSERVED.#DCS/PLC FEEDBACK, COMMAND RESPONSE, INTERLOCKS, AND LOOP CHECKS A RECOMPLETED SATISFACTORILY.#FINAL OPERATION IS ACCEPTED BY DEWA MAINTENANCE, OPERATIONS, AND I&C REPRESENTATIVES, AS APPLICABLE.5. H SE AND QUALITY REQUIREMENTS.#COMPLY WITH DEWA HSE REQUIREMENTS, PTW SYSTEM, LOCK-OUT/TAG-OUT REQUIREMENTS, AND SITE SAFETY INSTRUCTIONS.#CONDUCT TOOLBOX TALK AND JOB-SPECIFIC RISK ASSESSMENT BEFORE STARTING WORK.#USE CERTIFIED LIFTING TOOLS, INSPECTED TACKLES, COMPETENT RIGGERS, AND SUITABLE LIFTING PLANS WHERE REQUIRED.#USE CALIBRATED						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSTRUMENTS AND APPROVED TESTING EQUIPMENT FOR INSPECTION, CALIBRATION, AND TESTING ACTIVITIES. #MAINTAIN PROPER HOUSEKEEPING, BARRICADING, ACCESS CONTROL, AND SAFE STORAGE OF DISMANTLED COMPONENTS. #ENSURE ELECTRICAL ISOLATION AND VERIFICATION BEFORE WORKING ON ACTUATOR MOTORS, LIMIT SWITCHES, TORQUE SWITCHES, OR CONTROL WIRING. #DISPOSE OF USED GREASE, OIL, CLEANING MATERIALS, AND CONTAMINATED WASTE AS PER APPLICABLE ENVIRONMENTAL REQUIREMENTS. #.6. WARRANTY #THE CONTRACTOR SHALL PROVIDE A MINIMUM ONE-YEAR WARRANTY FROM THE DATE OF WORK COMPLETION AND ACCEPTANCE. #THE WARRANTY SHALL COVER WORKMANSHIP, REPAIR QUALITY, REPLACED PARTS SUPPLIED BY THE CONTRACTOR, REASSEMBLY, CALIBRATION, AND TESTING-RELATED DEFECTS. #THE CONTRACTOR SHALL ATTEND ANY WARRANTY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEFECT PROMPTLY WITHOUT ADVERSELY AFFECTING PLANT OPERATION.						
4		ITEM-00001	SCOPE OF WORK: AUX BOILER 87 DAMPER ACTUATORS & GEARBOXES INSPECTION, OVERHAUL AND TESTING OUTAGE DATE: 15.08.2026 (TENTATIVE) DURATION : 7 CALENDAR DAY EQUIPMENT/SYSTEM: AUX BOILER 87 DAMPER ACTUATORS AND ASSOCIATED GEARBOXES 1. OBJECTIVE TO CARRY OUT COMPLETE INSPECTION, DISMANTLING, REFURBISHMENT, REASSEMBLY, CALIBRATION, FUNCTIONAL TESTING, AND COMMISSIONING SUPPORT FOR AUX BOILER 87 DAMPER ACTUATORS AND ASSOCIATED GEARBOXES, ENSURING RELIABLE OPERATION, ACCURATE POSITIONING, PROPER TORQUE TRANSMISSION, AND COMPLIANCE WITH OEM RECOMMENDATIONS, DEWA REQUIREMENTS, APPLICABLE HSE RULES, AND QUALITY STANDARDS. 2. EQUIPMENT COVERED SN# DESCRIPTION# KKS NO.#1# DAMPER DIS	2	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CHARGE FD FAN A ACTUATOR#87HLA11AA001#2#DAMPER DISCHARGE FD FAN B ACTUATOR#87HLA12AA001#3#DAMPER AIR LINE TO BURNER BOX 1#87HLA21AA0 01#4#DAMPER AIR LINE TO BURNER BOX 2#87HLA22AA001#5#DAMPER AIR LINE TO BURNER BOX 3#87HLA23AA001#6#DAMPER SUCTION FGR FAN A#87HNF11A A001#7#DAMPER DISCHARGE FGR FAN A#87HNF11AA003#8#DAMPER SUCTION FGR FAN B#87HNF12AA001#9#DAMPER DISCHARGE FGR FAN B#87HNF12AA003#10# AUX BOILER STACK INLET DAMPER ACTUATOR#87HNA10AA001#11#FD FAN-A IGV ACTUATOR#87HLB11AA001#12#FD FAN-B IGV ACTUATOR#87HLB12AA001#3. S COPE OF WORK DETAILS3.1 PRE-OUTAGE ACTIVITIES.#CONDUCT SITE VISIT AND FAMILIARIZE WITH EQUIPMENT LOCATION, ACCESSREQUIREMENTS, LIFTI NG REQUIREMENTS, AND JOB-SPECIFIC SAFETY PRECAUTIONS.#COORDINATE WITH OPERATIONS AND I&C FOR EQUIPMENT ISOLATION,PERMISSIVE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CLEARANCE, PTW REQUIREMENTS, AND LOOP-CHECK READINESS.#CONFIRM AVAILABILITY OF REQUIRED MANPOWER, TOOLS, LIFTING EQUIPMENT, SPARE PARTS, CONSUMABLES, CALIBRATED INSTRUMENTS, AND APPROVED LUBRICANTS.3.2 DISMANTLING AND INSPECTION.#CHECK, RECORD AND MAINTAIN THE SAME TORQUE LIMIT AS EXISTING.#DISMANTLE ACTUATOR AND GEARBOX ASSEMBLIES IN A CONTROLLED MANNER AFTER CONFIRMING ISOLATION AND SAFE ACCESS.#INSPECT GEAR TRAIN, WORM GEARS, PLANETARY GEARS, BEARINGS, BUSHINGS, SHAFTS, COUPLINGS, KEYWAYS, SEALS, LIMIT SWITCHES, TORQUE SWITCHES, AND ACTUATOR MOTOR CONDITION.#CHECK FOR WEAR, CORROSION, ABNORMAL BACKLASH, MISALIGNMENT, MECHANICAL LOOSENESS, DAMAGED FASTENERS, OIL/GREASE CONTAMINATION, AND SEALING DETERIORATION.#DPT FOR GEARBOX</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>GEARS.#RECORD AS-FOUND CONDITION WITH PHOTOGRAPHS AND INSPECTIO NOBSERVATIONS BEFORE CLEANING OR REPAIR.3.3 CLEANING.#REMOVE OLD GREASE, OIL RESIDUE, DUST, DEPOSITS, AND FOREIGN MATERIALFROM ACTUA TOR AND GEARBOX INTERNAL PARTS.#CLEAN COMPONENTS USING APPROVED SOLVENTS, LINT FREE CLOTHS, ANDSUITABLE CLEANING METHODS WITHOUT DA MAGING MACHINED SURFACES ORELECTRICAL PARTS.#PREPARE MATING SURFACES, COVERS, SEALS, AND FASTENERS PRIOR TOREASSEMBLY.3.4 REPAIR AN D REPLACEMENT.#REPLACE DEFECTIVE OR WORN PARTS SUCH AS BEARINGS, SEALS, SWITCHES,GEARS, FASTENERS, COUPLINGS, AND OTHER IDENTIFIED C OMPONENTS USINGOEM-RECOMMENDED OR DEWA-APPROVED SPARE PARTS.(SFOT REPAIR KIT ANDBEARING CONTRACTOR SCOPE-OTHERS SPARE DEWA SCOPE).#R EPAIR REUSABLE COMPONENTS WITHIN OEM</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TOLERANCES AND RESTORE SERVICEABILITY AS APPLICABLE. #CORRECT ABNORMAL GEARBOX BACKLASH, RESTORE SEALING INTEGRITY, AND ENSURE FREE MOVEMENT OF MECHANICAL TRANSMISSION COMPONENTS. #REPORT ANY MAJOR DEFECT REQUIRING ADDITIONAL REPAIR, MACHINING, REPLACEMENT, OR ENGINEERING DECISION BEFORE PROCEEDING. 3.5 REASSEMBLY. #REASSEMBLE ACTUATOR AND GEARBOX ASSEMBLIES AS PER OEM SEQUENCE AND RECOMMENDED PRACTICES. #ENSURE CORRECT ALIGNMENT BETWEEN ACTUATOR, GEARBOX, COUPLING, AND DAMPER SHAFT. #APPLY OEM-APPROVED LUBRICANTS, GREASE, OIL, AND SEALANTS SUITABLE FOR THE OPERATING ENVIRONMENT AND TEMPERATURE ZONE. #TIGHTEN FASTENERS, COUPLINGS, AND LOCKING ARRANGEMENTS TO THE APPLICABLE TORQUE AND ENSURE PROPER MECHANICAL LOCKING. 3.6 TESTING, CALIBRATION, AND SETTING.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			#CARRY OUT FUNCTIONAL OPEN/CLOSE OPERATION TEST FOR EACH ACTUATOR ANDGEARBOX ASSEMBLY.#VERIFY TORQUE SWITCH OPERATION, LIMIT SWITCH OPERATION, END-POSITIONREPEATABILITY, AND STROKE DIRECTION.#PERFORM NO-LOAD AND LOADED CHECKS WHERE APPLICABLE, INCLUDINGOBSERVATI ON FOR ABNORMAL NOISE, VIBRATION, OVERHEATING, OR MECHANICALBINDING.#CALIBRATE OPEN/CLOSE LIMIT SWITCHES AND TORQUE SWITCH SETTINGS INCOORDINATION WITH I&C AND OPERATIONS.#VERIFY STROKE TIME AND ENSURE SETTINGS ARE ALIGNED WITH PLANTOPERATING REQUIREMENTS AND CO NTROL LOGIC INTERLOCKS.3.7 DOCUMENTATION AND REPORTING.#SUBMIT DETAILED INSPECTION REPORT INCLUDING AS-FOUND CONDITION,DEFECTS OBSER VED, CORRECTIVE ACTIONS, PARTS REPLACED, PHOTOGRAPHS, ANDRECOMMENDATIONS.#SUBMIT TEST AND						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CALIBRATION RECORDS FOR EACH ACTUATOR, INCLUDING LIMIT SWITCH SETTINGS, TORQUE SWITCH SETTINGS, STROKE VERIFICATION, AND FUNCTIONAL TEST RESULTS. #SUBMIT COMPLETION CERTIFICATE CONFIRMING THAT THE WORK HAS BEEN COMPLETED IN ACCORDANCE WITH OEM RECOMMENDATIONS, DEWA REQUIREMENTS, AND ACCEPTED MAINTENANCE PRACTICES. 4. ACCEPTANCE CRITERIA #ACTUATOR AND GEARBOX OPERATE SMOOTHLY ACROSS FULL STROKE WITHOUT ABNORMAL NOISE, VIBRATION, OVERHEATING, OR MECHANICAL BINDING. #DAMPER ACHIEVES FULL OPEN AND FULL CLOSE POSITIONS WITH CORRECT INDICATION AND REPEATABLE POSITIONING. #TORQUE AND LIMIT SWITCH SETTINGS ARE VERIFIED AND ALIGNED WITH OEM/PLANT REQUIREMENTS. #NO OIL/GREASE LEAKAGE, ABNORMAL BACKLASH, LOOSE COUPLING, SHAFT MISALIGNMENT, OR MECHANICAL LOOSENESS IS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OBSERVED.#DCS/PLC FEEDBACK, COMMAND RESPONSE, INTERLOCKS, AND LOOP CHECKS A RECOMPLETED SATISFACTORILY.#FINAL OPERATION IS ACCEPTED BY DEWA MAINTENANCE, OPERATIONS, AND I&CREPRESENTATIVES, AS APPLICABLE.5. H SE AND QUALITY REQUIREMENTS.#COMPLY WITH DEWA HSE REQUIREMENTS, PTW SYSTEM, LOCK-OUT/TAG-OUTREQUIREMENTS, AND SITE SAFETY INSTRUCTIO NS.#CONDUCT TOOLBOX TALK AND JOB-SPECIFIC RISK ASSESSMENT BEFORE STARTINGWORK.#USE CERTIFIED LIFTING TOOLS, INSPECTED TACKLES, COM PETENT RIGGERS,AND SUITABLE LIFTING PLANS WHERE REQUIRED.#USE CALIBRATED INSTRUMENTS AND APPROVED TESTING EQUIPMENT FORINSPECTION, CALIBRATION, AND TESTING ACTIVITIES.#MAINTAIN PROPER HOUSEKEEPING, BARRICADING, ACCESS CONTROL, AND SAFESTORAGE OF DISMANTLED COMPO NENTS.#ENSURE ELECTRICAL ISOLATION AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VERIFICATION BEFORE WORKING ON ACTUATOR MOTORS, LIMIT SWITCHES, TORQUE SWITCHES, OR CONTROL WIRING. #DISPOSE OF USED GREASE, OIL, CLEANING MATERIALS, AND CONTAMINATED WASTE AS PER APPLICABLE ENVIRONMENTAL REQUIREMENTS. #.6. WARRANTY #THE CONTRACTOR SHALL PROVIDE A MINIMUM ONE-YEAR WARRANTY FROM THE DATE OF WORK COMPLETION AND ACCEPTANCE. #THE WARRANTY SHALL COVER WORKMANSHIP, REPAIR QUALITY, REPLACED PARTS SUPPLIED BY THE CONTRACTOR, REASSEMBLY, CALIBRATION, AND TESTING-RELATED DEFECTS. #THE CONTRACTOR SHALL ATTEND ANY WARRANTY DEFECT PROMPTLY WITHOUT ADVERSELY AFFECTING PLANT OPERATION.</p>						
5		ITEM-00001	<p>SCOPE OF WORK: AUX BOILER 87 DAMPER ACTUATORS & GEARBOXES INSPECTION, OVERHAUL AND TESTING OUTAGE DATE: 15.08.2026 (TENTATIVE) DURATION : 7 CALENDAR DAY EQUIPMENT/SYSTEM: AUX</p>	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>BOILER 87 DAMPER ACTUATORS AND ASSOCIATED GEARBOXES.1. OBJECTIVE TO CARRY OUT COMPLETE INSPECTION, DISMANTLING, REFURBISHMENT, REASSEMBLY, CALIBRATION, FUNCTIONAL TESTING, AND COMMISSIONING SUPPORT FOR AUX BOILER 87 DAMPER ACTUATORS AND ASSOCIATED GEARBOXES, ENSURING RELIABLE OPERATION, ACCURATE POSITIONING, PROPER TORQUE TRANSMISSION, AND COMPLIANCE WITH OEM RECOMMENDATIONS, DEWA REQUIREMENTS, APPLICABLE HSE RULES, AND QUALITY STANDARDS.2. EQUIPMENT COVERED SN#DESCRIPTION#KKS NO.#1#DAMPER DISCHARGE FD FAN A ACTUATOR#87HLA11AA001#2#DAMPER DISCHARGE FD FAN B ACTUATOR#87HLA12AA001#3#DAMPER AIR LINE TO BURNER BOX 1#87HLA21AA001#4#DAMPER AIR LINE TO BURNER BOX 2#87HLA22AA001#5#DAMPER AIR LINE TO BURNER BOX 3#87HLA23AA001#6#DAMPER SUCTION FGR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FAN A#87HNF11A A001#7#DAMPER DISCHARGE FGR FAN A#87HNF11AA003#8#DAMPER SUCTION FGR FAN B#87HNF12AA001#9#DAMPER DISCHARGE FGR FAN B#87HNF12AA003#10# AUX BOILER STACK INLET DAMPER ACTUATOR#87HNA10AA001#11#FD FAN-A IGV ACTUATOR#87HLB11AA001#12#FD FAN-B IGV ACTUATOR#87HLB12AA001#3. S COPE OF WORK DETAILS3.1 PRE-OUTAGE ACTIVITIES.#CONDUCT SITE VISIT AND FAMILIARIZE WITH EQUIPMENT LOCATION, ACCESSREQUIREMENTS, LIFTI NG REQUIREMENTS, AND JOB-SPECIFIC SAFETY PRECAUTIONS.#COORDINATE WITH OPERATIONS AND I&C FOR EQUIPMENT ISOLATION,PERMISSIVE CLEARAN CES, PTW REQUIREMENTS, AND LOOP-CHECK READINESS.#CONFIRM AVAILABILITY OF REQUIRED MANPOWER, TOOLS, LIFTING EQUIPMENT,SPARE PARTS, C ONSUMABLES, CALIBRATED INSTRUMENTS, AND APPROVEDLUBRICANTS.3.2 DISMANTLING AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSPECTION.#CHECK, RECORD AND MAINTAIN THE SAME TORQUE LIMIT AS EXISTING.#DISMANTLE ACTUATOR AND GEARBOX ASSEMBLIES IN A CONTROLLED MANNER AFTER CONFIRMING ISOLATION AND SAFE ACCESS.#INSPECT GEAR TRAIN, WORM GEARS, PLANETARY GEARS, BEARINGS, BUSHINGS, SHAFTS, COUPLINGS, KEYWAYS, SEALS, LIMIT SWITCHES, TORQUE SWITCHES, AND ACTUATOR MOTOR CONDITION.#CHECK FOR WEAR, CORROSION, ABNORMAL BACKLASH, MISALIGNMENT, MECHANICAL LOOSENESS, DAMAGED FASTENERS, OIL/GREASE CONTAMINATION, AND SEALING DETERIORATION.#DPT FOR GEARBOX GEARS.#RECORD AS-FOUND CONDITION WITH PHOTOGRAPHS AND INSPECTION OBSERVATIONS BEFORE CLEANING OR REPAIR.3.3 CLEANING.#REMOVE OLD GREASE, OIL RESIDUE, DUST, DEPOSITS, AND FOREIGN MATERIAL FROM ACTUATOR AND GEARBOX INTERNAL PARTS.#CLEAN						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>COMPONENTS USING APPROVED SOLVENTS, LINT FREE CLOTHS, AND SUITABLE CLEANING METHODS WITHOUT DA</p> <p>MAGING MACHINED SURFACES OR ELECTRICAL PARTS. #PREPARE MATING SURFACES, COVERS, SEALS, AND FASTENERS PRIOR TO REASSEMBLY. 3.4 REPAIR AND REPLACEMENT. #REPLACE DEFECTIVE OR WORN PARTS SUCH AS BEARINGS, SEALS, SWITCHES, GEARS, FASTENERS, COUPLINGS, AND OTHER IDENTIFIED COMPONENTS USING OEM-RECOMMENDED OR DEWA-APPROVED SPARE PARTS. (SFOT REPAIR KIT AND BEARING CONTRACTOR SCOPE - OTHERS SPARE DEWA SCOPE). #R</p> <p>REPAIR REUSABLE COMPONENTS WITHIN OEM TOLERANCES AND RESTORE SERVICEABILITY AS APPLICABLE. #CORRECT ABNORMAL GEARBOX BACKLASH, RESTORE SEALING INTEGRITY, AND ENSURE FREE MOVEMENT OF MECHANICAL TRANSMISSION COMPONENTS. #REPORT ANY MAJOR DEFECT REQUIRING ADDITIONAL REPAIR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>AIR, MACHINING, REPLACEMENT, OR ENGINEERING DECISION BEFORE PROCEEDING.3.5 REASSEMBLY.#REASSEMBLE ACTUATOR AND GEARBOX ASSEMBLIES AS PER OEM SEQUENCE ANDRECOMMENDED PRACTICES.#ENSURE CORRECT ALIGNMENT BETWEEN ACTUATOR, GEARBOX, COUPLING, ANDDAMPER SHAFT.#APPLY OE M-APPROVED LUBRICANTS, GREASE, OIL, AND SEALANTS SUITABLE FORTHE OPERATING ENVIRONMENT AND TEMPERATURE ZONE.#TIGHTEN FASTENERS, COU PLINGS, AND LOCKING ARRANGEMENTS TO THEAPPLICABLE TORQUE AND ENSURE PROPER MECHANICAL LOCKING.3.6 TESTING, CALIBRATION, AND SETTING. #CARRY OUT FUNCTIONAL OPEN/CLOSE OPERATION TEST FOR EACH ACTUATOR ANDGEARBOX ASSEMBLY.#VERIFY TORQUE SWITCH OPERATION, LIMIT SWITCH OPERATION, END-POSITIONREPEATABILITY, AND STROKE DIRECTION.#PERFORM NO-LOAD AND LOADED CHECKS WHERE APPLICABLE,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INCLUDING OBSERVATION FOR ABNORMAL NOISE, VIBRATION, OVERHEATING, OR MECHANICAL BINDING. #CALIBRATE OPEN/CLOSE LIMIT SWITCHES AND TORQUE SWITCH SETTINGS IN COORDINATION WITH I&C AND OPERATIONS. #VERIFY STROKE TIME AND ENSURE SETTINGS ARE ALIGNED WITH PLANT OPERATING REQUIREMENTS AND CONTROL LOGIC INTERLOCKS. 3.7 DOCUMENTATION AND REPORTING. #SUBMIT DETAILED INSPECTION REPORT INCLUDING AS-FOUND CONDITION, DEFECTS OBSERVED, CORRECTIVE ACTIONS, PARTS REPLACED, PHOTOGRAPHS, AND RECOMMENDATIONS. #SUBMIT TEST AND CALIBRATION RECORDS FOR EACH ACTUATOR, INCLUDING LIMIT SWITCH SETTINGS, TORQUE SWITCH SETTINGS, STROKE VERIFICATION, AND FUNCTIONAL TEST RESULTS. #SUBMIT COMPLETION CERTIFICATE CONFIRMING THAT THE WORK HAS BEEN COMPLETED IN ACCORDANCE WITH OEM</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RECOMMENDATIONS, DEWA REQUIREMENTS, ANDACCEPTED MAINTENANCE PRACTICES.4. ACCEPTANCE CRITERIA.#ACTUATOR AND GEARBOX OPERATE SMOOTHLY ACROSS FULL STROKE WITHOUTABNORMAL NOISE, VIBRATION, OVERHEATING , OR MECHANICAL BINDING.#DAMPER ACHIEVES FULL OPEN AND FULL CLOSE POSITIONS WITH CORRECTINDICATION AND REPEATABLE POSITIONING.#TOR QUE AND LIMIT SWITCH SETTINGS ARE VERIFIED AND ALIGNED WITHOEM/PLANT REQUIREMENTS.#NO OIL/GREASE LEAKAGE, ABNORMAL BACKLASH, LOOSE COUPLING, SHAFTMISALIGNMENT, OR MECHANICAL LOOSENESS IS OBSERVED.#DCS/PLC FEEDBACK, COMMAND RESPONSE, INTERLOCKS, AND LOOP CHECKS A RECOMPLETED SATISFACTORILY.#FINAL OPERATION IS ACCEPTED BY DEWA MAINTENANCE, OPERATIONS, AND I&CREPRESENTATIVES, AS APPLICABLE.5. H SE AND QUALITY REQUIREMENTS.#COMPLY WITH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DEWA HSE REQUIREMENTS, PTW SYSTEM, LOCK-OUT/TAG-OUTREQUIREMENTS, AND SITE SAFETY INSTRUCTIO NS.#CONDUCT TOOLBOX TALK AND JOB-SPECIFIC RISK ASSESSMENT BEFORE STARTINGWORK.#USE CERTIFIED LIFTING TOOLS, INSPECTED TACKLES, COM PETENT RIGGERS,AND SUITABLE LIFTING PLANS WHERE REQUIRED.#USE CALIBRATED INSTRUMENTS AND APPROVED TESTING EQUIPMENT FORINSPECTION, CALIBRATION, AND TESTING ACTIVITIES.#MAINTAIN PROPER HOUSEKEEPING, BARRICADING, ACCESS CONTROL, AND SAFESTORAGE OF DISMANTLED COMPO NENTS.#ENSURE ELECTRICAL ISOLATION AND VERIFICATION BEFORE WORKING ONACTUATOR MOTORS, LIMIT SWITCHES, TORQUE SWITCHES, OR CONTROL W IRING.#DISPOSE OF USED GREASE, OIL, CLEANING MATERIALS, AND CONTAMINATEDWASTE AS PER APPLICABLE ENVIRONMENTAL REQUIREMENTS.#.6. WA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RRANTY-#THE CONTRACTOR SHALL PROVIDE A MINIMUM ONE-YEAR WARRANTY FROM THE DATE OF WORK COMPLETION AND ACCEPTANCE. #THE WARRANTY SHALL COVER WORKMANSHIP, REPAIR QUALITY, REPLACED PARTS SUPPLIED BY THE CONTRACTOR, REASSEMBLY, CALIBRATION, AND TESTING-RELATED DEFECTS. #THE CONTRACTOR SHALL ATTEND ANY WARRANTY DEFECT PROMPTLY WITHOUT ADVERSELY AFFECTING PLANT OPERATION.</p>						
6		ITEM-00001	<p>SCOPE OF WORK: AUX BOILER 87 DAMPER ACTUATORS & GEARBOXES INSPECTION, OVERHAUL AND TESTING OUTAGE DATE: 15.08.2026 (TENTATIVE) DURATION : 7 CALENDAR DAY EQUIPMENT/SYSTEM: AUX BOILER 87 DAMPER ACTUATORS AND ASSOCIATED GEARBOXES 1. OBJECTIVE TO CARRY OUT COMPLETE INSPECTION, DISMANTLING, REFURBISHMENT, REASSEMBLY, CALIBRATION, FUNCTIONAL TESTING, AND COMMISSIONING SUPPORT FOR AUX BOILER 87 DAMPER ACTUATOR</p>	2	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RS AND ASSOCIATED GEARBOXES, ENSURINGRELIABLE OPERATION, ACCURATE POSITIONING, PROPER TORQUE TRANSMISSION,AND COMPLIANCE WITH OEM RE COMMENDATIONS, DEWA REQUIREMENTS, APPLICABLEHSE RULES, AND QUALITY STANDARDS.2. EQUIPMENT COVEREDSN#DESCRIPTION#KKS NO.#1#DAMPER DIS CHARGE FD FAN A ACTUATOR#87HLA11AA001#2#DAMPER DISCHARGE FD FAN B ACTUATOR#87HLA12AA001#3#DAMPER AIR LINE TO BURNER BOX 1#87HLA21AA0 01#4#DAMPER AIR LINE TO BURNER BOX 2#87HLA22AA001#5#DAMPER AIR LINE TO BURNER BOX 3#87HLA23AA001#6#DAMPER SUCTION FGR FAN A#87HNF11A A001#7#DAMPER DISCHARGE FGR FAN A#87HNF11AA003#8#DAMPER SUCTION FGR FAN B#87HNF12AA001#9#DAMPER DISCHARGE FGR FAN B#87HNF12AA003#10# AUX BOILER STACK INLET DAMPER ACTUATOR#87HNA10AA001#11#FD FAN-A IGV						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ACTUATOR#87HLB11AA001#12#FD FAN-B IGV ACTUATOR#87HLB12AA001#3. S COPE OF WORK DETAILS3.1 PRE-OUTAGE ACTIVITIES.#CONDUCT SITE VISIT AND FAMILIARIZE WITH EQUIPMENT LOCATION, ACCESSREQUIREMENTS, LIFTI NG REQUIREMENTS, AND JOB-SPECIFIC SAFETY PRECAUTIONS.#COORDINATE WITH OPERATIONS AND I&C FOR EQUIPMENT ISOLATION,PERMISSIVE CLEARAN CES, PTW REQUIREMENTS, AND LOOP-CHECK READINESS.#CONFIRM AVAILABILITY OF REQUIRED MANPOWER, TOOLS, LIFTING EQUIPMENT,SPARE PARTS, C ONSUMABLES, CALIBRATED INSTRUMENTS, AND APPROVEDLUBRICANTS.3.2 DISMANTLING AND INSPECTION.#CHECK, RECORD AND MAINTAIN THE SAME TORQU E LIMIT AS EXISTING.#DISMANTLE ACTUATOR AND GEARBOX ASSEMBLIES IN A CONTROLLED MANNERAFTER CONFIRMING ISOLATION AND SAFE ACCESS.#IN SPECT GEAR TRAIN, WORM GEARS, PLANETARY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>GEARS, BEARINGS, BUSHINGS, SHAFTS, COUPLINGS, KEYWAYS, SEALS, LIMIT SWITCHES, TORQUE SWITCHES , ANDACTUATOR MOTOR CONDITION.#CHECK FOR WEAR, CORROSION, ABNORMAL BACKLASH, MISALIGNMENT, MECHANICAL LOOSENESS, DAMAGED FASTENERS, OIL/GREASE CONTAMINATION, ANDSEALING DETERIORATION.#DPT FOR GEARBOX GEARS.#RECORD AS-FOUND CONDITION WITH PHOTOGRAPHS AND INSPECTIO NOBSERVATIONS BEFORE CLEANING OR REPAIR.3.3 CLEANING.#REMOVE OLD GREASE, OIL RESIDUE, DUST, DEPOSITS, AND FOREIGN MATERIALFROM ACTUA TOR AND GEARBOX INTERNAL PARTS.#CLEAN COMPONENTS USING APPROVED SOLVENTS, LINT FREE CLOTHS, ANDSUITABLE CLEANING METHODS WITHOUT DA MAGING MACHINED SURFACES ORELECTRICAL PARTS.#PREPARE MATING SURFACES, COVERS, SEALS, AND FASTENERS PRIOR TOREASSEMBLY.3.4 REPAIR AN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>D REPLACEMENT.#REPLACE DEFECTIVE OR WORN PARTS SUCH AS BEARINGS, SEALS, SWITCHES,GEARS, FASTENERS, COUPLINGS, AND OTHER IDENTIFIED COMPONENTS USING OEM-RECOMMENDED OR DEWA-APPROVED SPARE PARTS.(SFOT REPAIR KIT AND BEARING CONTRACTOR SCOPE-OTHERS SPARE DEWA SCOPE).#R REPAIR REUSABLE COMPONENTS WITHIN OEM TOLERANCES AND RESTORE SERVICEABILITY AS APPLICABLE.#CORRECT ABNORMAL GEARBOX BACKLASH, RESTORE SEALING INTEGRITY, AND ENSURE FREE MOVEMENT OF MECHANICAL TRANSMISSION COMPONENTS.#REPORT ANY MAJOR DEFECT REQUIRING ADDITIONAL REPAIR, MACHINING, REPLACEMENT, OR ENGINEERING DECISION BEFORE PROCEEDING.3.5 REASSEMBLY.#REASSEMBLE ACTUATOR AND GEARBOX ASSEMBLIES AS PER OEM SEQUENCE AND RECOMMENDED PRACTICES.#ENSURE CORRECT ALIGNMENT BETWEEN ACTUATOR, GEARBOX, COUPLING,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ANDDAMPER SHAFT.#APPLY OE M-APPROVED LUBRICANTS, GREASE, OIL, AND SEALANTS SUITABLE FORTHE OPERATING ENVIRONMENT AND TEMPERATURE ZONE.#TIGHTEN FASTENERS, COU PLINGS, AND LOCKING ARRANGEMENTS TO THEAPPLICABLE TORQUE AND ENSURE PROPER MECHANICAL LOCKING.3.6 TESTING, CALIBRATION, AND SETTING.</p> <p>#CARRY OUT FUNCTIONAL OPEN/CLOSE OPERATION TEST FOR EACH ACTUATOR ANDGEARBOX ASSEMBLY.#VERIFY TORQUE SWITCH OPERATION, LIMIT SWITCH OPERATION, END-POSITIONREPEATABILITY, AND STROKE DIRECTION.#PERFORM NO-LOAD AND LOADED CHECKS WHERE APPLICABLE, INCLUDINGOBSERVATI ON FOR ABNORMAL NOISE, VIBRATION, OVERHEATING, OR MECHANICALBINDING.#CALIBRATE OPEN/CLOSE LIMIT SWITCHES AND TORQUE SWITCH SETTINGS INCOORDINATION WITH I&C AND OPERATIONS.#VERIFY STROKE TIME AND ENSURE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SETTINGS ARE ALIGNED WITH PLANT OPERATING REQUIREMENTS AND CONTROL LOGIC INTERLOCKS.3.7 DOCUMENTATION AND REPORTING.#SUBMIT DETAILED INSPECTION REPORT INCLUDING AS-FOUND CONDITION, DEFECTS OBSERVED, CORRECTIVE ACTIONS, PARTS REPLACED, PHOTOGRAPHS, AND RECOMMENDATIONS.#SUBMIT TEST AND CALIBRATION RECORDS FOR EACH ACTUATOR, INCLUDING LIMIT SWITCH SETTINGS, TORQUE SWITCH SETTINGS, STROKE VERIFICATION, AND FUNCTIONAL TEST RESULTS.#SUBMIT COMPLETION CERTIFICATE CONFIRMING THAT THE WORK HAS BEEN COMPLETED IN ACCORDANCE WITH OEM RECOMMENDATIONS, DEWA REQUIREMENTS, AND ACCEPTED MAINTENANCE PRACTICES.4. ACCEPTANCE CRITERIA.#ACTUATOR AND GEARBOX OPERATE SMOOTHLY ACROSS FULL STROKE WITHOUT ABNORMAL NOISE, VIBRATION, OVERHEATING, OR MECHANICAL BINDING.#DAMPER ACHIEVES</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FULL OPEN AND FULL CLOSE POSITIONS WITH CORRECT INDICATION AND REPEATABLE POSITIONING. #TOR QUE AND LIMIT SWITCH SETTINGS ARE VERIFIED AND ALIGNED WITH OEM/PLANT REQUIREMENTS. #NO OIL/GREASE LEAKAGE, ABNORMAL BACKLASH, LOOSE COUPLING, SHAFT MISALIGNMENT, OR MECHANICAL LOOSENESS IS OBSERVED. #DCS/PLC FEEDBACK, COMMAND RESPONSE, INTERLOCKS, AND LOOP CHECKS ARE COMPLETED SATISFACTORILY. #FINAL OPERATION IS ACCEPTED BY DEWA MAINTENANCE, OPERATIONS, AND I&C REPRESENTATIVES, AS APPLICABLE. 5. HSE AND QUALITY REQUIREMENTS #COMPLY WITH DEWA HSE REQUIREMENTS, PTW SYSTEM, LOCK-OUT/TAG-OUT REQUIREMENTS, AND SITE SAFETY INSTRUCTIONS. #CONDUCT TOOLBOX TALK AND JOB-SPECIFIC RISK ASSESSMENT BEFORE STARTING WORK. #USE CERTIFIED LIFTING TOOLS, INSPECTED TACKLES, COM</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PETENT RIGGERS,AND SUITABLE LIFTING PLANS WHERE REQUIRED.#USE CALIBRATED INSTRUMENTS AND APPROVED TESTING EQUIPMENT FORINSPECTION, CALIBRATION, AND TESTING ACTIVITIES.#MAINTAIN PROPER HOUSEKEEPING, BARRICADING, ACCESS CONTROL, AND SAFESTORAGE OF DISMANTLED COMPO NENTS.#ENSURE ELECTRICAL ISOLATION AND VERIFICATION BEFORE WORKING ONACTUATOR MOTORS, LIMIT SWITCHES, TORQUE SWITCHES, OR CONTROL W IRING.#DISPOSE OF USED GREASE, OIL, CLEANING MATERIALS, AND CONTAMINATEDWASTE AS PER APPLICABLE ENVIRONMENTAL REQUIREMENTS.#.6. WA RRANTY.#THE CONTRACTOR SHALL PROVIDE A MINIMUM ONE-YEAR WARRANTY FROM THEDATE OF WORK COMPLETION AND ACCEPTANCE.#THE WARRANTY SHALL COVER WORKMANSHIP, REPAIR QUALITY, REPLACED PARTSSUPPLIED BY THE CONTRACTOR, REASSEMBLY, CALIBRATION, AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TESTING-RELATED DEFECTS. # THE CONTRACTOR SHALL ATTEND ANY WARRANTY DEFECT PROMPTLY WITHOUT ADVERSELY AFFECTING PLANT OPERATION.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Aux Boiler 87 Damper Actuators <(>&<)> Gearboxes Inspection, Overhaul and Testing

NOTE: SITE VISIT IS MANDATORY PRIOR TO THE EXECUTION OF JOB

CONTACT PERSON:

PRIYABRATA BEHERA

MAIL ID - priyabrata.behera@dewa.gov.ae

m-+971524230464

STANDARD TERMS & CONDITIONS

1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.

2) Prices should be 'DDP' delivery duty paid at DEWA stores.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.
- 8)Data Privacy, Security and Sharing:
- a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- d) DEWA reserves the right to withhold data from third parties if deemed sensitive.
- e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601553
DATE : 29.06.2026
REQ No : 1032602914
REQ TITLE : Aux Boiler 87 Damper Actuator
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP