

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Tower Access Platform and Supporting Structure at Jebel Ali Staff Accommodation Building (A-Block)
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>SUPPLY AND REPLACEMENT OF COOLING TOWER DAMAGED GRATING PLATFORM JEBELALI STAFF ACCOMMODATION BUILDING (A-BLOCK) DEWA-CONFIDENTIAL S</p> <p>UPPLY AND REPLACEMENT OF COOLING TOWER DAMAGED GRATING PLATFORM JEBELALI STAFF ACCOMMODATION BUILDING (A-BLOCK)1. PROJECT OBJECTIVET</p> <p>HE OBJECTIVE OF THIS PROJECT IS TO RESTORE AND ENHANCE THE STRUCTURALINTEGRITY, SAFETY, AND OPERATIONAL RELIABILITY OF THE COOLING T</p> <p>OWERACCESS PLATFORM AND SUPPORTING STRUCTURE AT JEBEL ALI STAFFACCOMMODATION BUILDING (A-BLOCK) THROUGH THE REPLACEMENT OF DETERIORA</p> <p>TEDGRATING, REFURBISHMENT OF STRUCTURAL MEMBERS, STRENGTHENING OFSUPPORTING BEAMS, REPLACEMENT OF CABLE TRAYS, INSTALLATION OF FILTR</p> <p>ATIONUNIT COVERS, AND APPLICATION OF FRP PROTECTIVE SYSTEMS.THE CONTRACTOR SHALL PROVIDE ALL MATERIALS, LABOUR, SUPERVISION,</p>	1	JOB				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Towers
DELIVERY LOCATION :
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TOOLS, LIFTING EQUIPMENT, TRANSPORTATION, CONSUMABLES, TESTING INSTRUMENTS, AND ANCILLARY ITEMS NECESSARY FOR THE COMPLETE EXECUTION OF THE WORKS IN ACCORDANCE WITH THE REQUIREMENTS SPECIFIED HEREIN. THE CONTRACTOR SHALL CONDUCT A DETAILED SITE SURVEY AND VERIFY ALL DIMENSIONS, QUANTITIES, AND EXISTING SITE CONDITIONS PRIOR TO COMMENCEMENT OF WORK. ANY DISCREPANCIES IDENTIFIED DURING THE SITE SURVEY SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER BEFORE EXECUTION.</p> <p>2. DETAILED SCOPE OF WORK</p> <p>2.1 DISMANTLING, REMOVAL, AND DISPOSAL OF EXISTING GRATING SYSTEM</p> <p>THE CONTRACTOR SHALL CAREFULLY DISMANTLE AND REMOVE THE EXISTING DAMAGED GRATING PLATFORM, INCLUDING ALL ASSOCIATED SUPPORT MEMBERS, FIXING CLIPS, BRACKETS, FASTENERS, AND ACCESSORIES THAT ARE NOT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Towers
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LONGER SUITABLE FOR SERVICE. THE SCOPE SHALL INCLUDE:## REMOVAL OF ALL DAMAGED MS GRATING PANELS AROUND THE COOLING TOWERS PLATFORM.##DISMANTLING OF DETERIORATED SUPPORT CHANNELS AND ANCILLARY COMPONENTS IDENTIFIED BY THE ENGINEER. DEWA-CONFIDENTIAL##PROTECTION OF EXISTING COOLING TOWERS EQUIPMENT, PIPING, VALVES, INSTRUMENTATION, ELECTRICAL CABLES, AND ASSOCIATED SERVICES DURING DISMANTLING ACTIVITIES.##COLLECTION, SEGREGATION, LOADING, TRANSPORTATION, AND DISPOSAL OF ALL REMOVED MATERIALS. ALL DISMANTLED GRATING MATERIALS AND SCRAP STEEL COMPONENTS SHALL BE TRANSPORTED AND HANDED OVER TO DEWA RUWAIYAH SCRAP YARD. THE CONTRACTOR SHALL ARRANGE ALL NECESSARY:##VEHICLES AND TRANSPORTATION.##CRANE OR LIFTING EQUIPMENT.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Tower Grating
DELIVERY LOCATION :
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>##LOADING AND UNLOADING ACTIVITIES.##MANPOWER AND SUPERVISION.##ENTRY PERMITS AND GATE PASSES.##SCRAP DISPOSAL DOCUMENTATION.UPON COMPLETION, THE CONTRACTOR SHALL SUBMIT OFFICIAL SCRAP DISPOSAL RECORDS AND ACKNOWLEDGMENT RECEIPTS ISSUED BY DEWA.2.2 SUPPLY, FABRICATION, AND INSTALLATION OF NEW PULTRUDED FRP GRATING.THE CONTRACTOR SHALL DESIGN, SUPPLY, FABRICATE, AND INSTALL A COMPLETE NEW HEAVY-DUTY PULTRUDED FRP GRATING PLATFORM SYSTEM TO REPLACE THE EXISTING DAMAGED GRATING.THE GRATING SYSTEM SHALL BE SUITABLE FOR CONTINUOUS OPERATION IN A COOLING TOWER ENVIRONMENT AND RESISTANT TO MOISTURE, CHEMICALS, UV EXPOSURE, AND CORROSION.THE SCOPE SHALL INCLUDE:##DETAILED SITE MEASUREMENT AND FABRICATION DRAWINGS.##SUPPLY OF HEAVY-DUTY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Towers
DELIVERY LOCATION :
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PULTRUDED FRP GRATING PANELS.##FABRICATION OF GRATING SECTIONS TO SUIT SITE CONDITIONS.DEWA-CONFIDENTIAL#PROVISION OF ALL REQUIRED CUT-OUTS, NOTCHES, AND OPENINGS FOR: PIPEPENETRATIONS.#STRUCTURAL MEMBERS.#CABLE ROUTES.#MAINTENANCE ACCESS REQUIREMENTS.##SUPPLY AND INSTALLATION OF EDGE BANDING AND REINFORCEMENT MEMBERS.#SUPPLY AND INSTALLATION OF SS316 FIXING CLIPS, HOLD-DOWN CLAMPS,FASTENERS, AND ACCESSORIES.#INSTALLATION AND ALIGNMENT OF GRATING PANELS TO ENSURE A SAFE ANDLEVEL WALKING SURFACE.MINIMUM TECHNICAL REQUIREMENTS DESCRIPTION #REQUIREMENT #TYPE #PULTRUDED FRP GRATING #THICKNESS #MINIMUM 38 MM #SURFACE FINISH #ANTI-SLIP GRITTED SURFACE #RESIN SYSTEM #ISOPHTHALIC POLYESTER OR VINYL ESTER #UV PROTECTION #REQUIRED #FIRE RETARDANCY #ASTM E84</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Tower
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CLASS 1 OR EQUIVALENT REQUIRED #CORROSION RESISTANCE #SUITABLE FOR COOLING TOWER ENVIRONMENT # COLOUR #GREY OR APPROVED EQUIVALENT #FASTENERS #SS316 STAINLESS STEEL #2.3 REMOVAL AND REPLACEMENT OF EXISTING STRUCTURAL SUPPORT MEMBERS THE CONTRACTOR SHALL CARRY OUT A DETAILED INSPECTION OF THE SUPPORTING STEEL FRAMEWORK BENEATH THE COOLING TOWER PLATFORM. ALL DAMAGED, CORRODED, DEFORMED, OR STRUCTURALLY WEAKENED STEEL MEMBERS SHALL BE REMOVED AND REPLACED. DEWA-CONFIDENTIAL THE SCOPE SHALL INCLUDE: ##REMOVAL AND DISPOSAL OF DAMAGED MS HORIZONTAL AND VERTICAL SUPPORT MEMBERS. ##FABRICATION AND INSTALLATION OF NEW STRUCTURAL STEEL SUPPORTS. ##SUPPLY AND INSTALLATION OF STEEL CHANNELS, ANGLES, PLATES, BRACKETS, AND STIFFENERS AS REQUIRED. ##WELDING, BOLTING, AN</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Tower
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CHORING, AND ALIGNMENT OF ALL NEW STRUCTURALMEMBERS.##RESTORATION OF THE ORIGINAL LOAD-BEARING CAPACITY OF THE PLATFORMSUPPORT SYSTE M.##SURFACE TREATMENT AND PROTECTIVE COATING OF ALL NEWLY INSTALLEDSTEELWORK.ALL STRUCTURAL STEEL MEMBERS SHALL BE DESIGNED TO SAFELY WITHSTANDOPERATING LOADS, MAINTENANCE LOADS, AND DYNAMIC LOADING ASSOCIATED WITHCOOLING TOWER OPERATION.2.4 STRENGTHENING OF EXISTING COOLING TOWER BASE BEAMS FOLLOWING REMOVAL OF THE EXISTING GRATING SYSTEM, THE CONTRACTOR SHALLINSPECT THE COOLING TOWER FOUNDATION BEAMS AND SUPPORTING STRUCTURE.WHERE DETERIORATION, CORROSION, OR INSUFFICIENT STRUCTURAL CAPACITY ISIDENTIFIED, THE CONTRACTOR SHALL STRENGTHEN THE EXISTING STRUCTURETHROUGH THE INSTALLATION OF ADDITIONAL STRUCTURAL STEEL MEMBERS.THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Tower
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SCOPE SHALL INCLUDE:##STRUC CTURAL ASSESSMENT OF EXISTING SUPPORT BEAMS.##SUPPLY AND INSTALLATION OF ADDITIONAL SUPPORT CHANNELS ANDREINFORCEMENT MEMBERS.##INST ALLATION OF GUSSET PLATES, STIFFENERS, AND STRENGTHENINGBRACKETS.##REINFORCEMENT OF BEAM-TO-COLUMN AND BEAM-TO-SUPPORT CONNECTIONS.# #ENHANCEMENT OF LOAD DISTRIBUTION ACROSS THE SUPPORT STRUCTURE.##RESTORATION AND IMPROVEMENT OF THE OVERALL STRUCTURAL INTEGRITY OFT HE COOLING TOWER FOUNDATION.DEWA-CONFIDENTIALTHE STRENGTHENED STRUCTURE SHALL BE CAPABLE OF SUPPORTING THE COOLINGTOWER OPERATING WE IGH, WATER LOAD, VIBRATION LOAD, AND MAINTENANCEPERSONNEL LOADING.2.5 SUPPLY AND INSTALLATION OF ADDITIONAL T-TYPE STRUCTURAL SUPPO RTSTHE CONTRACTOR SHALL PROVIDE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Tower
DELIVERY LOCATION :
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ADDITIONAL T-TYPE STRUCTURAL SUPPORTS BENEATH THE MAIN SUPPORT BEAMS WHEREVER REQUIRED TO IMPROVE LOAD TRANSFER AND STRUCTURAL STABILITY. THE SCOPE SHALL INCLUDE: ## SITE VERIFICATION OF SUPPORT LOCATIONS. ## FABRICATION OF T-TYPE SUPPORT MEMBERS. ## INSTALLATION AND ANCHORING OF SUPPORTS. ## WELDING AND STRUCTURAL CONNECTION WORKS. ## CORROSION PROTECTION TREATMENT AND FINISH COATING. THE QUANTITY AND SPACING OF SUPPORTS SHALL BE DETERMINED BASED ON ACTUAL SITE CONDITIONS AND DEWA ENGINEER APPROVAL. 2.6 SUPPLY AND INSTALLATION OF NEW GRATING SUPPORT CHANNELS. THE CONTRACTOR SHALL SUPPLY AND INSTALL NEW GALVANIZED STRUCTURAL SUPPORT CHANNELS FOR SUPPORTING THE FRP GRATING SYSTEM. THE SCOPE SHALL INCLUDE: ## FABRICATION AND INSTALLATION OF PRIMARY AND SECONDARY SUPPORT CHANNELS.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Tower Trays
DELIVERY LOCATION :
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ELS.##PROVISION OF INTERMEDIATE SUPPORTS WHERE NECESSARY.##STRUCTURAL ANCHORING AND WELDING.DEWA-CONFIDENTIAL##ALIGNMENT AND LEVELING OF SUPPORT FRAMEWORK.##PROVISION OF SUPPORT SPACING IN ACCORDANCE WITH THE FRP GRATINGMANUFACTURER#S RECOMMENDATIONS.ALL SUPPORT CHANNELS SHALL BE ADEQUATELY DESIGNED TO PREVENT GRATINGDEFLECTION AND ENSURE SAFE ACCESS FOR MAINTENANCE PERSONNEL.2.7 REPLACEMENT OF DAMAGED CABLE TRAY SYSTEMTHE CONTRACTOR SHALL REMOVE AND REPLACE ALL DAMAGED CABLE TRAYS LOCATEDWITHIN THE COOLING TOWER PLATFORM AREA.THE SCOPE SHALL INCLUDE:##REMOVAL OF DAMAGED CABLE TRAYS AND SUPPORTS.##TEMPORARY SUPPORT AND PROTECTION OF EXISTING CABLES.##SUPPLY AND INSTALLATION OF NEW HEAVY-DUTY GALVANIZED CABLE TRAYS.##SUPPLY AND INSTALLATION OF NEW TRAY SUPPORTS,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Cooling Tower Grating Platform
DELIVERY LOCATION :
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BRACKETS, HANGERS, COUPLERS, BENDS, REDUCERS, AND ACCESSORIES.##REINSTATEMENT AND DRESSING OF EXISTING CABLES.##ALIGNMENT, LEVELING, AND SECURING OF CABLE TRAY SYSTEM.ALL CABLE TRAY WORKS SHALL COMPLY WITH APPLICABLE ELECTRICAL INSTALLATION STANDARDS AND SITE REQUIREMENTS.2.8 SUPPLY AND INSTALLATION OF SAND FILTRATION UNIT COVERSTHE CONTRACTOR SHALL SUPPLY, FABRICATE, AND						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Supply and Replacement of Cooling Tower Damaged Grating Platform Jebel Ali Staff Accommodation Building (A-Block)

Contact : Mohideen / 553810513

Site Visit Date <(>&<)> Time: 01/07/2026

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601563
DATE	: 29.06.2026
REQ No	: 1032602870
REQ TITLE	: Supply and Replacement of Cool
DELIVERY LOCATION	
CLOSING DATE	: 03.07.2026
CLOSING TIME	: 10:00:00

Payment Terms: 95% After completion of works

Retention Condition:5%

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page12 of 15

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601563
DATE	: 29.06.2026
REQ No	: 1032602870
REQ TITLE	: Supply and Replacement of Cool
DELIVERY LOCATION	
CLOSING DATE	: 03.07.2026
CLOSING TIME	: 10:00:00

shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8) Data Privacy, Security and Sharing:

- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- DEWA reserves the right to withhold data from third parties if deemed sensitive.
- Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Co
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601563
DATE : 29.06.2026
REQ No : 1032602870
REQ TITLE : Supply and Replacement of Co
DELIVERY LOCATION
CLOSING DATE : 03.07.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP