

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SUPPLY, REPLACEMENT, TESTING AND COMMISSIONING OF SPX MARLEY COOLINGTOWER (3 NOS) PVC FILL PACKS (INFILLS) AT HEAD OFFICE.1. GENERAL SCOPE THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE COMPLETE ENGINEERING, SUPPLY, DELIVERY, DISMANTLING, REMOVAL, REPLACEMENT, INSTALLATION, TESTING, COMMISSIONING AND HANDOVER OF THE EXISTING SPX MARLEY COOLINGTOWER- (3 NOS) PVC FILL PACKS (INFILLS) INSTALLED AT DEWA HEAD OFFICE COOLING TOWERS. THE WORK SHALL INCLUDE ALL LABOUR, SUPERVISION, TRANSPORTATION, VEHICLES, CRANES, LIFTING EQUIPMENT, SCAFFOLDING, TOOLS, CONSUMABLES, TEMPORARY WORKS, SAFETY MEASURES, TESTING INSTRUMENTS, CLEANING MATERIALS AND ALL ACCESSORIES NECESSARY TO PROVIDE A COMPLETE AND FULLY OPERATIONAL COOLING TOWER SYSTEM IN ACCORDANCE WITH DEWA REQUIREMENTS.2. MANDATORY SITE VISIT THE CONTR	3	NO				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ACTOR SHALL CARRY OUT A MANDATORY SITE VISIT PRIOR TO SUBMISSION OF THE QUOTATION TO VERIFY THE ACTUAL COOLING TOWER CONFIGURATION, FILL DIMENSIONS, QUANTITY, ACCESS CONDITIONS, LIFTING REQUIREMENTS AND THE CONDITION OF ALL INTERNAL COMPONENTS. SUBMISSION OF THE PROPOSAL SHALL BE DEEMED AS CONFIRMATION THAT THE CONTRACTOR HAS FULLY ASSESSED THE SITE CONDITIONS AND INCLUDED ALL ASSOCIATED COSTS. NO CLAIMS ARISING FROM FAILURE TO INSPECT THE SITE SHALL BE ENTERTAINED. 3. REMOVAL OF EXISTING PVC FILL PACKS: THE CONTRACTOR SHALL CAREFULLY DISMANTLE AND REMOVE ALL EXISTING PVC FILL PACKS WITHOUT CAUSING DAMAGE TO THE COOLING TOWER CASING, STRUCTURAL MEMBERS OR ADJACENT EQUIPMENT. THE CONTRACTOR SHALL ISOLATE THE COOLING TOWER, PROVIDE TEMPORARY PROTECTION WHERE NECESSARY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANDENSURE SAFE EXECUTION OF THE DISMANTLING WORKS.ALL DISMANTLED PVC FILL PACKS, DAMAGED MATERIALS AND SCRAP GENERATEDDURING THE WORKS SHALL BE REMOVED FROM THE SITE.4. TRANSPORTATION AND DISPOSAL OF SCRAP MATERIALSTHE CONTRACTOR SHALL PROVIDE ALL VEHICLES, DRIVERS, LABOUR, LIFTINGEQUIPMENT AND TRANSPORTATION NECESSARY TO COLLECT, LOAD, TRANSPORT ANDUNLOAD ALL DISMANTLED PVC FILL PACKS AND ASSOCIATED SCRAP MATERIALS TO THE DEWA RUWAIYAH SCRAP YARD.THE CONTRACTOR SHALL OBTAIN WRITTEN ACKNOWLEDGEMENT OF MATERIAL DELIVERYFROM THE DEWA REPRESENTATIVE AND SUBMIT THE SAME AS PART OF THE PROJECTCLOSE-OUT DOCUMENTATION.5. INTERNAL CLEANING OF COOLING TOWER DEWA-CONFIDENTIALIMMEDIATELY AFTER REMOVAL OF THE EXISTING FILL PACKS, THE CONTRACTORSHALL THOROUGHLY CLEAN THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ENTIRE INTERNAL COOLING TOWER INCLUDING THE BASIN, FULL SUPPORT STRUCTURE, CASING, SPRAY PIPING, DISTRIBUTION SYSTEM AND ALL ACCESSIBLE INTERNAL SURFACES. ALL ACCUMULATED SCALE, ALGAE, BIOLOGICAL GROWTH, MUD, DEBRIS, CORROSION PRODUCTS AND LOOSE DEPOSITS SHALL BE COMPLETELY REMOVED BEFORE INSTALLATION OF THE NEW FILL MEDIA. 6. INSPECTION OF INTERNAL COOLING TOWER COMPONENTS FOLLOWING REMOVAL OF THE FILL PACKS, THE CONTRACTOR SHALL CARRY OUT A COMPREHENSIVE INSPECTION OF ALL INTERNAL COOLING TOWER COMPONENTS. ANY DAMAGED, DETERIORATED, CORRODED, CRACKED, LOOSE OR DEFECTIVE COMPONENTS IDENTIFIED DURING DISMANTLING OR INSTALLATION SHALL BE REPLACED IMMEDIATELY AT NO ADDITIONAL COST TO DEWA. THIS SHALL INCLUDE ALL COMPONENTS NECESSARY TO RESTORE THE COOLING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TOWER TO ITS ORIGINAL OPERATING CONDITION, INCLUDING WATER DISTRIBUTION COMPONENTS, SPRAY NOZZLES, SPRAY HEADERS, FLOAT VALVE ASSEMBLIES, INTERNAL SUPPORT STRUCTURES, HANGING PIPES, DRIFT ELIMINATOR SUPPORTS, FASTENERS, BRACKET S, ANCHOR ARRANGEMENTS AND ANY OTHER ASSOCIATED INTERNAL HARDWARE. THE CONTRACTOR SHALL NOT ASSUME THAT EXISTING COMPONENTS ARE REUSABLE. ALL DEFECTIVE ITEMS IDENTIFIED DURING EXECUTION SHALL BE DEEMED INCLUDED WITHIN THE CONTRACTOR'S SCOPE OF WORK. 7. SUPPLY OF NEW PVC FILL PACKS THE CONTRACTOR SHALL SUPPLY BRAND NEW, GENUINE SPX MARLEY PVC FILL PACKS SUITABLE FOR THE EXISTING COOLING TOWERS AND FULLY COMPLIANT WITH THE TECHNICAL REQUIREMENTS SPECIFIED BELOW. THE SUPPLIED PVC FILL PACKS SHALL BE FULLY COMPATIBLE WITH THE EXISTING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COOLING TOWER DESIGN, DIMENSIONS, SUPPORT SYSTEM, AND OPERATING CONDITIONS. THEY SHALL BE CAPABLE OF DELIVERING THE REQUIRED THERMAL PERFORMANCE AND HYDRAULIC CHARACTERISTICS WITHOUT REQUIRING ANY MODIFICATION TO THE EXISTING COOLING TOWER STRUCTURE OR ASSOCIATED COMPONENTS. 8. INSTALLATION OF PVC FILL PACKS THE CONTRACTOR SHALL INSTALL THE NEW PVC FILL PACKS STRICTLY IN ACCORDANCE WITH THE MANUFACTURER'S INSTALLATION PROCEDURES. THE FILL PACKS SHALL BE CORRECTLY ALIGNED, SECURELY SUPPORTED AND UNIFORMLY INSTALLED TO ENSURE UNRESTRICTED AIRFLOW, PROPER WATER DISTRIBUTION AND MAXIMUM HEAT TRANSFER EFFICIENCY. DEWA-CONFIDENTIAL INSTALLATION SHALL PREVENT WATER BYPASS, AIR BYPASS, SETTLEMENT OR MOVEMENT OF THE FILL PACKS DURING OPERATION. 9. REPLACEMENT OF DRIFT ELIMINATOR THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONTRACTOR SHALL SUPPLY AND INSTALL NEW DRIFT ELIMINATORS MANUFACTURED FROM HIGH-QUALITY, DURABLE, UV-STABILIZED PVC. THE DRIFT ELIMINATORS SHALL BE DESIGNED FOR CONTINUOUS OUTDOOR OPERATION AND SHALL BE RESISTANT TO ULTRAVIOLET (UV) RADIATION, CORROSION, CHEMICAL ATTACK, AND ENVIRONMENTAL DEGRADATION. THE SUPPLIED DRIFT ELIMINATORS SHALL BE FULLY COMPATIBLE WITH THE EXISTING COOLING TOWER CONFIGURATION AND SHALL COMPLY WITH ALL THE TECHNICAL REQUIREMENTS SPECIFIED BELOW. THEY SHALL BE CAPABLE OF MINIMIZING DRIFT LOSSES WHILE MAINTAINING THE REQUIRED AIRFLOW AND THERMAL PERFORMANCE WITHOUT REQUIRING ANY MODIFICATION TO THE EXISTING COOLING TOWER STRUCTURE. 10. REPLACEMENT OF DAMAGED INTERNAL COMPONENTS DURING EXECUTION OF THE WORKS, IF ANY INTERNAL COOLING TOWER						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMPONENT IS FOUND DAMAGED, WORN, CORRODED OR UNSUITABLE FOR CONTINUED SERVICE, THE CONTRACTOR SHALL REPLACE THE COMPONENT WITH NEW OEM MATERIALS WITHOUT ANY VARIATION TO THE CONTRACT PRICE. THIS REQUIREMENT SHALL INCLUDE, BUT NOT BE LIMITED TO: #WATER DISTRIBUTION NOZZLES #SPRAY PIPING #FLOAT VALVE ASSEMBLIES #INTERNAL SUPPORTS #HANGING PIPES #FILL SUPPORT BEAMS #DRIFT ELIMINATOR SUPPORTS #FASTENERS #BRACKETS #ANCHOR SUPPORTS #STAINLESS STEEL HARDWARE #PVC SUPPORT MEMBERS #ANY OTHER ASSOCIATED COMPONENTS REQUIRED FOR PROPER OPERATION. #THE CONTRACTOR SHALL INCLUDE ALL SUCH REPLACEMENT WORKS IN THE LUMP SUM PRICE. DEWA-CONFIDENTIAL11. TESTING AND COMMISSIONING UPON COMPLETION OF INSTALLATION, THE CONTRACTOR SHALL PERFORM COMPLETION TESTING AND COMMISSIONING OF THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COOLING TOWER.TESTING SHALL INCLUDE VERIFICATION OF WATER DISTRIBUTION, INSPECTION OFFILL ALI GNMENT, STRUCTURAL STABILITY, DRIFT ELIMINATOR PERFORMANCE,LEAKAGE INSPECTION, WATER FLOW DISTRIBUTION AND OVERALL COOLING TOWEROPER ATION.THE COOLING TOWER SHALL BE DEMONSTRATED TO OPERATE SATISFACTORILY UNDERNORMAL OPERATING CONDITIONS BEFORE FINAL ACCEPTANCE.12. TECHNICAL REQUIREMENTS OF PVC FILL PACKSTHE SUPPLIED FILL PACKS SHALL MEET OR EXCEED THE FOLLOWING MINIMUMREQUIREMENTS: DESCRIPTION #REQUIREMENT #MANUFACTURER #SPX MARLEY OR APPROVED EQUIVALENT #MATERIAL #VIRGIN UV STABILIZED PVC #WIDTH #915 MM / 1220 MM / 1520 M M #LENGTH #MULTIPLE OF 206 MM #THICKNESS #15 MILS 0.38MM (.015#) #SHEET SPACING #0.75# #SHEET INCLINATION #5° #TENSILE STRENGTH #6,300 PSI (ROOM TEMPERATURE) #TENSILE MODULUS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			#325,000 PSI #HEAT TRANSFER AREA #51.2 FT²/FT³ #WEIGHT OF COMPLETED FILL PACKS #1.93 LB/FT³ @ 15 MIL #MAXIMUM CONTINUOUS HOT WATER TEMPERATURE #80°C #THE FILL MEDIA SHALL BE MANUFACTURED FROM HIGH-QUALITY VIRGIN PVC ANDSH ALL BE RESISTANT TO ULTRAVIOLET DEGRADATION, CORROSION, CHEMICALATTACK, BIOLOGICAL GROWTH AND AGEING. DEWA-CONFIDENTIAL13. CONTRACTOR'S RESPONSIBILITIES THE CONTRACTOR SHALL PROVIDE ALL QUALIFIED MANPOWER, SUPERVISORS,TRANSPORTATION, CRANES, LIFTING EQUIPMENT, SCAF FOLDING, ACCESSPLATFORMS, TOOLS, CONSUMABLES, SAFETY EQUIPMENT, TEMPORARY SUPPORTS,CLEANING MATERIALS AND TESTING INSTRUMENTS NECESSARY FOR COMPLETION OFTHE WORKS.THE CONTRACTOR SHALL PROTECT THE COOLING TOWER STRUCTURE AND ADJACENTEQUIPMENT THROUGHOUT THE EXECUTION OF THE WORKS. ANY DAMAGE CAUSED BYTHE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONTRACTOR SHALL BE REPAIRED OR REPLACED AT NO ADDITIONAL COST TO DEWA.14. WARRANTY THE CONTRACTOR SHALL PROVIDE A MINIMUM FIVE (5) YEARS COMPREHENSIVE REPLACEMENT WARRANTY FROM THE DATE OF FINAL ACCEPTANCE. THE WARRANTY SHALL COVER						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Supply, Replacement, Testing

Supply, Replacement, Testing and Commissioning of SPX MARLEY Cooling

Tower (3 Nos) PVC Fill Packs (Infills) at Head Office.

Contact: Mohideen/ 553810513

Site Visit: 20.07.2026 @10:00

Payment: After completion of work

STANDARD TERMS & CONDITIONS

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601721
DATE	: 15.07.2026
REQ No	: 1032603243
REQ TITLE	: Supply, Replacement, Testing
DELIVERY LOCATION	
CLOSING DATE	: 21.07.2026
CLOSING TIME	: 10:00:00

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.
- 8)Data Privacy, Security and Sharing:
 - a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
 - b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.

d) DEWA reserves the right to withhold data from third parties if deemed sensitive.

e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.

f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.

g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601721
DATE : 15.07.2026
REQ No : 1032603243
REQ TITLE : Supply, Replacement, Testing
DELIVERY LOCATION
CLOSING DATE : 21.07.2026
CLOSING TIME : 10:00:00

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP