

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601801
DATE : 27.07.2026
REQ No : 1032603413
REQ TITLE : HP-LP-2 Reduction Station Pre
DELIVERY LOCATION
CLOSING DATE : 31.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SCOPE OF WORK FOR L#2 STATION HP-LP-2 REDUCTION STATION PRESSURE CONTROL VALVE SILENCER REPLACEMENT1. PURPOSE TO REPLACE THE EXISTING SILENCER (PR TUBE) OF THE PRESSURE CONTROL VALVE(PCV) IN THE HIGH-PRESSURE TO LOW-PRESSURE (HP-LP) REDUCTION STATION DUE TO CRACKS TO ENSURE THE REQUIRED PRESSURE REDUCTION, OPTIMAL NOISE REDUCTION, AVOID EMERGENCY SHUTDOWN, SYSTEM DAMAGE, INCREASE THE SYSTEM EFFICIENCY AND RELIABILITY2. SCOPE OF WORK2.1 PRE-JOB PREPARATION.#OBTAIN ALL NECESSARY WORK PERMITS AND APPROVALS.#CONDUCT A RISK ASSESSMENT AND JOB SAFETY ANALYSIS (JSA).#ISOLATE AND DEPRESSURIZE THE SYSTEM AS PER STANDARD OPERATING PROCEDURES.#ARRANGE SCAFFOLDING AND LIFTING TOOLS.#ERECT SCAFFOLDING AND REMOVE ANY DISTURBING OR HINDERING	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601801
DATE : 27.07.2026
REQ No : 1032603413
REQ TITLE : HP-LP-2 Reduction Station Pre
DELIVERY LOCATION
CLOSING DATE : 31.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSTALLATION(STRUCTURES) WITHIN THE WORKING AREA.#VERIFY THE AVAILABILITY OF NEW SILENCER, CONTROL VALVE GASKETS,PACKING, AND OTHER REQUIRED MATERIALS.#VERIFY THE FITMENT OF ALL THE SILENCER PIPES, END PLATE AND SPACER.#VALVE AND PIPE DRAWING AND MATERIAL CROSS VERIFY.#ENSURE WPSS ARE AVAILABLE AS PER PIPE/VALVE MATERIAL SUBJECT TO THEBELOW CUTTING AND WELDING JOINTS.#COVER ALL THE SPRAY NOZZLES (TOTAL 8 NOS) FROM INSIDE TO AVOID ANYACCUMULATI ON DURING CUTTING.#TEMPORARY LOCKING OF BYPASS EQUIPMENT AND STEAM PIPING SYSTEM2.2 REPLACE OF THE EXISTING SILENCER.#REMOVE THE EXT ERNAL INSULATION TO MAKE ACCESS TO THE VALVE BODY,#REMOVE ACTUATOR OF BYPASS CONTROL VALVE,#DISMANTLE THE PCV.#MARK THE POINTS TO CUT THE VALVE BODY AND PIPE AS PER THE DRAWING.1.#CUTTING POINT NO.1 (JOINT NO. 10) #						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601801
DATE : 27.07.2026
REQ No : 1032603413
REQ TITLE : HP-LP-2 Reduction Station Pre
DELIVERY LOCATION
CLOSING DATE : 31.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BETWEEN VALVE BODY AND THE DISHHEAD2.#CUTTING POINT NO.2 # APPROXIMATELY 2000 MM AWAY FROM THE OUTLET PIPEWELDING JOINT. (THIS IS SUBJECT TO PROTECTIVE CONDUIT LENGTH, PART NO1/1/30. FOR L2 STATIONS HP-LP THE PROTECTIVE CONDUIT LENGTH ISAPPROXIMATELY 3 METER).3.#CUTTING POINT NO.3 (JOINT NO. 5.16)-ATOMIZING STEAM CONNECTION 50MM AWAY FROM THE EXISTING WELDING.4.#CUTTING POINT NO.5 # SPRAY WATER CONNECTION 50 MM AWAY FROM THEEXISTING WEL DING POINT.#KEEP IN A PROPER PLACE TO REMOVE THE PR TUBES AND DISH HEADS.#REMOVE THE OUTLET PIPE FROM THE POSITION WITH CRANE AND K EEP IT IN ANELEVATED POSITION FOR FURTHER ACTIVITY (TEMPORARY STRUCTURE WITHSCAFFOLDING)5.#CUTTING POINT NO.4 (JOINT NO. 13) CUT THE OUTLET PIPE FROM DISH HEAD50 MM AWAY FROM						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601801
DATE : 27.07.2026
REQ No : 1032603413
REQ TITLE : HP-LP-2 Reduction Station Pre
DELIVERY LOCATION
CLOSING DATE : 31.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE EXISTING WELDING JOINT AND REMOVE THE OUTLET FROM DISH HEAD WITH PR TUBE (OPTIONAL). IF THE CUTTING AND EXTERNAL WELDING OF THE SILENCER (PR TUBE) IS POSSIBLE FROM INSIDE OF THE PIPE, THEN NO NEED FOR CUTTING OF JOINT NUMBER 4.6. #CUTTING POINT NO.6 (JOINT NO. 8 & 8A). CUT AND REMOVE THE PR TUBE ASSEMBLY FROM THE DISH HEAD (WELDING JOINT 8) AS WELL AS FROM INSIDE (WELDING JOINT 8A) OF THE OUTLET PIPE AT THE WELDING JOINT 8.7. #CUTTING POINT NO.7 (JOINT NO. 9) REMOVE THE PR TUBE END PLATE BY CUTTING AT THE WELDING JOINT NO.9. THE SAME END PLATE CAN BE REUSED. (IF THE SPARE END PLATE NOT AVAILABLE) 8. #REMOVE THE SPACER FROM THE OUTER TUBE, WHICH IS SHRINK FITTED TO THE TUBE. AND SAME SPACER CAN BE REUSED. (IF THE SPARE END PLATE IS NOT AVAILABLE) FIT UP AND ASSEMBLY: #FIT UP THE OUTER PIPE OF THE SILENCER WITH THE END						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601801
DATE : 27.07.2026
REQ No : 1032603413
REQ TITLE : HP-LP-2 Reduction Station Pre
DELIVERY LOCATION
CLOSING DATE : 31.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PLATE.#PREHEATING AND WELDING OF THE OUTER PIPE OF THE SILENCER WITH THE ENDPLATE AS PER REQUIRED WPS. (WELD JOINT NUMBER 9).#NDT FOR THE WELDING JOINT NUMBER 9. UT SCAN & DPT.#ASSEMBLING THE INNER PIPES OF THE SILENCER IN THE SLOTS OF THE ENDPLATE. ENSURE THAT THE ORIENTATION OF THE PIPES ARE AS PER DRAWING.TOTAL 4 PIPE SPOOLS.#INSERT THE SPACER (PRESS FIT) AND MAINTAIN A 3 MM GAP BETWEEN THE SPACER PLATE AND SILENCER PIPES.#TACK WELDS THE SPACER AT 4 LOCATIONS.#FIX THE COMPLETE PR TUBE ASSEMBLY BACK TO THE DISH HEAD CUT POINTNUMBER 6 (WELDING JOINT NO 8 & 8A).#PREHEATING, WELDING AND PWHT OF THE CUT POINT NUMBER 6 (WELDING JOINTNO 8 & 8A).AS PER THE WPS.#WELD BACK THE DISH HEAD WITH PR TUBES TO THE OUTLET PIPE CUT POINTNO.4 (JOINT NO. 13) IF IT WAS CUT .#NDE AFTER WELDING FOR THE PIPE CUT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601801
DATE : 27.07.2026
REQ No : 1032603413
REQ TITLE : HP-LP-2 Reduction Station Pre
DELIVERY LOCATION
CLOSING DATE : 31.07.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			POINT NO.4. (IF IT WAS CUT)-#ERECT THE OUTLET PIPE TO THE ORIGINAL POSITION AND DO THE FIT UP.-#FIT UP OF THE DISH HEAD END, CUT POINT NO.1 (JOINT NO. 10) WITH THE VALVE BODY AND THE OUTLET PIPE TO THE EXISTING DOWNSTREAM PIPE CUT POINT NO.2.-#PREHEATING AND WELDING OF BOTH THE JOINTS AS PER WPS FOLLOWED WITH REQUIRED NDE.-#FIT UP AND WELD BACK THE ATOMIZING STEAM LINE CUT POINT NO. 3 (JOINT NO. 5.16) FOLLOWED WITH REQUIRED NDE.-#FIT UP AND WELD BACK THE SPRAY WATER LINE CUT POINT NO 5 FOLLOWED WITH REQUIRED NDE.-#ONCE ALL NDE IS CLEARED, REMOVE ALL THE TEMPORARY SUPPORTS OF BYPASS EQUIPMENT AND STEAM PIPING SYSTEM.-#REINSTALL ALL THE STRUCTURES REMOVED.-#REMOVE THE TEMPORARY COVER FROM ALL THE SPRAY NOZZLES (TOTAL 8 NOS) FROM INSIDE AND AIR CLEANING.-#DISMANTLING THE SCAFFOLDING AND FIXING THE INSULATION BACK.-#BOX UP THE PCV						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601801
DATE : 27.07.2026
REQ No : 1032603413
REQ TITLE : HP-LP-2 Reduction Station Pre
DELIVERY LOCATION
CLOSING DATE : 31.07.2026
CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

HP-LP-2 Reduction Station Pressure Control Valve Silencer Replacement at
L-2 station

CONTACT - S.ARUN KUMAR / arunkumar.sethuraman@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page7 of 10

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601801
DATE	: 27.07.2026
REQ No	: 1032603413
REQ TITLE	: HP-LP-2 Reduction Station Pre
DELIVERY LOCATION	
CLOSING DATE	: 31.07.2026
CLOSING TIME	: 10:00:00

connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:

- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- DEWA reserves the right to withhold data from third parties if deemed sensitive.
- Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601801
DATE : 27.07.2026
REQ No : 1032603413
REQ TITLE : HP-LP-2 Reduction Station Pre
DELIVERY LOCATION
CLOSING DATE : 31.07.2026
CLOSING TIME : 10:00:00

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601801
DATE : 27.07.2026
REQ No : 1032603413
REQ TITLE : HP-LP-2 Reduction Station Pre
DELIVERY LOCATION
CLOSING DATE : 31.07.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP