

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS - OUTSOURCING WORK. L STATION PHASE2, JEBEL ALINAME OF WORK:#SCOPE OF WORK FOR SPOOL PIPE FABRI CATION AND REPLACEMENTOF WASTEWATER TREATMENT PLANT DURING L2 STATION TOTAL SHUTDOWN.PERIOD OF WORK:#03 CALENDAR DAYS DURING PLANT T OTAL SHUTDOWNSCOPE OF WORK.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FA CILITIES, COMPLEXITIES, SAFETYMEASURES, ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE HE SUBMITSHIS BID.#PARTY SHALL SUBMIT ITP ALONG WITH WPS AND ERECTION PLAN AFTER GETTINGPO AND BEFORE COMMENCING ANY WORK.#AWARDING THE PO DOES NOT GUARANTEE THAT COMPLETE QUANTITY IN THE POWILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDEDBASED ON INSPECTION AND PAYMENT	18	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALL BE BASED ON ACTUAL WORK CARRIED OUT. #TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS AND METHOD STATEMENT PRIOR TO START THE WORK. #CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED IN METHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE CONDUCTED TO ALL CONTRACTOR TEAM. #PARTY SHALL MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELY AFTER DEWA NOTIFICATION. PARTY SHALL BE READY TO START THE WORK WITH ONE-DAY ADVANCE NOTIFICATION. #ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND TEST CERTIFICATE TO BE PROVIDED TO DEWA. #PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALID SCAFFOLDING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING. #REMOVE ALL THE REQUIRED CLADDING SHEETS, INSULATION AND INSULATIONFIXING CLAMPS. DISPOSE THE DAMAGED INSULATION ON THE DESIGNATED AREASHOWN BY DEWA ENGINEER FOLLOWING DEWA RULES AND REGULATIONS. KEEP THECLADDING SHEET AND GOOD INSULATION IN PROPER WAY. #INSPECT, MEASURE, AND COMPARE THE MEASUREMENTS, PROFILES, SIZE, CLASSAND THE SUPPLIED PIPE / FITTING AND EXISTING PIPE/FITTING. IN CASE OFANY DEVIATIONS IDENTIFIED, IMMEDIATELY INFORM TO DEWA. #AFTER PROPER CHECKING AND CONFIRMATION OF SUPPLIED PIPE / FITTING,PREPARE ADDITIONAL SUPPORTS AND LIFTING ARRANGEMENTS TO HOLD THEPIPELINES IN POSITION AND CUT EXISTING SUPPORTS IF REQUIRED. #MARK AND CUT THE INLET AND OUTLET JOINTS AS PER THE NEW						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FITTINGDIMENSIONS. REMOVED PIPE / FITTING SHALL SAFELY BRING DOWN TO GROUNDLEVEL AND SHALL KEEP IN A SAFE MANNER.#INSPECT THE EXITING INLET AND OUTLET PIPING FOR ANY DEFORMATIONS /DEFECTS.#CONTRACTOR SHALL TAKE INTO CONSIDERATION THAT THE EXISTING PIPESURFACES MAY HAVE IRREGULARITIES IN SHAPE AND THICKNESS, WHICH PARTYSHALL RECTIFY BEFORE FIT UP.#SURFACE PREPARATION OF INLET AND OUTLET JOINTS AS PER APPROVED WPS /ITP.#SURFACE PREPARATION OF NEW FITTING INLET AND OUTLET JOINTS AS PERAPPROVED WPS / ITP.#EXPERIENCED AND CERTIFIED RIGGERS FROM CONTRACTOR SHALL PERFORM THESHIFTING ACTIVITIES UNDER DEWA SUPERVISION.#REPLACEMENT OF PIPE / FITTING IN THE SAME ORIENTATION OF REMOVED PIPE/ FITTING AND FIT UP OF INLET AND OUTLET JOINTS.#FINAL ALIGNMENT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OF EACH FIT UP JOINTS SHALL VERIFY BY CONTRACTOR QCIN PRESENCE OF DEWA. WELDING SHALL START AFTER DEWA CLEARANCE ONLY. #WELDING OF I NLET AND OUTLET PIPING AS PER APPROVED WPS / ITP. #EXTRA PRECAUTION SHALL BE TAKEN DURING EXECUTION OF JOB NOT TO DAMAGE ANY NEARBY EQUIPMENT. #AFTER COMPLETION OF ABOVE SCOPE OF WORK, JOINT INSPECTION WITH DEWA ENGINEER. #ON SUCCESSFUL COMPLETION OF NDT AND AFTER FINAL CLEARANCE FROM DEWA, INSTALL BACK INSULATION CLAMPS, INSULATION, AND CLADDING SHEETS. #IN CASE OF NON-COMPLETION OF THE PROJECT WITHIN THE STIPULATED TIME OR EXTENSION OF SHUTDOWN DUE TO ANY REASONS FROM THE CONTRACTOR'S SIDE (INCLUDING FAILURE OF NDT), DEWA RESERVE THE RIGHT TO BACK CHARGE THE CONTRACTOR. #REMOVAL OF ALL METAL SCRAPS, TEMPORARY SUPPORTS AND ANY OTHER						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SCRAPSFROM WORKPLACE AND DISPOSAL AS PER DEWA ENGINEER INSTRUCTION. #HOUSEKEEPING # WORKPLACE AND DOWNSIDE AREAS. #INSPECTION AND APPROVAL FROM DEWA PERSONNEL. #DE-MOBILIZATION AND SITE CLEARANCE. #PREVIOUS SIMILAR EXPERIENCE PO # TO BE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY. #WORK COMPLETION REPORT INCLUDING ITP, WPS, PQR, WPQT, MTC, WELDMATRIX, RIGGING TOOL CERTIFICATES, RISK ASSESSMENT AND PHOTOS SHALLS UBMIT.TABLE: -SN #DESCRIPTION#TYPE #MATERIAL #SIZE (INCH)#QTY /LENGTH1#WWTP PIPE FABRICATION AND REPLACEMENTPIPE #SS316 #2 " 18 JOINTSPOOL PIPE SS316 4# 2ELBOW SS316 4# 2SPOOL PIPE SS316 6# 5ELBOW SS316 6# 7F LANGE#SS316#6" 2U CLAMP SS316 2# 30CONTRACTOR SCOPE OF SUPPLY. #TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			JOB.#MANP OWER.#WELDING CONSUMABLES.#ITP, WPS, NDT PLAN & ERECTION PLAN.#TEMPORARY SUPPORTSDEWA SCOPE.#PIPE / FITTING.#INSULATION MATERIAL AND CLADDING SHEET.#NDT.#SCAFFOLDING.#CRANE / FORKLIFT.#POWER.#WATERWARRANTY.#A MINIMUM WARRANTY OF 12 MONTHS FOR WELD JOINTS AND WORKM ANSHIP SHALLPROVIDE BY THE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROMDEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND R ECTIFY THE DEFECT WITHIN SHORTPERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.GENERAL TERMS & CONDITIONSTECHNICAL S AFETY DURING THE WORK:.#CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE PLANT PREMISES. #CONTRACTOR SHALL GIVE DAILY TOOLBOX TALK, RISK ASSESSMENT AND DYNAMIC RISK ASSESSMENT TO THEIR STAFFS. #CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THE AVAILABILITY OF LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORE START OF ANY WORK. #CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE ISOLATIONS BEFORE STARTING OF ANY OVERHAULING WORK. #THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS. #CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB. #THE CONTRACTOR MUST ENGAGE A QUALIFIED						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			IED SAFETY OFFICER TO ALWAYS ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPE INCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING AT HEIGHT.#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THE WORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES, AND IT MUST BE PRODUCED TO DEWA FOREMAN/ENGINEER UPON REQUEST.#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THE WORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANY DELAY.#DAILY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/ GRINDING/DRILLING/HEATING ETC..#DURING WELDING / CUTTING, ENSURE THA T WELDING SPARK / CUTTINGMATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETSSHALL BE USED DURING WELDING AND CUTTIN G WORK..#NO HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT ANDWITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATION..#CONTRACT OR SHALL ENSURE NO DISTURBANCE TO THE NEARBY OPERATING PLANT/ EQUIPMENT..#CONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE OR EFFECT ON INST ALLED OROPERATING MACHINES /EQUIPMENT/ PROPERTIES..#ENSURE PROPER HANDLING OF MATERIALS, TOOLS. SUITABLE BELTS ARE TO BEWORN TO AVOI D TOOLS FROM FALLING..#SAFETY SIGNS SHALL BE PROVIDED AT WORK SITE AND WHEREVER						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REQUIRED THE AREA IS TO BE BARRICADED FOR SAFETY AND TO PREVENT UNAUTHORIZED ENTRY. #CONTRACTOR STAFF ARE ALLOWED TO WORK ONLY IN THE AUTHORIZED WORKPLACE DESIGNATED BY DEWA. #CONTRACTOR STAFF ARE REQUIRED TO WEAR THEIR COMPANY UNIFORM & CARRY THEIR GATE PASS IDS DURING THE WORK INSIDE DEWA PREMISES. #ALL						
2		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS - OUTSOURCING WORK. L STATION PHASE 2, JEBEL ALI NAME OF WORK: #SCOPE OF WORK FOR SPOOL PIPE FABRICATION AND REPLACEMENT OF WASTEWATER TREATMENT PLANT DURING L2 STATION TOTAL SHUTDOWN. PERIOD OF WORK: #03 CALENDAR DAYS DURING PLANT TOTAL SHUTDOWN. SCOPE OF WORK: #THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES,	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE HE SUBMITSHIS BID.#PARTY SHALL SUBMIT ITP ALONG WITH WPS AND ERECTION PLAN AFTER GETTINGPO AND BEFORE COMMENCING ANY WORK.#AWARDING THE PO DOES NOT GUARANTEE THAT COMPLETE QUANTITY IN THE POWILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDEDBASED ON INSPECTION AND PAYMENT SHALL BE BASED ON ACTUAL WORK CARRIEDOUT.#TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS ANDMETHOD STATEMENT PRIOR TO START THE WO RK.#CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY ANDSAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.#A SAFE TY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE CONDUCT TOALL CON						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TRACTOR TEAM .#PARTY SHALL MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELYAFTER DEWA NOTIFICATION. PARTY SHALL BE READY TO S TART THE WORK WITHONE-DAY ADVANCE NOTIFICATION.#ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND TEST CERTIFICATE TOBE PROVIDED TO D EWA.#PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALIDSCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING.#REMOV E ALL THE REQUIRED CLADDING SHEETS, INSULATION AND INSULATIONFIXING CLAMPS. DISPOSE THE DAMAGED INSULATION ON THE DESIGNATED AREASHO WN BY DEWA ENGINEER FOLLOWING DEWA RULES AND REGULATIONS. KEEP THECLADDING SHEET AND GOOD INSULATION IN PROPER WAY.#INSPECT, MEASUR E, AND COMPARE THE MEASUREMENTS, PROFILES, SIZE, CLASSAND THE SUPPLIED PIPE / FITTING AND EXISTING PIPE/FITTING. IN CASE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OFANY DEVIA TIONS IDENTIFIED, IMMEDIATELY INFORM TO DEWA. #AFTER PROPER CHECKING AND CONFIRMATION OF SUPPLIED PIPE / F FITTING,PREPARE ADDITIONA L SUPPORTS AND LIFTING ARRANGEMENTS TO HOLD THEPIPELINES IN POSITION AND CUT EXISTING SUPPORTS IF REQUIRED. #MARK AND CUT THE INLET AND OUTLET JOINTS AS PER THE NEW FITTINGDIMENSIONS. REMOVED PIPE / FITTING SHALL SAFELY BRING DOWN TO GROUNDLEVEL AND SHALL KEEP IN A SAFE MANNER. #INSPECT THE EXITING INLET AND OUTLET PIPING FOR ANY DEFORMATIONS /DEFECTS. #CONTRACTOR SHALL TAKE INTO CONSIDERATION THAT THE EXISTING PIPESURFACES MAY HAVE IRREGULARITIES IN SHAPE AND THICKNESS, WHICH PARTYSHALL RECTIFY BEFORE FIT UP. #SURFACE PRE PARATION OF INLET AND OUTLET JOINTS AS PER APPROVED WPS /ITP. #SURFACE PREPARATION OF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NEW FITTING INLET AND OUTLET JOINTS AS PERAPPR OVED WPS / ITP. #EXPERIENCED AND CERTIFIED RIGGERS FROM CONTRACTOR SHALL PERFORM THESHIFTING ACTIVITIES UNDER DEWA SUPERVISION. #REP LACEMENT OF PIPE / FITTING IN THE SAME ORIENTATION OF REMOVED PIPE/ FITTING AND FIT UP OF INLET AND OUTLET JOINTS. #FINAL ALIGNMENT OF EACH FIT UP JOINTS SHALL VERIFY BY CONTRACTOR QCIN PRESENCE OF DEWA. WELDING SHALL START AFTER DEWA CLEARANCE ONLY. #WELDING OF I NLET AND OUTLET PIPING AS PER APPROVED WPS / ITP. #EXTRA PRECAUTION SHALL BE TAKEN DURING EXECUTION OF JOB NOT TO DAMAGEANY NEARBY E QUIPMENT. #AFTER COMPLETION OF ABOVE SCOPE OF WORK, JOINT INSPECTION WITH DEWAENGINEER. #ON SUCCESSFUL COMPLETION OF NDT AND AFTER F INAL CLEARANCE FROM DEWA,INSTALL BACK						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSULATION CLAMPS, INSULATION, AND CLADDING SHEETS. #IN CASE OF NON-COMPLETION OF THE PROJECT WITHIN THE STIPULATED TIMEOR EXTENSION OF SHUTDOWN DUE TO ANY REASONS FROM THE CONTRACTOR#S SIDE(INCLUDING FAILURE OF NDT), DEWA RESERVE THE RIGHT TO BACK CHARGE THECONTRACTOR. #REMOVAL OF ALL METAL SCRAPS, TEMPORARY SUPPORTS AND ANY OTHER SCRAPSFROM WORKPLACE AND DISPOSAL AS PER DEWA ENGINEER INSTRUCTION. #HOUSEKEEPING # WORKPLACE AND DOWNSIDE AREAS. #INSPECTION AND APPROVAL FROM DEWA PERSONNEL. #DE-MOBILIZATION AND SITE CLEARANCE. #PREVIOUS SIMILAR EXPERIENCE PO # TO BE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY. #WORK COMPLETION REPORT INCLUDING ITP, WPS, PQR, WPQT, MTC, WELDMATRIX, RIGGING TOOL CERTIFICATES, RISK ASSESSMENT AND PHOTOS SHALLS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			UBMIT.TABLE: -SN #DESCRIPTION#TYPE #MATERIAL #SIZE (INCH)#QTY /LENGTH1#WWTP PIPE FABRICATION AND REPLACEMENTPIPE #SS316 #2 " 18 JOINTSPOOL PIPE SS316 4# 2ELBOW SS316 4# 2SPOOL PIPE SS316 6# 5ELBOW SS316 6# 7F LANGE#SS316#6" 2U CLAMP SS316 2# 30CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.#MANP OWER.#WELDING CONSUMABLES.#ITP, WPS, NDT PLAN & ERECTION PLAN.#TEMPORARY SUPPORTSDEWA SCOPE.#PIPE / FITTING.#INSULATION MATERIAL AND CLADDING SHEET.#NDT.#SCAFFOLDING.#CRANE / FORKLIFT.#POWER.#WATERWARRANTY.#A MINIMUM WARRANTY OF 12 MONTHS FOR WELD JOINTS AND WORKM ANSHIP SHALLPROVIDE BY THE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROMDEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORT PERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER. GENERAL TERMS & CONDITIONS TECHNICAL SAFETY DURING THE WORK: #CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANT PREMISES. #CONTRACTOR SHALL GIVE DAILY TOOLBOX TALK, RISK ASSESSMENT AND DYNAMIC RISK ASSESSMENT TO THEIR STAFFS. #CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THE AVAILABILITY OF LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORE START OF ANY WORK. #CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE ISOLATIONS BEFORE STARTING OF ANY OVERHAULING WORK. #THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THEWORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.#CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS. #CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB.#THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ALWAYS ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISKASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPEINCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ATHEIGHT.#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THEWORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES, AND ITMUST BE PRODUCED TO DEWA FOREMAN/ ENGINEER UPON REQUEST.#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THEWORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANYDELAY.#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/ GRINDING/DRILLING/HEATING ETC.#DURING WELDING / CUTTING, ENSURE THA T WELDING SPARK / CUTTINGMATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETSSHALL BE USED DURING WELDING AND CUTTIN G WORK.#NO HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT ANDWITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATION.#CONTRACT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OR SHALL ENSURE NO DISTURBANCE TO THE NEARBY OPERATING PLANT/ EQUIPMENT. #CONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE OR EFFECT ON INSTALLED OPERATING MACHINES /EQUIPMENT/ PROPERTIES. #ENSURE PROPER HANDLING OF MATERIALS, TOOLS. SUITABLE BELTS ARE TO BE WORN TO AVOID TOOLS FROM FALLING. #SAFETY SIGNS SHALL BE PROVIDED AT WORK SITE AND WHEREVER REQUIRED THE AREA IS TO BE BARRICADED FOR SAFETY AND TO PREVENT UNAUTHORIZED ENTRY. #CONTRACTOR STAFF ARE ALLOWED TO WORK ONLY IN THE AUTHORIZED WORKPLACE DESIGNATED BY DEWA. #CONTRACTOR STAFF ARE REQUIRED TO WEAR THEIR COMPANY UNIFORM & CARRY THEIR GATE PASS IDS DURING THE WORK INSIDE DEWA PREMISES. #ALL						
3		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS - OUTSOURCING WORK. L STATION PHASE2, JEBEL ALI NAME OF WORK: #SCOPE OF WORK FOR SPOOL	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PIPE FABRI CATION AND REPLACEMENT OF WASTEWATER TREATMENT PLANT DURING L2 STATION TOTAL SHUTDOWN. PERIOD OF WORK: #03 CALENDAR DAYS DURING PLANT T OTAL SHUTDOWNSCOPE OF WORK: #THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES, ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE HE SUBMITS HIS BID. #PARTY SHALL SUBMIT ITP ALONG WITH WPS AND ERECTION PLAN AFTER GETTING PO AND BEFORE COMMENCING ANY WORK. #AWARDING THE PO DOES NOT GUARANTEE THAT COMPLETE QUANTITY IN THE PO WILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDED BASED ON INSPECTION AND PAYMENT SHALL BE BASED ON ACTUAL WORK CARRIED OUT. #TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ASSESSMENT FORMS ANDMETHOD STATEMENT PRIOR TO START THE WO RK.#CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY ANDSAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.#A SAFE TY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE CONDUCT TOALL CON TRACTOR TEAM .#PARTY SHALL MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELYAFTER DEWA NOTIFICATION. PARTY SHALL BE READY TO S TART THE WORK WITHONE-DAY ADVANCE NOTIFICATION.#ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND TEST CERTIFICATE TOBE PROVIDED TO D EWA.#PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALIDSCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING.#REMOV E ALL THE REQUIRED CLADDING SHEETS,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSULATION AND INSULATIONFIXING CLAMPS. DISPOSE THE DAMAGED INSULATION ON THE DESIGNATED AREASHO WN BY DEWA ENGINEER FOLLOWING DEWA RULES AND REGULATIONS. KEEP THECLADDING SHEET AND GOOD INSULATION IN PROPER WAY. #INSPECT, MEASUR E, AND COMPARE THE MEASUREMENTS, PROFILES, SIZE, CLASSAND THE SUPPLIED PIPE / FITTING AND EXISTING PIPE/FITTING. IN CASE OFANY DEVIA TIONS IDENTIFIED, IMMEDIATELY INFORM TO DEWA. #AFTER PROPER CHECKING AND CONFIRMATION OF SUPPLIED PIPE / F FITTING,PREPARE ADDITIONA L SUPPORTS AND LIFTING ARRANGEMENTS TO HOLD THEPIPELINES IN POSITION AND CUT EXISTING SUPPORTS IF REQUIRED. #MARK AND CUT THE INLET AND OUTLET JOINTS AS PER THE NEW FITTINGDIMENSIONS. REMOVED PIPE / FITTING SHALL SAFELY BRING DOWN TO GROUNDLEVEL AND SHALL KEEP IN						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			A SAFE MANNER. #INSPECT THE EXITING INLET AND OUTLET PIPING FOR ANY DEFORMATIONS /DEFECTS. #CONTRACTOR SHALL TAKE INTO CONSIDERATION THAT THE EXISTING PIPESURFACES MAY HAVE IRREGULARITIES IN SHAPE AND THICKNESS, WHICH PARTYSHALL RECTIFY BEFORE FIT UP. #SURFACE PREPARATION OF INLET AND OUTLET JOINTS AS PER APPROVED WPS /ITP. #SURFACE PREPARATION OF NEW FITTING INLET AND OUTLET JOINTS AS PERAPPROVED WPS / ITP. #EXPERIENCED AND CERTIFIED RIGGERS FROM CONTRACTOR SHALL PERFORM THESHIFTING ACTIVITIES UNDER DEWA SUPERVISION. #REPLACEMENT OF PIPE / FITTING IN THE SAME ORIENTATION OF REMOVED PIPE/ FITTING AND FIT UP OF INLET AND OUTLET JOINTS. #FINAL ALIGNMENT OF EACH FIT UP JOINTS SHALL VERIFY BY CONTRACTOR QCIN PRESENCE OF DEWA. WELDING SHALL START AFTER DEWA CLEARANCE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ONLY.#WELDING OF I NLET AND OUTLET PIPING AS PER APPROVED WPS / ITP.#EXTRA PRECAUTION SHALL BE TAKEN DURING EXECUTION OF JOB NOT TO DAMAGE ANY NEARBY E QUIPMENT.#AFTER COMPLETION OF ABOVE SCOPE OF WORK, JOINT INSPECTION WITH DEWAENGINEER.#ON SUCCESSFUL COMPLETION OF NDT AND AFTER F INAL CLEARANCE FROM DEWA,INSTALL BACK INSULATION CLAMPS, INSULATION, AND CLADDING SHEETS.#IN CASE OF NON-COMPLETION OF THE PROJECT WITHIN THE STIPULATED TIMEOR EXTENSION OF SHUTDOWN DUE TO ANY REASONS FROM THE CONTRACTOR#S SIDE(INCLUDING FAILURE OF NDT), DEWA RES ERVE THE RIGHT TO BACK CHARGE THECONTRACTOR.#REMOVAL OF ALL METAL SCRAPS, TEMPORARY SUPPORTS AND ANY OTHER SCRAPSFROM WORKPLACE AND DISPOSAL AS PER DEWA ENGINEER INSTRUCTION.#HOUSEKEEPING # WORKPLACE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND DOWNSIDE AREAS.#INSPECTION AND APPROVAL FROM DEWA PERSONNEL.#DE-MOBILIZATION AND SITE CLEARANCE.#PREVIOUS SIMILAR EXPERIENCE PO # TO BE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY. #WORK COMPLETION REPORT INCLUDING ITP, WPS, PQR, WPQT, MTC, WELDMATRIX, RIGGING TOOL CERTIFICATES, RISK ASSESSMENT AND PHOTOS SHALLS UBMIT.TABLE: -SN #DESCRIPTION#TYPE #MATERIAL #SIZE (INCH)#QTY /LENGTH1#WWTP PIPE FABRICATION AND REPLACEMENTPIPE #SS316 #2 " 18 JOINTSPOOL PIPE SS316 4# 2ELBOW SS316 4# 2SPOOL PIPE SS316 6# 5ELBOW SS316 6# 7F LANGE#SS316#6" 2U CLAMP SS316 2# 30CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.#MANPOWER.#WELDING CONSUMABLES.#ITP, WPS, NDT PLAN & ERECTION PLAN.#TEMPORARY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUPPORTSDEWA SCOPE.#PIPE / FITTING.#INSULATION MATERIAL AND CLADDING SHEET.#NDT.#SCAFFOLDING.#CRANE / FORKLIFT.#POWER.#WATERWARRANTY.#A MINIMUM WARRANTY OF 12 MONTHS FOR WELD JOINTS AND WORKM ANSHIP SHALLPROVIDE BY THE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROMDEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND R ECTIFY THE DEFECT WITHIN SHORTPERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.GENERAL TERMS & CONDITIONSTECHNICAL S AFETY DURING THE WORK:#CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANTPREMISES.#CONTRACTOR SHALL GIVE DAILY T OOLBOX TALK, RISK ASSESSMENT AND						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DYNAMICRISK ASSESSMENT TO THEIR STAFFS.#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THE AVAILABILITY OF LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORE START OF ANY WORK.#CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE ISOLATIONS BEFORE STARTING OF ANY OVERHAULING WORK.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT.#CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS.#CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB.#THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ALWAYS ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE. THE SAFETY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISKASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPEINCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING ATHEIGHT.#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THEWORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES, AND ITMUST BE PRODUCED TO DEWA FOREMAN/ ENGINEER UPON REQUEST.#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THEWORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANYDELAY.#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			GRINDING/DRILLING/HEATING ETC..#DURING WELDING / CUTTING, ENSURE THAT WELDING SPARK / CUTTINGMATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETSSHALL BE USED DURING WELDING AND CUTTING WORK..#NO HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT ANDWITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATION..#CONTRACTOR SHALL ENSURE NO DISTURBANCE TO THE NEARBY OPERATING PLANT/ EQUIPMENT..#CONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE OR EFFECT ON INSTALLED OROPERATING MACHINES /EQUIPMENT/ PROPERTIES..#ENSURE PROPER HANDLING OF MATERIALS, TOOLS. SUITABLE BELTS ARE TO BEWORN TO AVOID TOOLS FROM FALLING..#SAFETY SIGNS SHALL BE PROVIDED AT WORK SITE AND WHEREVER REQUIRED THEAREA IS TO BE BARRICADED FOR SAFETY AND TO PREVENT UNAUTHORIZED						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ENTRY.#CONTRACTOR STAFF ARE ALLOWED TO WORK ONLY IN THE AUTHORIZED WORKPLACEDESIGNATED BY DEWA.#CONTRACTOR STAFF ARE REQUIRED TO WEAR THEIR COMPANY UNIFORM & CARRYTHEIR GATE PASS IDS DURING THE WORK INSIDE DEWA PREMISES.#ALL						
4		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS - OUTSOURCING WORK. L STATION PHASE2, JEBEL ALINAME OF WORK:#SCOPE OF WORK FOR SPOOL PIPE FABRI CATION AND REPLACEMENTOF WASTEWATER TREATMENT PLANT DURING L2 STATION TOTAL SHUTDOWN.PERIOD OF WORK:#03 CALENDAR DAYS DURING PLANT T OTAL SHUTDOWNSCOPE OF WORK.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES, ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE HE SUBMITSHIS BID.#PARTY SHALL SUBMIT ITP	5	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ALONG WITH WPS AND ERECTION PLAN AFTER GETTING PO AND BEFORE COMMENCING ANY WORK. #AWARDING THE PO DOES NOT GUARANTEE THAT COMPLETE QUANTITY IN THE PO WILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDED BASED ON INSPECTION AND PAYMENT SHALL BE BASED ON ACTUAL WORK CARRIED OUT. #TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS AND METHOD STATEMENT PRIOR TO START THE WORK. #CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #A SAFETY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED IN METHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE CONDUCTED TO ALL CONTRACTOR TEAM. #PARTY SHALL MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELY AFTER DEWA NOTIFICATION. PARTY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALL BE READY TO START THE WORK WITH ONE-DAY ADVANCE NOTIFICATION. #ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND TEST CERTIFICATE TO BE PROVIDED TO DEWA. #PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALID SCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING. #REMOVE ALL THE REQUIRED CLADDING SHEETS, INSULATION AND INSULATION FIXING CLAMPS. DISPOSE THE DAMAGED INSULATION ON THE DESIGNATED AREA SHOWN BY DEWA ENGINEER FOLLOWING DEWA RULES AND REGULATIONS. KEEP THE CLADDING SHEET AND GOOD INSULATION IN PROPER WAY. #INSPECT, MEASURE, AND COMPARE THE MEASUREMENTS, PROFILES, SIZE, CLASS AND THE SUPPLIED PIPE / FITTING AND EXISTING PIPE/FITTING. IN CASE OF ANY DEFECTS IDENTIFIED, IMMEDIATELY INFORM TO DEWA. #AFTER PROPER CHECKING AND						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONFIRMATION OF SUPPLIED PIPE / F FITTING,PREPARE ADDITIONAL SUPPORTS AND LIFTING ARRANGEMENTS TO HOLD THEPIPELINES IN POSITION AND CUT EXISTING SUPPORTS IF REQUIRED.#MARK AND CUT THE INLET AND OUTLET JOINTS AS PER THE NEW FITTINGDIMENSIONS. REMOVED PIPE / FITTING SHALL SAFELY BRING DOWN TO GROUNDLEVEL AND SHALL KEEP IN A SAFE MANNER.#INSPECT THE EXITING INLET AND OUTLET PIPING FOR ANY DEFORMATIONS /DEFECTS.#CONTRACTOR SHALL TAKE INTO CONSIDERATION THAT THE EXISTING PIPESURFACES MAY HAVE IRREGULARITIES IN SHAPE AND THICKNESS, WHICH PARTYSHALL RECTIFY BEFORE FIT UP.#SURFACE PREPARATION OF INLET AND OUTLET JOINTS AS PER APPROVED WPS /ITP.#SURFACE PREPARATION OF NEW FITTING INLET AND OUTLET JOINTS AS PERAPPROVED WPS / ITP.#EXPERIENCED AND CERTIFIED						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RIGGERS FROM CONTRACTOR SHALL PERFORM THE SHIFTING ACTIVITIES UNDER DEWA SUPERVISION. #REP LACEMENT OF PIPE / FITTING IN THE SAME ORIENTATION OF REMOVED PIPE/ FITTING AND FIT UP OF INLET AND OUTLET JOINTS. #FINAL ALIGNMENT OF EACH FIT UP JOINTS SHALL VERIFY BY CONTRACTOR QC IN PRESENCE OF DEWA. WELDING SHALL START AFTER DEWA CLEARANCE ONLY. #WELDING OF I NLET AND OUTLET PIPING AS PER APPROVED WPS / ITP. #EXTRA PRECAUTION SHALL BE TAKEN DURING EXECUTION OF JOB NOT TO DAMAGE ANY NEARBY EQUIPMENT. #AFTER COMPLETION OF ABOVE SCOPE OF WORK, JOINT INSPECTION WITH DEWA ENGINEER. #ON SUCCESSFUL COMPLETION OF NDT AND AFTER FINAL CLEARANCE FROM DEWA, INSTALL BACK INSULATION CLAMPS, INSULATION, AND CLADDING SHEETS. #IN CASE OF NON-COMPLETION OF THE PROJECT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WITHIN THE STIPULATED TIMEOR EXTENSION OF SHUTDOWN DUE TO ANY REASONS FROM THE CONTRACTOR#S SIDE(INCLUDING FAILURE OF NDT), DEWA RESERVE THE RIGHT TO BACK CHARGE THECONTRACTOR.#REMOVAL OF ALL METAL SCRAPS, TEMPORARY SUPPORTS AND ANY OTHER SCRAPSFROM WORKPLACE AND DISPOSAL AS PER DEWA ENGINEER INSTRUCTION.#HOUSEKEEPING # WORKPLACE AND DOWNSIDE AREAS.#INSPECTION AND APPROVAL FROM DEWA PERSONNEL.#DE-MOBILIZATION AND SITE CLEARANCE.#PREVIOUS SIMILAR EXPERIENCE PO # TO BE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY.#WORK COMPLETION REPORT INCLUDING ITP, WPS, PQR, WPQT, MTC, WELDMATRIX, RIGGING TOOL CERTIFICATES, RISK ASSESSMENT AND PHOTOS SHALLS UBMIT.TABLE: -SN #DESCRIPTION#TYPE #MATERIAL #SIZE (INCH)#QTY /LENGTH1#WWTP PIPE FABRICATION AND REPLACEMENTPIPE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			#SS316 #2 " 18 JOINTSPOOL PIPE SS316 4# 2ELBOW SS316 4# 2SPOOL PIPE SS316 6# 5ELBOW SS316 6# 7F LANGE#SS316#6" 2U CLAMP SS316 2# 30CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.#MANP OWER.#WELDING CONSUMABLES.#ITP, WPS, NDT PLAN & ERECTION PLAN.#TEMPORARY SUPPORTSDEWA SCOPE.#PIPE / FITTING.#INSULATION MATERIAL AND CLADDING SHEET.#NDT.#SCAFFOLDING.#CRANE / FORKLIFT.#POWER.#WATERWARRANTY.#A MINIMUM WARRANTY OF 12 MONTHS FOR WELD JOINTS AND WORKM ANSHIP SHALLPROVIDE BY THE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROMDEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WORK AND RECTIFY THE DEFECT WITHIN SHORT PERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER. GENERAL TERMS & CONDITIONS TECHNICAL SAFETY DURING THE WORK: #CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANT PREMISES. #CONTRACTOR SHALL GIVE DAILY TOOLBOX TALK, RISK ASSESSMENT AND DYNAMIC RISK ASSESSMENT TO THEIR STAFFS. #CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THE AVAILABILITY OF LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORE START OF ANY WORK. #CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE ISOLATIONS BEFORE STARTING OF ANY OVERHAULING WORK. #THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WORKINGENVIRONMENT.#CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS. #CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB.#THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ALWAYS ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPE INCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING AT HEIGHT.#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THE WORK. ALL THE RIGGING TOOLS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MUST HAVE VALID TEST CERTIFICATES, AND ITMUST BE PRODUCED TO DEWA FOREMAN/ ENGINEER UPON REQUEST.#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THEWORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANYDELAY.#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/ GRINDING/DRILLING/HEATING ETC.#DURING WELDING / CUTTING, ENSURE THA T WELDING SPARK / CUTTINGMATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETSSHALL BE USED DURING WELDING AND CUTTIN G WORK.#NO HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT ANDWITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATION.#CONTRACT OR SHALL ENSURE NO DISTURBANCE TO THE NEARBY OPERATING PLANT/ EQUIPMENT.#CONTRACTOR IS RESPONSIBLE FOR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANY DAMAGE OR EFFECT ON INSTALLED OPERATING MACHINES /EQUIPMENT/ PROPERTIES. #ENSURE PROPER HANDLING OF MATERIALS, TOOLS. SUITABLE BELTS ARE TO BE WORN TO AVOID TOOLS FROM FALLING. #SAFETY SIGNS SHALL BE PROVIDED AT WORK SITE AND WHEREVER REQUIRED THE AREA IS TO BE BARRICADED FOR SAFETY AND TO PREVENT UNAUTHORIZED ENTRY. #CONTRACTOR STAFF ARE ALLOWED TO WORK ONLY IN THE AUTHORIZED WORKPLACE DESIGNATED BY DEWA. #CONTRACTOR STAFF ARE REQUIRED TO WEAR THEIR COMPANY UNIFORM & CARRY THEIR GATE PASS IDS DURING THE WORK INSIDE DEWA PREMISES. #ALL						
5		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS - OUTSOURCING WORK. L STATION PHASE2, JEBEL ALI NAME OF WORK: #SCOPE OF WORK FOR SPOOL PIPE FABRICATION AND REPLACEMENT OF WASTEWATER TREATMENT PLANT DURING L2 STATION TOTAL	7	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHUTDOWN.PERIOD OF WORK:#03 CALENDAR DAYS DURING PLANT T OTAL SHUTDOWNSCOPE OF WORK.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETYMEASURES, ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE HE SUBMITSHIS BID.#PARTY SHALL SUBMIT ITP ALONG WITH WPS AND ERECTION PLAN AFTER GETTINGPO AND BEFORE COMMENCING ANY WORK.#AWARDING THE PO DOES NOT GUARANTEE THAT COMPLETE QUANTITY IN THE POWILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDEDBASED ON INSPECTION AND PAYMENT SHALL BE BASED ON ACTUAL WORK CARRIEDOUT.#TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS ANDMETHOD STATEMENT PRIOR TO START THE WORK.#CHECK CONDITION SUITABLE TO CARRY OUT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WORK. CONDUCT SITE SURVEY ANDSAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #A SAFE TY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE CONDUCT TOALL CON TRACTOR TEAM . #PARTY SHALL MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELYAFTER DEWA NOTIFICATION. PARTY SHALL BE READY TO S TART THE WORK WITHONE-DAY ADVANCE NOTIFICATION. #ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND TEST CERTIFICATE TOBE PROVIDED TO D EWA. #PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALIDSCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING. #REMOV E ALL THE REQUIRED CLADDING SHEETS, INSULATION AND INSULATIONFIXING CLAMPS. DISPOSE THE DAMAGED INSULATION ON THE DESIGNATED AREASHO						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WN BY DEWA ENGINEER FOLLOWING DEWA RULES AND REGULATIONS. KEEP THECLADDING SHEET AND GOOD INSULATION IN PROPER WAY. #INSPECT, MEASUR E, AND COMPARE THE MEASUREMENTS, PROFILES, SIZE, CLASSAND THE SUPPLIED PIPE / FITTING AND EXISTING PIPE/FITTING. IN CASE OFANY DEVA TIONS IDENTIFIED, IMMEDIATELY INFORM TO DEWA. #AFTER PROPER CHECKING AND CONFIRMATION OF SUPPLIED PIPE / F FITTING,PREPARE ADDITIONA L SUPPORTS AND LIFTING ARRANGEMENTS TO HOLD THEPIPELINES IN POSITION AND CUT EXISTING SUPPORTS IF REQUIRED. #MARK AND CUT THE INLET AND OUTLET JOINTS AS PER THE NEW FITTINGDIMENSIONS. REMOVED PIPE / FITTING SHALL SAFELY BRING DOWN TO GROUNDLEVEL AND SHALL KEEP IN A SAFE MANNER. #INSPECT THE EXITING INLET AND OUTLET PIPING FOR ANY DEFORMATIONS /DEFECTS. #CONTRACTOR SHALL TAKE INTO						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONSIDERATION THAT THE EXISTING PIPESURFACES MAY HAVE IRREGULARITIES IN SHAPE AND THICKNESS, WHICH PARTYSHALL RECTIFY BEFORE FIT UP.#SURFACE PRE PARATION OF INLET AND OUTLET JOINTS AS PER APPROVED WPS /ITP.#SURFACE PREPARATION OF NEW FITTING INLET AND OUTLET JOINTS AS PERAPPR OVED WPS / ITP.#EXPERIENCED AND CERTIFIED RIGGERS FROM CONTRACTOR SHALL PERFORM THESHIFTING ACTIVITIES UNDER DEWA SUPERVISION.#REP LACEMENT OF PIPE / FITTING IN THE SAME ORIENTATION OF REMOVED PIPE/ FITTING AND FIT UP OF INLET AND OUTLET JOINTS.#FINAL ALIGNMENT OF EACH FIT UP JOINTS SHALL VERIFY BY CONTRACTOR QCIN PRESENCE OF DEWA. WELDING SHALL START AFTER DEWA CLEARANCE ONLY.#WELDING OF I NLET AND OUTLET PIPING AS PER APPROVED WPS / ITP.#EXTRA PRECAUTION SHALL BE TAKEN						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DURING EXECUTION OF JOB NOT TO DAMAGE ANY NEARBY EQUIPMENT. #AFTER COMPLETION OF ABOVE SCOPE OF WORK, JOINT INSPECTION WITH DEWA ENGINEER. #ON SUCCESSFUL COMPLETION OF NDT AND AFTER FINAL CLEARANCE FROM DEWA, INSTALL BACK INSULATION CLAMPS, INSULATION, AND CLADDING SHEETS. #IN CASE OF NON-COMPLETION OF THE PROJECT WITHIN THE STIPULATED TIME OR EXTENSION OF SHUTDOWN DUE TO ANY REASONS FROM THE CONTRACTOR'S SIDE (INCLUDING FAILURE OF NDT), DEWA RESERVE THE RIGHT TO BACK CHARGE THE CONTRACTOR. #REMOVAL OF ALL METAL SCRAPS, TEMPORARY SUPPORTS AND ANY OTHER SCRAPS FROM WORKPLACE AND DISPOSAL AS PER DEWA ENGINEER INSTRUCTION. #HOUSEKEEPING # WORKPLACE AND DOWNSIDE AREAS. #INSPECTION AND APPROVAL FROM DEWA PERSONNEL. #DE-MOBILIZATION AND SITE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CLEARANCE. #PREVIOUS SIMILAR EXPERIENCE PO # TO BE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY. #WORK COMPLETION REPORT INCLUDING ITP, WPS, PQR, WPQT, MTC, WELDMATRIX, RIGGING TOOL CERTIFICATES, RISK ASSESSMENT AND PHOTOS SHALLS UBMIT.TABLE: -SN #DESCRIPTION#TYPE #MATERIAL #SIZE (INCH)#QTY /LENGTH1#WWTP PIPE FABRICATION AND REPLACEMENTPIPE #SS316 #2 " 18 JOINTSPOOL PIPE SS316 4# 2ELBOW SS316 4# 2SPOOL PIPE SS316 6# 5ELBOW SS316 6# 7F LANGE#SS316#6" 2U CLAMP SS316 2# 30CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.#MANP OWER.#WELDING CONSUMABLES.#ITP, WPS, NDT PLAN & ERECTION PLAN.#TEMPORARY SUPPORTSDEWA SCOPE.#PIPE / FITTING.#INSULATION MATERIAL AND CLADDING SHEET.#NDT.#SCAFFOLDING.#CRANE /						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FORKLIFT.#POWER.#WATERWARRANTY.#A MINIMUM WARRANTY OF 12 MONTHS FOR WELD JOINTS AND WORKM ANSHIP SHALLPROVIDE BY THE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROMDEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND R ECTIFY THE DEFECT WITHIN SHORTPERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER.GENERAL TERMS & CONDITIONSTECHNICAL S AFETY DURING THE WORK:#CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANTPREMISES.#CONTRACTOR SHALL GIVE DAILY T OOLBOX TALK, RISK ASSESSMENT AND DYNAMICRISK ASSESSMENT TO THEIR STAFFS.#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM TH						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EAVAILABILITY OF LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORE START OF ANY WORK. #CONTRACTOR STAFF MUST CHECK AND VERIFY OF THE ISOLATIONS BEFORE STARTING OF ANY OVERHAULING WORK. #THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS. #CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB. #THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ALWAYS ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPEINCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING ATHEIGHT.#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THEWORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES, AND ITMUST BE PRODUCED TO DEWA FOREMAN/ ENGINEER UPON REQUEST.#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THEWORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANYDELAY.#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/ GRINDING/DRILLING/HEATING ETC.#DURING WELDING / CUTTING, ENSURE THAT WELDING SPARK / CUTTINGMATERIALS SHALL						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKET SHALL BE USED DURING WELDING AND CUTTING WORK. #NO HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT AND WITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATION. #CONTRACTOR SHALL ENSURE NO DISTURBANCE TO THE NEARBY OPERATING PLANT/ EQUIPMENT. #CONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE OR EFFECT ON INSTALLED OR OPERATING MACHINES /EQUIPMENT/ PROPERTIES. #ENSURE PROPER HANDLING OF MATERIALS, TOOLS. SUITABLE BELTS ARE TO BE WORN TO AVOID TOOLS FROM FALLING. #SAFETY SIGNS SHALL BE PROVIDED AT WORK SITE AND WHEREVER REQUIRED THE AREA IS TO BE BARRICADED FOR SAFETY AND TO PREVENT UNAUTHORIZED ENTRY. #CONTRACTOR STAFF ARE ALLOWED TO WORK ONLY IN THE AUTHORIZED WORKPLACE DESIGNATED BY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEWA.#CONTRACTOR STAFF ARE REQUIRED TO WEAR THEIR COMPANY UNIFORM & CARRY THEIR GATE PASS IDS DURING THE WORK INSIDE DEWA PREMISES.#ALL						
6		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS - OUTSOURCING WORK. L STATION PHASE2, JEBEL ALINAME OF WORK:#SCOPE OF WORK FOR SPOOL PIPE FABRI CATION AND REPLACEMENT OF WASTEWATER TREATMENT PLANT DURING L2 STATION TOTAL SHUTDOWN.PERIOD OF WORK:#03 CALENDAR DAYS DURING PLANT T OTAL SHUTDOWNSCOPE OF WORK.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FA CILITIES, COMPLEXITIES, SAFETY MEASURES, ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE HE SUBMIT HIS BID.#PARTY SHALL SUBMIT ITP ALONG WITH WPS AND ERECTION PLAN AFTER GETTING PO AND BEFORE COMMENCING ANY WORK.#AWARDING THE PO DOES NOT	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			GUARANTEE THAT COMPLETE QUANTITY IN THE POWILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDEDBASED ON INSPECTION AND PAYMENT SHALL BE BASED ON ACTUAL WORK CARRIEDOUT. #TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS ANDMETHOD STATEMENT PRIOR TO START THE WO RK. #CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY ANDSAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #A SAFE TY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED INMETHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE CONDUCT TOALL CON TRACTOR TEAM. #PARTY SHALL MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELYAFTER DEWA NOTIFICATION. PARTY SHALL BE READY TO S TART THE WORK WITHONE-DAY ADVANCE NOTIFICATION. #ALL LIFTING AND POWER TOOLS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALL BE TESTED AND TEST CERTIFICATE TO BE PROVIDED TO DEWA. #PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALID SCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING. #REMOVE ALL THE REQUIRED CLADDING SHEETS, INSULATION AND INSULATION FIXING CLAMPS. DISPOSE THE DAMAGED INSULATION ON THE DESIGNATED AREA SHOWN BY DEWA ENGINEER FOLLOWING DEWA RULES AND REGULATIONS. KEEP THE CLADDING SHEET AND GOOD INSULATION IN PROPER WAY. #INSPECT, MEASURE, AND COMPARE THE MEASUREMENTS, PROFILES, SIZE, CLASS AND THE SUPPLIED PIPE / FITTING AND EXISTING PIPE / FITTING. IN CASE OF ANY DEVIATIONS IDENTIFIED, IMMEDIATELY INFORM TO DEWA. #AFTER PROPER CHECKING AND CONFIRMATION OF SUPPLIED PIPE / FITTING, PREPARE ADDITIONAL SUPPORTS AND LIFTING ARRANGEMENTS TO						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HOLD THE PIPELINES IN POSITION AND CUT EXISTING SUPPORTS IF REQUIRED. #MARK AND CUT THE INLET AND OUTLET JOINTS AS PER THE NEW FITTING DIMENSIONS. REMOVED PIPE / FITTING SHALL SAFELY BRING DOWN TO GROUND LEVEL AND SHALL KEEP IN A SAFE MANNER. #INSPECT THE EXISTING INLET AND OUTLET PIPING FOR ANY DEFORMATIONS / DEFECTS. #CONTRACTOR SHALL TAKE INTO CONSIDERATION THAT THE EXISTING PIPE SURFACES MAY HAVE IRREGULARITIES IN SHAPE AND THICKNESS, WHICH PARTY SHALL RECTIFY BEFORE FIT UP. #SURFACE PREPARATION OF INLET AND OUTLET JOINTS AS PER APPROVED WPS / ITP. #SURFACE PREPARATION OF NEW FITTING INLET AND OUTLET JOINTS AS PER APPROVED WPS / ITP. #EXPERIENCED AND CERTIFIED RIGGERS FROM CONTRACTOR SHALL PERFORM THE SHIFTING ACTIVITIES UNDER DEWA SUPERVISION. #REP						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			LACEMENT OF PIPE / FITTING IN THE SAME ORIENTATION OF REMOVED PIPE/ FITTING AND FIT UP OF INLET AND OUTLET JOINTS.#FINAL ALIGNMENT OF EACH FIT UP JOINTS SHALL VERIFY BY CONTRACTOR QCIN PRESENCE OF DEWA. WELDING SHALL START AFTER DEWA CLEARANCE ONLY.#WELDING OF I NLET AND OUTLET PIPING AS PER APPROVED WPS / ITP.#EXTRA PRECAUTION SHALL BE TAKEN DURING EXECUTION OF JOB NOT TO DAMAGEANY NEARBY E QUIPMENT.#AFTER COMPLETION OF ABOVE SCOPE OF WORK, JOINT INSPECTION WITH DEWAENGINEER.#ON SUCCESSFUL COMPLETION OF NDT AND AFTER F INAL CLEARANCE FROM DEWA,INSTALL BACK INSULATION CLAMPS, INSULATION, AND CLADDING SHEETS.#IN CASE OF NON-COMPLETION OF THE PROJECT WITHIN THE STIPULATED TIMEOR EXTENSION OF SHUTDOWN DUE TO ANY REASONS FROM THE CONTRACTOR#S SIDE(INCLUDING FAILURE OF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NDT), DEWA RES ERVE THE RIGHT TO BACK CHARGE THECONTRACTOR.#REMOVAL OF ALL METAL SCRAPS, TEMPORARY SUPPORTS AND ANY OTHER SCRAPSFROM WORKPLACE AND DISPOSAL AS PER DEWA ENGINEER INSTRUCTION.#HOUSEKEEPING # WORKPLACE AND DOWNSIDE AREAS.#INSPECTION AND APPROVAL FROM DEWA PERSONN EL.#DE-MOBILIZATION AND SITE CLEARANCE.#PREVIOUS SIMILAR EXPERIENCE PO # TO BE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY. #WORK COMPLETION REPORT INCLUDING ITP, WPS, PQR, WPQT, MTC, WELDMATRIX, RIGGING TOOL CERTIFICATES, RISK ASSESSMENT AND PHOTOS SHALLS UBMIT.TABLE: -SN #DESCRIPTION#TYPE #MATERIAL #SIZE (INCH)#QTY /LENGTH1#WWTP PIPE FABRICATION AND REPLACEMENTPIPE #SS316 #2 " 18 JOINTSPOOL PIPE SS316 4# 2ELBOW SS316 4# 2SPOOL PIPE SS316 6#						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			5ELBOW SS316 6# 7F LANGE#SS316#6" 2U CLAMP SS316 2# 30CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.#MANP OWER.#WELDING CONSUMABLES.#ITP, WPS, NDT PLAN & ERECTION PLAN.#TEMPORARY SUPPORTSDEWA SCOPE.#PIPE / FITTING.#INSULATION MATERIAL AND CLADDING SHEET.#NDT.#SCAFFOLDING.#CRANE / FORKLIFT.#POWER.#WATERWARRANTY.#A MINIMUM WARRANTY OF 12 MONTHS FOR WELD JOINTS AND WORKM ANSHIP SHALLPROVIDE BY THE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROMDEWA.#IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THISCONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND ANDCARRY OUT THE NECESSARY REPAIR WORK AND R ECTIFY THE DEFECT WITHIN SHORTPERIOD WITHOUT AFFECTING THE PRODUCTION OF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELECTRICITY AND WATER.GENERAL TERMS & CONDITIONSTECHNICAL S AFETY DURING THE WORK:.#CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANTPREMISES.#CONTRACTOR SHALL GIVE DAILY T OOLBOX TALK, RISK ASSESSMENT AND DYNAMICRISK ASSESSMENT TO THEIR STAFFS.#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM TH EAVAILABILITY OF LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORESTART OF ANY WORK.#CONTRACTOR STAFF MUST CHECK AND VERIFY OF TH E ISOLATIONS BEFORESTARTING OF ANY OVERHAULING WORK.#THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THEWORK. CONDUCT T SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKINGENVIRONMENT.#CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS.						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			#CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB.#THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ALWAYS ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS#).#CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE PPE INCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC.#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING AT HEIGHT.#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THE WORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES, AND IT MUST BE PRODUCED TO DEWA FOREMAN/ ENGINEER UPON REQUEST.#CONTRACTOR MUST						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THEWORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANYDELAY.#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/ GRINDING/DRILLING/HEATING ETC.#DURING WELDING / CUTTING, ENSURE THA T WELDING SPARK / CUTTINGMATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETSSHALL BE USED DURING WELDING AND CUTTIN G WORK.#NO HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT ANDWITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATION.#CONTRACT OR SHALL ENSURE NO DISTURBANCE TO THE NEARBY OPERATING PLANT/ EQUIPMENT.#CONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE OR EFFECT ON INST ALLED OROPERATING MACHINES /EQUIPMENT/ PROPERTIES.#ENSURE PROPER HANDLING OF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MATERIALS, TOOLS. SUITABLE BELTS ARE TO BE WORN TO AVOID TOOLS FROM FALLING. #SAFETY SIGNS SHALL BE PROVIDED AT WORK SITE AND WHEREVER REQUIRED THE AREA IS TO BE BARRICADED FOR SAFETY AND TO PREVENT UNAUTHORIZED ENTRY. #CONTRACTOR STAFF ARE ALLOWED TO WORK ONLY IN THE AUTHORIZED WORKPLACE DESIGNATED BY DEWA. #CONTRACTOR STAFF ARE REQUIRED TO WEAR THEIR COMPANY UNIFORM & CARRY THEIR GATE PASS IDS DURING THE WORK INSIDE DEWA PREMISES. #ALL						
7		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS - OUTSOURCING WORK. L STATION PHASE 2, JEBEL ALI NAME OF WORK: #SCOPE OF WORK FOR SPOOL PIPE FABRICATION AND REPLACEMENT OF WASTEWATER TREATMENT PLANT DURING L2 STATION TOTAL SHUTDOWN. PERIOD OF WORK: #03 CALENDAR DAYS DURING PLANT TOTAL SHUTDOWN. SCOPE OF WORK: #THE	30	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES, ERECTION PROCEDURES, NUMBER OF WELDS ETC., BEFORE HE SUBMITS HIS BID. #PARTY SHALL SUBMIT ITP ALONG WITH WPS AND ERECTION PLAN AFTER GETTING PO AND BEFORE COMMENCING ANY WORK. #AWARDING THE PO DOES NOT GUARANTEE THAT COMPLETE QUANTITY IN THE PO WILL BE CARRIED OUT. ACTUAL QUANTITY OF REPLACEMENT WILL BE DECIDED BASED ON INSPECTION AND PAYMENT SHALL BE BASED ON ACTUAL WORK CARRIED OUT. #TO GET A PTW, HWP CONTRACTOR MUST SUBMIT RISK ASSESSMENT FORMS AND METHOD STATEMENT PRIOR TO START THE WORK. #CHECK CONDITION SUITABLE TO CARRY OUT WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #A SAFE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TY MEETING WILL BE HELD TO EVALUATE THE RISK INVOLVED IN METHODS TO BE USED. RISK ASSESSMENT AND TOOLBOX TALK TO BE CONDUCT TO ALL CONTRACTOR TEAM. #PARTY SHALL MOBILIZE THE LABOR, EQUIPMENT, TOOLS, ETC. IMMEDIATELY AFTER DEWA NOTIFICATION. PARTY SHALL BE READY TO START THE WORK WITH ONE-DAY ADVANCE NOTIFICATION. #ALL LIFTING AND POWER TOOLS SHALL BE TESTED AND TEST CERTIFICATE TO BE PROVIDED TO DEWA. #PARTY SHALL VERIFY THAT SCAFFOLDS ARE SAFE TO WORK AND VALID SCAFFOLDING TAGS ARE PROVIDED BEFORE USING ANY SCAFFOLDING. #REMOVE ALL THE REQUIRED CLADDING SHEETS, INSULATION AND INSULATION FIXING CLAMPS. DISPOSE THE DAMAGED INSULATION ON THE DESIGNATED AREA SHOWN BY DEWA ENGINEER FOLLOWING DEWA RULES AND REGULATIONS. KEEP THE CLADDING SHEET AND GOOD INSULATION IN PROPER						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WAY. #INSPECT, MEASUR E, AND COMPARE THE MEASUREMENTS, PROFILES, SIZE, CLASSAND THE SUPPLIED PIPE / FITTING AND EXISTING PIPE/FITTING. IN CASE OFANY DEVI ATIONS IDENTIFIED, IMMEDIATELY INFORM TO DEWA. #AFTER PROPER CHECKING AND CONFIRMATION OF SUPPLIED PIPE / F FITTING,PREPARE ADDITIONA L SUPPORTS AND LIFTING ARRANGEMENTS TO HOLD THEPIPELINES IN POSITION AND CUT EXISTING SUPPORTS IF REQUIRED. #MARK AND CUT THE INLET AND OUTLET JOINTS AS PER THE NEW FITTINGDIMENSIONS. REMOVED PIPE / FITTING SHALL SAFELY BRING DOWN TO GROUNDLEVEL AND SHALL KEEP IN A SAFE MANNER. #INSPECT THE EXITING INLET AND OUTLET PIPING FOR ANY DEFORMATIONS /DEFECTS. #CONTRACTOR SHALL TAKE INTO CONSIDERATION THAT THE EXISTING PIPESURFACES MAY HAVE IRREGULARITIES IN SHAPE AND THICKNESS,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WHICH PARTY SHALL RECTIFY BEFORE FIT UP. #SURFACE PREPARATION OF INLET AND OUTLET JOINTS AS PER APPROVED WPS / ITP. #SURFACE PREPARATION OF NEW FITTING INLET AND OUTLET JOINTS AS PER APPROVED WPS / ITP. #EXPERIENCED AND CERTIFIED RIGGERS FROM CONTRACTOR SHALL PERFORM THE SHIFTING ACTIVITIES UNDER DEWA SUPERVISION. #REPLACEMENT OF PIPE / FITTING IN THE SAME ORIENTATION OF REMOVED PIPE/ FITTING AND FIT UP OF INLET AND OUTLET JOINTS. #FINAL ALIGNMENT OF EACH FIT UP JOINTS SHALL VERIFY BY CONTRACTOR QC IN PRESENCE OF DEWA. WELDING SHALL START AFTER DEWA CLEARANCE ONLY. #WELDING OF INLET AND OUTLET PIPING AS PER APPROVED WPS / ITP. #EXTRA PRECAUTION SHALL BE TAKEN DURING EXECUTION OF JOB NOT TO DAMAGE ANY NEARBY EQUIPMENT. #AFTER COMPLETION OF ABOVE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SCOPE OF WORK, JOINT INSPECTION WITH DEWAENGINEER.#ON SUCCESSFUL COMPLETION OF NDT AND AFTER FINAL CLEARANCE FROM DEWA,INSTALL BACK INSULATION CLAMPS, INSULATION, AND CLADDING SHEETS.#IN CASE OF NON-COMPLETION OF THE PROJECT WITHIN THE STIPULATED TIMEOR EXTENSION OF SHUTDOWN DUE TO ANY REASONS FROM THE CONTRACTOR#S SIDE(INCLUDING FAILURE OF NDT), DEWA RESERVE THE RIGHT TO BACK CHARGE THECONTRACTOR.#REMOVAL OF ALL METAL SCRAPS, TEMPORARY SUPPORTS AND ANY OTHER SCRAPSFROM WORKPLACE AND DISPOSAL AS PER DEWA ENGINEER INSTRUCTION.#HOUSEKEEPING # WORKPLACE AND DOWNSIDE AREAS.#INSPECTION AND APPROVAL FROM DEWA PERSONNEL.#DE-MOBILIZATION AND SITE CLEARANCE.#PREVIOUS SIMILAR EXPERIENCE PO # TO BE PROVIDED FROM DEWA OR ANYOTHER WELL-KNOWN COMPANY.						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			#WORK COMPLETION REPORT INCLUDING ITP, WPS, PQR, WPQT, MTC, WELDMATRIX, RIGGING TOOL CERTIFICATES, RISK ASSESSMENT AND PHOTOS SHALLS UBMIT.TABLE: -SN #DESCRIPTION#TYPE #MATERIAL #SIZE (INCH)#QTY /LENGTH1#WWTP PIPE FABRICATION AND REPLACEMENTPIPE #SS316 #2 " 18 JOINTSPOOL PIPE SS316 4# 2ELBOW SS316 4# 2SPOOL PIPE SS316 6# 5ELBOW SS316 6# 7F LANGE#SS316#6" 2U CLAMP SS316 2# 30CONTRACTOR SCOPE OF SUPPLY.#TOOLS, TACKLES, AND EQUIPMENT TO CARRY OUT THE JOB.#MANP OWER.#WELDING CONSUMABLES.#ITP, WPS, NDT PLAN & ERECTION PLAN.#TEMPORARY SUPPORTSDEWA SCOPE.#PIPE / FITTING.#INSULATION MATERIAL AND CLADDING SHEET.#NDT.#SCAFFOLDING.#CRANE / FORKLIFT.#POWER.#WATERWARRANTY.#A MINIMUM WARRANTY OF 12 MONTHS FOR WELD JOINTS AND WORKM						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANSHIP SHALL PROVIDE BY THE CONTRACTOR STARTING FROM THE DATE OF FINAL CLEARANCE FROM DEWA. #IN CASE OF ANY DAMAGE/DEFECT OF THE WORK CARRIED OUT UNDER THIS CONTRACT WITHIN THIS WARRANTY PERIOD, THE CONTRACTOR SHALL ATTEND AND CARRY OUT THE NECESSARY REPAIR WORK AND RECTIFY THE DEFECT WITHIN SHORT PERIOD WITHOUT AFFECTING THE PRODUCTION OF ELECTRICITY AND WATER. GENERAL TERMS & CONDITIONS TECHNICAL S SAFETY DURING THE WORK: #CONTRACTOR STAFF MUST HAVE VALID GATE PASS BEFORE ENTERING THE PLANT PREMISES. #CONTRACTOR SHALL GIVE DAILY TOOLBOX TALK, RISK ASSESSMENT AND DYNAMIC RISK ASSESSMENT TO THEIR STAFFS. #CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL CONFIRM THE AVAILABILITY OF LINE CLEARANCE (LC) AND PERMIT TO WORK (PTW) BEFORE START OF ANY WORK. #CONTRACTOR STAFF MUST CHECK AND						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			VERIFY OF THE ISOLATIONS BEFORE STARTING OF ANY OVERHAULING WORK. #THE CONTRACTOR SHALL CHECK THE CONDITION SUITABLE TO CARRY OUT THE WORK. CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. #CONTRACTOR SHALL ENSURE HOUSEKEEPING IS DONE ON DAILY BASIS. #CONTRACTOR SITE SUPERVISOR SHALL BE CONTINUOUSLY PRESENT AT THE WORKSITE TO SUPERVISE THE JOB. #THE CONTRACTOR MUST ENGAGE A QUALIFIED SAFETY OFFICER TO ALWAYS ENSURE OBSERVANCE OF SAFETY AND SAFE WORKING PRACTICES BY HIS MEN AT SITE. THE SAFETY SUPERVISOR SHALL KEEP ALL RECORDS (TBT, RISK ASSESSMENT, HOT WORK PERMIT, PTW, MSDS, ALL SAFETY RELATED DOCUMENTS #). #CONTRACTOR STAFF INVOLVED IN ANY ACTIVITY SHALL USE APPROPRIATE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PPESINCLUDING GLOVES, HELMET, GOGGLES, SAFETY SHOE AND MASK ETC..#CONTRACTOR STAFF SHALL USE FULL BODY SAFETY HARNESS WHEN WORKING ATHEIGHT..#ONLY TESTED AND CERTIFIED RIGGING TOOLS SHALL BE USED DURING THEWORK. ALL THE RIGGING TOOLS MUST HAVE VALID TEST CERTIFICATES, AND ITMUST BE PRODUCED TO DEWA FOREMAN/ ENGINEER UPON REQUEST..#CONTRACTOR MUST BE READY WITH ALL REQUIRED RESOURCES TO EXECUTE THEWORK AS PER AGREED SCOPE WORK DURING THE OUTAGE SCHEDULE TO AVOID ANYDELAY..#DAILY HOT WORK PERMIT IS REQUIRED BEFORE START OF ANY HOT WORK LIKEWELDING/ CUTTING/ GRINDING/DRILLING/HEATING ETC..#DURING WELDING / CUTTING, ENSURE THA T WELDING SPARK / CUTTINGMATERIALS SHALL NOT FALL ON NEARBY EQUIPMENT. ADEQUATE FIRE BLANKETSSHALL BE USED DURING WELDING AND CUTTIN						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			G WORK.#NO HOT WORK SHALL BE STARTED WITHOUT GETTING HOT WORK PERMIT ANDWITHOUT FIRE EXTINGUISHER NEAR THE WORK LOCATION.#CONTRACT OR SHALL ENSURE NO DISTURBANCE TO THE NEARBY OPERATING PLANT/ EQUIPMENT.#CONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE OR EFFECT ON INSTALLED OROPERATING MACHINES /EQUIPMENT/ PROPERTIES.#ENSURE PROPER HANDLING OF MATERIALS, TOOLS. SUITABLE BELTS ARE TO BEWORN TO AVOID TOOLS FROM FALLING.#SAFETY SIGNS SHALL BE PROVIDED AT WORK SITE AND WHEREVER REQUIRED THEAREA IS TO BE BARRICADED FOR SAFETY AND TO PREVENT UNAUTHORIZED ENTRY.#CONTRACTOR STAFF ARE ALLOWED TO WORK ONLY IN THE AUTHORIZED WORKPLACEDESIGNATED BY DEWA.#CONTRACTOR STAFF ARE REQUIRED TO WEAR THEIR COMPANY UNIFORM & CARRYTHEIR GATE PASS IDS DURING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE WORK INSIDE DEWA PREMISES..#ALL						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

WASTE WATER TREATMENT PLANT DAMAGED PIPE AND ELBOW REPLACEMENT DURING
PLANT TOTAL OUTAGE.

CONTACT DETAILS:

PRIYABRATA BEHERA

MAIL ID-priyabrata.behera@dewa.gov.ae

M-+971524230464

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332601879
DATE	: 03.08.2026
REQ No	: 1032603452
REQ TITLE	: WASTE WATER TREATMENT
DELIVERY LOCATION	
CLOSING DATE	: 07.08.2026
CLOSING TIME	: 10:00:00

- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.
- 8)Data Privacy, Security and Sharing:
- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
 - DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
 - DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
 - DEWA reserves the right to withhold data from third parties if deemed sensitive.
 - Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
 - Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
 - Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601879
DATE : 03.08.2026
REQ No : 1032603452
REQ TITLE : WASTE WATER TREATMENT
DELIVERY LOCATION
CLOSING DATE : 07.08.2026
CLOSING TIME : 10:00:00

compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP