

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	THIRD PARTY INSPECTION OF WHB BOILERS 1A, 1B & 1C AT #E# STATION - JEBELALI POWER STATION DEWA.SCOPE OF WORK FOR INSPECTION ACCORDING TO EIAC-RQ-IB-004 (DAC REQ-08):REFER TO THE EIAC DOCUMENT FOR FURTHER REQUIREMENTS.1. FUNCTIONALITY TEST SHALL COVER INSPECTION ACTIVITY TO ENSURE THAT:1.1: PRE OUTAGE INSPECTION:A.#REVIEW OF MANUFACTURER#S CERTIFICATION FOR THE BOILER AND IDENTIFICATION BASED ON MANUFACTURER#S MARKINGS/ASME/CE MARKINGS.B.#REVIEW OF RECORDS FOR SITE ERECTION AND FINAL EXAMINATION RESULTS/REPAIR/ALTERATION RECORDS.C.#VISUAL EXAMINATION OF ALL ACCESSIBLE AREAS.D.#REVIEW AND VERIFY THERMOGRAPHY REPORTS.E.#EXTERNAL VISUAL EXAMINATION OF ALL ACCESSIBLE AREAS.F.#WALK DOWN AND PUNCH LIST REPORTS BASED ON FINDINGS AND INTERVIEWS.G.#RECOMMENDATION FOR NDE	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TASKS TO BE PERFORMED DURING INSPECTIONS. SH.#REVIEW OF LAST INSPECTION REPORT. I.#REVIEW OF LATEST OPERATING DATA FROM CONTROL SYSTEM HISTORIANS AND OTHER AVAILABLE ARCHIVES. J.#INSPECTION FOR VIBRATION OF PIPE, HEADERS, STEEL STRUCTURE, ETC. 1.2: OUTAGE INSPECTION: A.#A VISUAL SURVEY OF THE WHB GENERAL CONDITION, EXTERNAL CASING, INTERNAL GAS SIDE MECHANICAL PARTS AND AUXILIARY EQUIPMENT READILY ACCESSIBLE PRESSURE PARTS ETC. B.#THE INTERNAL THOROUGH INSPECTION CONSTITUTES A VISUAL EXAMINATION/SURVEY OF THE ACCESSIBLE SURFACE OF THE BOILER PRESSURE PARTS, THE TUBES HEADERS, ACCESSIBLE SUPPORTING ARRANGEMENTS, REFRACTORY LINING, BURNER, FLOW GRID SUPPORTS, SILENCERS, DRUMS, AND INTERNAL FITTINGS TO DETECT ANY SIGN OF GENERAL OR LOCALIZED DEFORMATION/DETERIORATION.						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WHERE APPLICABLE OR NECESSARY, NON-DESTRUCTIVE TESTING METHODS, DESTRUCTIVE TESTING OF SAMPLES, IN-SITU METALLOGRAPHY ETC. SHALL BE USED TO COMPLEMENT THE VISUAL INSPECTION. C.#EXTERNAL VISUAL EXAMINATION WAS CARRIED OUT ON ALL ACCESSIBLE AREAS. D.#VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OF HIGH, MEDIUM AND LOW-PRESSURE STEAM PIPING AND HEADER. SE.#VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OF PRESSURE VESSELS AND PIPING SYSTEMS. F.#REVIEW OF THICKNESS MEASUREMENT RECORDS TO VERIFY WHETHER THE CURRENT THICKNESS IS NOT LESS THAN THE MINIMUM ALLOWABLE WALL THICKNESS. G.#REVIEW ALL CRITICAL STEAM-PIPING HANGERS BY CHECKING THE INDICATOR OF HOT POSITION & ADJUST IF NECESSARY. H.#VISUAL INSPECTION / SURVEY OF DUCT BURNERS, EXPANSION						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			JOINTS AND PIPE PENETRATIONS. I. #INSPECT THE MAIN STACK/BYPASS STACK & ITS ACCESSORIES FOR ANY DISCREPANCY. J. #BASED ON VISUAL INSPECTION AND PREVIOUS RECORD REVIEW, THE INSPECTOR MAY IDENTIFY ADDITIONAL NDE (THICKNESS MEASUREMENT, MT, PT, HARDNESS ETC.), THE NDE RESULTS WILL BE REVIEWED FOR COMPLIANCE TO DRAWINGS, CODE AND SPECIFICATION IF AVAILABLE OR RETAINED FOR FUTURE REFERENCE. K. #ALL ABNORMAL CONDITIONS SUCH AS POOR COATING, RUSTED/CORRODED/PITTED SURFACE, RUSTED BOLTS/NUTS, LOOSELY BOLTED ASSEMBLIES, RUSTED WELD SEAMS, CRACKS, DISTORTION, BENDS, DENTS, SAGGING, BULGING ITEMS, AN INDICATION OF A LEAK, AN INDICATION OF WATER INGRESS, PIPING/TUBE EXCESSIVE VIBRATIONS, WASTAGE REDUCTION OF PRESSURE RETAINING THICKNESS SHALL BE REPORTED. L. #VISUAL INSPECT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ION OF INTERNAL CASING, AND INSULATIONS, AND REVIEWHOT SPOTS DURING BOILER RUNNING.1.3 POST OUTAGE INSPECTION:A.#REVIEW OF INSPECTIO N REPORT AND RECORDS FOR REPAIR IF ANY PERFORMED.B.#WITNESS THE HYDRO TEST AS APPLICABLEC.#WITNESS FUNCTIONALITY TEST AND REVIEW OF FUNCTIONALITY TEST REPORTD.#REVIEW / VERIFICATION OF CALIBRATION CERTIFICATES OF PRESSURE,TEMPERATURE GAUGES, TRANSMITTERS AND OTHER INSTRUMENTSE.#REVIEW OF WATER CHEMISTRY RECORDSF.#WITNESS SAFETY VALVE TESTS AND REVIEW OF SAFETY VALVE TESTCERTIFICATESG.#THE BOIL ER SHALL BE VISUALLY EXAMINED EXTERNALLY UNDER NORMALWORKING CONDITIONS.H.#WATER LEVEL GAUGE ACCURACY, FEED WATER CONTROLS, LOW/HIGH -LEVELWATER ALARMS, LOW WATER LEVEL ACTIONS, BLOW-DOWN SYSTEM OPERATIONS ETC.WILL BE REVIEWED.I.#REVIEW OF OPERATING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND DESIGN PARA METERSJ.#VERIFICATION TO CHECK THE BOILER IS PROVIDED WITH THE NEEDED SAFETYACCESSORIES AND THESE ACCESSORIES ARE IN PLACE.4. DELI VERABLES SHALL BE:ISSUE OF VISIT REPORT DETAILING SCOPE OF INSPECTION UNDERTAKEN ASREQUIRED.ISSUE OF INSPECTION CERTIFICATE DETAILIN G THE SCOPE OF INSPECTIONUNDERTAKEN AND RESULTS &RECOMMENDATIONS UPON SATISFACTORY COMPLETION OF THE INSPECTION.ISSUE OF INSPECTION REPORT DETAILING THE SCOPE OF INSPECTION UNDERTAKENIF ANOMALIESIDENTIFIED ARE NOT RESOLVED UNDER EIAC-RQ-IB-004 REQUIREMENTS.5. FUNC TIONALITY TEST:I.#DELIVERABLES WILL BE #CERTIFICATE FOR NORMAL OPERATING CONDITION# ASPER EIAC REQUIREMENT. THE CERTIFICATE WILL BE NOTED ON THE NEXTINSPECTION DATE IN COMPLIANCE WITH EIAC REQUIREMENTS.II.#IF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANOMALIES/FINDINGS ARE NOTED #REPORT OF EXAMINATION UNDER NORMALWORKING CONDITION# WILL BE ISSUED AS PER EIAC REQUIREMENT. THESEFINDINGS WILL NEED TO BE RESOLVED BY YOU SUITABLY.INTERNAL INSPECTION:I.#DELIVERABLES WILL BE #CERTIFICATE OF EXAMINATION OF STEAM BOILER# AS PER EIAC REQUIREMENT. THE CERTIFICATE WILL NOTE THE NEXT INSPECTION DATEIN COMPLIANCE WITH EIAC REQUIREMENTS.II.#IF ANOMALIES/FINDINGS ARE NOTED #REPORT OF EXAMINATION OF STEAMBOILER # WILL BE ISSUED AS PER EIAC REQUIREMENT. THESE FINDINGS WILL NEEDTO BE RESOLVED BY YOU SUITABLY.III.#CERTIFICATE TO EIAC REQUIREMEN TS SHALL BE LIMITED TOPRESSURE-RETAINING ITEMS GENERALLY RESTRICTED TO THE GEOMETRIC LIMIT DEFINED IN ASMESECTION I FIGURE PG-5 8.2-1.IV. ISSUE OF VISIT REPORT DETAILING THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SCOPE OF INSPECTION UNDERTAKEN AS REQUIRED FOR ANY INTERMEDIATE REPORTING.D EWA SCOPE OF WORK:A) SHALL ARRANGE CLEANING, NON-DESTRUCTIVE EXAMINATION (NDE), THICKNESS GAUGING IN-SITU METALLOGRAPHYB) FACILITIES FOR SAFE ACCESS TO EQUIPMENT/SCAFFOLDING,C) WORK PERMITS, CONFINED SPACE ENTRY PERMITS AND GATE PASSESD) INSULATION REMOVALS , AS REQUIRED.NOTE TO CONTRACTORS: #CONTRACTORS SHOULD VISIT THE SITE TO UNDERSTAND THE SITE CONDITIONS, CONTRACT SCOPE, AND INTRICACIES OF THE WORK TO ENSURE THAT THEY ADEQUATELY COMPREHEND THE SCOPE OF WORK FOR DESIGN, ENGINEERING, AND COST ESTIMATION. #NO CLAIMS FOR OR EXTRA PAYMENTS SHALL BE ACCEPTED FOR ANY ADDITIONAL MATERIALS OR WORKS THAT WERE FOUND REQUIRED AT THE TIME OF EXECUTION OF THE WORK						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			K DUE TO A LACK OF UNDERSTANDING OF THE SCOPE, EXTENT OF WORK, PLANT/SITE RESTRICTIONS, UNDERESTIMATION OF THE SCOPE, ETC., #IRRESPECTIVE OF BEING EXPLICITLY OR IMPLICITLY MENTIONED IN THIS SPECIFICATION, THE CONTRACTOR SHALL NOTE THAT ALL TECHNICAL AND ENGINEERING REQUIREMENTS ESSENTIAL TO COMPLETING THE SCOPE OF WORK ARE INCLUDED IN THIS PR DOCUMENT. #ANY AMBIGUITIES OR DISCREPANCIES BETWEEN THE CONTRACTOR'S OFFER AND THIS TECHNICAL SPECIFICATION AFTER THE AWARD OF THE CONTRACT SHALL BE RESOLVED BY THE DEWA, WHO SHALL THEN INSTRUCT THE CONTRACTOR THEREON. INTERPRETATION, CHANGE, OR CORRECTION MADE BY DEWA WILL BE BINDING FOR THE CONTRACTOR IN THIS REGARD WITHOUT ANY ADDITIONAL COST TO DEWA. #NO CLAIMS FOR EXTRA PAYMENTS SHALL BE ACCEPTED FOR DEMOBILIZATION						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ANDREMOBILIZATION OR WAITING TIME OR IDLE TIME DUE TO DEWA#S OPERATIONALCONSTRAINTS OR OTHER CRITICAL MAINTENANCE ACTIVITIES CARRIED OUT BY DEWAAT THE SITE.#THIS IS A LUMP SUM JOB, AND NO PART PAYMENT WILL BE PROCESSED.						
2		ITEM-00001	THIRD PARTY INSPECTION OF WHB BOILERS 1A, 1B & 1C AT #E# STATION - JEBELALI POWER STATION DEWA.SCOPE OF WORK FOR INSPECTION ACCORDIN G TO EIAC-RQ-IB-004 (DAC REQ-08):REFER TO THE EIAC DOCUMENT FOR FURTHER REQUIREMENTS.1. FUNCTIONALITY TEST SHALL COVER INSPECTION AC TIVITY TO ENSURE THAT:1.1: PRE OUTAGE INSPECTION:A.#REVIEW OF MANUFACTURER#S CERTIFICATION FOR THE BOILER ANDIDENTIFICATION BASED O N MANUFACTURER#S MARKINGS/ASME/CE MARKINGS.B.#REVIEW OF RECORDS FOR SITE ERECTION AND FINAL EXAMINATIONRESULTS/REPAIR/ALTERATION REC	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ORDS.C.#VISUAL EXAMINATION OF ALL ACCESSIBLE AREAS.D.#REVIEW AND VERIFY THERMOGRAPHY REPORTSE.#EXTERNAL VISUAL EXAMINATION OF ALL AC CESSIBLE AREAS.F.#WALK DOWN AND PUNCH LIST REPORTS BASED ON FINDINGS AND INTERVIEWSG.#RECOMMENDATION FOR NDE TASKS TO BE PERFORMED DURING INSPECTIONSH.#REVIEW OF LAST INSPECTION REPORTI.#REVIEW OF LATEST OPERATING DATA FROM CONTROL SYSTEM HISTORIANS ANDOTHER AVAIL ABLE ARCHIVESJ.#INSPECTION FOR VIBRATION OF PIPE, HEADERS, STEEL STRUCTURE, ETC.1.2: OUTAGE INSPECTION:A.#A VISUAL SURVEY OF THE WHB GENERAL CONDITION, EXTERNAL CASING,INTERNAL GAS SIDE MECHANICAL PARTS AND AUXILIARY EQUIPMENT READILYACCESSIBLE PRESSURE PARTS ETC. B.#THE INTERNAL THOROUGH INSPECTION CONSTITUTES A VISUALEXAMINATION/SURVEY OF THE ACCESSIBLE SURFACE OF THE BOILER						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PRESSUREPARTS, TH E TUBES HEADERS, ACCESSIBLE SUPPORTING ARRANGEMENTS, REFRACTORYLINING, BURNER, FLOW GRID SUPPORTS, SILENCERS, DRUMS, AND INTERNALFIT TINGS TO DETECT ANY SIGN OF GENERAL OR LOCALIZEDDEFORMATION/DETERIORATION. WHERE APPLICABLE OR NECESSARY,NON-DESTRUCTIVE TESTING MET HODS, DESTRUCTIVE TESTING OF SAMPLES, IN-SITUMETALLOGRAPHY ETC. SHALL BE USED TO COMPLEMENT THE VISUAL INSPECTION.C.#EXTERNAL VISUAL EXAMINATION WAS CARRIED OUT ON ALL ACCESSIBLE AREAS.D.#VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OF HIGH,MEDIUM AND LOW-PRESSURE STEAM PIPING AND HEADERSE.#VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OFPRESSURE VESSELS AND PIPING SYS TEMSF.#REVIEW OF THICKNESS MEASUREMENT RECORDS TO VERIFY WHETHER THECURRENT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THICKNESS IS NOT LESS THAN THE MINIMUM ALLOWABLE WALL THICKNESSG.#REVIEW ALL CRITICAL STEAM-PIPING HANGERS BY CHECKING THE INDICATOROF HOT POSITION & ADJUST IF NECESSARYH.#VISUAL INSPECTIO N / SURVEY OF DUCT BURNERS, EXPANSION JOINTS ANDPIPE PENETRATIONS.I.#INSPECT THE MAIN STACK/BYPASS STACK & ITS ACCESSORIES FOR ANYDI SCREPANCYJ.#BASED ON VISUAL INSPECTION AND PREVIOUS RECORD REVIEW, THE INSPECTORMAY IDENTIFY ADDITIONAL NDE (THICKNESS MEASUREMENT, MT, PT, HARDNESSETC.), THE NDE RESULTS WILL BE REVIEWED FOR COMPLIANCE TO DRAWINGS,CODE AND SPECIFICATION IF AVAILABLE OR RETAINED FOR FUTURE REFERENCE.K.#ALL ABNORMAL CONDITIONS SUCH AS POOR COATING, RUSTED/CORRODED/PITTEDSURFACE, RUSTED BOLTS/NUTS, LOOSELY BOLT ED ASSEMBLIES, RUSTED WELDSEAMS, CRACKS,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DISTORTION, BENDS, DENTS, SAGGING, BULGING ITEMS, ANINDICATION OF A LEAK, AN INDICATION OF WATER INGRESS, PIPING/TUBEEXCESSIVE VIBRATIONS, WASTAGE REDUCTION OF PRESSURE RETAINING THICKNESSSHALL BE REPORTED.L.#VISUAL INSPECT ION OF INTERNAL CASING, AND INSULATIONS, AND REVIEWHOT SPOTS DURING BOILER RUNNING.1.3 POST OUTAGE INSPECTION:A.#REVIEW OF INSPECTIO N REPORT AND RECORDS FOR REPAIR IF ANY PERFORMED.B.#WITNESS THE HYDRO TEST AS APPLICABLEC.#WITNESS FUNCTIONALITY TEST AND REVIEW OF FUNCTIONALITY TEST REPORTD.#REVIEW / VERIFICATION OF CALIBRATION CERTIFICATES OF PRESSURE,TEMPERATURE GAUGES, TRANSMITTERS AND OTHER INSTRUMENTSE.#REVIEW OF WATER CHEMISTRY RECORDSF.#WITNESS SAFETY VALVE TESTS AND REVIEW OF SAFETY VALVE TESTCERTIFICATESG.#THE BOIL						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ER SHALL BE VISUALLY EXAMINED EXTERNALLY UNDER NORMALWORKING CONDITIONS.H.#WATER LEVEL GAUGE ACCURACY, FEED WATER CONTROLS, LOW/HIGH -LEVELWATER ALARMS, LOW WATER LEVEL ACTIONS, BLOW-DOWN SYSTEM OPERATIONS ETC.WILL BE REVIEWED.I.#REVIEW OF OPERATING AND DESIGN PARA METERSJ.#VERIFICATION TO CHECK THE BOILER IS PROVIDED WITH THE NEEDED SAFETYACCESSORIES AND THESE ACCESSORIES ARE IN PLACE.4. DELI VERABLES SHALL BE:ISSUE OF VISIT REPORT DETAILING SCOPE OF INSPECTION UNDERTAKEN ASREQUIRED.ISSUE OF INSPECTION CERTIFICATE DETAILIN G THE SCOPE OF INSPECTIONUNDERTAKEN AND RESULTS &RECOMMENDATIONS UPON SATISFACTORY COMPLETION OF THE INSPECTION.ISSUE OF INSPECTION REPORT DETAILING THE SCOPE OF INSPECTION UNDERTAKENIF ANOMALIESIDENTIFIED ARE NOT RESOLVED UNDER EIAC-RQ-IB-004						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REQUIREMENTS.5. FUNCTIONALITY TEST:I.#DELIVERABLES WILL BE #CERTIFICATE FOR NORMAL OPERATING CONDITION# AS PER EIAC REQUIREMENT. THE CERTIFICATE WILL BE NOTED ON THE NEXT INSPECTION DATE IN COMPLIANCE WITH EIAC REQUIREMENTS.II.#IF ANOMALIES/FINDINGS ARE NOTED #REPORT OF EXAMINATION UNDER NORMAL WORKING CONDITION# WILL BE ISSUED AS PER EIAC REQUIREMENT. THESE FINDINGS WILL NEED TO BE RESOLVED BY YOU SUITABLY.INTERNAL INSPECTION:I.#DELIVERABLES WILL BE #CERTIFICATE OF EXAMINATION OF STEAM BOILER# AS PER EIAC REQUIREMENT. THE CERTIFICATE WILL NOTE THE NEXT INSPECTION DATE IN COMPLIANCE WITH EIAC REQUIREMENTS.II.#IF ANOMALIES/FINDINGS ARE NOTED #REPORT OF EXAMINATION OF STEAM BOILER # WILL BE ISSUED AS PER EIAC REQUIREMENT. THESE FINDINGS WILL NEED TO BE RESOLVED BY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			YOU SUITABLY.III.#CERTIFICATE TO EIAC REQUIREMEN TS SHALL BE LIMITED TOPRESSURE-RETAINING ITEMS GENERALLY RESTRICTED TO THE GEOMETRIC LIMIT DEFINED IN ASMESECTION I FIGURE PG-5 8.2-1.IV. ISSUE OF VISIT REPORT DETAILING THE SCOPE OF INSPECTIONUNDERTAKEN AS REQUIRED FOR ANY INTERMEDIATE REPORTING.D EWA SCOPE OF WORK:A) SHALL ARRANGE CLEANING, NON-DESTRUCTIVE EXAMINATION (NDE),THICKNESS GAUGING IN-SITU METALLOGRAPHYB) FACILIT IES FOR SAFE ACCESS TO EQUIPMENT/SCAFFOLDING,C) WORK PERMITS, CONFINED SPACE ENTRY PERMITS AND GATE PASSESD) INSULATION REMOVALS , AS REQUIRED.NOTE TO CONTRACTORS:#CONTRACTORS SHOULD VISIT THE SITE TO UNDERSTAND THE SITE CONDITIONS,CONTRACT SCOPE, AND INTRICAC IES OF THE WORK TO ENSURE THAT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THEYADEQUATELY COMPREHEND THE SCOPE OF WORK FOR DESIGN, ENGINEERING, ANDCOST ESTIMATION.#NO CLAIMS F OR EXTRA PAYMENTS SHALL BE ACCEPTED FOR ANY ADDITIONALMATERIALS OR WORKS THAT WERE FOUND REQUIRED AT THE TIME OF EXECUTION OFTHE WOR K DUE TO A LACK OF UNDERSTANDING OF THE SCOPE, EXTENT OF WORK,PLANT/SITE RESTRICTIONS, UNDERESTIMATION OF THE SCOPE, ETC.,.#IRRESPEC TIVE OF BEING EXPLICITLY OR IMPLICITLY MENTIONED IN THISSPECIFICATION, THE CONTRACTOR SHALL NOTE THAT ALL TECHNICAL ANDENGINEERING R EQUIREMENTS ESSENTIAL TO COMPLETING THE SCOPE OF WORK AREINCLUDED IN THIS PR DOCUMENT.#ANY AMBIGUITIES OR DISCREPANCIES BETWEEN THE CONTRACTOR#S OFFER ANDTHIS TECHNICAL SPECIFICATION AFTER THE AWARD OF THE CONTRACT SHALL BERESOLVED BY THE DEWA, WHO SHALL THEN INS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TRUCT THE CONTRACTOR THEREON.INTERPRETATION, CHANGE, OR CORRECTION MADE BY DEWA WILL BE BINDING FORTHE CONTRACTOR IN THIS REGARD WIT HOUT ANY ADDITIONAL COST TO DEWA.#NO CLAIMS FOR EXTRA PAYMENTS SHALL BE ACCEPTED FOR DEMOBILIZATION ANDREMOBILIZATION OR WAITING TI ME OR IDLE TIME DUE TO DEWA#S OPERATIONALCONSTRAINTS OR OTHER CRITICAL MAINTENANCE ACTIVITIES CARRIED OUT BY DEWAAT THE SITE.#THIS IS A LUMP SUM JOB, AND NO PART PAYMENT WILL BE PROCESSED.						
3		ITEM-00001	THIRD PARTY INSPECTION OF WHB BOILERS 1A, 1B & 1C AT #E# STATION - JEBELALI POWER STATION DEWA.SCOPE OF WORK FOR INSPECTION ACCORDIN G TO EIAC-RQ-IB-004 (DAC REQ-08):REFER TO THE EIAC DOCUMENT FOR FURTHER REQUIREMENTS.1. FUNCTIONALITY TEST SHALL COVER INSPECTION AC TIVITY TO ENSURE THAT:1.1: PRE OUTAGE	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSPECTION:A.#REVIEW OF MANUFACTURER#S CERTIFICATION FOR THE BOILER ANDIDENTIFICATION BASED O N MANUFACTURER#S MARKINGS/ASME/CE MARKINGS.B.#REVIEW OF RECORDS FOR SITE ERECTION AND FINAL EXAMINATIONRESULTS/REPAIR/ALTERATION REC ORDS.C.#VISUAL EXAMINATION OF ALL ACCESSIBLE AREAS.D.#REVIEW AND VERIFY THERMOGRAPHY REPORTSE.#EXTERNAL VISUAL EXAMINATION OF ALL AC CESSIBLE AREAS.F.#WALK DOWN AND PUNCH LIST REPORTS BASED ON FINDINGS AND INTERVIEWSG.#RECOMMENDATION FOR NDE TASKS TO BE PERFORMED D URING INSPECTIONSH.#REVIEW OF LAST INSPECTION REPORTI.#REVIEW OF LATEST OPERATING DATA FROM CONTROL SYSTEM HISTORIANS ANDOTHER AVAIL ABLE ARCHIVESJ.#INSPECTION FOR VIBRATION OF PIPE, HEADERS, STEEL STRUCTURE, ETC.1.2: OUTAGE INSPECTION:A.#A VISUAL SURVEY OF THE WHB						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			GENERAL CONDITION, EXTERNAL CASING,INTERNAL GAS SIDE MECHANICAL PARTS AND AUXILIARY EQUIPMENT READILYACCESSIBLE PRESSURE PARTS ETC. B.#THE INTERNAL THOROUGH INSPECTION CONSTITUTES A VISUALEXAMINATION/SURVEY OF THE ACCESSIBLE SURFACE OF THE BOILER PRESSUREPARTS, TH E TUBES HEADERS, ACCESSIBLE SUPPORTING ARRANGEMENTS, REFRACTORYLINING, BURNER, FLOW GRID SUPPORTS, SILENCERS, DRUMS, AND INTERNALFIT TINGS TO DETECT ANY SIGN OF GENERAL OR LOCALIZEDDEFORMATION/DETERIORATION. WHERE APPLICABLE OR NECESSARY,NON-DESTRUCTIVE TESTING MET HODS, DESTRUCTIVE TESTING OF SAMPLES, IN-SITUMETALLOGRAPHY ETC. SHALL BE USED TO COMPLEMENT THE VISUAL INSPECTION.C.#EXTERNAL VISUAL EXAMINATION WAS CARRIED OUT ON ALL ACCESSIBLE AREAS.D.#VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OF						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HIGH,MEDIUM AND LOW-PRESSURE STEAM PIPING AND HEADERSE.#VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OFPRESSURE VESSELS AND PIPING SYS TEMSF.#REVIEW OF THICKNESS MEASUREMENT RECORDS TO VERIFY WHETHER THECURRENT THICKNESS IS NOT LESS THAN THE MINIMUM ALLOWABLE WALL TH ICKNESSG.#REVIEW ALL CRITICAL STEAM-PIPING HANGERS BY CHECKING THE INDICATOROF HOT POSITION & ADJUST IF NECESSARYH.#VISUAL INSPECTIO N / SURVEY OF DUCT BURNERS, EXPANSION JOINTS ANDPIPE PENETRATIONS.I.#INSPECT THE MAIN STACK/BYPASS STACK & ITS ACCESSORIES FOR ANYDI SCREPANCYJ.#BASED ON VISUAL INSPECTION AND PREVIOUS RECORD REVIEW, THE INSPECTORMAY IDENTIFY ADDITIONAL NDE (THICKNESS MEASUREMENT, MT, PT, HARDNESSETC.), THE NDE RESULTS WILL BE REVIEWED FOR COMPLIANCE TO						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DRAWINGS, CODE AND SPECIFICATION IF AVAILABLE OR RETAINED FOR FUTURE REFERENCE. K.#ALL ABNORMAL CONDITIONS SUCH AS POOR COATING, RUSTED/CORRODED/PITTED SURFACE, RUSTED BOLTS/NUTS, LOOSELY BOLTED ASSEMBLIES, RUSTED WELD SEAMS, CRACKS, DISTORTION, BENDS, DENTS, SAGGING, BULGING ITEMS, AN INDICATION OF A LEAK, AN INDICATION OF WATER INGRESS, PIPING/TUBE EXCESSIVE VIBRATIONS, WASTAGE REDUCTION OF PRESSURE RETAINING THICKNESS SHALL BE REPORTED. L.#VISUAL INSPECTION OF INTERNAL CASING, AND INSULATIONS, AND REVIEW HOT SPOTS DURING BOILER RUNNING. 1.3 POST OUTAGE INSPECTION: A.#REVIEW OF INSPECTION REPORT AND RECORDS FOR REPAIR IF ANY PERFORMED. B.#WITNESS THE HYDRO TEST AS APPLICABLE. C.#WITNESS FUNCTIONALITY TEST AND REVIEW OF FUNCTIONALITY TEST REPORT. D.#REVIEW /						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			VERIFICATION OF CALIBRATION CERTIFICATES OF PRESSURE,TEMPERATURE GAUGES, TRANSMITTERS AND OTHER INSTRUMENTSE.#REVIEW OF WATER CHEMISTRY RECORDSF.#WITNESS SAFETY VALVE TESTS AND REVIEW OF SAFETY VALVE TESTCERTIFICATESG.#THE BOILER SHALL BE VISUALLY EXAMINED EXTERNALLY UNDER NORMALWORKING CONDITIONS.H.#WATER LEVEL GAUGE ACCURACY, FEED WATER CONTROLS, LOW/HIGH -LEVELWATER ALARMS, LOW WATER LEVEL ACTIONS, BLOW-DOWN SYSTEM OPERATIONS ETC.WILL BE REVIEWED.I.#REVIEW OF OPERATING AND DESIGN PARA METERSJ.#VERIFICATION TO CHECK THE BOILER IS PROVIDED WITH THE NEEDED SAFETYACCESSORIES AND THESE ACCESSORIES ARE IN PLACE.4. DELI VERABLES SHALL BE:ISSUE OF VISIT REPORT DETAILING SCOPE OF INSPECTION UNDERTAKEN ASREQUIRED.ISSUE OF INSPECTION CERTIFICATE DETAILIN						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			G THE SCOPE OF INSPECTION UNDERTAKEN AND RESULTS & RECOMMENDATIONS UPON SATISFACTORY COMPLETION OF THE INSPECTION. ISSUE OF INSPECTION REPORT DETAILING THE SCOPE OF INSPECTION UNDERTAKEN IF ANOMALIES IDENTIFIED ARE NOT RESOLVED UNDER EIAC-RQ-IB-004 REQUIREMENTS. 5. FUNCTIONALITY TEST: I. # DELIVERABLES WILL BE # CERTIFICATE FOR NORMAL OPERATING CONDITION # AS PER EIAC REQUIREMENT. THE CERTIFICATE WILL BE NOTED ON THE NEXT INSPECTION DATE IN COMPLIANCE WITH EIAC REQUIREMENTS. II. # IF ANOMALIES/FINDINGS ARE NOTED # REPORT OF EXAMINATION UNDER NORMAL WORKING CONDITION # WILL BE ISSUED AS PER EIAC REQUIREMENT. THESE FINDINGS WILL NEED TO BE RESOLVED BY YOU SUITABLY. INTERNAL INSPECTION: I. # DELIVERABLES WILL BE # CERTIFICATE OF EXAMINATION OF STEAM BOILER # AS PER EIAC REQUIREMENT. THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CERTIFICATE WILL NOTE THE NEXT INSPECTION DATE IN COMPLIANCE WITH EIA REQUIREMENTS. II. # IF ANOMALIES/FINDINGS ARE NOTED # REPORT OF EXAMINATION OF STEAMBOILER # WILL BE ISSUED AS PER EIA REQUIREMENT. THESE FINDINGS WILL NEED TO BE RESOLVED BY YOU SUITABLY. III. # CERTIFICATE TO EIA REQUIREMENTS SHALL BE LIMITED TO PRESSURE-RETAINING ITEMS GENERALLY RESTRICTED TO THE GEOMETRIC LIMIT DEFINED IN ASME SECTION I FIGURE PG-5 8.2-1.IV. ISSUE OF VISIT REPORT DETAILING THE SCOPE OF INSPECTION UNDERTAKEN AS REQUIRED FOR ANY INTERMEDIATE REPORTING. D EWA SCOPE OF WORK: A) SHALL ARRANGE CLEANING, NON-DESTRUCTIVE EXAMINATION (NDE), THICKNESS GAUGING IN-SITU METALLOGRAPHY B) FACILITIES FOR SAFE ACCESS TO EQUIPMENT/SCAFFOLDING, C) WORK PERMITS,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONFINED SPACE ENTRY PERMITS AND GATE PASSED) INSULATION REMOVALS , AS REQUIRED.NOTE TO CONTRACTORS:·#CONTRACTORS SHOULD VISIT THE SITE TO UNDERSTAND THE SITE CONDITIONS,CONTRACT SCOPE, AND INTRICAC IES OF THE WORK TO ENSURE THAT THEYADEQUATELY COMPREHEND THE SCOPE OF WORK FOR DESIGN, ENGINEERING, ANDCOST ESTIMATION.·#NO CLAIMS F OR EXTRA PAYMENTS SHALL BE ACCEPTED FOR ANY ADDITIONALMATERIALS OR WORKS THAT WERE FOUND REQUIRED AT THE TIME OF EXECUTION OFTHE WOR K DUE TO A LACK OF UNDERSTANDING OF THE SCOPE, EXTENT OF WORK,PLANT/SITE RESTRICTIONS, UNDERESTIMATION OF THE SCOPE, ETC.,·#IRRESPEC TIVE OF BEING EXPLICITLY OR IMPLICITLY MENTIONED IN THISSPECIFICATION, THE CONTRACTOR SHALL NOTE THAT ALL TECHNICAL ANDENGINEERING R EQUIREMENTS ESSENTIAL TO COMPLETING THE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SCOPE OF WORK ARE INCLUDED IN THIS PR DOCUMENT. #ANY AMBIGUITIES OR DISCREPANCIES BETWEEN THE CONTRACTOR'S OFFER AND THIS TECHNICAL SPECIFICATION AFTER THE AWARD OF THE CONTRACT SHALL BE RESOLVED BY THE DEWA, WHO SHALL THEN INSTRUCT THE CONTRACTOR THEREON. INTERPRETATION, CHANGE, OR CORRECTION MADE BY DEWA WILL BE BINDING FOR THE CONTRACTOR IN THIS REGARD WITHOUT ANY ADDITIONAL COST TO DEWA. #NO CLAIMS FOR EXTRA PAYMENTS SHALL BE ACCEPTED FOR DEMOBILIZATION AND REMOBILIZATION OR WAITING TIME OR IDLE TIME DUE TO DEWA'S OPERATIONAL CONSTRAINTS OR OTHER CRITICAL MAINTENANCE ACTIVITIES CARRIED OUT BY DEWA AT THE SITE. #THIS IS A LUMP SUM JOB, AND NO PART PAYMENT WILL BE PROCESSED.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SPECIAL NOTES / INSTRUCTIONS:

'E' Stn. Ph-I, Boilers WHB 1A, 1B <(>&<)> 1C Third part inspection
according to EIAC-RQ-IB-004

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page29 of 32

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8) Data Privacy, Security and Sharing:

- a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- d) DEWA reserves the right to withhold data from third parties if deemed sensitive.
- e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332601981
DATE : 14.08.2026
REQ No : 1032603707
REQ TITLE : 'E' Stn. Ph-I, Boilers WHB 1
DELIVERY LOCATION
CLOSING DATE : 20.08.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP