

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SCOPE OF WORK AND TECHNICAL REQUIREMENTS {CONTRACTORS SCOPE}THE SCOPE OF WORK AND TECHNICAL REQUIREMENTS OF THE PUMPS ARE ASMENTIONE D BELOW: SECTIONAL DRAWINGS AND TECHNICAL DETAILS ARE FURNISHED1)#COLLECT AND RECORD ALL PRE-SHUTDOWN DATA OF THE PUMPS WHICH SHALLI NCLUDE ALL THE PARAMETERS SUCH AS SUCTION AND DISCHARGE PRESSURE,VIBRATION READINGS, MOTOR CURRENT ETC.2)#DECOUPLE MOTOR AND PUMP BY REMOVING COUPLING BOLTS AND REMOVE PIPINGCONNECTIONS (MOTOR DISCONNECTION AND REMOVAL BY DEWA IF REQUIRED).3)#TRANSPORT THE PUMP TO SERVICE PROVIDER'S WORKSHOP OR AT FACILITIESAT DEWA PREMISES. PUMP INSPECTION AND OVERHAUL1)#DISMANTLE THE PUMP AS PER OEM MAINTENANCE PROCEDURE.2)#CLEAN, INSPECT EACH COMPONENT. CHECK FOR WEAR, EROSION, CORROSION,SCORING, CRACKS ETC. FOR ALL	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMPONENTS AND RECORD ALL FINDINGS.3)#MEASURE AND RECORD ALL DIMENSIONS AND CLEARANCES AND COMPARE WITH THE OEM MAXIMUM AVAILABLE TOLERANCES4)#CHECK THE RUN OUT OF THE SHAFT (SHALL BE STRAIGHTENED IF REQUIRED) AND ROTOR (SHALL BE MACHINED IF REQUIRED) COMPARE WITH OEMS MAXIMUM AVAILABLE TOLERANCES.5)#PREPARE AND SUBMIT A DETAILED INSPECTION REPORT TO DEWA MAINTENANCE PERSONNEL WITHIN TWO WORKING DAYS FROM RECEIPT OF THE PUMP. INSPECTION REPORT SHALL INCLUDE ALL AS FOUND DETAILS, RECOMMENDATIONS FOR REPAIR, REPLACEMENT SPARE PARTS AND UPGRADES.6)# SERVICE PROVIDER SHALL PROCEED FOR THE OVERHAUL OF THE PUMP AFTER GETTING RESPONSE/CLEARANCE FROM DEWA MAINTENANCE SECTION. DEWA WILL PROVIDE REQUIRED MUTUALLY AGREED UPON SPARE PARTS BASED ON THE INSPECTION REPORT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND DEWA ENGINEERS INSPECTION AND COMMON CONSUMABLES SHOULD BE ARRANGE FROM SERVICE PROVIDER.7)#THE PUMP CASINGS/MAJOR PARTS SHALL BE CLEANED THOROUGHLY TO REMOVETHE SCALE FORMATIONS IN TERNALLY AND EXTERNALLY AND A SUITABLE PAINTCOATING SHALL BE APPLIED. CLEANING CAN BE DONE WITH GRIT BLASTING.8)#MAJOR REPAIR WORKS IF ANY SHALL BE CARRIED OUT AFTER APPROVAL FROMDEWA AT AN EXTRA COST AGREED.9)#WEIR RING FIXING (IF REQUIRED) AND MAINTAIN THE CLEAR ANCE, SKIMMACHINING WILL BE CARRIED OUT BY THE SERVICE PROVIDER WITHOUT ANYADDITIONAL COST.10)#COMPLETE PUMP ROTOR SHALL BE DYNAMICA LLY BALANCED AT THE SERVICEPROVIDER'S WORKSHOP AND REPORT TO BE SUBMITTED.11)#RE-ASSEMBLE THE PUMP BY REPLACING THE WEAR, DAMAGED PA RTS ANDREPAIRS IF ANY AS PER OEM						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RECOMMENDATIONS AND INSTRUCTIONS.12)#PREPARE FINAL AS BUILD REPORT DETAILING THE DAMAGES, WITH PICTORIAL ATTACHMENTS, REPAIRS CARRIED OUT, AS BUILT RUNNING CLEARANCES, SPAREPARTS USED ETC.13)#TRANSPORT THE PUMP BACK TO THE SITE INCL UDING ALL THE FORMALITIES.ALL OLD USED PARTS SHALL ALSO BE RETURNED TO DEWA.14)#INSPECT THE GEAR COUPLING FOR WEAR OF TOOTH/ FLEXIBLE COUPLING FOR CRACKS, COUPLING ELEMENTS FOR DAMAGES15)#RE-INSTALL THE PUMP AT SITE16)#BEFORE RE-INSTALL CLEAN THE MACHINED SURFACES OF THE MOTORPEDESTAL, BARREL FLANGES BASE AND OUTSIDE SURFACES OF THE COUPLING.17)##ALL RE-ASSEMBLY/INSTALL MUST BE DONE ACCORDING TO THE JOINTMARKS, WHICH HAVE BEEN PUT ON EACH PART DURING DISASSEMBLY.18)#WHEN RE-ASSEMBLING FLEXIBLE COUPLINGS TO THE SHAFT, A COAT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OFANTI-GALLING COMPOUND (ANTI-SEIZE OR EQUIVALENT) SHALL BE APPLIED AT THEMATING SURFACES, TO PREVENT SEIZING WHILE TIGHTENING THE FIXING BOLTS.19)#CARRY OUT THE ALIGNMENT OF THE PUMP AND MOTOR AS PER OEMSPECIFICATIONS.20)#RECOUPLE PUMP AND MOTOR AND REFILL BEARI NG/COUPLING ASSEMBLY WITHREQUIRED TYPE AND AMOUNT OF GREASE/OIL.21)#OTHER WORK AS NECESSARY TO MAKE THE SCOPE COMPLETE AND PUMP READ YFOR SERVICE. INCLUDING REMOVAL OF ALL TEMPORARY SUPPORTS, SCAFFOLDING,HOUSEKEEPING AND DISPOSAL OF WASTE TO SEGREGATED AREA. FINAL SAFETY WALKDOWN INSPECTIONCOMMISSIONING OF PUMP AT SITE1)#CARRY OUT RE-COMMISSIONING OF THE PUMP AND CHECK THE PUMP UNDEROPERATING C ONDITIONS, MONITORING THE PARAMETERS NOTED IN THE PRE-SHUTDOWN DATA CHECKS.2)##RESTORE BACK THE EQUIPMENT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PREFERABLY TO A BETTER CONDITION AND INNO CASE WORSE THAN THE ORIGINAL CONDITION. SUCH CONDITION WILL BEMUTUALLY AGREED AND DATA TAKEN BEFORE DIS-ASSEMBLY, IT WILL INVOLVEVIBRATION, FLOW, PRESSURE, TEMPERATURE OF BEARING, SPEED, MOTOR AMPSETC.3)##VIBRATION LEVEL MUST BE BETTER/ ACCEPTABLE ISO LIMITS OR AT LEASTNOT WORSE THAN THE CONDITION BEFORE DISMANTLING.REPORTS :1)#RECORD CONDITION OF EACH PUMP BEFORE AND AFTER THE OVERHAUL WORK2)#DETAILS OF INSPECTION AND WORK UNDERTAKEN3)#DESCRIPTION OF ON-SITE AND OFF-SITE WORK CARRIED OUT4)#INSPECTION CHECK LISTS.5)#DETAILS OF PERSONNEL WHO UNDERTOOK THE WORK.6)#LIST OF PARTS USED.7)#IDENTIFICATION OF DEFECTS TOGETHER WITH DETAILS OF AN Y REMEDIAL WORKCARRIED OUT.8)#PHOTO DOCUMENTATION9)#RECOMMENDATIONS FOR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PUMPS OPERATION10)#THE ABOVE REPORT SHALL BE SUBMITTED WITHI N ONE WEEK AFTER THECOMPLETION OF OVERHAUL.QUALIFICATION OF SERVICE PROVIDERTHE PUMP SERVICE PROVIDER SHALL BE CAPABLE OF CONDUCTING SITEINSPECTIONS AND OVERHAUL FOR A VARIETY OF PUMPS AS INSTALLED IN THEPLANT. THEY SHALL DEMONSTRATE:1.1.#THEY POSSESS THE TECHNICA L EXPERTISE IN THE FORM OF A COMPETENTSTAFF BASE.1.2.#THEY HAVE THE FACILITIES AND EQUIPMENT TO CONDUCT THE WORK TO THEAPPROPRIATE Q UALITY STANDARD.1.3.#A PROVEN TRACK RECORD OF SIMILAR WORK ON SIMILAR EQUIPMENT -REFERENCE TO BE PROVIDED.1.4.##THEY HAVE SYSTEMS IN PLACE TO MANAGE HEALTH, SAFETY, ANDENVIRONMENTAL ASPECTS OF THEIR BUSINESS - PREFERABLY EXTERNALLYACCREDITED.1.5.#THEY HAVE QUALITY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SYSTEMS IN PLACE - QUALITY PLANS WILL BEREQUIRED FOR EACH PUMP AND ACCREDITATION TO ISO: 9001 IS PREFERABLE.						
2		ITEM-00001	SCOPE OF WORK AND TECHNICAL REQUIREMENTS {CONTRACTORS SCOPE)THE SCOPE OF WORK AND TECHNICAL REQUIREMENTS OF THE PUMPS ARE ASMENTIONE D BELOW: SECTIONAL DRAWINGS AND TECHNICAL DETAILS ARE FURNISHED1)#COLLECT AND RECORD ALL PRE-SHUTDOWN DATA OF THE PUMPS WHICH SHALLI NCLUDE ALL THE PARAMETERS SUCH AS SUCTION AND DISCHARGE PRESSURE,VIBRATION READINGS, MOTOR CURRENT ETC.2)#DECOUPLE MOTOR AND PUMP BY REMOVING COUPLING BOLTS AND REMOVE PIPINGCONNECTIONS (MOTOR DISCONNECTION AND REMOVAL BY DEWA IF REQUIRED).3)#TRANSPORT THE PUMP TO SERVICE PROVIDER'S WORKSHOP OR AT FACILITIESAT DEWA PREMISES. PUMP INSPECTION AND OVERHAUL1)#DISMANTLE THE PUMP AS PER OEM MAINTENANCE	1	AU				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NANCE PROCEDURE.2)#CLEAN, INSPECT EACH COMPONENT. CHECK FOR WEAR, EROSION, CORROSION, SCORING, CRACKS ETC. FOR ALL COMPONENTS AND RECORD ALL FINDINGS.3)#MEASURE AND RECORD ALL DIMENSIONS AND CLEARANCES AND COMPARE WITH THE OEM MAXIMUM AVAILABLE TOLERANCES.4)#CHECK THE RUN OUT OF THE SHAFT (SHALL BE STRAIGHTENED IF REQUIRED) AND ROTOR (SHALL BE MACHINED IF REQUIRED) COMPARE WITH OEMS MAXIMUM AVAILABLE TOLERANCES.5)#PREPARE AND SUBMIT A DETAILED INSPECTION REPORT TO DEWA MAINTENANCE PERSONNEL WITHIN TWO WORKING DAYS FROM RECEIPT OF THE PUMP. INSPECTION REPORT SHALL INCLUDE ALL AS FOUND DETAILS, RECOMMENDATIONS FOR REPAIR, REPLACEMENT SPARE PARTS AND UPGRADES.6)# SERVICE PROVIDER SHALL PROCEED FOR THE OVERHAUL OF THE PUMP AFTER GETTING RESPONSE/CLEARANCE FROM DEWA						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MAINTENANCE SECTION. DEWA WILL PROVIDE REQUIRED MUTUALLY AGREED UPON SPARE PARTS BASED ON THE INSPECTION REPORT AND DEWA ENGINEERS INSPECTION AND COMMON CONSUMABLES SHOULD BE ARRANGE FROM SERVICE PROVIDER.7)#THE PUMP CASINGS/MAJOR PARTS SHALL BE CLEANED THOROUGHLY TO REMOVE THE SCALE FORMATIONS INTERNALLY AND EXTERNALLY AND A SUITABLE PAINT COATING SHALL BE APPLIED. CLEANING CAN BE DONE WITH GRIT BLASTING.8)#MAJOR REPAIR WORKS IF ANY SHALL BE CARRIED OUT AFTER APPROVAL FROM DEWA AT AN EXTRA COST AGREED.9)#WEIR RING FIXING (IF REQUIRED) AND MAINTAIN THE CLEAR ANCE, SKIMMACHINING WILL BE CARRIED OUT BY THE SERVICE PROVIDER WITHOUT ANY ADDITIONAL COST.10)#COMPLETE PUMP ROTOR SHALL BE DYNAMICALLY BALANCED AT THE SERVICE PROVIDER'S WORKSHOP AND REPORT TO BE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUBMITTED.11)#RE-ASSEMBLE THE PUMP BY REPLACING THE WEAR, DAMAGED PARTS AND REPAIRS IF ANY AS PER OEM RECOMMENDATIONS AND INSTRUCTIONS.12)#PREPARE FINAL AS BUILD REPORT DETAILING THE DAMAGES, WITH PICTORIAL ATTACHMENTS, REPAIRS CARRIED OUT, AS BUILT RUNNING CLEARANCES, SPARE PARTS USED ETC.13)#TRANSPORT THE PUMP BACK TO THE SITE INCLUDING ALL THE FORMALITIES. ALL OLD USED PARTS SHALL ALSO BE RETURNED TO DEWA.14)#INSPECT THE GEAR COUPLING FOR WEAR OF TOOTH/ FLEXIBLE COUPLING FOR CRACKS, COUPLING ELEMENTS FOR DAMAGES.15)#RE-INSTALL THE PUMP AT SITE.16)#BEFORE RE-INSTALL CLEAN THE MACHINED SURFACES OF THE MOTOR PEDESTAL, BARREL FLANGES BASE AND OUTSIDE SURFACES OF THE COUPLING.17)##ALL RE-ASSEMBLY/INSTALL MUST BE DONE ACCORDING TO THE JOINT MARKS, WHICH HAVE BEEN PUT ON						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EACH PART DURING DISASSEMBLY.18)#WHEN RE-ASSEMBLING FLEXIBLE COUPLINGS TO THE SHAFT, A COAT OF ANTI-GALLING COMPOUND (ANTI-SEIZE OR EQUIVALENT) SHALL BE APPLIED AT THE MATING SURFACES, TO PREVENT SEIZING WHILE TIGHTENING THE FIXING BOLTS.19)#CARRY OUT THE ALIGNMENT OF THE PUMP AND MOTOR AS PER OEM SPECIFICATIONS.20)#RECOUPLE PUMP AND MOTOR AND REFILL BEARING/COUPLING ASSEMBLY WITH REQUIRED TYPE AND AMOUNT OF GREASE/OIL.21)#OTHER WORK AS NECESSARY TO MAKE THE SCOPE COMPLETE AND PUMP READY FOR SERVICE. INCLUDING REMOVAL OF ALL TEMPORARY SUPPORTS, SCAFFOLDING, HOUSEKEEPING AND DISPOSAL OF WASTE TO SEGREGATED AREA. FINAL SAFETY WALKDOWN INSPECTION COMMISSIONING OF PUMP AT SITE1)#CARRY OUT RE-COMMISSIONING OF THE PUMP AND CHECK THE PUMP UNDER OPERATING C						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONDITIONS, MONITORING THE PARAMETERS NOTED IN THE PRE-SHUTDOWN DATA CHECKS.2)##RESTORE BACK THE EQUIPMENT PREFERABLY TO A BETTER CONDITION AND INNO CASE WORSE THAN THE ORIGINAL CONDITION. SUCH CONDITION WILL BE MUTUALLY AGREED AND DATA TAKEN BEFORE DIS-ASSEMBLY, IT WILL INVOLVE VIBRATION, FLOW, PRESSURE, TEMPERATURE OF BEARING, SPEED, MOTOR AMP SETC.3)##VIBRATION LEVEL MUST BE BETTER/ ACCEPTABLE ISO LIMITS OR AT LEAST NOT WORSE THAN THE CONDITION BEFORE DISMANTLING. REPORTS :1)#RECORD CONDITION OF EACH PUMP BEFORE AND AFTER THE OVERHAUL WORK2)#DETAILS OF INSPECTION AND WORK UNDERTAKEN3)#DESCRIPTION OF ON-SITE AND OFF-SITE WORK CARRIED OUT4)#INSPECTION CHECK LISTS.5)#DETAILS OF PERSONNEL WHO UNDERTOOK THE WORK.6)#LIST OF PARTS USED.7)#IDENTIFICATION OF DEFECTS TOGETHER						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WITH DETAILS OF AN Y REMEDIAL WORKCARRIED OUT.8)#PHOTO DOCUMENTATION9)#RECOMMENDATIONS FOR PUMPS OPERATION10)#THE ABOVE REPORT SHALL BE SUBMITTED WITHI N ONE WEEK AFTER THECOMPLETION OF OVERHAUL.QUALIFICATION OF SERVICE PROVIDERTHE PUMP SERVICE PROVIDER SHALL BE CAPABLE OF CONDUCTING SITEINSPECTIONS AND OVERHAUL FOR A VARIETY OF PUMPS AS INSTALLED IN THEPLANT. THEY SHALL DEMONSTRATE:1.1.#THEY POSSESS THE TECHNICA L EXPERTISE IN THE FORM OF A COMPETENTSTAFF BASE.1.2.#THEY HAVE THE FACILITIES AND EQUIPMENT TO CONDUCT THE WORK TO THEAPPROPRIATE Q UALITY STANDARD.1.3.#A PROVEN TRACK RECORD OF SIMILAR WORK ON SIMILAR EQUIPMENT -REFERENCE TO BE PROVIDED.1.4.##THEY HAVE SYSTEMS IN PLACE TO MANAGE HEALTH, SAFETY, ANDENVIRONMENTAL ASPECTS OF THEIR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BUSINESS - PREFERABLY EXTERNALLY ACCREDITED.1.5.#THEY HAVE QUALITY SYSTEMS IN PLACE - QUALITY PLANS WILL BE REQUIRED FOR EACH PUMP AND ACCREDITATION TO ISO: 9001 IS PREFERABLE.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

D Ph2 Boiler feed pump and condensate extraction pump overhauling inspection.

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332602007
DATE	: 18.08.2026
REQ No	: 1032603702
REQ TITLE	: D Ph2 Boiler feed pump and co
DELIVERY LOCATION	
CLOSING DATE	: 24.08.2026
CLOSING TIME	: 10:00:00

- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.
- 8)Data Privacy, Security and Sharing:
- Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
 - DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
 - DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
 - DEWA reserves the right to withhold data from third parties if deemed sensitive.
 - Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
 - Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
 - Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332602007
DATE	: 18.08.2026
REQ No	: 1032603702
REQ TITLE	: D Ph2 Boiler feed pump and co
DELIVERY LOCATION	
CLOSING DATE	: 24.08.2026
CLOSING TIME	: 10:00:00

evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602007
DATE : 18.08.2026
REQ No : 1032603702
REQ TITLE : D Ph2 Boiler feed pump and co
DELIVERY LOCATION
CLOSING DATE : 24.08.2026
CLOSING TIME : 10:00:00

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP