

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION FOR OUTSOURCING WORKSITE REFURBISHMENT OF ST 86 LP EXT PCV ACTUATOR (MAKE: SERVO VALVE) AT LPH II STATION, JEBEL ALI POWER STATION. 1. INTRODUCTION THIS DOCUMENT OUTLINES THE TECHNICAL AND GENERAL SPECIFICATIONS FOR THE OUTSOURCING OF REFURBISHMENT SERVICES FOR THE ST 86 LP EXT PCV ACTUATOR (MANUFACTURED BY M/S SERVO VALVE) AT THE LPH II STATION, JEBEL ALI POWER STATION. THE OBJECTIVE IS TO ENSURE HIGH-QUALITY OVERHAULING, TESTING, AND REINSTATEMENT OF THE ACTUATOR WITHIN A STIPULATED PERIOD. 2. NAME OF WORK: REFURBISHMENT OF ST 86 LP EXT PCV ACTUATOR, MAKE: SERVO VALVE. 3. PERIOD OF WORK: TOTAL DURATION FOR COMPLETION OF THE REFURBISHMENT WORK IS 5 DAYS DURING ST 86 ANNUAL OUTAGE. TENTATIVE DATE 13.11.2026. 4. SCOPE OF WORK: 1. #DISASSEMBLY OF THE	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ACTUATOR CYLINDER AND CONNECTION HOUSING ON THE SITE AND EXECUTION OF STANDARD OVERHAULING DOWN TO INDIVIDUAL COMPONENT PARTS. 2.#REPLACE THE O-RINGS, GASKETS AS INDICATED BY A STAR MARK IN THE SUPPLIED DRAWINGS. 3.#CLEAN AND CONDUCT DIMENSIONAL CHECKS OF ALL INDIVIDUAL PARTS TO CONFIRM DIMENSIONAL INTEGRITY. 4.#INSPECT AND SERVICE ALL INTERNAL COMPONENTS. ANY INTERNAL DAMAGES DETECTED MUST BE RECTIFIED OR RECONDITIONED. THE DEWA ENGINEER MUST BE CONSULTED IN THE EVENT OF ANY INDICATION OF DAMAGE. 5.#FINAL ASSEMBLY OF THE ACTUATOR INCORPORATING NEW OR REFURBISHED PARTS AS APPROPRIATE. 6.#CONDUCT A LEAK TEST OF THE ACTUATOR AT 6 BARS PRESSURE, WITH DEWA PERSONNEL PRESENT FOR WITNESSING. 7.#CARRY OUT A FULL STROKE TEST OF THE ACTUATOR TO ENSURE SMOOTH OPERATION. THIS						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TEST WILL BE WITNESSED BY A DEWA ENGINEER.8.#SUB MIT A COMPREHENSIVE INSPECTION, REPAIR, AND TESTING REPORT TODWA UPON COMPLETION OF THE WORK.9.#PROVIDE A WARRANTY FOR THE ACTUATOR FOR A PERIOD OF ONE YEAR FROMTHE DATE OF ACCEPTANCE BY DEWA.5. GENERAL TERMS & CONDITIONS1.#THE CONTRACTOR MUST POSSESS PROVEN EXPE RIENCE IN PERFORMING SIMILARREFURBISHMENT WORK. THE CONTRACTOR IS REQUIRED TO REVIEW ALL DRAWINGSSUPPLIED BY DEWA PRIOR TO COMMENCEM ENT OF WORK.2.#THE CONTRACTOR SHALL VISIT THE SITE TO BECOME THOROUGHLY FAMILIARWITH THE SCOPE AND REQUIREMENTS OF THE WORK.3.#THE C ONTRACTOR IS FULLY RESPONSIBLE FOR ANY DELAYS IN EXECUTING THEWORK AND MUST TAKE ALL NECESSARY MEASURES TO AVOID SUCH DELAYS.4.#THE DEWA ENGINEER-IN-CHARGE MUST BE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REGULARLY UPDATED ON THE PROGRESS OF THE WORK THROUGHOUT THE DURATION OF THE CONTRACT.6. DELIVERABLES #REFURBISHED AND FULLY OPERATIONAL ST 85 LP EXT PCV ACTUATOR DELIVERED TO DEWA, JEBEL ALI. #INSPECTION, REPAIR, AND TESTING REPORTS SUBMITTED TO DEWA. #ONE-YEAR WARRANTY CERTIFICATE FOR THE ACTUATOR.7. CONCLUSION ALL WORK MUST BE PERFORMED IN ACCORDANCE WITH DEWA STANDARDS AND REQUIREMENTS. STRICT ADHERENCE TO THE OUTLINED SCOPE, TERMS, AND TIMELINES IS MANDATORY TO ENSURE THE RELIABILITY AND CONTINUOUS OPERATION OF THE JEBEL ALI POWER STATION.						
2		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION FOR OUTSOURCING WORKSITEL REFURBISHMENT OF ST 86 LP EXT PCV ACTUATOR (MAKE: SERVO VALVE) AT LPH II STATION, JEBEL ALI POWER STATION1. INTRODUCTION THIS DOCUMENT OUTLINES THE	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TECHNICAL AND GENERAL SPECIFICATIONS FOR THE OUTSOURCING OF REFURBISHMENT SERVICES FOR THE ST 86 LP EXT PCV ACTUATOR (MANUFACTURED BY M/S SERVO VALVE) AT THE LPH II STATION, JEBEL ALI POWER STATION. THE OBJECTIVE IS TO ENSURE HIGH-QUALITY OVERHAULING, TESTING, AND REINSTATEMENT OF THE ACTUATOR WITHIN A STIPULATED PERIOD. 2. NAME OF WORK: REFURBISHMENT OF ST 86 LP EXT PCV ACTUATOR, MAKE: SERVO VALVE. 3. PERIOD OF WORK: TOTAL DURATION FOR COMPLETION OF THE REFURBISHMENT WORK IS 5 DAYS DURING ST 86 ANNUAL OUTAGE. TENTATIVE DATE 13.11.2026. 4. SCOPE OF WORK: 1. #DISASSEMBLY OF THE ACTUATOR CYLINDER AND CONNECTION HOUSING ON THE SITE AND EXECUTION OF STANDARD OVERHAULING DOWN TO INDIVIDUAL COMPONENT PARTS. 2. #REPLACE THE O-RINGS, GASKETS AS INDICATED BY A STAR MARK IN						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE SUPPLIED DRAWINGS.3.#CLEAN AND CONDUCT DIMENSIONAL CHECKS OF ALL INDIVIDUAL PARTS TO CONFIRM DIMENSIONAL INTEGRITY.4.#INSPECT AND SERVICE ALL INTERNAL COMPONENTS. ANY INTERNAL DAMAGES DETECTED MUST BE RECTIFIED OR RECONDITIONED. THE DEWA ENGINEER MUST BE CONSULTED IN THE EVENT OF ANY INDICATION OF DAMAGE.5.#FINAL ASSEMBLY OF THE ACTUATOR INCORPORATING NEW OR REFURBISHED PARTS AS APPROPRIATE.6.#CONDUCT A LEAK TEST OF THE ACTUATOR AT 6 BARS PRESSURE, WITH DEWA PERSONNEL PRESENT FOR WITNESSING.7.#CARRY OUT A FULL STROKE TEST OF THE ACTUATOR TO ENSURE SMOOTH OPERATION. THIS TEST WILL BE WITNESSED BY A DEWA ENGINEER.8.#SUBMIT A COMPREHENSIVE INSPECTION, REPAIR, AND TESTING REPORT TO DEWA UPON COMPLETION OF THE WORK.9.#PROVIDE A WARRANTY FOR THE ACTUATOR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FOR A PERIOD OF ONE YEAR FROM THE DATE OF ACCEPTANCE BY DEWA.5. GENERAL TERMS & CONDITIONS1.#THE CONTRACTOR MUST POSSESS PROVEN EXPERIENCE IN PERFORMING SIMILAR REFURBISHMENT WORK. THE CONTRACTOR IS REQUIRED TO REVIEW ALL DRAWINGS SUPPLIED BY DEWA PRIOR TO COMMENCEMENT OF WORK.2.#THE CONTRACTOR SHALL VISIT THE SITE TO BECOME THOROUGHLY FAMILIAR WITH THE SCOPE AND REQUIREMENTS OF THE WORK.3.#THE CONTRACTOR IS FULLY RESPONSIBLE FOR ANY DELAYS IN EXECUTING THE WORK AND MUST TAKE ALL NECESSARY MEASURES TO AVOID SUCH DELAYS.4.#THE DEWA ENGINEER-IN-CHARGE MUST BE REGULARLY UPDATED ON THE PROGRESS OF THE WORK THROUGHOUT THE DURATION OF THE CONTRACT.6. DELIVERABLES #REFURBISHED AND FULLY OPERATIONAL ST 85 LP EXT PCV ACTUATOR DELIVERED TO DEWA, JEBEL ALI.#INSPECTION, REPAIR, AND TESTING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REPORT S UBMITTED TO DEWA.#ONE-YEAR WARRANTY CERTIFICATE FOR THE ACTUATOR.7. CONCLUSIONALL WORK MUST BE PERFORMED IN ACCORDANCE WITH DEWA ST ANDARDS ANDREQUIREMENTS. STRICT ADHERENCE TO THE OUTLINED SCOPE, TERMS, ANDTIMELINES IS MANDATORY TO ENSURE THE RELIABILITY AND CONT INUOUSOPERATION OF THE JEBEL ALI POWER STATION.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Insite Refurbishment of ST 86 LP EXT PCV Actuator (Make: Servo valve) at
LPH II Station, Jebel Ali Power Station

Contact Arunkumar.sethuraman@dewa.gov.ae

STANDARD TERMS & CONDITIONS

1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details,

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page8 of 11

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.

2) Prices should be 'DDP' delivery duty paid at DEWA stores.

3) Quotation to be submitted only in local currency U.A.E Dirhams

4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.

5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.

7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:

a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.

b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.

c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332602502
DATE	: 06.10.2026
REQ No	: 1032604864
REQ TITLE	: Insite Refurbishment of ST 86
DELIVERY LOCATION	
CLOSING DATE	: 12.10.2026
CLOSING TIME	: 10:00:00

- commencement.
- d) DEWA reserves the right to withhold data from third parties if deemed sensitive.
- e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.
- 9) Liquidated Damages for PO total value in excess of AED 50,000:
- If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.
- 10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.
- 11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.
- 12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.
- 13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602502
DATE : 06.10.2026
REQ No : 1032604864
REQ TITLE : Insite Refurbishment of ST 86
DELIVERY LOCATION
CLOSING DATE : 12.10.2026
CLOSING TIME : 10:00:00

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP