

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER FOR EMERGENCYEYEWASH SYSTEMTHE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF A COMPLETE CHILLED WATER SYSTEM FOR THEEMERGENCY EYEWASH AND SAFETY SHOWER FACILITY. THE SCOPE OF WORK SHALLINCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING: #SUPPLY AND INSTALLATION OF A SUITABLE WATER CHILLER UNIT COMP LETEWITH ALL NECESSARY ACCESSORIES. #SUPPLY AND INSTALLATION OF A 1 M³ WATER STORAGE TANK, CHILLER ALONGWITH ALL ASSOCIATED PIPING, FITTINGS, SUPPORTS, VALVES, AND ACCESSORIESREQUIRED FOR A COMPLETE AND FUNCTIONAL SYSTEM. #SUPPLY, INSTALLATION, AND COMMISSIONING O F A WATER PUMP WITH ADEQUATECAPACITY TO MAINTAIN THE REQUIRED FLOW AND PRESSURE TO THE EYEWASH ANDSHOWER SYSTEM. #SUPPLY	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND INSTALL ATION OF A PRESSURE CONTROLLER/PRESSURE REGULATING SYSTEM TO ENSURE STABLE AND RELIABLE OPERATION OF THE COMPLETE SYSTEM. #PROVISION OF ALL ELECTRICAL, MECHANICAL, AND CONTROL CONNECTIONS REQUIRED FOR THE CHILLER, TANK, PUMP, AND ASSOCIATED EQUIPMENT. #THE STORAGE T ANK SHALL BE EQUIPPED WITH A TEMPERATURE SENSOR/TRANSMITTER AND LOCAL TEMPERATURE INDICATION. #THE CHILLED WATER TEMPERATURE SHALL BE MAINTAINED BETWEEN 20°C AND 22°C AT ALL TIMES. ##IN CASE THE WATER TEMPERATURE EXCEEDS THE PRESET UPPER LIMIT, THE CONTROL SYSTEM SHALL LL AUTOMATICALLY START THE RECIRCULATION SYSTEM AND OPERATE THE CHILLER TO RESTORE THE WATER TEMPERATURE TO THE REQUIRED RANGE. #ALL C HILLED WATER PIPING, FITTINGS AND VALVES SHALL BE PROPERLY INSULATED WITH UV						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RESISTANT OUTDOOR CLADDING.#TESTING, COMMISSIONING, AND DEMONSTRATION OF THE COMPLETE SYSTEM TOTHE SATISFACTION OF DEWA/OWNER REPRESENTATIVE.#THE BIDDER SHALL BE RESPONSIBLE FOR SITE MEASUREMENT, ENGINEERING,FABRICATION, SUPPLY OF CONSUMABLES, TOOLS, MANPOWER, TRANSPORTATION, ANDALL ACTIVITIES NECESSARY TO DELIVER A COMPLETE OPERATIONAL SYSTEM.THE BIDDER SHALL ENSURE THAT ALL SUPPLIED EQUIPMENT AND MATERIALS ARESUITABLE FOR OUTDOOR INDUSTRIAL SERVICE CONDITIONS AND COMPLY WITHAPPLICABLE INTERNATIONAL STANDARDS AND MANUFACTURER RECOMMENDATIONS.						
2		ITEM-00001	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER FOR EMERGENCYEYEWASH SYSTEMTHE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SUPPLY, INSTALLATION,TESTING, AND COMMISSIONING OF A COMPLETE CHILLED WATER SYSTEM FOR	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE EMERGENCY EYEWASH AND SAFETY SHOWER FACILITY. THE SCOPE OF WORK SHALL INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING: .#SUPPLY AND INSTALLATION OF A SUITABLE WATER CHILLER UNIT COMP LET WITH ALL NECESSARY ACCESSORIES. .#SUPPLY AND INSTALLATION OF A 1 M³ WATER STORAGE TANK, CHILLER ALONG WITH ALL ASSOCIATED PIPING, FITTINGS, SUPPORTS, VALVES, AND ACCESSORIES REQUIRED FOR A COMPLETE AND FUNCTIONAL SYSTEM. .#SUPPLY, INSTALLATION, AND COMMISSIONING OF A WATER PUMP WITH ADEQUATE CAPACITY TO MAINTAIN THE REQUIRED FLOW AND PRESSURE TO THE EYEWASH AND SHOWER SYSTEM. .#SUPPLY AND INSTALL ATION OF A PRESSURE CONTROLLER/PRESSURE REGULATING SYSTEM TO ENSURE STABLE AND RELIABLE OPERATION OF THE COMPLETE SYSTEM. .#PROVISION OF ALL ELECTRICAL, MECHANICAL, AND CONTROL						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONNECTIONSREQUIRED FOR THE CHILLER, TANK, PUMP, AND ASSOCIATED EQUIPMENT. #THE STORAGE T ANK SHALL BE EQUIPPED WITH A TEMPERATURESENSOR/TRANSMITTER AND LOCAL TEMPERATURE INDICATION. #THE CHILLED WATER TEMPERATURE SHALL BE MAINTAINED BETWEEN 20°C AND22°C AT ALL TIMES. ##IN CASE THE WATER TEMPERATURE EXCEEDS THE PRESET UPPER LIMIT, THECONTROL SYSTEM SHA LL AUTOMATICALLY START THE RECIRCULATION SYSTEM ANDOPERATE THE CHILLER TO RESTORE THE WATER TEMPERATURE TO THE REQUIREDRANGE. #ALL C HILLED WATER PIPING, FITTINGS AND VALVES SHALL BE PROPERLYINSULATED WITH UV RESISTANT OUTDOOR CLADDING. #TESTING, COMMISSIONING, AND DEMONSTRATION OF THE COMPLETE SYSTEM TOTHE SATISFACTION OF DEWA/OWNER REPRESENTATIVE. #THE BIDDER SHALL BE RESPONSIBLE FOR SITE MEA						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUREMENT, ENGINEERING,FABRICATION, SUPPLY OF CONSUMABLES, TOOLS, MANPOWER, TRANSPORTATION, ANDALL ACTIVITIES NECESSARY TO DELIVER A COMPLETE OPERATIONAL SYSTEM.THE BIDDER SHALL ENSURE THAT ALL SUPPLIED EQUIPMENT AND MATERIALS ARESUITABLE FOR OUTDOOR INDUSTRIAL SER VICE CONDITIONS AND COMPLY WITHAPPLICABLE INTERNATIONAL STANDARDS AND MANUFACTURER RECOMMENDATIONS.						
3		ITEM-00001	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER FOR EMERGENCYEYEWASH SYSTEMTHE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SUPPLY, INSTALLATION,TESTING, AND COMMISSIONING OF A COMPLETE CHILLED WATER SYSTEM FOR THEEMERGENCY EYEWASH AND SAFETY SHOWER FACILITY. THE SCOPE OF WORK SHALLINCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING: #SUPPLY AND INSTALLATION OF A SUITABLE WATER CHILLER UNIT COMP	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			LET WITH ALL NECESSARY ACCESSORIES. #SUPPLY AND INSTALLATION OF A 1 M³ WATER STORAGE TANK, CHILLER ALONG WITH ALL ASSOCIATED PIPING, FITTINGS, SUPPORTS, VALVES, AND ACCESSORIES REQUIRED FOR A COMPLETE AND FUNCTIONAL SYSTEM. #SUPPLY, INSTALLATION, AND COMMISSIONING OF A WATER PUMP WITH ADEQUATE CAPACITY TO MAINTAIN THE REQUIRED FLOW AND PRESSURE TO THE EYE WASH AND SHOWER SYSTEM. #SUPPLY AND INSTALLATION OF A PRESSURE CONTROLLER/PRESSURE REGULATING SYSTEM TO ENSURE STABLE AND RELIABLE OPERATION OF THE COMPLETE SYSTEM. #PROVISION OF ALL ELECTRICAL, MECHANICAL, AND CONTROL CONNECTIONS REQUIRED FOR THE CHILLER, TANK, PUMP, AND ASSOCIATED EQUIPMENT. #THE STORAGE TANK SHALL BE EQUIPPED WITH A TEMPERATURE SENSOR/TRANSMITTER AND LOCAL TEMPERATURE INDICATION. #THE CHILLED WATER						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TEMPERATURE SHALL BE MAINTAINED BETWEEN 20°C AND 22°C AT ALL TIMES. ##IN CASE THE WATER TEMPERATURE EXCEEDS THE PRESET UPPER LIMIT, THE CONTROL SYSTEM SHALL AUTOMATICALLY START THE RECIRCULATION SYSTEM AND OPERATE THE CHILLER TO RESTORE THE WATER TEMPERATURE TO THE REQUIRED RANGE. ##ALL C HILLED WATER PIPING, FITTINGS AND VALVES SHALL BE PROPERLY INSULATED WITH UV RESISTANT OUTDOOR CLADDING. ##TESTING, COMMISSIONING, AND DEMONSTRATION OF THE COMPLETE SYSTEM TO THE SATISFACTION OF DEWA/OWNER REPRESENTATIVE. ##THE BIDDER SHALL BE RESPONSIBLE FOR SITE MEASUREMENT, ENGINEERING, FABRICATION, SUPPLY OF CONSUMABLES, TOOLS, MANPOWER, TRANSPORTATION, AND ALL ACTIVITIES NECESSARY TO DELIVER A COMPLETE OPERATIONAL SYSTEM. THE BIDDER SHALL ENSURE THAT ALL SUPPLIED EQUIPMENT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND MATERIALS ARESUITABLE FOR OUTDOOR INDUSTRIAL SER VICE CONDITIONS AND COMPLY WITHAPPLICABLE INTERNATIONAL STANDARDS AND MANUFACTURER RECOMMENDATIONS.						
4		ITEM-00001	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER FOR EMERGENCYEYEWASH SYSTEMTHE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF A COMPLETE CHILLED WATER SYSTEM FOR THEEMERGENCY EYEWASH AND SAFETY SHOWER FACILITY. THE SCOPE OF WORK SHALLINCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING: #SUPPLY AND INSTALLATION OF A SUITABLE WATER CHILLER UNIT COMP LETEWITH ALL NECESSARY ACCESSORIES. #SUPPLY AND INSTALLATION OF A 1 M³ WATER STORAGE TANK, CHILLER ALONGWITH ALL ASSOCIATED PIPING, FITTINGS, SUPPORTS, VALVES, AND ACCESSORIESREQUIRED FOR A COMPLETE AND	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FUNCTIONAL SYSTEM. #SUPPLY, INSTALLATION, AND COMMISSIONING OF A WATER PUMP WITH ADEQUATE CAPACITY TO MAINTAIN THE REQUIRED FLOW AND PRESSURE TO THE EYEWASH AND SHOWER SYSTEM. #SUPPLY AND INSTALLATION OF A PRESSURE CONTROLLER/PRESSURE REGULATING SYSTEM TO ENSURE STABLE AND RELIABLE OPERATION OF THE COMPLETE SYSTEM. #PROVISION OF ALL ELECTRICAL, MECHANICAL, AND CONTROL CONNECTIONS REQUIRED FOR THE CHILLER, TANK, PUMP, AND ASSOCIATED EQUIPMENT. #THE STORAGE TANK SHALL BE EQUIPPED WITH A TEMPERATURE SENSOR/TRANSMITTER AND LOCAL TEMPERATURE INDICATION. #THE CHILLED WATER TEMPERATURE SHALL BE MAINTAINED BETWEEN 20°C AND 22°C AT ALL TIMES. ##IN CASE THE WATER TEMPERATURE EXCEEDS THE PRESET UPPER LIMIT, THE CONTROL SYSTEM SHALL AUTOMATICALLY START THE RECIRCULATION						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SYSTEM AND OPERATE THE CHILLER TO RESTORE THE WATER TEMPERATURE TO THE REQUIRED RANGE. #ALL C HILLED WATER PIPING, FITTINGS AND VALVES SHALL BE PROPERLY INSULATED WITH UV RESISTANT OUTDOOR CLADDING. #TESTING, COMMISSIONING, AND DEMONSTRATION OF THE COMPLETE SYSTEM TO THE SATISFACTION OF DEWA/OWNER REPRESENTATIVE. #THE BIDDER SHALL BE RESPONSIBLE FOR SITE MEASUREMENT, ENGINEERING, FABRICATION, SUPPLY OF CONSUMABLES, TOOLS, MANPOWER, TRANSPORTATION, AND ALL ACTIVITIES NECESSARY TO DELIVER A COMPLETE OPERATIONAL SYSTEM. THE BIDDER SHALL ENSURE THAT ALL SUPPLIED EQUIPMENT AND MATERIALS ARE SUITABLE FOR OUTDOOR INDUSTRIAL SERVICE CONDITIONS AND COMPLY WITH APPLICABLE INTERNATIONAL STANDARDS AND MANUFACTURER RECOMMENDATIONS.						
5		ITEM-00001	SUPPLY, INSTALLATION, TESTING &	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMMISSIONING OF CHILLER FOR EMERGENCYEYEWASH SYSTEMTHE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF A COMPLETE CHILLED WATER SYSTEM FOR THEEMERGENCY EYEWASH AND SAFETY SHOWER FACILITY. THE SCOPE OF WORK SHALLINCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING: #SUPPLY AND INSTALLATION OF A SUITABLE WATER CHILLER UNIT COMP LETEWITH ALL NECESSARY ACCESSORIES. #SUPPLY AND INSTALLATION OF A 1 M³ WATER STORAGE TANK, CHILLER ALONGWITH ALL ASSOCIATED PIPING, FITTINGS, SUPPORTS, VALVES, AND ACCESSORIESREQUIRED FOR A COMPLETE AND FUNCTIONAL SYSTEM. #SUPPLY, INSTALLATION, AND COMMISSIONING O F A WATER PUMP WITH ADEQUATECAPACITY TO MAINTAIN THE REQUIRED FLOW AND PRESSURE TO THE EYEWASH ANDSHOWER SYSTEM. #SUPPLY AND INSTALL						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ATION OF A PRESSURE CONTROLLER/PRESSURE REGULATING SYSTEM TO ENSURE STABLE AND RELIABLE OPERATION OF THE COMPLETE SYSTEM. #PROVISION OF ALL ELECTRICAL, MECHANICAL, AND CONTROL CONNECTIONS REQUIRED FOR THE CHILLER, TANK, PUMP, AND ASSOCIATED EQUIPMENT. #THE STORAGE TANK SHALL BE EQUIPPED WITH A TEMPERATURE SENSOR/TRANSMITTER AND LOCAL TEMPERATURE INDICATION. #THE CHILLED WATER TEMPERATURE SHALL BE MAINTAINED BETWEEN 20°C AND 22°C AT ALL TIMES. ##IN CASE THE WATER TEMPERATURE EXCEEDS THE PRESET UPPER LIMIT, THE CONTROL SYSTEM SHALL AUTOMATICALLY START THE RECIRCULATION SYSTEM AND OPERATE THE CHILLER TO RESTORE THE WATER TEMPERATURE TO THE REQUIRED RANGE. #ALL CHILLED WATER PIPING, FITTINGS AND VALVES SHALL BE PROPERLY INSULATED WITH UV RESISTANT OUTDOOR CLADDING. #TESTING,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMMISSIONING, AND DEMONSTRATION OF THE COMPLETE SYSTEM TO THE SATISFACTION OF DEWA/OWNER REPRESENTATIVE. #THE BIDDER SHALL BE RESPONSIBLE FOR SITE MEASUREMENT, ENGINEERING, FABRICATION, SUPPLY OF CONSUMABLES, TOOLS, MANPOWER, TRANSPORTATION, AND ALL ACTIVITIES NECESSARY TO DELIVER A COMPLETE OPERATIONAL SYSTEM. THE BIDDER SHALL ENSURE THAT ALL SUPPLIED EQUIPMENT AND MATERIALS ARE SUITABLE FOR OUTDOOR INDUSTRIAL SERVICE CONDITIONS AND COMPLY WITH APPLICABLE INTERNATIONAL STANDARDS AND MANUFACTURER RECOMMENDATIONS.						
6		ITEM-00001	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER FOR EMERGENCY EYE WASH SYSTEM. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF A COMPLETE CHILLED WATER SYSTEM FOR THE EMERGENCY EYE WASH AND SAFETY SHOWER	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FACILITY. THE SCOPE OF WORK SHALL INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING: #SUPPLY AND INSTALLATION OF A SUITABLE WATER CHILLER UNIT COMP LE WITH ALL NECESSARY ACCESSORIES. #SUPPLY AND INSTALLATION OF A 1 M³ WATER STORAGE TANK, CHILLER ALONG WITH ALL ASSOCIATED PIPING, FITTINGS, SUPPORTS, VALVES, AND ACCESSORIES REQUIRED FOR A COMPLETE AND FUNCTIONAL SYSTEM. #SUPPLY, INSTALLATION, AND COMMISSIONING OF A WATER PUMP WITH ADEQUATE CAPACITY TO MAINTAIN THE REQUIRED FLOW AND PRESSURE TO THE EYE WASH AND SHOWER SYSTEM. #SUPPLY AND INSTALLATION OF A PRESSURE CONTROLLER/PRESSURE REGULATING SYSTEM TO ENSURE STABLE AND RELIABLE OPERATION OF THE COMPLETE SYSTEM. #PROVISION OF ALL ELECTRICAL, MECHANICAL, AND CONTROL CONNECTIONS REQUIRED FOR THE CHILLER, TANK,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PUMP, AND ASSOCIATED EQUIPMENT. #THE STORAGE TANK SHALL BE EQUIPPED WITH A TEMPERATURE SENSOR/TRANSMITTER AND LOCAL TEMPERATURE INDICATION. #THE CHILLED WATER TEMPERATURE SHALL BE MAINTAINED BETWEEN 20°C AND 22°C AT ALL TIMES. ##IN CASE THE WATER TEMPERATURE EXCEEDS THE PRESET UPPER LIMIT, THE CONTROL SYSTEM SHALL AUTOMATICALLY START THE RECIRCULATION SYSTEM AND OPERATE THE CHILLER TO RESTORE THE WATER TEMPERATURE TO THE REQUIRED RANGE. #ALL CHILLED WATER PIPING, FITTINGS AND VALVES SHALL BE PROPERLY INSULATED WITH UV RESISTANT OUTDOOR CLADDING. #TESTING, COMMISSIONING, AND DEMONSTRATION OF THE COMPLETE SYSTEM TO THE SATISFACTION OF DEWA/OWNER REPRESENTATIVE. #THE BIDDER SHALL BE RESPONSIBLE FOR SITE MEASUREMENT, ENGINEERING, FABRICATION, SUPPLY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			OF CONSUMABLES, TOOLS, MANPOWER, TRANSPORTATION, AND ALL ACTIVITIES NECESSARY TO DELIVER A COMPLETE OPERATIONAL SYSTEM. THE BIDDER SHALL ENSURE THAT ALL SUPPLIED EQUIPMENT AND MATERIALS ARE SUITABLE FOR OUTDOOR INDUSTRIAL SERVICE CONDITIONS AND COMPLY WITH APPLICABLE INTERNATIONAL STANDARDS AND MANUFACTURER RECOMMENDATIONS.						
7		ITEM-00001	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER FOR EMERGENCY EYE WASH SYSTEM. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF A COMPLETE CHILLED WATER SYSTEM FOR THE EMERGENCY EYE WASH AND SAFETY SHOWER FACILITY. THE SCOPE OF WORK SHALL INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING: - SUPPLY AND INSTALLATION OF A SUITABLE WATER CHILLER UNIT - COMPLETE WITH ALL NECESSARY	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ACCESSORIES.#SUPPLY AND INSTALLATION OF A 1 M³ WATER STORAGE TANK, CHILLER ALONGWITH ALL ASSOCIATED PIPING, FITTINGS, SUPPORTS, VALVES, AND ACCESSORIESREQUIRED FOR A COMPLETE AND FUNCTIONAL SYSTEM.#SUPPLY, INSTALLATION, AND COMMISSIONING O F A WATER PUMP WITH ADEQUATECAPACITY TO MAINTAIN THE REQUIRED FLOW AND PRESSURE TO THE EYEWASH ANDSHOWER SYSTEM.#SUPPLY AND INSTALL ATION OF A PRESSURE CONTROLLER/PRESSURE REGULATINGSYSTEM TO ENSURE STABLE AND RELIABLE OPERATION OF THE COMPLETE SYSTEM.#PROVISION OF ALL ELECTRICAL, MECHANICAL, AND CONTROL CONNECTIONSREQUIRED FOR THE CHILLER, TANK, PUMP, AND ASSOCIATED EQUIPMENT.#THE STORAGE T ANK SHALL BE EQUIPPED WITH A TEMPERATURESENSOR/TRANSMITTER AND LOCAL TEMPERATURE INDICATION.#THE CHILLED WATER TEMPERATURE SHALL BE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MAINTAINED BETWEEN 20°C AND 22°C AT ALL TIMES. ##IN CASE THE WATER TEMPERATURE EXCEEDS THE PRESET UPPER LIMIT, THE CONTROL SYSTEM SHALL AUTOMATICALLY START THE RECIRCULATION SYSTEM AND OPERATE THE CHILLER TO RESTORE THE WATER TEMPERATURE TO THE REQUIRED RANGE. #ALL C HILLED WATER PIPING, FITTINGS AND VALVES SHALL BE PROPERLY INSULATED WITH UV RESISTANT OUTDOOR CLADDING. #TESTING, COMMISSIONING, AND DEMONSTRATION OF THE COMPLETE SYSTEM TO THE SATISFACTION OF DEWA/OWNER REPRESENTATIVE. #THE BIDDER SHALL BE RESPONSIBLE FOR SITE MEASUREMENT, ENGINEERING, FABRICATION, SUPPLY OF CONSUMABLES, TOOLS, MANPOWER, TRANSPORTATION, AND ALL ACTIVITIES NECESSARY TO DELIVER A COMPLETE OPERATIONAL SYSTEM. THE BIDDER SHALL ENSURE THAT ALL SUPPLIED EQUIPMENT AND MATERIALS ARE SUITABLE FOR OUTDOOR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INDUSTRIAL SERVICE CONDITIONS AND COMPLY WITH APPLICABLE INTERNATIONAL STANDARDS AND MANUFACTURER RECOMMENDATIONS.						
8		ITEM-00001	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER FOR EMERGENCY EYEWASH SYSTEM THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF A COMPLETE CHILLED WATER SYSTEM FOR THE EMERGENCY EYEWASH AND SAFETY SHOWER FACILITY. THE SCOPE OF WORK SHALL INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING: #SUPPLY AND INSTALLATION OF A SUITABLE WATER CHILLER UNIT COMPLETE WITH ALL NECESSARY ACCESSORIES. #SUPPLY AND INSTALLATION OF A 1 M ³ WATER STORAGE TANK, CHILLER ALONG WITH ALL ASSOCIATED PIPING, FITTINGS, SUPPORTS, VALVES, AND ACCESSORIES REQUIRED FOR A COMPLETE AND FUNCTIONAL SYSTEM. #SUPPLY, INSTALLATION,	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND COMMISSIONING OF A WATER PUMP WITH ADEQUATE CAPACITY TO MAINTAIN THE REQUIRED FLOW AND PRESSURE TO THE EYEWASH AND SHOWER SYSTEM. #SUPPLY AND INSTALLATION OF A PRESSURE CONTROLLER/PRESSURE REGULATING SYSTEM TO ENSURE STABLE AND RELIABLE OPERATION OF THE COMPLETE SYSTEM. #PROVISION OF ALL ELECTRICAL, MECHANICAL, AND CONTROL CONNECTIONS REQUIRED FOR THE CHILLER, TANK, PUMP, AND ASSOCIATED EQUIPMENT. #THE STORAGE TANK SHALL BE EQUIPPED WITH A TEMPERATURE SENSOR/TRANSMITTER AND LOCAL TEMPERATURE INDICATION. #THE CHILLED WATER TEMPERATURE SHALL BE MAINTAINED BETWEEN 20°C AND 22°C AT ALL TIMES. ##IN CASE THE WATER TEMPERATURE EXCEEDS THE PRESET UPPER LIMIT, THE CONTROL SYSTEM SHALL AUTOMATICALLY START THE RECIRCULATION SYSTEM AND OPERATE THE CHILLER TO RESTORE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE WATER TEMPERATURE TO THE REQUIRED RANGE. #ALL C HILLED WATER PIPING, FITTINGS AND VALVES SHALL BE PROPERLY INSULATED WITH UV RESISTANT OUTDOOR CLADDING. #TESTING, COMMISSIONING, AND DEMONSTRATION OF THE COMPLETE SYSTEM TO THE SATISFACTION OF DEWA/OWNER REPRESENTATIVE. #THE BIDDER SHALL BE RESPONSIBLE FOR SITE MEASUREMENT, ENGINEERING, FABRICATION, SUPPLY OF CONSUMABLES, TOOLS, MANPOWER, TRANSPORTATION, AND ALL ACTIVITIES NECESSARY TO DELIVER A COMPLETE OPERATIONAL SYSTEM. THE BIDDER SHALL ENSURE THAT ALL SUPPLIED EQUIPMENT AND MATERIALS ARE SUITABLE FOR OUTDOOR INDUSTRIAL SERVICE CONDITIONS AND COMPLY WITH APPLICABLE INTERNATIONAL STANDARDS AND MANUFACTURER RECOMMENDATIONS.						
9		ITEM-00001	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER FOR	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EMERGENCYEYEWASH SYSTEMTHE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF A COMPLETE CHILLED WATER SYSTEM FOR THEEMERGENCY EYEWASH AND SAFETY SHOWER FACILITY. THE SCOPE OF WORK SHALLINCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING: #SUPPLY AND INSTALLATION OF A SUITABLE WATER CHILLER UNIT COMP LETEWITH ALL NECESSARY ACCESSORIES. #SUPPLY AND INSTALLATION OF A 1 M³ WATER STORAGE TANK, CHILLER ALONGWITH ALL ASSOCIATED PIPING, FITTINGS, SUPPORTS, VALVES, AND ACCESSORIESREQUIRED FOR A COMPLETE AND FUNCTIONAL SYSTEM. #SUPPLY, INSTALLATION, AND COMMISSIONING O F A WATER PUMP WITH ADEQUATECAPACITY TO MAINTAIN THE REQUIRED FLOW AND PRESSURE TO THE EYEWASH ANDSHOWER SYSTEM. #SUPPLY AND INSTALL ATION OF A PRESSURE CONTROLLER/PRESSURE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REGULATING SYSTEM TO ENSURE STABLE AND RELIABLE OPERATION OF THE COMPLETE SYSTEM. #PROVISION OF ALL ELECTRICAL, MECHANICAL, AND CONTROL CONNECTIONS REQUIRED FOR THE CHILLER, TANK, PUMP, AND ASSOCIATED EQUIPMENT. #THE STORAGE TANK SHALL BE EQUIPPED WITH A TEMPERATURE SENSOR/TRANSMITTER AND LOCAL TEMPERATURE INDICATION. #THE CHILLED WATER TEMPERATURE SHALL BE MAINTAINED BETWEEN 20°C AND 22°C AT ALL TIMES. ##IN CASE THE WATER TEMPERATURE EXCEEDS THE PRESET UPPER LIMIT, THE CONTROL SYSTEM SHALL AUTOMATICALLY START THE RECIRCULATION SYSTEM AND OPERATE THE CHILLER TO RESTORE THE WATER TEMPERATURE TO THE REQUIRED RANGE. #ALL CHILLED WATER PIPING, FITTINGS AND VALVES SHALL BE PROPERLY INSULATED WITH UV RESISTANT OUTDOOR CLADDING. #TESTING, COMMISSIONING, AND						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEMONSTRATION OF THE COMPLETE SYSTEM TO THE SATISFACTION OF DEWA/OWNER REPRESENTATIVE. #THE BIDDER SHALL BE RESPONSIBLE FOR SITE MEASUREMENT, ENGINEERING, FABRICATION, SUPPLY OF CONSUMABLES, TOOLS, MANPOWER, TRANSPORTATION, AND ALL ACTIVITIES NECESSARY TO DELIVER A COMPLETE OPERATIONAL SYSTEM. THE BIDDER SHALL ENSURE THAT ALL SUPPLIED EQUIPMENT AND MATERIALS ARE SUITABLE FOR OUTDOOR INDUSTRIAL SERVICE CONDITIONS AND COMPLY WITH APPLICABLE INTERNATIONAL STANDARDS AND MANUFACTURER RECOMMENDATIONS.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

G Station Desalination units auxiliary plant eye washer chiller installation work.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

Contact mohammad.rafi@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.
- 2) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 3) Quotation to be submitted only in local currency U.A.E Dirhams
- 4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.
- 5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page26 of 29

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8) Data Privacy, Security and Sharing:

- a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
- b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
- c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
- d) DEWA reserves the right to withhold data from third parties if deemed sensitive.
- e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
- f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA's authorized data owner written approval.
- g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA's data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:

If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2332602609
DATE : 12.10.2026
REQ No : 1032604393
REQ TITLE : G Station Desalination units
DELIVERY LOCATION
CLOSING DATE : 16.10.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP