REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	#TECHNICAL AND GENERAL SPECIFICATIONS -OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#IN SERVICE EXTERNAL INTEGRITY INS PECTION OF ABOVE GROUNDSTORAGE TANKS (DFO & WATER) IN JAPS L1 STATION. WO (511387437)PERIOD OF WORK:##10 DAYS AFTER RECEIVING POPRE- BID SITE INSPECTION:·#THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THEWORK SCOPE, PLANT ACCESS, FACILITIES, AND COMPLEXITIES BEFORE SUBMITTINGTHE BID. DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL COSTS BEYOND THEAGREED RATES/PRICES DURING AN D AFTER THE EXECUTION OF THE WORK.QUALIFICATION OF BIDDER:·#THE BIDDER MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OROTHER WELL-KNOWN COMPANIES.·#ALL INSPECTIONS MUST BE CONDUCTED BY AN AUTHORIZED API INSPECTOR.·#ALL NDE REQUIREMENTS MUST BE	2	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CARRIED OUT BY AN EIAC ACCREDITEDCONTRACTOR.·#PERSONNEL PERFORMING NDE SHALL MEET THE QUALIFICATIONS IDENTIFIED ASASME V AND API 510. THE RESULT S OF ANY NDE WORK MUST BE CONSIDERED INTHE EVALUATION OF THE TANK BY AN AUTHORIZED INSPECTOR.SCOPE OF WORK1.#GENERAL·#ALL TANKS INCL UDED IN THIS SCOPE OF WORK HAVE PREVIOUSLY UNDERGONEINTEGRITY INSPECTION AND REMAINING LIFE ASSESSMENT (RLA). THIS PR/RFXCOVERS THE SUBSEQUENT EXTERNAL IN-SERVICE INSPECTION AND INTEGRITYASSESSMENT ONLY.·#PRIOR TO BID SUBMISSION, THE CONTRACTOR SHALL REVIEW ALL PR EVIOUSINTEGRITY INSPECTION/RLA REPORTS AND DETERMINE NDE (IF REQUIRED) INACCORDANCE WITH THE APPLICABLE CODE (API 653 / API 510). TH ECONTRACTOR#S BID SHALL INCLUDE ALL NDE CONSIDERED NECESSARY TO COMPLETETHE						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SPECIFIED INSPECTION AND INTEGRITY ASSESSMENT. ANY NDE S UBSEQUENTLYDETERMINED TO BE REQUIRED BASED ON INFORMATION AVAILABLE IN THE PREVIOUSREPORTS SHALL BE DEEMED INCLUDED IN THE QUOTED PR ICE, AND NO ADDITIONALCOST CLAIM SHALL BE ENTERTAINED.·#THE CONTRACTOR SHALL CARRY OUT EXTERNAL IN-SERVICE INSPECTION ANDINTEGRITY A SSESSMENT OF THE IDENTIFIED TANKS/PRESSURE VESSELS INACCORDANCE WITH THE APPLICABLE REQUIREMENTS OF:O#API 653 FOR ATMOSPHERIC STORAG E TANKS.O#API 510 FOR PRESSURE VESSELS.·#THE INSPECTION AND INTEGRITY ASSESSMENT SHALL BE PERFORMED/SUPERVISEDBY A VALID API 653 AUT HORIZED INSPECTOR OR API 510 AUTHORIZED PRESSUREVESSEL INSPECTOR, AS APPLICABLE.·#QUALIFIED NDE PERSONNEL AND ALL REQUIRED CALIBRATE D INSPECTION/NDEEQUIPMENT, TOOLS, ACCESS						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EQUIPMENT, PPE AND CONSUMABLES SHALL BEPROVIDED BY THE CONTRACTOR.2.#DOCUMENT REVIEW AND IT P·#PRIOR TO INSPECTION, THE CONTRACTOR SHALL REVIEW AVAILABLE EQUIPMENTINFORMATION INCLUDING DESIGN/FABRICATION DATA, DRAWINGS, MATE RIALS OFCONSTRUCTION, DESIGN/OPERATING CONDITIONS, SERVICE HISTORY, PREVIOUSINTEGRITY INSPECTION/NDE/THICKNESS RECORDS AND REPAIR/AL TERATIONHISTORY. MISSING DATA AND ASSUMPTIONS/LIMITATIONS AFFECTING THEASSESSMENT SHALL BE IDENTIFIED IN THE REPORT.·#THE CONTRACTOR SHALL PREPARE AND SUBMIT AN INSPECTION AND TESTPLAN/PROTOCOL (ITP) COVERING ALL APPLICABLE ACCESSIBLE COMPONENTS,EXTERNAL VISUAL EX AMINATION, CML/TML LOCATIONS, NDE METHODS(IF REQUIRED)AND APPLICABLE ACCEPTANCE/EVALUATION CRITERIA.3.#EXTERNAL VISUAL INSPECTION·#A					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COMPREHENSIVE EXTERNAL VISUAL INSPECTION OF ALL ACCESSIBLECOMPONENTS WITHIN THE APPLICABLE API 510/API 653 EQUIPMENT BOUNDARYSHALL BE CARRIED OUT FOR:##LEAKAGE OR SEEPAGE.##GENERAL/LOCALIZED CORROSION AND PITTING.##CRACKING OR SUSPECTED CRACKING.##DEFORMATION, BU LGING, BUCKLING AND MECHANICAL DAMAGE.##EXTERNAL WELD CONDITION.##SHELL/BODY, HEADS/ROOF AND ATTACHMENTS.##NOZZLES, MANWAYS AND REIN FORCEMENT AREAS.##COATING/PAINTING AND INSULATION/CLADDING CONDITION, WHERE APPLICABLE.##SUPPORTS, ANCHORAGES AND ASSOCIATED STRUCTU RAL COMPONENTS.##THE CONDITION AND FUNCTIONAL OF HEAT DETECTORS, FLAME DETECTORS ANDALARM SYSTEM EQUIPMENT SHALL BE CHECKED THOROUGH LY.##INSPECTION OF CP SYSTEM & EARTHLING TERMINAL.##LEVEL INDICATOR, VALVES AND OTHER TANK RELATED EQUIPMENT						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSPECTION·#AREAS THAT ARE INACCESSIBLE OR NOT INSPECTED SHALL BE CLEARLYIDENTIFIED IN THE FINAL REPORT TOGETHER WITH THE REASON.4.#API 653 SPECIFIC REQUIR EMENTS·#FOR EQUIPMENT ASSESSED UNDER API 653, THE EXTERNAL INSPECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##FOUNDATION CONDITIO N AND EVIDENCE OF SETTLEMENT/DIFFERENTIALSETTLEMENT.##SHELL -TO-BOTTOM JUNCTION.##ACCESSIBLE BOTTOM/ANNULAR PLATE PROJECTION OR TANK CHIME.##ROOF AND ROOF-TO-SHELL JUNCTION.##NOZZLES, MANWAYS, LADDERS, PLATFORMS AND OTHER TANK APPURTENANCES.##EVIDENCE OF LEAKAGE, F OUNDATION DETERIORATION OR SHELL DISTORTION.·#A DETAILED SETTLEMENT SURVEY SHALL BE PERFORMED OR RECOMMENDED WHEREWARRANTED BY OBSER VED CONDITIONS OR AVAILABLE HISTORICAL DATA.5.#API 510 SPECIFIC REQUIREMENTS·#FOR						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EQUIPMENT ASSESSED UNDER API 510, THE EXTERNAL INS PECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##PRESSURE-RETAINING SHELL/BODY AND HEADS.##PRESSURE-BOUNDARY WELDS.##NOZZLES AND R EINFORCEMENT AREAS.##SUPPORTS, SKIRTS, SADDLES, LEGS AND ANCHORAGES.##EVIDENCE OF LEAKAGE, DEFORMATION OR DETERIORATION AFFECTING PR ESSUREINTEGRITY.##VERIFICATION OF APPLICABLE PRESSURE-RELIEVING DEVICE IDENTIFICATIONAND REVIEW OF AVAILABLE SET-PRESSURE/CERTIFICAT ION INFORMATION AGAINSTEQUIPMENT DESIGN/MAWP REQUIREMENTS.6.#CML/TML AND NDE (IF REQUIRED AS PER THE APPLICABLE INSPECTION CODE)·#EX ISTING CML/TML LOCATIONS SHALL BE REVIEWED AND RETAINED, WHEREPRACTICABLE, FOR THICKNESS TRENDING. ADDITIONAL LOCATIONS SHALL BESELE CTED BASED ON EQUIPMENT GEOMETRY,						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SERVICE, HISTORICAL DETERIORATIONAND OBSERVED/SUSPECTED DEGRADATION.·#UT THICKNESS MEASUREMENTS SH ALL BE PERFORMED AT THE ESTABLISHEDCML/TML LOCATIONS AND ADDITIONAL SUSPECT AREAS.·#WHERE REQUIRED BY INSPECTION FINDINGS, APPROPRIA TE ADDITIONAL NDESUCH AS PT, MT AND/OR UT SCANNING SHALL BE PERFORMED TO CHARACTERIZERELEVANT INDICATIONS.·#A MARKED-UP DRAWING/SKET CH SHOWING UNIQUELY IDENTIFIED CML/TMLLOCATIONS SHALL BE PROVIDED.7.#INTEGRITY AND FFS ASSESSMENT·#THE API AUTHORIZED INSPECTOR SHAL L EVALUATE THE INSPECTION/NDERESULTS (IF CARRIED OUT) IN ACCORDANCE WITH THE APPLICABLE API 510/API653 REQUIREMENTS AND DETERMINE, A S APPLICABLE:##ACTUAL MEASURED THICKNESS##METAL LOSS.##MINIMUM REQUIRED/ACCEPTABLE					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THICKNESS.##CORROSION RATE BASED ON RELIABLE AVAI LABLE DATA.##SUITABILITY FOR CONTINUED SERVICE.##FOR API 510 EQUIPMENT, CONTINUED SUITABILITY AT THE APPLICABLEDESIGN/OPERATING PRES SURE OR MAWP.·#WHERE SUFFICIENT HISTORICAL DATA ARE UNAVAILABLE FOR RELIABLECORROSION-RATE/RLA CALCULATION, THE LIMITATION AND ASSES SMENT BASISSHALL BE CLEARLY DOCUMENTED.8.#FINDINGS AND RECOMMENDATIONS·#ANY CONDITION THAT MAY AFFECT EQUIPMENT INTEGRITY OR SAFE OP ERATIONSHALL BE IMMEDIATELY NOTIFIED TO THE DEWA ENGINEER.·#THE API AUTHORIZED INSPECTOR SHALL PROVIDE RECOMMENDATIONS, ASAPPLICABLE , FOR:##REPAIR/CORRECTIVE ACTION.##ADDITIONAL NDE.##ENGINEERING/FITNESS-FOR-SERVICE EVALUATION.##CONDITION MONITORING.##FURTHER INTE						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RNAL INSPECTION OR SHUTDOWN EXAMINATION WHERE EXTERNALINSPECTION IS INSUFFICIENT.9.#NEXT INSPECTION INTERVAL·#THE CONTRACTOR/API AUT HORIZED INSPECTOR SHALL DETERMINE AND RECOMMENDTHE NEXT APPLICABLE INSPECTION DUE DATE/INTERVAL BASED ON THE RELEVANTAPI 510/API 653 REQUIREMENTS, EQUIPMENT CONDITION, MEASURED THICKNESS,CORROSION RATE AND AVAILABLE INTEGRITY INSPECTION HISTORY.·#THE BASIS FOR EST ABLISHING THE RECOMMENDED INSPECTION INTERVAL SHALLBE INCLUDED IN THE FINAL REPORT.10.#INSPECTION REPORT·#THE CONTRACTOR SHALL SUBMI T A FINAL EXTERNAL IN-SERVICE INSPECTIONREPORT FOR EACH EQUIPMENT ITEM, INCLUDING AS A MINIMUM:##EQUIPMENT IDENTIFICATION/KKS AND AP PLICABLE INSPECTION CODE.##DEWA - TANK IN SERVICE INSPECTION CHECKLIST.##INSPECTION DATE, INSPECTION TYPE AND SCOPE.##DESIGN					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND SER VICE INFORMATION REVIEWED.##INSPECTION LIMITATIONS AND INACCESSIBLE/UNINSPECTED AREAS.##EXTERNAL INSPECTION CHECKLIST AND FINDINGS.# #CML/TML LOCATION DRAWING AND UT READINGS (IF NDE CARRIED OUT)##PHOTOGRAPHS OF SIGNIFICANT FINDINGS.##APPLICABLE NDE REPORTS. (IF ND E CARRIED OUT)##MINIMUM REQUIRED/ACCEPTABLE THICKNESS ASSESSMENT.##CORROSION-R						
2		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS -OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#IN SERVICE EXTERNAL INTEGRITY INSP ECTION OF ABOVE GROUNDSTORAGE TANKS (DFO & WATER) IN JAPS L1 STATION. WO (511387437)PERIOD OF WORK:##10 DAYS AFTER RECEIVING POPRE-B ID SITE INSPECTION:·#THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THEWORK SCOPE, PLANT ACCESS, FACILITIES,	1	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND COMPLEXITIES BEFORE SUBMITTINGTHE BID. DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL COSTS BEYOND THEAGREED RATES/PRICES DURING AND AFTER THE EXECUTION OF THE WORK.QUALIFICATION OF BIDDER:·#THE BIDDER MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OROTHER WELL-KNOWN COMPANIES.·#ALL INSPECTIONS MUST BE CONDUCTED BY AN AUTHORIZED API INSPECTOR.·#ALL NDE REQUIREMENTS MUST BE CARRIED OUT B Y AN EIAC ACCREDITEDCONTRACTOR.·#PERSONNEL PERFORMING NDE SHALL MEET THE QUALIFICATIONS IDENTIFIED ASASME V AND API 510. THE RESULTS OF ANY NDE WORK MUST BE CONSIDERED INTHE EVALUATION OF THE TANK BY AN AUTHORIZED INSPECTOR.SCOPE OF WORK1.#GENERAL·#ALL TANKS INCLU DED IN THIS SCOPE OF WORK HAVE PREVIOUSLY						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			UNDERGONEINTEGRITY INSPECTION AND REMAINING LIFE ASSESSMENT (RLA). THIS PR/RFXCOVERS THE S UBSEQUENT EXTERNAL IN-SERVICE INSPECTION AND INTEGRITYASSESSMENT ONLY.·#PRIOR TO BID SUBMISSION, THE CONTRACTOR SHALL REVIEW ALL PRE VIOUSINTEGRITY INSPECTION/RLA REPORTS AND DETERMINE NDE (IF REQUIRED) INACCORDANCE WITH THE APPLICABLE CODE (API 653 / API 510). THE CONTRACTOR#S BID SHALL INCLUDE ALL NDE CONSIDERED NECESSARY TO COMPLETETHE SPECIFIED INSPECTION AND INTEGRITY ASSESSMENT. ANY NDE SU BSEQUENTLYDETERMINED TO BE REQUIRED BASED ON INFORMATION AVAILABLE IN THE PREVIOUSREPORTS SHALL BE DEEMED INCLUDED IN THE QUOTED PRI CE, AND NO ADDITIONALCOST CLAIM SHALL BE ENTERTAINED.·#THE CONTRACTOR SHALL CARRY OUT EXTERNAL IN-SERVICE INSPECTION ANDINTEGRITY AS						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SESSMENT OF THE IDENTIFIED TANKS/PRESSURE VESSELS INACCORDANCE WITH THE APPLICABLE REQUIREMENTS OF:O#API 653 FOR ATMOSPHERIC STORAGE TANKS.O#API 510 FOR PRESSURE VESSELS.·#THE INSPECTION AND INTEGRITY ASSESSMENT SHALL BE PERFORMED/SUPERVISEDBY A VALID API 653 AUTH ORIZED INSPECTOR OR API 510 AUTHORIZED PRESSUREVESSEL INSPECTOR, AS APPLICABLE.·#QUALIFIED NDE PERSONNEL AND ALL REQUIRED CALIBRATED INSPECTION/NDEEQUIPMENT, TOOLS, ACCESS EQUIPMENT, PPE AND CONSUMABLES SHALL BEPROVIDED BY THE CONTRACTOR.2.#DOCUMENT REVIEW AND ITP ·#PRIOR TO INSPECTION, THE CONTRACTOR SHALL REVIEW AVAILABLE EQUIPMENTINFORMATION INCLUDING DESIGN/FABRICATION DATA, DRAWINGS, MATER IALS OFCONSTRUCTION, DESIGN/OPERATING CONDITIONS, SERVICE HISTORY, PREVIOUSINTEGRITY INSPECTION/NDE/THICKNESS					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			RECORDS AND REPAIR/ALT ERATIONHISTORY. MISSING DATA AND ASSUMPTIONS/LIMITATIONS AFFECTING THEASSESSMENT SHALL BE IDENTIFIED IN THE REPORT.·#THE CONTRACTOR SHALL PREPARE AND SUBMIT AN INSPECTION AND TESTPLAN/PROTOCOL (ITP) COVERING ALL APPLICABLE ACCESSIBLE COMPONENTS,EXTERNAL VISUAL EXA MINATION, CML/TML LOCATIONS, NDE METHODS(IF REQUIRED)AND APPLICABLE ACCEPTANCE/EVALUATION CRITERIA.3.#EXTERNAL VISUAL INSPECTION·#A COMPREHENSIVE EXTERNAL VISUAL INSPECTION OF ALL ACCESSIBLECOMPONENTS WITHIN THE APPLICABLE API 510/API 653 EQUIPMENT BOUNDARYSHALL B E CARRIED OUT FOR:##LEAKAGE OR SEEPAGE.##GENERAL/LOCALIZED CORROSION AND PITTING.##CRACKING OR SUSPECTED CRACKING.##DEFORMATION, BUL GING, BUCKLING AND MECHANICAL DAMAGE.##EXTERNAL WELD						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONDITION.##SHELL/BODY, HEADS/ROOF AND ATTACHMENTS.##NOZZLES, MANWAYS AND REINF ORCEMENT AREAS.##COATING/PAINTING AND INSULATION/CLADDING CONDITION, WHERE APPLICABLE.##SUPPORTS, ANCHORAGES AND ASSOCIATED STRUCTUR AL COMPONENTS.##THE CONDITION AND FUNCTIONAL OF HEAT DETECTORS, FLAME DETECTORS ANDALARM SYSTEM EQUIPMENT SHALL BE CHECKED THOROUGHL Y.##INSPECTION OF CP SYSTEM & EARTHLING TERMINAL.##LEVEL INDICATOR, VALVES AND OTHER TANK RELATED EQUIPMENT INSPECTION·#AREAS THAT A RE INACCESSIBLE OR NOT INSPECTED SHALL BE CLEARLYIDENTIFIED IN THE FINAL REPORT TOGETHER WITH THE REASON.4.#API 653 SPECIFIC REQUIRE MENTS·#FOR EQUIPMENT ASSESSED UNDER API 653, THE EXTERNAL INSPECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##FOUNDATION CONDITION AND EVIDENCE OF						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SETTLEMENT/DIFFERENTIALSETTLEMENT.##SHELL -TO-BOTTOM JUNCTION.##ACCESSIBLE BOTTOM/ANNULAR PLATE PROJECTION OR TANK C HIME.##ROOF AND ROOF-TO-SHELL JUNCTION.##NOZZLES, MANWAYS, LADDERS, PLATFORMS AND OTHER TANK APPURTENANCES.##EVIDENCE OF LEAKAGE, FO UNDATION DETERIORATION OR SHELL DISTORTION.·#A DETAILED SETTLEMENT SURVEY SHALL BE PERFORMED OR RECOMMENDED WHEREWARRANTED BY OBSERV ED CONDITIONS OR AVAILABLE HISTORICAL DATA.5.#API 510 SPECIFIC REQUIREMENTS·#FOR EQUIPMENT ASSESSED UNDER API 510, THE EXTERNAL INSP ECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##PRESSURE-RETAINING SHELL/BODY AND HEADS.##PRESSURE-BOUNDARY WELDS.##NOZZLES AND RE INFORCEMENT AREAS.##SUPPORTS, SKIRTS, SADDLES, LEGS AND ANCHORAGES.##EVIDENCE OF LEAKAGE, DEFORMATION OR DETERIORATION AFFECTING PRE					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SSUREINTEGRITY.##VERIFICATION OF APPLICABLE PRESSURE-RELIEVING DEVICE IDENTIFICATIONAND REVIEW OF AVAILABLE SET-PRESSURE/CERTIFICATI ON INFORMATION AGAINSTEQUIPMENT DESIGN/MAWP REQUIREMENTS.6.#CML/TML AND NDE (IF REQUIRED AS PER THE APPLICABLE INSPECTION CODE)·#EXI STING CML/TML LOCATIONS SHALL BE REVIEWED AND RETAINED, WHEREPRACTICABLE, FOR THICKNESS TRENDING. ADDITIONAL LOCATIONS SHALL BESELEC TED BASED ON EQUIPMENT GEOMETRY, SERVICE, HISTORICAL DETERIORATIONAND OBSERVED/SUSPECTED DEGRADATION.·#UT THICKNESS MEASUREMENTS SHA LL BE PERFORMED AT THE ESTABLISHEDCML/TML LOCATIONS AND ADDITIONAL SUSPECT AREAS.·#WHERE REQUIRED BY INSPECTION FINDINGS, APPROPRIAT E ADDITIONAL NDESUCH AS PT, MT AND/OR UT SCANNING SHALL BE PERFORMED TO CHARACTERIZERELEVANT INDICATIONS.·#A						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MARKED-UP DRAWING/SKETCH SHOWING UNIQUELY IDENTIFIED CML/TMLLOCATIONS SHALL BE PROVIDED.7.#INTEGRITY AND FFS ASSESSMENT·#THE API AUTHORIZED INSPECTOR SHALL EVALUATE THE INSPECTION/NDERESULTS (IF CARRIED OUT) IN ACCORDANCE WITH THE APPLICABLE API 510/API653 REQUIREMENTS AND DETERMINE, AS APPLICABLE:##ACTUAL MEASURED THICKNESS##METAL LOSS.##MINIMUM REQUIRED/ACCEPTABLE THICKNESS.##CORROSION RATE BASED ON RELIABLE AVAILABLE DATA.##SUITABILITY FOR CONTINUED SERVICE.##FOR API 510 EQUIPMENT, CONTINUED SUITABILITY AT THE APPLICABLEDESIGN/OPERATING PRESSURE OR MAWP.·#WHERE SUFFICIENT HISTORICAL DATA ARE UNAVAILABLE FOR RELIABLECORROSION-RATE/RLA CALCULATION, THE LIMITATION AND ASSESS						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MENT BASISSHALL BE CLEARLY DOCUMENTED.8.#FINDINGS AND RECOMMENDATIONS·#ANY CONDITION THAT MAY AFFECT EQUIPMENT INTEGRITY OR SAFE OPE RATIONSHALL BE IMMEDIATELY NOTIFIED TO THE DEWA ENGINEER.·#THE API AUTHORIZED INSPECTOR SHALL PROVIDE RECOMMENDATIONS, ASAPPLICABLE, FOR:##REPAIR/CORRECTIVE ACTION.##ADDITIONAL NDE.##ENGINEERING/FITNESS-FOR-SERVICE EVALUATION.##CONDITION MONITORING.##FURTHER INTER NAL INSPECTION OR SHUTDOWN EXAMINATION WHERE EXTERNALINSPECTION IS INSUFFICIENT.9.#NEXT INSPECTION INTERVAL·#THE CONTRACTOR/API AUTH ORIZED INSPECTOR SHALL DETERMINE AND RECOMMENDTHE NEXT APPLICABLE INSPECTION DUE DATE/INTERVAL BASED ON THE RELEVANTAPI 510/API 653 REQUIREMENTS, EQUIPMENT CONDITION, MEASURED THICKNESS,CORROSION RATE AND					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AVAILABLE INTEGRITY INSPECTION HISTORY.·#THE BASIS FOR ESTA BLISHING THE RECOMMENDED INSPECTION INTERVAL SHALLBE INCLUDED IN THE FINAL REPORT.10.#INSPECTION REPORT·#THE CONTRACTOR SHALL SUBMIT A FINAL EXTERNAL IN-SERVICE INSPECTIONREPORT FOR EACH EQUIPMENT ITEM, INCLUDING AS A MINIMUM:##EQUIPMENT IDENTIFICATION/KKS AND APP LICABLE INSPECTION CODE.##DEWA - TANK IN SERVICE INSPECTION CHECKLIST.##INSPECTION DATE, INSPECTION TYPE AND SCOPE.##DESIGN AND SERV ICE INFORMATION REVIEWED.##INSPECTION LIMITATIONS AND INACCESSIBLE/UNINSPECTED AREAS.##EXTERNAL INSPECTION CHECKLIST AND FINDINGS.## CML/TML LOCATION DRAWING AND UT READINGS (IF NDE CARRIED OUT)##PHOTOGRAPHS OF SIGNIFICANT FINDINGS.##APPLICABLE NDE REPORTS. (IF NDE CARRIED OUT)##MINIMUM						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REQUIRED/ACCEPTABLE THICKNESS ASSESSMENT.##CORROSION-RATE,						
3		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS -OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#IN SERVICE EXTERNAL INTEGRITY INSP ECTION OF ABOVE GROUNDSTORAGE TANKS (DFO & WATER) IN JAPS L1 STATION. WO (511387437)PERIOD OF WORK:##10 DAYS AFTER RECEIVING POPRE-B ID SITE INSPECTION:·#THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THEWORK SCOPE, PLANT ACCESS, FACILITIES, AND COMPLEXITIES BEFORE SUBMITTINGTHE BID. DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL COSTS BEYOND THEAGREED RATES/PRICES DURING AND AFTER THE EXECUTION OF THE WORK.QUALIFICATION OF BIDDER:·#THE BIDDER MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OROTHER WELL-KNOWN COMPANIES.·#ALL INSPECTIONS	2	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MUST BE CONDUCTED BY AN AUTHORIZED API INSPECTOR.·#ALL NDE REQUIREMENTS MUST BE CARRIED OUT B Y AN EIAC ACCREDITEDCONTRACTOR.·#PERSONNEL PERFORMING NDE SHALL MEET THE QUALIFICATIONS IDENTIFIED ASASME V AND API 510. THE RESULTS OF ANY NDE WORK MUST BE CONSIDERED INTHE EVALUATION OF THE TANK BY AN AUTHORIZED INSPECTOR.SCOPE OF WORK1.#GENERAL·#ALL TANKS INCLU DED IN THIS SCOPE OF WORK HAVE PREVIOUSLY UNDERGONEINTEGRITY INSPECTION AND REMAINING LIFE ASSESSMENT (RLA). THIS PR/RFXCOVERS THE S UBSEQUENT EXTERNAL IN-SERVICE INSPECTION AND INTEGRITYASSESSMENT ONLY.·#PRIOR TO BID SUBMISSION, THE CONTRACTOR SHALL REVIEW ALL PRE VIOUSINTEGRITY INSPECTION/RLA REPORTS AND DETERMINE NDE (IF REQUIRED) INACCORDANCE WITH THE APPLICABLE CODE (API 653 / API 510).						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE CONTRACTOR#S BID SHALL INCLUDE ALL NDE CONSIDERED NECESSARY TO COMPLETETHE SPECIFIED INSPECTION AND INTEGRITY ASSESSMENT. ANY NDE SU BSEQUENTLYDETERMINED TO BE REQUIRED BASED ON INFORMATION AVAILABLE IN THE PREVIOUSREPORTS SHALL BE DEEMED INCLUDED IN THE QUOTED PRI CE, AND NO ADDITIONALCOST CLAIM SHALL BE ENTERTAINED.·#THE CONTRACTOR SHALL CARRY OUT EXTERNAL IN-SERVICE INSPECTION ANDINTEGRITY AS SESSMENT OF THE IDENTIFIED TANKS/PRESSURE VESSELS INACCORDANCE WITH THE APPLICABLE REQUIREMENTS OF:O#API 653 FOR ATMOSPHERIC STORAGE TANKS.O#API 510 FOR PRESSURE VESSELS.·#THE INSPECTION AND INTEGRITY ASSESSMENT SHALL BE PERFORMED/SUPERVISEDBY A VALID API 653 AUTH ORIZED INSPECTOR OR API 510 AUTHORIZED PRESSUREVESSEL INSPECTOR, AS						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			APPLICABLE.·#QUALIFIED NDE PERSONNEL AND ALL REQUIRED CALIBRATED INSPECTION/NDEEQUIPMENT, TOOLS, ACCESS EQUIPMENT, PPE AND CONSUMABLES SHALL BEPROVIDED BY THE CONTRACTOR.2.#DOCUMENT REVIEW AND ITP ·#PRIOR TO INSPECTION, THE CONTRACTOR SHALL REVIEW AVAILABLE EQUIPMENTINFORMATION INCLUDING DESIGN/FABRICATION DATA, DRAWINGS, MATER IALS OFCONSTRUCTION, DESIGN/OPERATING CONDITIONS, SERVICE HISTORY, PREVIOUSINTEGRITY INSPECTION/NDE/THICKNESS RECORDS AND REPAIR/ALT ERATIONHISTORY. MISSING DATA AND ASSUMPTIONS/LIMITATIONS AFFECTING THEASSESSMENT SHALL BE IDENTIFIED IN THE REPORT.·#THE CONTRACTOR SHALL PREPARE AND SUBMIT AN INSPECTION AND TESTPLAN/PROTOCOL (ITP) COVERING ALL APPLICABLE ACCESSIBLE COMPONENTS,EXTERNAL VISUAL EXA MINATION, CML/TML LOCATIONS, NDE METHODS(IF						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REQUIRED)AND APPLICABLE ACCEPTANCE/EVALUATION CRITERIA.3.#EXTERNAL VISUAL INSPECTION·#A COMPREHENSIVE EXTERNAL VISUAL INSPECTION OF ALL ACCESSIBLECOMPONENTS WITHIN THE APPLICABLE API 510/API 653 EQUIPMENT BOUNDARYSHALL B E CARRIED OUT FOR:##LEAKAGE OR SEEPAGE.##GENERAL/LOCALIZED CORROSION AND PITTING.##CRACKING OR SUSPECTED CRACKING.##DEFORMATION, BUL GING, BUCKLING AND MECHANICAL DAMAGE.##EXTERNAL WELD CONDITION.##SHELL/BODY, HEADS/ROOF AND ATTACHMENTS.##NOZZLES, MANWAYS AND REINF ORCEMENT AREAS.##COATING/PAINTING AND INSULATION/CLADDING CONDITION, WHERE APPLICABLE.##SUPPORTS, ANCHORAGES AND ASSOCIATED STRUCTUR AL COMPONENTS.##THE CONDITION AND FUNCTIONAL OF HEAT DETECTORS, FLAME DETECTORS ANDALARM SYSTEM EQUIPMENT SHALL BE CHECKED THOROUGHL						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			Y.##INSPECTION OF CP SYSTEM & EARTHLING TERMINAL.##LEVEL INDICATOR, VALVES AND OTHER TANK RELATED EQUIPMENT INSPECTION·#AREAS THAT A RE INACCESSIBLE OR NOT INSPECTED SHALL BE CLEARLYIDENTIFIED IN THE FINAL REPORT TOGETHER WITH THE REASON.4.#API 653 SPECIFIC REQUIRE MENTS·#FOR EQUIPMENT ASSESSED UNDER API 653, THE EXTERNAL INSPECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##FOUNDATION CONDITION AND EVIDENCE OF SETTLEMENT/DIFFERENTIALSETTLEMENT.##SHELL -TO-BOTTOM JUNCTION.##ACCESSIBLE BOTTOM/ANNULAR PLATE PROJECTION OR TANK C HIME.##ROOF AND ROOF-TO-SHELL JUNCTION.##NOZZLES, MANWAYS, LADDERS, PLATFORMS AND OTHER TANK APPURTENANCES.##EVIDENCE OF LEAKAGE, FO UNDATION DETERIORATION OR SHELL DISTORTION.·#A DETAILED SETTLEMENT SURVEY SHALL BE PERFORMED OR RECOMMENDED						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WHEREWARRANTED BY OBSERV ED CONDITIONS OR AVAILABLE HISTORICAL DATA.5.#API 510 SPECIFIC REQUIREMENTS·#FOR EQUIPMENT ASSESSED UNDER API 510, THE EXTERNAL INSP ECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##PRESSURE-RETAINING SHELL/BODY AND HEADS.##PRESSURE-BOUNDARY WELDS.##NOZZLES AND RE INFORCEMENT AREAS.##SUPPORTS, SKIRTS, SADDLES, LEGS AND ANCHORAGES.##EVIDENCE OF LEAKAGE, DEFORMATION OR DETERIORATION AFFECTING PRE SSUREINTEGRITY.##VERIFICATION OF APPLICABLE PRESSURE-RELIEVING DEVICE IDENTIFICATIONAND REVIEW OF AVAILABLE SET-PRESSURE/CERTIFICATI ON INFORMATION AGAINSTEQUIPMENT DESIGN/MAWP REQUIREMENTS.6.#CML/TML AND NDE (IF REQUIRED AS PER THE APPLICABLE INSPECTION CODE)·#EXI STING CML/TML LOCATIONS SHALL BE REVIEWED AND RETAINED, WHEREPRACTICABLE, FOR						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THICKNESS TRENDING. ADDITIONAL LOCATIONS SHALL BESELEC TED BASED ON EQUIPMENT GEOMETRY, SERVICE, HISTORICAL DETERIORATIONAND OBSERVED/SUSPECTED DEGRADATION.·#UT THICKNESS MEASUREMENTS SHA LL BE PERFORMED AT THE ESTABLISHEDCML/TML LOCATIONS AND ADDITIONAL SUSPECT AREAS.·#WHERE REQUIRED BY INSPECTION FINDINGS, APPROPRIAT E ADDITIONAL NDESUCH AS PT, MT AND/OR UT SCANNING SHALL BE PERFORMED TO CHARACTERIZERELEVANT INDICATIONS.·#A MARKED-UP DRAWING/SKETC H SHOWING UNIQUELY IDENTIFIED CML/TMLLOCATIONS SHALL BE PROVIDED.7.#INTEGRITY AND FFS ASSESSMENT·#THE API AUTHORIZED INSPECTOR SHALL EVALUATE THE INSPECTION/NDERESULTS (IF CARRIED OUT) IN ACCORDANCE WITH THE APPLICABLE API 510/API653 REQUIREMENTS AND DETERMINE, AS					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			APPLICABLE:##ACTUAL MEASURED THICKNESS##METAL LOSS.##MINIMUM REQUIRED/ACCEPTABLE THICKNESS.##CORROSION RATE BASED ON RELIABLE AVAIL ABLE DATA.##SUITABILITY FOR CONTINUED SERVICE.##FOR API 510 EQUIPMENT, CONTINUED SUITABILITY AT THE APPLICABLEDESIGN/OPERATING PRESS URE OR MAWP.·#WHERE SUFFICIENT HISTORICAL DATA ARE UNAVAILABLE FOR RELIABLECORROSION-RATE/RLA CALCULATION, THE LIMITATION AND ASSESS MENT BASISSHALL BE CLEARLY DOCUMENTED.8.#FINDINGS AND RECOMMENDATIONS·#ANY CONDITION THAT MAY AFFECT EQUIPMENT INTEGRITY OR SAFE OPE RATIONSHALL BE IMMEDIATELY NOTIFIED TO THE DEWA ENGINEER.·#THE API AUTHORIZED INSPECTOR SHALL PROVIDE RECOMMENDATIONS, ASAPPLICABLE, FOR:##REPAIR/CORRECTIVE ACTION.##ADDITIONAL					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NDE.##ENGINEERING/FITNESS-FOR-SERVICE EVALUATION.##CONDITION MONITORING.##FURTHER INTER NAL INSPECTION OR SHUTDOWN EXAMINATION WHERE EXTERNALINSPECTION IS INSUFFICIENT.9.#NEXT INSPECTION INTERVAL·#THE CONTRACTOR/API AUTH ORIZED INSPECTOR SHALL DETERMINE AND RECOMMENDTHE NEXT APPLICABLE INSPECTION DUE DATE/INTERVAL BASED ON THE RELEVANTAPI 510/API 653 REQUIREMENTS, EQUIPMENT CONDITION, MEASURED THICKNESS,CORROSION RATE AND AVAILABLE INTEGRITY INSPECTION HISTORY.·#THE BASIS FOR ESTA BLISHING THE RECOMMENDED INSPECTION INTERVAL SHALLBE INCLUDED IN THE FINAL REPORT.10.#INSPECTION REPORT·#THE CONTRACTOR SHALL SUBMIT A FINAL EXTERNAL IN-SERVICE INSPECTIONREPORT FOR EACH EQUIPMENT ITEM, INCLUDING AS A MINIMUM:##EQUIPMENT IDENTIFICATION/KKS AND APP						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			LICABLE INSPECTION CODE.##DEWA - TANK IN SERVICE INSPECTION CHECKLIST.##INSPECTION DATE, INSPECTION TYPE AND SCOPE.##DESIGN AND SERV ICE INFORMATION REVIEWED.##INSPECTION LIMITATIONS AND INACCESSIBLE/UNINSPECTED AREAS.##EXTERNAL INSPECTION CHECKLIST AND FINDINGS.## CML/TML LOCATION DRAWING AND UT READINGS (IF NDE CARRIED OUT)##PHOTOGRAPHS OF SIGNIFICANT FINDINGS.##APPLICABLE NDE REPORTS. (IF NDE CARRIED OUT)##MINIMUM REQUIRED/ACCEPTABLE THICKNESS ASSESSMENT.##CORROSION-RATE,						
4		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS -OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#IN SERVICE EXTERNAL INTEGRITY INSP ECTION OF ABOVE GROUNDSTORAGE TANKS (DFO & WATER) IN JAPS L1 STATION. WO (511387437)PERIOD OF WORK:##10 DAYS AFTER RECEIVING POPRE-B	2	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ID SITE INSPECTION:·#THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THEWORK SCOPE, PLANT ACCESS, FACILITIES, AND COMPLEXITIES BEFORE SUBMITTINGTHE BID. DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL COSTS BEYOND THEAGREED RATES/PRICES DURING AND AFTER THE EXECUTION OF THE WORK.QUALIFICATION OF BIDDER:·#THE BIDDER MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OROTHER WELL-KNOWN COMPANIES.·#ALL INSPECTIONS MUST BE CONDUCTED BY AN AUTHORIZED API INSPECTOR.·#ALL NDE REQUIREMENTS MUST BE CARRIED OUT B Y AN EIAC ACCREDITEDCONTRACTOR.·#PERSONNEL PERFORMING NDE SHALL MEET THE QUALIFICATIONS IDENTIFIED ASASME V AND API 510. THE RESULTS OF ANY NDE WORK MUST BE CONSIDERED INTHE EVALUATION OF THE TANK BY AN AUTHORIZED						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSPECTOR.SCOPE OF WORK1.#GENERAL·#ALL TANKS INCLU DED IN THIS SCOPE OF WORK HAVE PREVIOUSLY UNDERGONEINTEGRITY INSPECTION AND REMAINING LIFE ASSESSMENT (RLA). THIS PR/RFXCOVERS THE S UBSEQUENT EXTERNAL IN-SERVICE INSPECTION AND INTEGRITYASSESSMENT ONLY.·#PRIOR TO BID SUBMISSION, THE CONTRACTOR SHALL REVIEW ALL PRE VIOUSINTEGRITY INSPECTION/RLA REPORTS AND DETERMINE NDE (IF REQUIRED) INACCORDANCE WITH THE APPLICABLE CODE (API 653 / API 510). THE CONTRACTOR#S BID SHALL INCLUDE ALL NDE CONSIDERED NECESSARY TO COMPLETETHE SPECIFIED INSPECTION AND INTEGRITY ASSESSMENT. ANY NDE SU BSEQUENTLYDETERMINED TO BE REQUIRED BASED ON INFORMATION AVAILABLE IN THE PREVIOUSREPORTS SHALL BE DEEMED INCLUDED IN THE QUOTED PRI CE, AND NO ADDITIONALCOST CLAIM SHALL BE						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ENTERTAINED.·#THE CONTRACTOR SHALL CARRY OUT EXTERNAL IN-SERVICE INSPECTION ANDINTEGRITY AS SESSMENT OF THE IDENTIFIED TANKS/PRESSURE VESSELS INACCORDANCE WITH THE APPLICABLE REQUIREMENTS OF:O#API 653 FOR ATMOSPHERIC STORAGE TANKS.O#API 510 FOR PRESSURE VESSELS.·#THE INSPECTION AND INTEGRITY ASSESSMENT SHALL BE PERFORMED/SUPERVISEDBY A VALID API 653 AUTH ORIZED INSPECTOR OR API 510 AUTHORIZED PRESSUREVESSEL INSPECTOR, AS APPLICABLE.·#QUALIFIED NDE PERSONNEL AND ALL REQUIRED CALIBRATED INSPECTION/NDEEQUIPMENT, TOOLS, ACCESS EQUIPMENT, PPE AND CONSUMABLES SHALL BEPROVIDED BY THE CONTRACTOR.2.#DOCUMENT REVIEW AND ITP ·#PRIOR TO INSPECTION, THE CONTRACTOR SHALL REVIEW AVAILABLE EQUIPMENTINFORMATION INCLUDING DESIGN/FABRICATION DATA, DRAWINGS, MATER					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			IALS OFCONSTRUCTION, DESIGN/OPERATING CONDITIONS, SERVICE HISTORY, PREVIOUSINTEGRITY INSPECTION/NDE/THICKNESS RECORDS AND REPAIR/ALT ERATIONHISTORY. MISSING DATA AND ASSUMPTIONS/LIMITATIONS AFFECTING THEASSESSMENT SHALL BE IDENTIFIED IN THE REPORT.·#THE CONTRACTOR SHALL PREPARE AND SUBMIT AN INSPECTION AND TESTPLAN/PROTOCOL (ITP) COVERING ALL APPLICABLE ACCESSIBLE COMPONENTS,EXTERNAL VISUAL EXA MINATION, CML/TML LOCATIONS, NDE METHODS(IF REQUIRED)AND APPLICABLE ACCEPTANCE/EVALUATION CRITERIA.3.#EXTERNAL VISUAL INSPECTION·#A COMPREHENSIVE EXTERNAL VISUAL INSPECTION OF ALL ACCESSIBLECOMPONENTS WITHIN THE APPLICABLE API 510/API 653 EQUIPMENT BOUNDARYSHALL B E CARRIED OUT FOR:##LEAKAGE OR SEEPAGE.##GENERAL/LOCALIZED CORROSION AND PITTING.##CRACKING OR SUSPECTED						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CRACKING.##DEFORMATION, BUL GING, BUCKLING AND MECHANICAL DAMAGE.##EXTERNAL WELD CONDITION.##SHELL/BODY, HEADS/ROOF AND ATTACHMENTS.##NOZZLES, MANWAYS AND REINF ORCEMENT AREAS.##COATING/PAINTING AND INSULATION/CLADDING CONDITION, WHERE APPLICABLE.##SUPPORTS, ANCHORAGES AND ASSOCIATED STRUCTUR AL COMPONENTS.##THE CONDITION AND FUNCTIONAL OF HEAT DETECTORS, FLAME DETECTORS ANDALARM SYSTEM EQUIPMENT SHALL BE CHECKED THOROUGHL Y.##INSPECTION OF CP SYSTEM & EARTHLING TERMINAL.##LEVEL INDICATOR, VALVES AND OTHER TANK RELATED EQUIPMENT INSPECTION·#AREAS THAT A RE INACCESSIBLE OR NOT INSPECTED SHALL BE CLEARLYIDENTIFIED IN THE FINAL REPORT TOGETHER WITH THE REASON.4.#API 653 SPECIFIC REQUIRE MENTS·#FOR EQUIPMENT ASSESSED UNDER API 653, THE EXTERNAL INSPECTION						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##FOUNDATION CONDITION AND EVIDENCE OF SETTLEMENT/DIFFERENTIALSETTLEMENT.##SHELL -TO-BOTTOM JUNCTION.##ACCESSIBLE BOTTOM/ANNULAR PLATE PROJECTION OR TANK C HIME.##ROOF AND ROOF-TO-SHELL JUNCTION.##NOZZLES, MANWAYS, LADDERS, PLATFORMS AND OTHER TANK APPURTENANCES.##EVIDENCE OF LEAKAGE, FO UNDATION DETERIORATION OR SHELL DISTORTION.·#A DETAILED SETTLEMENT SURVEY SHALL BE PERFORMED OR RECOMMENDED WHEREWARRANTED BY OBSERV ED CONDITIONS OR AVAILABLE HISTORICAL DATA.5.#API 510 SPECIFIC REQUIREMENTS·#FOR EQUIPMENT ASSESSED UNDER API 510, THE EXTERNAL INSP ECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##PRESSURE-RETAINING SHELL/BODY AND HEADS.##PRESSURE-BOUNDARY WELDS.##NOZZLES AND RE INFORCEMENT AREAS.##SUPPORTS, SKIRTS,					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SADDLES, LEGS AND ANCHORAGES.##EVIDENCE OF LEAKAGE, DEFORMATION OR DETERIORATION AFFECTING PRE SSUREINTEGRITY.##VERIFICATION OF APPLICABLE PRESSURE-RELIEVING DEVICE IDENTIFICATIONAND REVIEW OF AVAILABLE SET-PRESSURE/CERTIFICATI ON INFORMATION AGAINSTEQUIPMENT DESIGN/MAWP REQUIREMENTS.6.#CML/TML AND NDE (IF REQUIRED AS PER THE APPLICABLE INSPECTION CODE)·#EXI STING CML/TML LOCATIONS SHALL BE REVIEWED AND RETAINED, WHEREPRACTICABLE, FOR THICKNESS TRENDING. ADDITIONAL LOCATIONS SHALL BESELEC TED BASED ON EQUIPMENT GEOMETRY, SERVICE, HISTORICAL DETERIORATIONAND OBSERVED/SUSPECTED DEGRADATION.·#UT THICKNESS MEASUREMENTS SHA LL BE PERFORMED AT THE ESTABLISHEDCML/TML LOCATIONS AND ADDITIONAL SUSPECT AREAS.·#WHERE REQUIRED BY INSPECTION FINDINGS, APPROPRIAT					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			E ADDITIONAL NDESUCH AS PT, MT AND/OR UT SCANNING SHALL BE PERFORMED TO CHARACTERIZERELEVANT INDICATIONS.·#A MARKED-UP DRAWING/SKETC H SHOWING UNIQUELY IDENTIFIED CML/TMLLOCATIONS SHALL BE PROVIDED.7.#INTEGRITY AND FFS ASSESSMENT·#THE API AUTHORIZED INSPECTOR SHALL EVALUATE THE INSPECTION/NDERESULTS (IF CARRIED OUT) IN ACCORDANCE WITH THE APPLICABLE API 510/API653 REQUIREMENTS AND DETERMINE, AS APPLICABLE:##ACTUAL MEASURED THICKNESS##METAL LOSS.##MINIMUM REQUIRED/ACCEPTABLE THICKNESS.##CORROSION RATE BASED ON RELIABLE AVAIL ABLE DATA.##SUITABILITY FOR CONTINUED SERVICE.##FOR API 510 EQUIPMENT, CONTINUED SUITABILITY AT THE APPLICABLEDESIGN/OPERATING PRESS URE OR MAWP.·#WHERE SUFFICIENT HISTORICAL					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DATA ARE UNAVAILABLE FOR RELIABLECORROSION-RATE/RLA CALCULATION, THE LIMITATION AND ASSESS MENT BASISSHALL BE CLEARLY DOCUMENTED.8.#FINDINGS AND RECOMMENDATIONS·#ANY CONDITION THAT MAY AFFECT EQUIPMENT INTEGRITY OR SAFE OPE RATIONSHALL BE IMMEDIATELY NOTIFIED TO THE DEWA ENGINEER.·#THE API AUTHORIZED INSPECTOR SHALL PROVIDE RECOMMENDATIONS, ASAPPLICABLE, FOR:##REPAIR/CORRECTIVE ACTION.##ADDITIONAL NDE.##ENGINEERING/FITNESS-FOR-SERVICE EVALUATION.##CONDITION MONITORING.##FURTHER INTER NAL INSPECTION OR SHUTDOWN EXAMINATION WHERE EXTERNALINSPECTION IS INSUFFICIENT.9.#NEXT INSPECTION INTERVAL·#THE CONTRACTOR/API AUTH ORIZED INSPECTOR SHALL DETERMINE AND RECOMMENDTHE NEXT APPLICABLE INSPECTION DUE DATE/INTERVAL BASED ON THE RELEVANTAPI					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			510/API 653 REQUIREMENTS, EQUIPMENT CONDITION, MEASURED THICKNESS,CORROSION RATE AND AVAILABLE INTEGRITY INSPECTION HISTORY.·#THE BASIS FOR ESTA BLISHING THE RECOMMENDED INSPECTION INTERVAL SHALLBE INCLUDED IN THE FINAL REPORT.10.#INSPECTION REPORT·#THE CONTRACTOR SHALL SUBMIT A FINAL EXTERNAL IN-SERVICE INSPECTIONREPORT FOR EACH EQUIPMENT ITEM, INCLUDING AS A MINIMUM:##EQUIPMENT IDENTIFICATION/KKS AND APP LICABLE INSPECTION CODE.##DEWA - TANK IN SERVICE INSPECTION CHECKLIST.##INSPECTION DATE, INSPECTION TYPE AND SCOPE.##DESIGN AND SERV ICE INFORMATION REVIEWED.##INSPECTION LIMITATIONS AND INACCESSIBLE/UNINSPECTED AREAS.##EXTERNAL INSPECTION CHECKLIST AND FINDINGS.## CML/TML LOCATION DRAWING AND UT READINGS (IF NDE CARRIED OUT)##PHOTOGRAPHS OF						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SIGNIFICANT FINDINGS.##APPLICABLE NDE REPORTS. (IF NDE CARRIED OUT)##MINIMUM REQUIRED/ACCEPTABLE THICKNESS ASSESSMENT.##CORROSION-RATE,						
5		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS -OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#IN SERVICE EXTERNAL INTEGRITY INSP ECTION OF ABOVE GROUNDSTORAGE TANKS (DFO & WATER) IN JAPS L1 STATION. WO (511387437)PERIOD OF WORK:##10 DAYS AFTER RECEIVING POPRE-B ID SITE INSPECTION:·#THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THEWORK SCOPE, PLANT ACCESS, FACILITIES, AND COMPLEXITIES BEFORE SUBMITTINGTHE BID. DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL COSTS BEYOND THEAGREED RATES/PRICES DURING AND AFTER THE EXECUTION OF THE WORK.QUALIFICATION OF BIDDER:·#THE BIDDER	2	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OROTHER WELL-KNOWN COMPANIES.·#ALL INSPECTIONS MUST BE CONDUCTED BY AN AUTHORIZED API INSPECTOR.·#ALL NDE REQUIREMENTS MUST BE CARRIED OUT B Y AN EIAC ACCREDITEDCONTRACTOR.·#PERSONNEL PERFORMING NDE SHALL MEET THE QUALIFICATIONS IDENTIFIED ASASME V AND API 510. THE RESULTS OF ANY NDE WORK MUST BE CONSIDERED INTHE EVALUATION OF THE TANK BY AN AUTHORIZED INSPECTOR.SCOPE OF WORK1.#GENERAL·#ALL TANKS INCLU DED IN THIS SCOPE OF WORK HAVE PREVIOUSLY UNDERGONEINTEGRITY INSPECTION AND REMAINING LIFE ASSESSMENT (RLA). THIS PR/RFXCOVERS THE S UBSEQUENT EXTERNAL IN-SERVICE INSPECTION AND INTEGRITYASSESSMENT ONLY.·#PRIOR TO BID SUBMISSION, THE CONTRACTOR SHALL REVIEW ALL PRE						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			VIOUSINTEGRITY INSPECTION/RLA REPORTS AND DETERMINE NDE (IF REQUIRED) INACCORDANCE WITH THE APPLICABLE CODE (API 653 / API 510). THE CONTRACTOR#S BID SHALL INCLUDE ALL NDE CONSIDERED NECESSARY TO COMPLETETHE SPECIFIED INSPECTION AND INTEGRITY ASSESSMENT. ANY NDE SU BSEQUENTLYDETERMINED TO BE REQUIRED BASED ON INFORMATION AVAILABLE IN THE PREVIOUSREPORTS SHALL BE DEEMED INCLUDED IN THE QUOTED PRI CE, AND NO ADDITIONALCOST CLAIM SHALL BE ENTERTAINED.·#THE CONTRACTOR SHALL CARRY OUT EXTERNAL IN-SERVICE INSPECTION ANDINTEGRITY AS SESSMENT OF THE IDENTIFIED TANKS/PRESSURE VESSELS INACCORDANCE WITH THE APPLICABLE REQUIREMENTS OF:O#API 653 FOR ATMOSPHERIC STORAGE TANKS.O#API 510 FOR PRESSURE VESSELS.·#THE INSPECTION AND INTEGRITY ASSESSMENT SHALL BE PERFORMED/SUPERVISEDBY A VALID API 653						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AUTH ORIZED INSPECTOR OR API 510 AUTHORIZED PRESSUREVESSEL INSPECTOR, AS APPLICABLE.·#QUALIFIED NDE PERSONNEL AND ALL REQUIRED CALIBRATED INSPECTION/NDEEQUIPMENT, TOOLS, ACCESS EQUIPMENT, PPE AND CONSUMABLES SHALL BEPROVIDED BY THE CONTRACTOR.2.#DOCUMENT REVIEW AND ITP ·#PRIOR TO INSPECTION, THE CONTRACTOR SHALL REVIEW AVAILABLE EQUIPMENTINFORMATION INCLUDING DESIGN/FABRICATION DATA, DRAWINGS, MATER IALS OFCONSTRUCTION, DESIGN/OPERATING CONDITIONS, SERVICE HISTORY, PREVIOUSINTEGRITY INSPECTION/NDE/THICKNESS RECORDS AND REPAIR/ALT ERATIONHISTORY. MISSING DATA AND ASSUMPTIONS/LIMITATIONS AFFECTING THEASSESSMENT SHALL BE IDENTIFIED IN THE REPORT.·#THE CONTRACTOR SHALL PREPARE AND SUBMIT AN INSPECTION AND TESTPLAN/PROTOCOL (ITP) COVERING ALL						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			APPLICABLE ACCESSIBLE COMPONENTS,EXTERNAL VISUAL EXA MINATION, CML/TML LOCATIONS, NDE METHODS(IF REQUIRED)AND APPLICABLE ACCEPTANCE/EVALUATION CRITERIA.3.#EXTERNAL VISUAL INSPECTION·#A COMPREHENSIVE EXTERNAL VISUAL INSPECTION OF ALL ACCESSIBLECOMPONENTS WITHIN THE APPLICABLE API 510/API 653 EQUIPMENT BOUNDARYSHALL B E CARRIED OUT FOR:##LEAKAGE OR SEEPAGE.##GENERAL/LOCALIZED CORROSION AND PITTING.##CRACKING OR SUSPECTED CRACKING.##DEFORMATION, BUL GING, BUCKLING AND MECHANICAL DAMAGE.##EXTERNAL WELD CONDITION.##SHELL/BODY, HEADS/ROOF AND ATTACHMENTS.##NOZZLES, MANWAYS AND REINF ORCEMENT AREAS.##COATING/PAINTING AND INSULATION/CLADDING CONDITION, WHERE APPLICABLE.##SUPPORTS, ANCHORAGES AND ASSOCIATED STRUCTUR AL COMPONENTS.##THE CONDITION AND					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FUNCTIONAL OF HEAT DETECTORS, FLAME DETECTORS ANDALARM SYSTEM EQUIPMENT SHALL BE CHECKED THOROUGHL Y.##INSPECTION OF CP SYSTEM & EARTHLING TERMINAL.##LEVEL INDICATOR, VALVES AND OTHER TANK RELATED EQUIPMENT INSPECTION·#AREAS THAT A RE INACCESSIBLE OR NOT INSPECTED SHALL BE CLEARLYIDENTIFIED IN THE FINAL REPORT TOGETHER WITH THE REASON.4.#API 653 SPECIFIC REQUIRE MENTS·#FOR EQUIPMENT ASSESSED UNDER API 653, THE EXTERNAL INSPECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##FOUNDATION CONDITION AND EVIDENCE OF SETTLEMENT/DIFFERENTIALSETTLEMENT.##SHELL -TO-BOTTOM JUNCTION.##ACCESSIBLE BOTTOM/ANNULAR PLATE PROJECTION OR TANK C HIME.##ROOF AND ROOF-TO-SHELL JUNCTION.##NOZZLES, MANWAYS, LADDERS, PLATFORMS AND OTHER TANK APPURTENANCES.##EVIDENCE OF LEAKAGE, FO						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			UNDATION DETERIORATION OR SHELL DISTORTION.·#A DETAILED SETTLEMENT SURVEY SHALL BE PERFORMED OR RECOMMENDED WHEREWARRANTED BY OBSERV ED CONDITIONS OR AVAILABLE HISTORICAL DATA.5.#API 510 SPECIFIC REQUIREMENTS·#FOR EQUIPMENT ASSESSED UNDER API 510, THE EXTERNAL INSP ECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##PRESSURE-RETAINING SHELL/BODY AND HEADS.##PRESSURE-BOUNDARY WELDS.##NOZZLES AND RE INFORCEMENT AREAS.##SUPPORTS, SKIRTS, SADDLES, LEGS AND ANCHORAGES.##EVIDENCE OF LEAKAGE, DEFORMATION OR DETERIORATION AFFECTING PRE SSUREINTEGRITY.##VERIFICATION OF APPLICABLE PRESSURE-RELIEVING DEVICE IDENTIFICATIONAND REVIEW OF AVAILABLE SET-PRESSURE/CERTIFICATI ON INFORMATION AGAINSTEQUIPMENT DESIGN/MAWP REQUIREMENTS.6.#CML/TML AND NDE (IF REQUIRED AS PER THE APPLICABLE						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSPECTION CODE)·#EXI STING CML/TML LOCATIONS SHALL BE REVIEWED AND RETAINED, WHEREPRACTICABLE, FOR THICKNESS TRENDING. ADDITIONAL LOCATIONS SHALL BESELEC TED BASED ON EQUIPMENT GEOMETRY, SERVICE, HISTORICAL DETERIORATIONAND OBSERVED/SUSPECTED DEGRADATION.·#UT THICKNESS MEASUREMENTS SHA LL BE PERFORMED AT THE ESTABLISHEDCML/TML LOCATIONS AND ADDITIONAL SUSPECT AREAS.·#WHERE REQUIRED BY INSPECTION FINDINGS, APPROPRIAT E ADDITIONAL NDESUCH AS PT, MT AND/OR UT SCANNING SHALL BE PERFORMED TO CHARACTERIZERELEVANT INDICATIONS.·#A MARKED-UP DRAWING/SKETC H SHOWING UNIQUELY IDENTIFIED CML/TMLLOCATIONS SHALL BE PROVIDED.7.#INTEGRITY AND FFS ASSESSMENT·#THE API AUTHORIZED INSPECTOR SHALL EVALUATE THE INSPECTION/NDERESULTS (IF						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CARRIED OUT) IN ACCORDANCE WITH THE APPLICABLE API 510/API653 REQUIREMENTS AND DETERMINE, AS APPLICABLE:##ACTUAL MEASURED THICKNESS##METAL LOSS.##MINIMUM REQUIRED/ACCEPTABLE THICKNESS.##CORROSION RATE BASED ON RELIABLE AVAIL ABLE DATA.##SUITABILITY FOR CONTINUED SERVICE.##FOR API 510 EQUIPMENT, CONTINUED SUITABILITY AT THE APPLICABLEDESIGN/OPERATING PRESS URE OR MAWP.·#WHERE SUFFICIENT HISTORICAL DATA ARE UNAVAILABLE FOR RELIABLECORROSION-RATE/RLA CALCULATION, THE LIMITATION AND ASSESS MENT BASISSHALL BE CLEARLY DOCUMENTED.8.#FINDINGS AND RECOMMENDATIONS·#ANY CONDITION THAT MAY AFFECT EQUIPMENT INTEGRITY OR SAFE OPE RATIONSHALL BE IMMEDIATELY NOTIFIED TO THE DEWA ENGINEER.·#THE API AUTHORIZED INSPECTOR SHALL PROVIDE RECOMMENDATIONS,						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ASAPPLICABLE, FOR:##REPAIR/CORRECTIVE ACTION.##ADDITIONAL NDE.##ENGINEERING/FITNESS-FOR-SERVICE EVALUATION.##CONDITION MONITORING.##FURTHER INTER NAL INSPECTION OR SHUTDOWN EXAMINATION WHERE EXTERNALINSPECTION IS INSUFFICIENT.9.#NEXT INSPECTION INTERVAL·#THE CONTRACTOR/API AUTH ORIZED INSPECTOR SHALL DETERMINE AND RECOMMENDTHE NEXT APPLICABLE INSPECTION DUE DATE/INTERVAL BASED ON THE RELEVANTAPI 510/API 653 REQUIREMENTS, EQUIPMENT CONDITION, MEASURED THICKNESS,CORROSION RATE AND AVAILABLE INTEGRITY INSPECTION HISTORY.·#THE BASIS FOR ESTA BLISHING THE RECOMMENDED INSPECTION INTERVAL SHALLBE INCLUDED IN THE FINAL REPORT.10.#INSPECTION REPORT·#THE CONTRACTOR SHALL SUBMIT A FINAL EXTERNAL IN-SERVICE					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSPECTIONREPORT FOR EACH EQUIPMENT ITEM, INCLUDING AS A MINIMUM:##EQUIPMENT IDENTIFICATION/KKS AND APP LICABLE INSPECTION CODE.##DEWA - TANK IN SERVICE INSPECTION CHECKLIST.##INSPECTION DATE, INSPECTION TYPE AND SCOPE.##DESIGN AND SERV ICE INFORMATION REVIEWED.##INSPECTION LIMITATIONS AND INACCESSIBLE/UNINSPECTED AREAS.##EXTERNAL INSPECTION CHECKLIST AND FINDINGS.## CML/TML LOCATION DRAWING AND UT READINGS (IF NDE CARRIED OUT)##PHOTOGRAPHS OF SIGNIFICANT FINDINGS.##APPLICABLE NDE REPORTS. (IF NDE CARRIED OUT)##MINIMUM REQUIRED/ACCEPTABLE THICKNESS ASSESSMENT.##CORROSION-RATE,						
6		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATIONS -OUTSOURCING WORK. L STATION PHASE I, JEBEL ALINAME OF WORK:#IN SERVICE EXTERNAL INTEGRITY INSP ECTION OF ABOVE GROUNDSTORAGE TANKS (DFO	1	EA				

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			& WATER) IN JAPS L1 STATION. WO (511387437)PERIOD OF WORK:##10 DAYS AFTER RECEIVING POPRE-B ID SITE INSPECTION:·#THE CONTRACTOR MUST VISIT THE SITE AND BECOME FULLY FAMILIAR WITH THEWORK SCOPE, PLANT ACCESS, FACILITIES, AND COMPLEXITIES BEFORE SUBMITTINGTHE BID. DEWA WILL NOT ACCEPT ANY CLAIMS FOR ADDITIONAL COSTS BEYOND THEAGREED RATES/PRICES DURING AND AFTER THE EXECUTION OF THE WORK.QUALIFICATION OF BIDDER:·#THE BIDDER MUST HAVE PROVEN EXPERIENCE WITH SIMILAR JOBS IN DEWA OROTHER WELL-KNOWN COMPANIES.·#ALL INSPECTIONS MUST BE CONDUCTED BY AN AUTHORIZED API INSPECTOR.·#ALL NDE REQUIREMENTS MUST BE CARRIED OUT B Y AN EIAC ACCREDITEDCONTRACTOR.·#PERSONNEL PERFORMING NDE SHALL MEET THE QUALIFICATIONS IDENTIFIED ASASME V AND API						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			510. THE RESULTS OF ANY NDE WORK MUST BE CONSIDERED INTHE EVALUATION OF THE TANK BY AN AUTHORIZED INSPECTOR.SCOPE OF WORK1.#GENERAL·#ALL TANKS INCLU DED IN THIS SCOPE OF WORK HAVE PREVIOUSLY UNDERGONEINTEGRITY INSPECTION AND REMAINING LIFE ASSESSMENT (RLA). THIS PR/RFXCOVERS THE S UBSEQUENT EXTERNAL IN-SERVICE INSPECTION AND INTEGRITYASSESSMENT ONLY.·#PRIOR TO BID SUBMISSION, THE CONTRACTOR SHALL REVIEW ALL PRE VIOUSINTEGRITY INSPECTION/RLA REPORTS AND DETERMINE NDE (IF REQUIRED) INACCORDANCE WITH THE APPLICABLE CODE (API 653 / API 510). THE CONTRACTOR#S BID SHALL INCLUDE ALL NDE CONSIDERED NECESSARY TO COMPLETETHE SPECIFIED INSPECTION AND INTEGRITY ASSESSMENT. ANY NDE SU BSEQUENTLYDETERMINED TO BE REQUIRED BASED ON INFORMATION AVAILABLE IN THE					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PREVIOUSREPORTS SHALL BE DEEMED INCLUDED IN THE QUOTED PRI CE, AND NO ADDITIONALCOST CLAIM SHALL BE ENTERTAINED.·#THE CONTRACTOR SHALL CARRY OUT EXTERNAL IN-SERVICE INSPECTION ANDINTEGRITY AS SESSMENT OF THE IDENTIFIED TANKS/PRESSURE VESSELS INACCORDANCE WITH THE APPLICABLE REQUIREMENTS OF:O#API 653 FOR ATMOSPHERIC STORAGE TANKS.O#API 510 FOR PRESSURE VESSELS.·#THE INSPECTION AND INTEGRITY ASSESSMENT SHALL BE PERFORMED/SUPERVISEDBY A VALID API 653 AUTH ORIZED INSPECTOR OR API 510 AUTHORIZED PRESSUREVESSEL INSPECTOR, AS APPLICABLE.·#QUALIFIED NDE PERSONNEL AND ALL REQUIRED CALIBRATED INSPECTION/NDEEQUIPMENT, TOOLS, ACCESS EQUIPMENT, PPE AND CONSUMABLES SHALL BEPROVIDED BY THE CONTRACTOR.2.#DOCUMENT REVIEW AND ITP ·#PRIOR TO INSPECTION, THE CONTRACTOR SHALL					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REVIEW AVAILABLE EQUIPMENTINFORMATION INCLUDING DESIGN/FABRICATION DATA, DRAWINGS, MATER IALS OFCONSTRUCTION, DESIGN/OPERATING CONDITIONS, SERVICE HISTORY, PREVIOUSINTEGRITY INSPECTION/NDE/THICKNESS RECORDS AND REPAIR/ALT ERATIONHISTORY. MISSING DATA AND ASSUMPTIONS/LIMITATIONS AFFECTING THEASSESSMENT SHALL BE IDENTIFIED IN THE REPORT.·#THE CONTRACTOR SHALL PREPARE AND SUBMIT AN INSPECTION AND TESTPLAN/PROTOCOL (ITP) COVERING ALL APPLICABLE ACCESSIBLE COMPONENTS,EXTERNAL VISUAL EXA MINATION, CML/TML LOCATIONS, NDE METHODS(IF REQUIRED)AND APPLICABLE ACCEPTANCE/EVALUATION CRITERIA.3.#EXTERNAL VISUAL INSPECTION·#A COMPREHENSIVE EXTERNAL VISUAL INSPECTION OF ALL ACCESSIBLECOMPONENTS WITHIN THE APPLICABLE API 510/API 653 EQUIPMENT BOUNDARYSHALL B						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			E CARRIED OUT FOR:##LEAKAGE OR SEEPAGE.##GENERAL/LOCALIZED CORROSION AND PITTING.##CRACKING OR SUSPECTED CRACKING.##DEFORMATION, BUL GING, BUCKLING AND MECHANICAL DAMAGE.##EXTERNAL WELD CONDITION.##SHELL/BODY, HEADS/ROOF AND ATTACHMENTS.##NOZZLES, MANWAYS AND REINF ORCEMENT AREAS.##COATING/PAINTING AND INSULATION/CLADDING CONDITION, WHERE APPLICABLE.##SUPPORTS, ANCHORAGES AND ASSOCIATED STRUCTUR AL COMPONENTS.##THE CONDITION AND FUNCTIONAL OF HEAT DETECTORS, FLAME DETECTORS ANDALARM SYSTEM EQUIPMENT SHALL BE CHECKED THOROUGHL Y.##INSPECTION OF CP SYSTEM & EARTHLING TERMINAL.##LEVEL INDICATOR, VALVES AND OTHER TANK RELATED EQUIPMENT INSPECTION·#AREAS THAT A RE INACCESSIBLE OR NOT INSPECTED SHALL BE CLEARLYIDENTIFIED IN THE FINAL REPORT TOGETHER WITH THE REASON.4.#API 653 SPECIFIC						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REQUIRE MENTS·#FOR EQUIPMENT ASSESSED UNDER API 653, THE EXTERNAL INSPECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##FOUNDATION CONDITION AND EVIDENCE OF SETTLEMENT/DIFFERENTIALSETTLEMENT.##SHELL-TO-BOTTOM JUNCTION.##ACCESSIBLE BOTTOM/ANNULAR PLATE PROJECTION OR TANK CHIME.##ROOF AND ROOF-TO-SHELL JUNCTION.##NOZZLES, MANWAYS, LADDERS, PLATFORMS AND OTHER TANK APPURTENANCES.##EVIDENCE OF LEAKAGE, FOUNDATION DETERIORATION OR SHELL DISTORTION.·#A DETAILED SETTLEMENT SURVEY SHALL BE PERFORMED OR RECOMMENDED WHEREWARRANTED BY OBSERV ED CONDITIONS OR AVAILABLE HISTORICAL DATA.5.#API 510 SPECIFIC REQUIREMENTS·#FOR EQUIPMENT ASSESSED UNDER API 510, THE EXTERNAL INSP ECTION SHALLADDITIONALLY INCLUDE, AS APPLICABLE:##PRESSURE-RETAINING SHELL/BODY						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			AND HEADS.##PRESSURE-BOUNDARY WELDS.##NOZZLES AND RE INFORCEMENT AREAS.##SUPPORTS, SKIRTS, SADDLES, LEGS AND ANCHORAGES.##EVIDENCE OF LEAKAGE, DEFORMATION OR DETERIORATION AFFECTING PRE SSUREINTEGRITY.##VERIFICATION OF APPLICABLE PRESSURE-RELIEVING DEVICE IDENTIFICATIONAND REVIEW OF AVAILABLE SET-PRESSURE/CERTIFICATI ON INFORMATION AGAINSTEQUIPMENT DESIGN/MAWP REQUIREMENTS.6.#CML/TML AND NDE (IF REQUIRED AS PER THE APPLICABLE INSPECTION CODE)·#EXI STING CML/TML LOCATIONS SHALL BE REVIEWED AND RETAINED, WHEREPRACTICABLE, FOR THICKNESS TRENDING. ADDITIONAL LOCATIONS SHALL BESELEC TED BASED ON EQUIPMENT GEOMETRY, SERVICE, HISTORICAL DETERIORATIONAND OBSERVED/SUSPECTED DEGRADATION.·#UT THICKNESS MEASUREMENTS SHA LL BE PERFORMED AT THE ESTABLISHEDCML/TML					

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			LOCATIONS AND ADDITIONAL SUSPECT AREAS.·#WHERE REQUIRED BY INSPECTION FINDINGS, APPROPRIAT E ADDITIONAL NDESUCH AS PT, MT AND/OR UT SCANNING SHALL BE PERFORMED TO CHARACTERIZERELEVANT INDICATIONS.·#A MARKED-UP DRAWING/SKETC H SHOWING UNIQUELY IDENTIFIED CML/TMLLOCATIONS SHALL BE PROVIDED.7.#INTEGRITY AND FFS ASSESSMENT·#THE API AUTHORIZED INSPECTOR SHALL EVALUATE THE INSPECTION/NDERESULTS (IF CARRIED OUT) IN ACCORDANCE WITH THE APPLICABLE API 510/API653 REQUIREMENTS AND DETERMINE, AS APPLICABLE:##ACTUAL MEASURED THICKNESS##METAL LOSS.##MINIMUM REQUIRED/ACCEPTABLE THICKNESS.##CORROSION RATE BASED ON RELIABLE AVAIL ABLE DATA.##SUITABILITY FOR CONTINUED SERVICE.##FOR API 510 EQUIPMENT, CONTINUED						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUITABILITY AT THE APPLICABLEDESIGN/OPERATING PRESSURE OR MAWP.·#WHERE SUFFICIENT HISTORICAL DATA ARE UNAVAILABLE FOR RELIABLECORROSION-RATE/RLA CALCULATION, THE LIMITATION AND ASSESSMENT BASISSHALL BE CLEARLY DOCUMENTED.8.#FINDINGS AND RECOMMENDATIONS·#ANY CONDITION THAT MAY AFFECT EQUIPMENT INTEGRITY OR SAFE OPERATIONSHALL BE IMMEDIATELY NOTIFIED TO THE DEWA ENGINEER.·#THE API AUTHORIZED INSPECTOR SHALL PROVIDE RECOMMENDATIONS, ASAPPLICABLE, FOR:##REPAIR/CORRECTIVE ACTION.##ADDITIONAL NDE.##ENGINEERING/FITNESS-FOR-SERVICE EVALUATION.##CONDITION MONITORING.##FURTHER INTERNAL INSPECTION OR SHUTDOWN EXAMINATION WHERE EXTERNALINSPECTION IS INSUFFICIENT.9.#NEXT INSPECTION INTERVAL·#THE CONTRACTOR/API AUTH						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ORIZED INSPECTOR SHALL DETERMINE AND RECOMMENDTHE NEXT APPLICABLE INSPECTION DUE DATE/INTERVAL BASED ON THE RELEVANTAPI 510/API 653 REQUIREMENTS, EQUIPMENT CONDITION, MEASURED THICKNESS,CORROSION RATE AND AVAILABLE INTEGRITY INSPECTION HISTORY.·#THE BASIS FOR ESTA BLISHING THE RECOMMENDED INSPECTION INTERVAL SHALLBE INCLUDED IN THE FINAL REPORT.10.#INSPECTION REPORT·#THE CONTRACTOR SHALL SUBMIT A FINAL EXTERNAL IN-SERVICE INSPECTIONREPORT FOR EACH EQUIPMENT ITEM, INCLUDING AS A MINIMUM:##EQUIPMENT IDENTIFICATION/KKS AND APP LICABLE INSPECTION CODE.##DEWA - TANK IN SERVICE INSPECTION CHECKLIST.##INSPECTION DATE, INSPECTION TYPE AND SCOPE.##DESIGN AND SERV ICE INFORMATION REVIEWED.##INSPECTION LIMITATIONS AND INACCESSIBLE/UNINSPECTED AREAS.##EXTERNAL INSPECTION CHECKLIST AND						

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER : 2332603117

DATE : 26.11.2026

REQ No : 1032605809

REQ TITLE : IN SERVICE EXTERNAL

DELIVERY LOCATION

CLOSING DATE : 02.12.2026

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FINDINGS.## CML/TML LOCATION DRAWING AND UT READINGS (IF NDE CARRIED OUT)##PHOTOGRAPHS OF SIGNIFICANT FINDINGS.##APPLICABLE NDE REPORTS. (IF NDE CARRIED OUT)##MINIMUM REQUIRED/ACCEPTABLE THICKNESS ASSESSMENT.##CORROSION-RATE,						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

IN SERVICE EXTERNAL INTEGRITY INSPECTION OF ABOVE GROUND
STORAGE/DRAIN/EXPANSION TANKS (DFO <(>&<)> WATER) IN JAPS L1 STATION

Contact Person - basil.joy@dewa.gov.ae

Note to LPD - Please share attached SOW along with invitation

STANDARD TERMS & CONDITIONS

1) RFQ Document Disclaimer: The PDF version of this Request for Quotation (RFQ) is provided for convenience only and contains a summary of key information. It does not include all technical details, requirements, or specifications. Bidders must refer to the complete system documentation and all referenced materials to obtain full and accurate information necessary for preparing their proposals.

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332603117
DATE	: 26.11.2026
REQ No	: 1032605809
REQ TITLE	: IN SERVICE EXTERNAL
DELIVERY LOCATION	
CLOSING DATE	: 02.12.2026
CLOSING TIME	: 10:00:00

2) Prices should be 'DDP' delivery duty paid at DEWA stores.

3) Quotation to be submitted only in local currency U.A.E Dirhams

4) DEWA Standard Payments: Payment will be made within 30 days from the date the Supplier/Contractor submits a complete and accurate invoice, together with all required supporting documents, subject to the material and/or services having been duly accepted.

5) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

6) The offered product and/or services in the Quotation, shall be confirming and in accordance with DEWA Energy Management Policy & EnMS Manual.

7) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer. If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements. The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

8)Data Privacy, Security and Sharing:
a) Third-party shall handle DEWA data in accordance with all applicable laws, regulations, and DEWA policies.
b) DEWA data shall not be shared outside UAE, in line with DESC ISR requirements.
c) DEWA's Non-Disclosure Agreement (NDA) and External Party Acknowledgment (EPA) shall be signed by the third-party and their sub-contractors who handle DEWA data prior to the contract commencement.
d) DEWA reserves the right to withhold data from third parties if deemed sensitive.

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332603117
DATE	: 26.11.2026
REQ No	: 1032605809
REQ TITLE	: IN SERVICE EXTERNAL
DELIVERY LOCATION	
CLOSING DATE	: 02.12.2026
CLOSING TIME	: 10:00:00

e) Access to data must be restricted to authorized, named third-party employees only and DEWA must be informed of any changes in employment status of those with access.
f) Third party shall not disclose, transfer or share any DEWA data with other third parties (government, semi government, private) without obtaining DEWA#s authorized data owner written approval.
g) Upon the completion/ termination of the agreement the external party shall securely delete all DEWA#s data in their custody/ control including the backup and provide written confirmation and evidence to DEWA upon the data deletion completion as per agreed data disposal process, this is to address risk of data remanence.

9) Liquidated Damages for PO total value in excess of AED 50,000:
If the Contractor/Supplier delays or fails to deliver, fails to commence or perform the services, DEWA has the right to deduct an amount equal to 1.25% per day/week of the total PO fee for the services/supplies delayed, not performed or not delivered, subject to a cap of 10% of the total PO fee without recourse to any judicial proceedings, as compensation for the delay or failure to perform. If the deducted amount exceeds 10% of the total PO fee, without prejudice to any of DEWA's rights under the applicable law, DEWA shall be entitled to terminate the PO immediately without the need for any notice or judicial proceedings against the defaulting Supplier, and without the need to prove the damage.

10) Indemnity: The Supplier shall indemnify DEWA from and against all claims, damages, costs and liabilities brought by any third party against DEWA arising out of or in connection with any of acts or omissions of the Supplier/Contractor, or any failure to perform its obligations under this PO.

11) Dispute Resolution: Any dispute arising out of or in connection with this PO shall be settled through mutual good faith negotiation and understanding between the Parties: Failing amicable settlement, the dispute shall finally be referred to the courts having appropriate jurisdiction in the Emirate of Dubai.

12) Intellectual Property Rights: The Supplier/Contractor shall not use DEWA's intellectual property, including logos, trademarks, service marks, trade names, service names, and brand names, whether in a press release or otherwise, without obtaining DEWA's prior written consent. All intellectual property rights in the deliverables created or developed, under this PO, shall be solely owned by DEWA.

13) Assignment and Transfer: The Supplier/Contractor shall not assign this PO or any part thereof without the prior written consent of DEWA. Such consent shall not relieve the Contractor of any of its obligations or duties under this PO.

14) Force Majeure: If either party is affected by a Force Majeure event, it will promptly notify the other party of the nature and extent thereof. Neither party will be deemed to be in breach of this PO, by reason of any delay or non-performance, of any of its obligations hereunder, due to any Force Majeure event of which it has notified the other party. The time for performance of these obligations will be

REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION

RFQ NUMBER	: 2332603117
DATE	: 26.11.2026
REQ No	: 1032605809
REQ TITLE	: IN SERVICE EXTERNAL
DELIVERY LOCATION	
CLOSING DATE	: 02.12.2026
CLOSING TIME	: 10:00:00

extended accordingly as may be fair and reasonable in the circumstances. Provided always that if the duration of such delay or impediment exceeds thirty (30) days, either party may give a fifteen (15) working days' notice to terminate a specific item or the PO in its entirety.

15) Certificate of Conformity for Green Materials and Services Specifications: The Bidder shall, wherever applicable, provide a Certificate of conformity issued by accredited body/ laboratory as proof of compliance with the applicable green materials, services and specifications.

16) Taking Over Certificate: TOC shall be issued only after full delivery or completion of the service or deliverables. TOC will be issued conditionally ("conditional TOC") with the reasonable guarantee/observation in case of any defects after delivery or completion of the PO.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP

DISCLAIMER : THIS IS A SYSTEM GENERATED DOCUMENT , DOSEN'T NEED SIGNATURE.