

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401026
DATE : 15.07.2024
REQ No : 1032402275
REQ TITLE : 1032402275 fire fighting pump
DELIVERY LOCATION
CLOSING DATE : 26.07.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	SUPPLY AND INSTALLATION FOR FIREFIGHTING PUMP SET.THE 50GPM DIESEL AND ELECTRICAL PUMP SET, AS PER DUBAI CIVIL DEFENSEMINISTER UL LI STED, HAS THE FOLLOWING SPECIFICATIONS:##IT IS A FIRE FIGHTING PUMP SET THAT OPERATES AT 50GPM @7BAR.##THE SET INCLUDES A DIESEL ENG INE, AN ELECTRIC MOTOR, AND A JOCKEYPUMP.##THIS PUMP MACHINE UNIT IS SUITABLE FOR FIREFIGHTING OR FORSTABILIZING PRESSURE IN A HOUSE OR SMALL BUILDING.##THE PUMP SET IS CUSTOMIZED ACCORDING TO NFPA 20 AND GB STANDARDS.##THE PUMP SET SHOULD BE UL LISTED, DESIGNED B Y SEPARATE DIESEL ANDELECTRICAL PUMP DIGITALLY CONTROLLED PANELS.##THE PUMP SET IS DESIGNED AND MANUFACTURED WITH ADVANCED TESTING ANDACCREDITATION TO ENSURE THE UTMOST EQUIPMENT RELIABILITY.FIRE FIGHTING PUMP SET (DIESEL ENGINE + ELECTRIC MOTOR)UL	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401026
DATE : 15.07.2024
REQ No : 1032402275
REQ TITLE : 1032402275 fire fighting pump
DELIVERY LOCATION
CLOSING DATE : 26.07.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LISTED:##FLOW RATE: 50 GPM (APPROXIMATELY 190 LPM)##PRESSURE: 7 BAR (APPROXIMATELY 100 PSI # 148PSI)##FLOW RANGE: 50 GPM##HEAD RANGE: 3-20 BAR##SP EED: 2900 R/MIN##FREQUENCY: 50 HZ OR 60 HZ.##TOUCHSCREEN BASED ELECTRIC FIRE PUMP CONTROLLERS.##DIESEL ENGINE FIRE PUMP CONTROLLERS. ADDITIONAL SPECIFICATIONS:##INTERFACING WITH FACP PANEL.##THE WORK INCLUDES SUPPLY, INSTALLATION, AND COMMISSIONING OF 50GPM DIESEL AND ELECTRICAL PUMPS.##ALL INSTALLATION IN ACCORDANCE WITH DCD RULES AND REGULATIONS.##ELECTRICAL POWER CONNECTION FROM DB TO PUMP SET INCLUDED AS PER REQUIRED.##ALL WIRING ACCESSORIES, WIRE AND DUCTS/PIPES REPLACE AS PER REQUIREMENTS AND STANDARD.##INCLUDING ANY TYPE OF CIVIL WORK (INTERLOCK EXCAVATION AND REINSTATEMENT, SAND EXCAVATION AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401026
DATE : 15.07.2024
REQ No : 1032402275
REQ TITLE : 1032402275 fire fighting pump
DELIVERY LOCATION
CLOSING DATE : 26.07.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BACK FILLING, WALL HOLES) WILL BE THE RESPONSIBILITY OF THE CONTRACTOR.##SUPPLY OF DEDICATED GRP TANK HORIZONTAL FOR FIREFIGHTING.##WATER TANK 3000 US GALLON, FIBERGLASS WATER TANKS MADE OF HIGH QUALITY RAW MATERIAL TO AVOID THE GROWTH OF BACTERIA, FUNGI & ALGAE. SURFACE MOUNTED IN HORIZONTAL SHAPE.						
2		ITEM-00001	SUPPLY AND INSTALLATION OF FIRE HOSE REEL WITH CABINETS. FIRE HOSE REEL CABINETS.##SURFACE-MOUNTED.##MATERIAL OPTIONS: STAINLESS STEEL WITH A MIRROR FINISH.##LOCKING MECHANISMS: ROUND HANDLE CAM LATCH.##DOOR OPTIONS: SOLID DOOR.##VERTICAL VERSIONS ARE AVAILABLE FOR BREACHING INLET CABINETS.##COMPLY WITH BSEN 671-1 STANDARDS.##DIMENSIONS VARY BASED ON SITE VISIT.2.#FIRE HOSE REEL:3.##WATER CONSUMPTION: 30 L/MIN.##HOSE PIPE: 1# X 30MTR LONG.##CAPABLE OF ROTATING IN MORE THAN	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401026
DATE : 15.07.2024
REQ No : 1032402275
REQ TITLE : 1032402275 fire fighting pump
DELIVERY LOCATION
CLOSING DATE : 26.07.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ONE PLANE, WITH MOUNTING OPTIONSINCLUDING SWINGING ARM AND FULLY AUTOMATIC VERSION.##AUTOMATIC FIRE HOSE REELS WILL OPEN FULLY WITHIN 3 REVOLUTIONS OF THEREEL.##NOZZLE WITH SHUT, JET , AND SPRAY CONTROL SETTINGS.##MINIMUM FLOW RATE OF HOSE REELS IN JET AND SPRAY SETTINGS AT 220 KPAPRESSURE FOR 25MM NOZZLE IS 0.55 L/S.##EFFECTIVE THROW RANGE OF DISCHARGE AT 0.2 MPA (2 BAR) PRESSURE IS 10METERS IN JET SETTING.##REEL DISCS PAINTED RED WITH PRINTE D USER INSTRUCTIONS.ADDITIONAL SPECIFICATIONS:##INLET WATER LINE SCHEDULE 40 UL LISTED; ALL ACCESSORIES, DUCTS/PIPESREPLACED AS PER REQUIREMENTS.##CONTRACTOR RESPONSIBLE FOR ANY CIVIL WORK (INTERLOCK EXCAVATION ANDREINSTATEMENT, SAND EXCAVATION AND BACKFILLING, WA LL HOLES), INCLUDINGPROVIDING STANDARD</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401026
DATE : 15.07.2024
REQ No : 1032402275
REQ TITLE : 1032402275 fire fighting pump
DELIVERY LOCATION
CLOSING DATE : 26.07.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DUCT PIPE WITH WARNING TAPE AS PER DEWA STANDARD, IF EXCAVATION IS REQUIRED.						
3		ITEM-00001	SUPPLY AND FABRICATE THE SAND BUCKET STAND WITH HANGING BUCKET: -SCOPE OF WORK: FIRE BUCKET STAND FOR 6 BUCKETS WITH ROOF/CANOPY: SPECIFICATION##MADE OF 2# MS SQUARE TUBE AND (ROOF/CANOPY) 4 FT X 3 FT CRC/GALVANIZED SHEET.##HEIGHT: 4 FT X 4 FT WIDE.##DESIGNED TO FOLD IN FOUR PIECES FOR EASY TRANSPORTATION.##SIX HOOKS ARE PROVIDED TO HANG 6 BUCKETS.##ROOF/CANOPY PROTECTS FROM DIRT AND RAIN.##FULLY POWDER-COATED IN RED COLOR, WITH #FIRE# PRINTED ON THE ROOF/CANOPY.##PLASTIC/RUBBER GROMMET PROVIDED AT EACH HOLE. FIRE BUCKET STAND: ##MATERIAL: MILD STEEL (MS)##BUCKET HOLDING CAPACITY: 6 BUCKETS##SURFACE TREATMENT: POWDER COATED##CERTIFICATION: CE (CONFORMITY EUROPEAN).##USAGE: INDUSTRIAL, OUTSIDE##MS	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401026
DATE : 15.07.2024
REQ No : 1032402275
REQ TITLE : 1032402275 fire fighting pump
DELIVERY LOCATION
CLOSING DATE : 26.07.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BODY MATERIAL OF FIRE FIGHTING BUCKET.##FULLY POWDER-COATED IN RED COLOR.##WHEEL TO PROVIDE FOR EASY SHIFTING.						
4		ITEM-00001	FM200 FIRE GI PIPE REROUTING THE AS PER STANDARD AT MBR PS PHASE 1&2: -REROUTE ALL EXISTING EXPOSE GI PIPE FOR FM200 LAID ON FLOOR I N LV ROOMAND NEED TO BE GROUNDED IN LV ROOM.##INSPECT THE CURRENT PIPE LAYOUT AND IDENTIFY THE AREAS THAT NEEDREROUTING.##DETERMINE THE NEW PIPE ROUTING PATH, ENSURING IT AVOIDS OBSTACLES,MAINTAINS PROPER CLEARANCE, AND ADHERES TO SAFETY REGULATIONS. PLAN FORPIPE SUPPORTS AND HANGERS TO SECURE THE PIPES.##USE GI PIPES FOR THE REROUTING. GI PIPES ARE DURABLE AND SUITABLE FORFIRE SUPPRESSION SYS TEMS. ENSURE PROPER GROUNDING OF THE PIPES TOPREVENT HAZARDS.##REMOVE THE EXISTING PIPES CAREFULLY.##INSTALL THE NEW	2	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401026
DATE : 15.07.2024
REQ No : 1032402275
REQ TITLE : 1032402275 fire fighting pump
DELIVERY LOCATION
CLOSING DATE : 26.07.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			GI PIPES ALONG THE PLANNED ROUTE AND SUBMIT A DRAWINGFOR APPROVAL.##CONNECT THE PIPES TO THE FM200 SYSTEM COMPONENTS (CYLINDERS, NOZZLES,ETC.).##CO NDUCT A PRESSURE TEST ON THE NEW PIPE ROUTING TO VERIFY ITSINTEGRITY.##TEST THE FM200 SYSTEM TO ENSURE PROPER FUNCTIONALITY AFTER RE ROUTING.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Supply, installation, and commissioning of Fire Fighting Pump Set with
fire hose reel at MBR pumping station phase 1<(>&<)>2.

for more deatils please contact Eng : Adnan Haider -509634981
site visit 6/6/2024 10:00 AM.

STANDARD TERMS & CONDITIONS

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page7 of 8

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401026
DATE : 15.07.2024
REQ No : 1032402275
REQ TITLE : 1032402275 fire fighting pump
DELIVERY LOCATION
CLOSING DATE : 26.07.2024
CLOSING TIME : 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP