

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	REMOVAL AND REPLACEMENT OF EXISTING FLUID MAKE DELUGE VALVE ASSEMBLIES & GATE VALVES AND SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF ALTERNATE DEWA-TP APPROVED DELUGE VALVE ASSEMBLY & GATE VALVES INCLUDING ASSOCIATED WORKS AT MBRSTATE 132KV SUBSTATION SCOPE OF WORK RK##### THE SCOPE OF WORKS COVERS BUT NOT LIMITED TO THE FOLLOWING: SCHEDULE OF VALVES TO BE REPLACED SL# DESCRIPTION# EXISTING MAKE# MODEL# SIZE# QTY # LOCATION #1.## OS&Y GATE VALVE # FLUID # F722F#10 INCH #2# FWT 1&2 OUTLET #2.## OS&Y GATE VALVE # FLUID # F722F#8 INCH#11# INSIDE FP ROOM #3.## OS&Y GATE VALVE # FLUID # F722F#6 INCH#14# FIRE MAINS & HYDRANT#4.## OS&Y GATE VALVE # FLUID # F722F#4 INCH#8# FWT 1 &2 INFILLING, IDT-1,2&3 MANIFOLD, WET RISER 1&2 #5.## OS&Y GATE VALVE # FLUID # F722F#3 INCH#5# SHX-1&2, FWT 1&2, DRAIN AND FP	3	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SPRINKL ER #6.##OS&amp;Y GATE VALVE #FLUID #F722F#2 ½ INCH#3#ET-1,2&amp;3 MANIFOLD#SL#DESCRIPTION#EXISTING MAKE#MODEL#SIZE#QTY #LOCATION#1.##DELUGE VALVE WITH TRIM #FLUID #FDV-10#4 INCH#3#IDT-1,2&amp;3 #2.##DELUGE VALVE WITH TRIM #FLUID #FDV-10#3 INCH#2#SHX-1&amp;2 #3.##DELUGE VALVE WIT H TRIM #FLUID #FX#2 INCH#3#ET-1,2&amp;3#.#NEW DELUGE VALVE WITH TRIM ASSEMBLY &amp; OS&amp;Y GATE VALVE SHALL BEDEWA-TP APPROVED MODEL.# REFER T ABLE ABOVE FOR AREA AND SIZE.#EXISTING WET PILOT LINE TO BE RETAINED.#NECESSARY MODIFICATIONS IN MANIFOLD AS REQUIRED BY SITE COND ITION.#WORKS SHALL BE CARRIED OUT BY TP-APPROVED FPS CONTRACTOR ORCONTRACTORS WITH EXPERIENCE IN SIMILAR JOBS IN DEWA TP 132 KV OR 400 KVSUBSTATION.#INTERFACING AND TESTING OF NEW DELUGE PRESSURE SWITCHES WITH</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EXISTINGFIRE ALARM CONTROL PANEL / SCADA.#ALL ASSOCIATED CIVIL AND ELECTRICAL WORKS REQUIRED FOR THE JOB.#ALL MANIFOLDS TO BE PAINTED INCLUDING RISER PIPE.#DELUGE RESETTING PROCEDUR E (ANODIZED ALUMINIUM PLATE) SHALL BE FIXEDNEAR ALL MANIFOLDS.#ANY DELUGE VALVE IDENTIFICATION PLATE MISSING TO BE PROVIDED.#EXISTING DELUGE ISOLATION VALVE WITH TRIM TO BE REPLACED WITH NEWDEWA-TP APPROVED MODELS.#NEW SUPERVISORY SWITCH TO BE PROVIDED FOR EXISTING ONES AT SITE.#PROVISION OF NEW SUPERVISORY SWITCH, ADDITIONAL FIRE ALARM MODULE ANDASSOCIATE FIRE ALARM PROGRAMMING ARE NOT PART OF THE SCOPE.#NEW PRV AND ARV SHALL BE PROVIDED IN ALL MANIFOLDS WITH DEDICATEDISOLATION VALVES.#ALL SCRAP MATERIALS TO BE SHIFTE D TO DEWA RUWAIYYAH SCRAPYARD, AS						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PERDEWA INSTRUCTION.#ISOLATION OF FIRE PROTECTION SHALL BE MINIMAL. PREFABRICATED PIPINGASSEMBLIE S SHALL BE USED WHEREVER POSSIBLE.#HYDROSTATIC PRESSURE TEST TO BE PERFORMED FOR REPLACED ITEMS,WHEREVER APPLICABLE.#SUCCESSFUL DISCHARGE TEST TO BE PERFORMED FOR FINAL ACCEPTANCE.#AS BUILT DRAWINGS, O&amp;M MANUALS AND TEST REPORTS SHALL BE PROVIDED ASPER DEWA REQUIREMENTS.#ALL TOOLS, LIFTING EQUIPMENT#S, SCAFFOLDING, LADDERS AND TESTINGEQUIPMENTS REQUIRED FOR THE JOB IS CONTRACTOR SCOPE.#ADD ITIONAL CABLING WORKS WHEREVER REQUIRED.#CONTRACTOR MUST FOLLOW DEWA OUTAGE SCHEDULES WHEREVER APPLICABLE,DURING THE EXECUTION OF JOB.#CONTRACTOR MUST FOLLOW ALL DEWA SAFETY RULES AND FORMALITIES DURINGTHE EXECUTION OF THE JOB.#CONTRACTOR SHALL ACCEPT FULL RESP</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ONSIBILITY FOR ANY DAMAGE THAT MAYBE CAUSED TO ANY PLANTS DUE TO NEGLIGENCE. #POWER SUPPLY AND WATER REQUIRED FOR THE WORK WILL BE PROVIDED BYDEWA. #WARRANTY OF TWO YEAR FOR THE ENTIRE JOB, FROM THE DATE OF FINALACCEPTANCE 2. SPECIFICATION2.1 DELUGE VALVE SETS S</p> <p>HALL INCLUDE: --#STOP VALVE OF APPROVED CONSTRUCTION WITH AN INDICATOR SHOWING "OPEN"AND "CLOSED" POSITIONS, COMPLETE WITH PADLOCKED</p> <p>SECURING STRAPS. THEVALVE SHALL BE MOUNTED ON THE INCOMING SIDE OF THE ALARM OR DELUGEVALVE. ALL VALVES SHALL BE FLANGED OS &amp; Y AND</p> <p>RESILIENT SEATED TYPE. ALLVALVES SHALL BE EASILY ACCESSIBLE OR PROVIDE PERMANENT PLATFORM FOROPERATION AND MAINTENANCE PURPOSE. #AL</p> <p>L SUCH VALVES AND VALVE SEATS SHALL BE LEAK TIGHT UNDER ALLPRESSURE UP TO THE TEST PRESSURE OF THE SYSTEM. EACH CONTROL</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VALVESTATION SHALL BE PROVIDED WITH INDIVIDUAL MECHANICAL ALARM. ADEQUATE TESTING ARRANGEMENT SHALL BE PROVIDED WITHOUT SPRAY THE FIREWATER TO HAZ ARD. #EACH PRESSURE (ALARM) SWITCH SHALL HAVE TWO SEPARATE OPERATING SWITCHES. RANGE OF ALARM PRESSURE SWITCHES SHALL BE 0 ~ 20 PSI (  FACTORY SET). #DIAL PRESSURE GAUGES (WITH ANTI-VIBRATION FLUID), WEATHERPROOF, 4 INCH DIAL, SS BODY, ARRANGED TO MONITOR THE WATER PRE SSURES ABOVE AND BELOW THE DELUGE VALVE SET THAT MEANS EACH DELUGE VALVE SHOULD HAVE TWO DIAL PRESSURE GAUGES. EACH GAUGE SHALL BE PRO VIDED WITH A THREE-WAY ISOLATING VALVE SO THAT IT CAN BE EASILY ISOLATED AND REMOVED FOR TESTING AND CHECKING WITHOUT SHUTTING DOWN THE E WATER SUPPLY. #ARRANGEMENT SHOULD BE PROVIDED FOR TESTING THE OPERATION</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OFWATER-MOTOR-ALARM WHILE KEEPING DELUGE ISOLATION VALVE CLOSED.#MANUAL RELEASE DEVICES (BOX TYPE) SHALL BE PROVIDED FOR ALL DELUGEVALVES. SUCH DEVICES SHALL BE CONTROLLED FROM READILY ACCESSIBLE LOCATIONS IN THE EVENT OF FIRE. CONTROL SHALL BE MECHANICAL. MANUALRELEASE DEVICES ARE TO BE FITTED WITH A WIRE SEAL.#PROVIDE LABELS/MARKING TO EACH DRAIN VALVE, TRIM COMPONENTS WITHRESPECTIVE TRANSFORMERS.#DELUGE VALVE TO BE RED IN COLOR.#NEW ALARM GONG AND MANUAL RELEASE BOX TO BE PROVIDED.PIPES AND FITTINGS:STANDARD WEIGHT STEEL PIPE ASTM A53, SEAMLESS, SCHEDULE-40, FACTORYGALVANIZED.#ALL THE PIPING OF SIZE 2" DIA &amp; BELOW SHALL BE THREADED TYPE &amp; MILLGALVANIZED, AND 2.5" DIA &amp; ABOVE SHALL BE HOP DIP GALVANIZED AFTERFABRICATION &amp; WELDING.ALL FITTINGS AND</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FIXTURES FOR PIPE WORK SHALL BE OF SEAMLESS CARBONSTEEL SCHEDULE 40, HOT DIPPED GALVANIZED AND PAINTED TO COLOR RED.USE OF WELDED JOINTS WITH GALVANIZED STEEL PIPES NOT ACCEPTABLE.DEWA TP APPROVED PIPES AND FITTINGS. PAINTING ALL SURFACES OF PIPES AND FITTINGS SHOULD BE CLEAN, DRY AND FREE FROM CONTAMINATION.PAINTING SHALL BE DONE AS PER PAINT MANUFACTURER'S SPECIFICATION. TWO COAT OF RED OXIDE AND TWO COAT OF GLOSS RED PAINT BY MIXING WITH PROPER RATIO OF BASE AND CURING AGENT WITH THINNER. EXPOSED PIPE WORK SHALL ADDITIONALLY BE PAINTED ONE COAT GLOSS RED.SPECIFICATION AND METHOD STATEMENT FROM PAINT MANUFACTURER SHALL BE SUBMITTED FOR DEWA APPROVAL</p> <p>FLUSHING ALL PIPE WORKS INSTALLED UNDER THIS CONTRACT SHALL BE THOROUGHLY FLUSHED WITH WATER IN</p>						



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ORDER TO REMOVE FOREIGN MATER.GENERALTHE CONTRACTOR SHALL SUBMIT TECHNICAL OFFER WITH FULL DETAILED WORKINGPROGRAM TO EXECUTE THIS J OB. THE CONTRACTOR MUST COMPLETE THE EXECUTIONOF THE PROJECT WITH 6 MONTHS PERIOD. THIS WORK PLAN PROGRAM SHALLINCLUDE BUT NOT LIMI TED TO THE FOLLOWINGS:O#MATERIAL SUBMITTALSO#INSTALLATIONO#COMMISSIONING DATEO#SYSTEM HAND OVER DATEFOR SITE VISIT AND ENTRY PERMIT, CONTACT THE FOLLOWING ENGINEER MR.SABIYUR RAHMAN SHEIK ABDUL KADER(MOB: 0553000627)/ MR. MOHD YACOOBNAVEED (MOB:0559761412) AND FOR OTHER TECHNICAL QUERIES CONTACT MR.VISHNU VIJAY (MOB:0509463644)						
2		ITEM-00001	REMOVAL AND REPLACEMENT OF EXISTING FLUID MAKE DELUGE VALVE ASSEMBLIES &GATE VALVES AND SUPPLY, INSTALLATION, TESTING & COMMISSIONIN G OFALTERNATE DEWA-TP APPROVED DELUGE	5	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VALVE ASSEMBLY &amp; GATE VALVES INCLUDING ASSOCIATED WORKS AT MBRSTATE 132KV SUBSTATION SCOPE OF WORKS COVERED BUT NOT LIMITED TO THE FOLLOWING: SCHEDULE OF VALVES TO BE REPLACED</p> <p>SL# DESCRIPTION# EXISTING MAKE# MODEL# SIZE# QTY # LOCATION #1. ## OS&amp;Y GATE VALVE # FLUID # F722F#10 INCH #2# FWT 1&amp;2 OUTLET #2. ## OS&amp;Y GATE VALVE # FLUID # F722F#8 INCH#11# INSIDE FP ROOM #3. ## OS&amp;Y GATE VALVE # FLUID # F722F#6 INCH#14# FIRE MAINS &amp; HYDRANT #4. ## OS&amp;Y GATE VALVE # FLUID # F722F#4 INCH#8# FWT 1 &amp;2 INFILLING, IDT-1,2&amp;3 MANIFOLD, WET RISER 1&amp;2 #5. ## OS&amp;Y GATE VALVE # FLUID # F722F#3 INCH#5# SHX-1&amp;2, FWT 1&amp;2, DRAIN AND FP SPRINKLER #6. ## OS&amp;Y GATE VALVE # FLUID # F722F#2 1/2 INCH#3# ET-1,2&amp;3 MANIFOLD# SL# DESCRIPTION# EXISTING MAKE# MODEL# SIZE# QTY # LOCATION #1. ## DELUGE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VALVE WITH TRIM #FLUID #FDV-10#4 INCH#3#IDT-1,2&amp;3 #2.##DELUGE VALVE WITH TRIM #FLUID #FDV-10#3 INCH#2#SHX-1&amp;2 #3.##DELUGE VALVE WIT H TRIM #FLUID #FX#2 INCH#3#ET-1,2&amp;3#.#NEW DELUGE VALVE WITH TRIM ASSEMBLY &amp; OS&amp;Y GATE VALVE SHALL BEDEWA-TP APPROVED MODEL.# REFER T ABLE ABOVE FOR AREA AND SIZE.#EXISTING WET PILOT LINE TO BE RETAINED.#NECESSARY MODIFICATIONS IN MANIFOLD AS REQUIRED BY SITE COND ITION.#WORKS SHALL BE CARRIED OUT BY TP-APPROVED FPS CONTRACTOR ORCONTRACTORS WITH EXPERIENCE IN SIMILAR JOBS IN DEWA TP 132 KV OR 400 KVSUBSTATION.#INTERFACING AND TESTING OF NEW DELUGE PRESSURE SWITCHES WITH EXISTINGFIRE ALARM CONTROL PANEL / SCADA.#ALL ASSOC IATED CIVIL AND ELECTRICAL WORKS REQUIRED FOR THE JOB.#ALL MANIFOLDS TO BE PAINTED INCLUDING RISER PIPE.#DELUGE RESETTING</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROCEDUR E (ANODIZED ALUMINIUM PLATE) SHALL BE FIXEDNEAR ALL MANIFOLDS.#ANY DELUGE VALVE IDENTIFICATION PLATE MISSING TO BE PROVIDED.#EXISTI NG DELUGE ISOLATION VALVE WITH TRIM TO BE REPLACED WITH NEWDEWA-TP APPROVED MODELS.#NEW SUPERVISORY SWITCH TO BE PROVIDED FOR EXIST ING ONES AT SITE.#PROVISION OF NEW SUPERVISORY SWITCH, ADDITIONAL FIRE ALARM MODULE ANDASSOCIATE FIRE ALARM PROGRAMMING ARE NOT PAR T OF THE SCOPE.#NEW PRV AND ARV SHALL BE PROVIDED IN ALL MANIFOLDS WITH DEDICATEDISOLATION VALVES.#ALL SCRAP MATERIALS TO BE SHIFTE D TO DEWA RUWAIYYAH SCRAPYARD, AS PERDEWA INSTRUCTION.#ISOLATION OF FIRE PROTECTION SHALL BE MINIMAL. PREFABRICATED PIPINGASSEMBLIE S SHALL BE USED WHEREVER POSSIBLE.#HYDROSTATIC PRESSURE TEST TO BE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PERFORMED FOR REPLACED ITEMS,WHEREVER APPLICABLE.#SUCCESSFUL DIS CHARGE TEST TO BE PERFORMED FOR FINAL ACCEPTANCE.#AS BUILT DRAWINGS, O&M MANUALS AND TEST REPORTS SHALL BE PROVIDED ASPER DEWA REQUIREMENTS.#ALL TOOLS, LIFTING EQUIPMENT#S, SCAFFOLDING, LADDERS AND TESTINGEQUIPMENTS REQUIRED FOR THE JOB IS CONTRACTOR SCOPE.#ADD ITIONAL CABLING WORKS WHEREVER REQUIRED.#CONTRACTOR MUST FOLLOW DEWA OUTAGE SCHEDULES WHEREVER APPLICABLE,DURING THE EXECUTION OF JOB.#CONTRACTOR MUST FOLLOW ALL DEWA SAFETY RULES AND FORMALITIES DURINGTHE EXECUTION OF THE JOB.#CONTRACTOR SHALL ACCEPT FULL RESPONSIBILITY FOR ANY DAMAGE THAT MAYBE CAUSED TO ANY PLANTS DUE TO NEGLIGENCE.#POWER SUPPLY AND WATER REQUIRED FOR THE WORK WILL BE PROVIDED BYDEWA.#WARRANTY OF TWO YEAR						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR THE ENTIRE JOB, FROM THE DATE OF FINALACCEPTANCE 2. SPECIFICATION2.1 DELUGE VALVE SETS S</p> <p>HALL INCLUDE: --#STOP VALVE OF APPROVED CONSTRUCTION WITH AN INDICATOR SHOWING "OPEN"AND "CLOSED" POSITIONS, COMPLETE WITH PADLOCKED</p> <p>SECURING STRAPS. THEVALVE SHALL BE MOUNTED ON THE INCOMING SIDE OF THE ALARM OR DELUGEVALVE. ALL VALVES SHALL BE FLANGED OS &amp; Y AND</p> <p>RESILIENT SEATED TYPE. ALLVALVES SHALL BE EASILY ACCESSIBLE OR PROVIDE PERMANENT PLATFORM FOROPERATION AND MAINTENANCE PURPOSE..#AL</p> <p>L SUCH VALVES AND VALVE SEATS SHALL BE LEAK TIGHT UNDER ALLPRESSURE UP TO THE TEST PRESSURE OF THE SYSTEM. EACH CONTROL VALVESTATION</p> <p>SHALL BE PROVIDED WITH INDIVIDUAL MECHANICAL ALARM. ADEQUATETESTING ARRANGEMENT SHALL BE PROVIDED WITHOUT SPRAY THE FIREWATER TOHAZ</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ARD.#EACH PRESSURE (ALARM) SWITCH SHALL HAVE TWO SEPARATE OPERATINGSWITCHES. RANGE OF ALARM PRESSURE SWITCHES SHALL BE 0 ~ 20 PSI ( FACTORYSET).#DIAL PRESSURE GAUGES (WITH ANTI-VIBRATION FLUID), WEATHERPROOF, 4INCH DIAL, SS BODY, ARRANGED TO MONITOR THE WATER PRE SSURES ABOVE ANDBELOW THE DELUGE VALVE SET THAT MEANS EACH DELUGE VALVE SHOULD HAVE TWODIAL PRESSURE GAUGES. EACH GAUGE SHALL BE PRO VIDED WITH A THREE-WAYISOLATING VALVE SO THAT IT CAN BE EASILY ISOLATED AND REMOVED FORTESTING AND CHECKING WITHOUT SHUTTING DOWN TH E WATER SUPPLY.#ARRANGEMENT SHOULD BE PROVIDED FOR TESTING THE OPERATION OFWATER-MOTOR-ALARM WHILE KEEPING DELUGE ISOLATION VALVE C LOSED.#MANUAL RELEASE DEVICES (BOX TYPE) SHALL BE PROVIDED FOR ALL DELUGEVALVES. SUCH DEVICES SHALL BE CONTROLLED FROM</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>READILY ACCE SSIBLELOCATIONS IN THE EVENT OF FIRE. CONTROL SHALL BE MECHANICAL. MANUALRELEASE DEVICES ARE TO BE FITTED WITH A WIRE SEAL.#PROVIDE LABELS/MARKING TO EACH DRAIN VALVE, TRIM COMPONENTS WITHRESPECTIVE TRANSFORMERS.#DELUGE VALVE TO BE RED IN COLOR.#NEW ALARM GONG AND MANUAL RELEASE BOX TO BE PROVIDED.PIPES AND FITTINGS:STANDARD WEIGHT STEEL PIPE ASTM A53, SEAMLESS, SCHEDULE-40, FACTORYGALVANIZ ED.#ALL THE PIPING OF SIZE 2" DIA &amp; BELOW SHALL BE THREADED TYPE &amp; MILLGALVANIZED, AND 2.5" DIA &amp; ABOVE SHALL BE HOP DIP GALVANIZED AFTERFABRICATION &amp; WELDING.ALL FITTINGS AND FIXTURES FOR PIPE WORK SHALL BE OF SEAMLESS CARBONSTEEL SCHEDULE 40, HOT DIPPED GALVANIZ ED AND PAINTED TO COLOR RED.USE OF WELDED JOINTS WITH GALVANIZED STEEL PIPES NOT</p>						



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ACCEPTABLE.DEWA TP APPROVED PIPES AND FITTINGS. PAI</p> <p>NTINGALL SURFACES OF PIPES AND FITTINGS SHOULD BE CLEAN, DRY AND FREE FROMCONTAMINATIONPAINTING SHALL BE DONE AS PER PAINT MANUFACTU</p> <p>RER#S SPECIFICATION. TWOCOAT OF RED OXIDE AND TWO COAT OF GLOSS RED PAINT BY MIXING WITH PROPERRATIO OF BASE AND CURING AGENT WITH T</p> <p>HINNER. EXPOSED PIPE WORK SHALLADDITIONALLY BE PAINTED ONE COAT GLOSS RED.SPECIFICATION AND METHOD STATEMENT FROM PAINT MANUFACTURER SHALL BESUBMITTED FOR DEWA APPROVAL FLUSHINGALL PIPE WORKS INSTALLED UNDER THIS CONTRACT SHALL BE THOROUGHLY FLUSHEDWITH WATER IN ORDER TO REMOVE FOREIGN MATER.GENERALTHE CONTRACTOR SHALL SUBMIT TECHNICAL OFFER WITH FULL DETAILED WORKINGPROGRAM TO EXECUTE THIS J OB. THE CONTRACTOR MUST COMPLETE THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			EXECUTION OF THE PROJECT WITH 6 MONTHS PERIOD. THIS WORK PLAN PROGRAM SHALL INCLUDE BUT NOT LIMITED TO THE FOLLOWINGS: O# MATERIAL SUBMITTAL SO# INSTALLATION O# COMMISSIONING DATE O# SYSTEM HAND OVER DATE FOR SITE VISIT AND ENTRY PERMIT, CONTACT THE FOLLOWING ENGINEER MR. SABYUR RAHMAN SHEIK ABDUL KADER (MOB: 0553000627) / MR. MOHD YACOOB NAVEED (MOB: 0559761412) AND FOR OTHER TECHNICAL QUERIES CONTACT MR. VISHNU VIJAY (MOB: 0509463644)						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

Float to all FPS Contractors; Contact Person: Vishnu Vijay /  
vishnu.vijay@dewa.gov.ae / 04-32 21393 / 509463644

### STANDARD TERMS & CONDITIONS

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412401091  
**DATE** : 24.07.2024  
**REQ No** : 1032400529  
**REQ TITLE** : MBRSTATE-Repl.of Fluid Make  
**DELIVERY LOCATION**  
**CLOSING DATE** : 02.08.2024  
**CLOSING TIME** : 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**