

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	7000000011		SUPPLY & INSTALLATION OF 7 NOS. OF SPLIT A/C UNITS IN M-EXT 70UBA01 LERS& MV SWGR ROOM AND 3 NOS. IN 70UBA02 LER ROOM. (TOTAL: 10 UNITS)MAKE: O-GENERAL/ MITSUBISHI/ WHITE WESTING HOUSE.ELECTRICAL SUPPLY: 220VAC 50HZRATING: 2.5TR AT 50 DEG.C WITH HFC REFRIGERANTSCO PE OF WORK:1) ALL THE REFRIGERANT PIPING SHALL BE INSULATED AND LAID IN GRPTRUNKING FOR OUTDOOR AREA AND PVC TRUNKING FOR INDOOR ARE A.2) CONTROL CABLING FROM INDOOR TO OUTDOOR UNIT SHALL BE LAID IN GICONDUIT PIPE/ GI COPEX (SAMPLE TO BE SUBMITTED FOR APPROVAL).3) ELECTRICAL POWER SUPPLY SHALL BE TAKEN FROM THE NEAREST DISTRIBUTIONPANEL.4) POWER CABLE FROM DISTRIBUTION PANEL TO LOCAL ISOLATOR A ND FROMISOLATOR TO THE OUTDOOR UNIT SHALL BE LAID IN GI CONDUIT PIPE/ GI COPEX.5) PVC DRAIN WITH INSULATION SHALL BE INSTALLED AND R	10	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OUTED TO THE NEAREST DRAIN POINT. DRAIN PIPE SHOULD BE WRAPPED WITH FOSTERING. 6) OUTDOOR UNIT SHALL BE MOUNTED ON GI FRAME/ CONCRETE BLOCK, AS PER SITE REQUIREMENT. 7) THE FRAME SHALL BE PAINTED WITH ANTI-CORROSIVE PAINT OR CONCRETE BLOCK SHALL BE PLASTERED AND PAINTED. 8) CORNER DRILLING SHALL BE DONE AT ALL WALL CROSSINGS FOR ROUTING REFRIGERANT & DRAIN LINES AND CABLES. ALL SUCH OPENINGS SHALL BE SEALED PROPERLY WITH FIRE SEALANT AND PAINTED. 9) IDENTIFICATION TAGS SHALL BE INSTALLED FOR THE INDOOR & OUTDOOR AC UNITS, ALL CABLES AND TRUNKS/CONDUITS. 10) EARTHING SHALL BE DONE CONTINUOUSLY AT ALL JOINTS OF CONDUIT/TRUNKS. OUTDOOR A/C UNITS SHALL BE EARTHED PROPERLY. 11) TESTING & COMMISSIONING OF THE UNITS, ALL THE COMMISSIONING REPORTS TO BE SUBMITTED. 12) THE FOLLOWING DOCUMENTS</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SHALL BE SUBMITTED AT THE TIME OF DELIVERY:A)CERTIFICATE OF WARRANTY FOR 1 YEAR FOR THE A/C UNITS AND FOR 5 YEARSFOR THE COMPRESSORS.B)O&M MANUAL AND C ONTROL CIRCUIT DRAWINGS OF THE UNITS.13)CONTRACTOR SHALL VISIT DEWA M-STATION SITE, TO FAMILIARIZE WITH SITELAYOUT AND REQUIREMENTS, BEFORE QUOTING. FOR ANY CLARIFICATION, PLEASECONTACT MR. MUMTAZ (04-3225864/ 055-6471260).						
2	7000000011		SUPPLY & INSTALLATION OF 4 NOS. OF SPLIT A/C UNITS IN M STATION (AUXBOILER CEMS 50 & 60. (TOTAL: 4 UNITS)MAKE: O-GENERAL/ MITSUBISHI / WHITE WESTING HOUSE/ SKM.ELECTRICAL SUPPLY: 220VAC 50HZRATING: 1.5TR AT 50 DEG.C AMBIENT WITH HFC REFRIGERANT.SCOPE OF WORK:1) EXI STINGS UNIT SHALL BE ISOLATED AND ITS REFRIGERANT TO BE RECOVERED2) ALL THE REFRIGERANT PIPING SHALL BE INSULATED AND LAID IN GRPTRU	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>NKING FOR OUTDOOR AREA AND PVC TRUNKING FOR INDOOR AREA.3) CONTROL CABLING FROM INDOOR TO OUTDOOR UNIT SHALL BE LAID IN GICONDUIT PI</p> <p>PE (LONG LENGTH)/ GI COPEXA FOR SHORT LENGTH (SAMPLE TO BESUBMITTED FOR APPROVAL).4) ELECTRICAL POWER SUPPLY SHALL BE TAKEN FROM EXI</p> <p>STING SOCKET. EXISTINGSOCKET SHALL BE REPLACED WITH THE ISOLATOR.5) POWER CABLE FROM DISTRIBUTION PANEL TO LOCAL ISOLATOR AND FROMIS</p> <p>OLATOR TO THE OUTDOOR UNIT SHALL BE LAID IN GI CONDUIT PIPE/ GI COPEX.6) PVC DRAIN WITH INSULATION SHALL BE ROUTED TO THE NEAREST DR</p> <p>AINPOINT.FOSTERING TO BE DONE FOR DRAIN PIPE.7) OUTDOOR UNIT SHALL BE MOUNTED ON GI FRAME/ CONCRETE BLOCK, AS PERSITE REQUIREMENT.8)</p> <p>THE FRAME SHALL BE PAINTED WITH ANTI-CORROSIVE PAINT OR CONCRETEBLOCK SHALL PLASTERED AND PAINTED.9) CORE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DRILLING SHALL BE DONE AT ALL WALL CROSSINGS FOR ROUTING THEREFRIGERANT & DRAIN LINES AND CABLES. ALL SUCH OPENINGS SHALL BE SEALED PROPERLY WITH FIRE SEALANT AND PAINTED.10) IDENTIFICATION TAGS SHALL BE INSTALLED FOR THE INDOOR & OUTDOOR ACUNITS, ALL CABLES AND TRUNK/CONDUITS.11) EARTHING SHALL BE DONE CONTINUOUSLY AT ALL JOINTS OF CONDUIT/TRUNKS.OUTDOOR A/C UNITS SHALL BE EARTHED PROPERLY.12) TESTING & COMMISSIONING OF THE UNITS, ALL THE COMMISSIONING REPORTS TO BE SUBMITTED.13) THE FOLLOWING DOCUMENTS SHALL BE SUBMITTED AT THE TIME OF DELIVERY:A) CERTIFICATE OF WARRANTY FOR 1 YEAR FOR THE A/C UNITS AND FOR 5 YEARS FOR THE COMPRESSORS.B) O&M MANUAL AND CONTROL CIRCUIT DRAWINGS OF THE UNITS.14) CONTRACTOR SHALL VISIT DEWA M-STATION SITE, TO FAMILIARIZE WITH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SITELAYOUT AND REQUIREMENTS, BEFORE QUOTING. FOR ANY CLARIFICATION, PLEASE CONTACT MR. MUMTAZ (04-3225864/ 055-6471260, EMAIL:MUMTAZ.ABRO@DEWA.GOV.AE).						
3	7000000011		SUPPLY & INSTALLATION OF 2 NOS. OF SPLIT A/C UNITS FOR OLD CLO2 SKID.MAKE: O-GENERAL/ MITSUBISHI/ WHITE WESTING HOUSE/ SKM.ELECTRICAL SUPPLY: 220VAC 50HZ RATING: 1.5TR AT 50 DEG.C AMBIENT WITH HFC REFRIGERANT.INDOOR UNIT SHALL BE CHEMICAL RESISTANT AND OUTDOOR UNIT SHALL BE COATED ANTI-CORROSIVE.SCOPE OF WORK:1) EXISTING UNIT SHALL BE ISOLATED AND ITS REFRIGERANT TO BE RECOVERED2) ALL THE REFRIGERANT PIPING SHALL BE INSULATED AND LAID IN GRP TRUNKING FOR OUTDOOR AREA AND PVC TRUNKING FOR INDOOR AREA.3) CONTROL CABLING FROM INDOOR TO OUTDOOR UNIT SHALL BE LAID IN GI CONDUIT PIPE (LONG LENGTH)/ GI COPEX FOR	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SHORT LENGTH (SAMPLE TO BE SUBMITTED FOR APPROVAL)</p> <p>.4) ELECTRICAL POWER SUPPLY SHALL BE TAKEN FROM EXISTING SOCKET. EXISTING SOCKET SHALL BE REPLACED WITH THE ISOLATOR.5) POWER CABLE FROM DISTRIBUTION PANEL TO LOCAL ISOLATOR AND FROM ISOLATOR TO THE OUTDOOR UNIT SHALL BE LAID IN GI CONDUIT PIPE/ GI COPEX.6) PVC DRAIN WITH INSULATION SHALL BE ROUTED TO THE NEAREST DRAINPOINT. FOSTERING TO BE DONE FOR DRAIN PIPE.7) OUTDOOR UNIT SHALL BE MOUNTED ON GI FRAME/ CONCRETE BLOCK, AS PER SITE REQUIREMENT.8) THE FRAME SHALL BE PAINTED WITH ANTI-CORROSIVE PAINT OR CONCRETE BLOCK SHALL BE PLASTERED AND PAINTED.9) CORE DRILLING SHALL BE DONE AT ALL WALL CROSSINGS FOR ROUTING THEREFRIGERANT & DRAIN LINES AND CABLES. ALL SUCH OPENINGS SHALL BE SEALED PROPERLY WITH</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FIRE SEALANT AND PAINTED.10) IDENTIFICATION TAGS SHALL BE INSTALLED FOR THE INDOOR & OUTDOOR</p> <p>ACUNITS, ALL CABLES AND TRUNK/CONDUITS.11) EARTHING SHALL BE DONE CONTINUOUSLY AT ALL JOINTS OF CONDUIT/TRUNKS.OUTDOOR A/C UNITS SHALL BE EARTHED PROPERLY.12) TESTING & COMMISSIONING OF THE UNITS, ALL THE COMMISSIONING REPORTS TO BE SUBMITTED.13) THE FOLLOWING DOCUMENTS SHALL BE SUBMITTED AT THE TIME OF DELIVERY:A)CERTIFICATE OF WARRANTY FOR 1 YEAR FOR THE A/C UNITS AND FOR 5 YEARS FOR THE COMPRESSORS.B)O&M MANUAL AND CONTROL CIRCUIT DRAWINGS OF THE UNITS.14)CONTRACTOR SHALL VISIT DEWA M-STATION SITE, TO FAMILIARIZE WITH SITE LAYOUT AND REQUIREMENTS, BEFORE QUOTING. FOR ANY CLARIFICATION, PLEASE CONTACT MR. MUMTAZ (04-3225864/ 055-6471260, EMAIL:MUMTAZ.ABR</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			O@DEWA.GOV.AE).						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Split A/Cs

STANDARD TERMS & CONDITIONS

- Prices should be 'DDP' delivery duty paid at DEWA stores.
- Quotation to be submitted only in local currency U.A.E Dirhams
- DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412401693
DATE : 30.10.2024
REQ No : 1172400413
REQ TITLE : Split A/Cs 1172400413
DELIVERY LOCATION : 0022 - M STORE
CLOSING DATE : 05.11.2024
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP