

RFQ NUMBER : 2412500636

DATE : 22.04.2025

REQ No : 1032501371

REQ TITLE: REFURBISHMENT 1032501371

DELIVERY LOCATION

CLOSING DATE : 29.04.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	METHOD STATEMENT FOR REFURBISHMENT OF	1	EA				
			FIRE WATER TANKSSUBSTATION & TANK: SRSLG						
			_FWT-1SAFETY MEASURES1.#AN APPROVED PTW						
			AND MOS MUST						
			BE AVAILABLE ON-SITE.2.#ALL ACTIVITIES WILL BE						
			SUPERVISED BY DESIGNATED DEWA						
			PERSONNEL.3.#ALL RELEVANT SAFETY						
			PROCEDURES, INCLUDING						
			THE USE OF PPE AND HAZARDMITIGATION						
			MEASURES, MUST BE STRICTLY						
			FOLLOWED.CONTRACTOR SCOPE OF						
			WORK1.#SUPPLY AND INSTALLATION OF TOOLS						
			AND EQUIPMENT:O#PROVIDE ALL NECESSARY						
			TOOLS, SCAFFOLDING, AND EQUIPMENT						
			REQUIRED FORTHE REFURBISHMENT, INCLUDING						
			MATERIALS FOR SHEET						
			REMOVAL, INSTALLATION, AND SAFETY						
			SYSTEMS.2.#REPLACEMENT OF						
			SHEETS:O#REPLACE ALL BOTTOM LAYER SHEETS						
			AS PART OF THE REFURBISHMENT PR						
			OCESS.O#ANY ADDITIONAL SHEETS IDENTIFIED AS						
			DEFECTIVE DURING INSPECTION ORREQUESTED						
			BY THE DEWA SUPERVISOR, INCLUDING THOSE						



RFQ NUMBER : 2412500636

DATE : 22.04.2025

REQ No : 1032501371

REQ TITLE : REFURBISHMENT 1032501371

DELIVERY LOCATION

CLOSING DATE : 29.04.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ABOVE TH						
			E BOTTOMLAYER, SHALL ALSO BE						
			REPLACED.O#BEFORE AND AFTER PHOTOS OF						
			REPLACED SHEETS MUST BE TAKEN						
			FORDOCUMENTATION, ALONG WITH CLEAR						
			RECORDS OF THE WORK PERFORMED.3.#TANK						
			ACCESS AND PREPARATIONS:O#DRAIN THE TANK						
			COMPLETELY AND ENTER USING THE LOW-LEVEL						
			MANWAY ORINT						
			ERNAL LADDER. REMOVE ONE BOTTOM SHEET IF						
			REQUIRED FOR ACCESS.O#REMOVE ANY						
			RESIDUAL WATER AND SILT NOT DRAINED VIA THE						
			VALVE USINGPUM						
			PS.O#DISASSEMBLE AND SAFELY STORE ALL						
			FITTINGS, INCLUDING SUCTION, DRAIN, AND GAUGE						
			COMPONENTS.4.#LINER AND BASE						
			PREPARATIONS:O#CUT A						
			ND REMOVE THE BOTTOM LINER PORTION,						
			FOLLOWED BY A THOROUGHCLEANING OF THE						
			BASE.O#REMOVE THE REMAINING LINER						
			SECTIONS AFTER SCAFFOLDI						
			NG INSTALLATION.5.#SCAFFOLDING AND ROOF						
			WORK:O#INSTALL SCAFFOLDING TO ACCESS THE						



RFQ NUMBER : 2412500636

DATE : 22.04.2025

REQ No : 1032501371

REQ TITLE : REFURBISHMENT 1032501371

DELIVERY LOCATION

CLOSING DATE : 29.04.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TANK'S TOP SECTION.O#REMOVE ROOF						
			SUPPORTS AND ROOF						
			SHEETS CAREFULLY. CLEAN AND STORE						
			ROOFSHEETS FOR REUSE.6.#INSPECTION AND						
			REPLACEMENT OF SHEETS:O#CONDUCT AN						
			INTERNAL INSPECTION OF T						
			HE TANK, STARTING WITH THE BOTTOMROW						
			SHEETS. IDENTIFY AND MARK DEFECTIVE SHEETS						
			WITH VISIBLE PITTING,HOLES, OR						
			CORROSION.O#TO BE DIS						
			CUSSED BEFORE APPLIED THIS POINT: REPLACE						
			DEFECTIVE SHEETSWITH NEW ONES OF THE SAME						
			OR SLIGHTLY INCREASED THICKNESS (UP TO 0.5						
			MMHIG						
			HER BUT NOT EXCEEDING 3.0 MM). ALIGN AND						
			MATCH BOLT HOLES						
			DURINGINSTALLATION.O#APPLY A 3-LAYER						
			MARINE-GRADE COATING TO THE REPLACED						
			SHEETS ANDDRILLED AREAS.O#TAKE DETAILED						
			PHOTOS BEFORE AND AFTER THE REPLACEMENT						
			PROCESS						
			FORDOCUMENTATION.7.#REINSTALLATION OF						
			ROOF A						



RFQ NUMBER : 2412500636

DATE : 22.04.2025

REQ No : 1032501371

REQ TITLE : REFURBISHMENT 1032501371

DELIVERY LOCATION

CLOSING DATE : 29.04.2025

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ND SUPPORTS:O#REINSTALL NEW ROOF						
			SUPPORTS AND ROOF SHEETS, ENSURING						
			STRUCTURALINTEGRITY.8.#LINER AND FITTINGS						
			INSTALLATION:O#INSTALL						
			A NEW LINER AND MATTING BAG USING A ROPE						
			AND PULLEY SYSTEM, ALIGNING WITH SUMP						
			POSITIONS IF APPLICABLE.O#REPLACE INTERNAL						
			FLANGES (G						
			AUGE/DRAIN) WITH STAINLESS						
			STEELCOMPONENTS IF EXISTING ONES ARE						
			GALVANIZED IRON.9.#FINAL COMPONENTS AND						
			TESTING:O#CLEAN AND REINSTAL						
			L THE CONTENT GAUGE, ENSURING ACCURATE						
			READINGS.REPLACE THE NON-RETURN VALVE						
			(NRV) IF DAMAGED.O#REFILL THE TANK						
			INCREMENTALLY, SHEET						
			BY SHEET, WHILE INSPECTING						
			FORLEAKS.O#VERIFY THE TANK'S INTEGRITY TO						
			ENSURE NO LEAKAGES.10.#SITE CLEARANCE AND						
			DOCUMENTATION:O#REMO						
			VE AND DISPOSE OF ALL DISMANTLED SHEETS,						
			LINER SECTIONS, ANDDEBRIS IN COMPLIANCE						
			WITH DEWA#S ENVIRONMENTAL						



RFQ NUMBER : 2412500636

DATE : 22.04.2025

REQ No : 1032501371

REQ TITLE : REFURBISHMENT 1032501371

DELIVERY LOCATION

CLOSING DATE : 29.04.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			GUIDELINES.O#PROVIDE A DE						
			TAILED SITE ACCEPTANCE TEST (SAT) REPORT						
			UPON PROJECTCOMPLETION, INCLUDING ALL						
			BEFORE-AND-AFTER PHOTOS.11.#GENERAL						
			REQUIREMENTS:O#AD						
			HERE TO DEWA#S HEALTH, SAFETY, AND						
			OPERATIONAL PROCEDURESTHROUGHOUT THE						
			PROJECT.O#USE ONLY EXPERIENCED AND						
			CERTIFIED TECHNICIANS. CE						
			RTIFICATES OFCOMPETENCY MUST BE						
			PROVIDED.O#FOLLOW DEWA#S OFFICIAL						
			WORKING HOURS DURING PROJECT						
			EXECUTION.O#PROVIDE A 10-YEAR WARRANT						
			Y ON SUPPLIED COMPONENTS AND						
			INSTALLATION.12.#ACCOUNTABILITY:O#ANY						
			DAMAGE TO ASSETS OR EQUIPMENT DURING THE						
			PROJECT EXECUTION WILLBE						
			THE CONTRACTOR'S RESPONSIBILITY, AND THEY						
			WILL BE HELD LIABLE FORRECTIFICATION.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

REFURBISHMENT

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.



RFQ NUMBER : 2412500636

DATE : 22.04.2025

REQ No : 1032501371

REQ TITLE : REFURBISHMENT 1032501371

DELIVERY LOCATION

CLOSING DATE : 29.04.2025

CLOSING TIME : 10:00:00

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP