

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412500889
DATE : 09.06.2025
REQ No : 1032502296
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 13.06.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	REMOVAL/RETRIEVAL OF FAULTY/DETECTIVE SUBMERSIBLE PUMP-MOTOR SETS WITHGI RAISER PIPES, DIPPING TUBE AND ITS FITTINGS FROM THE WELLS ANDINSTALLATION OF THE SAME ON THE SAME WELL FOR MARGHAM, NAJWA, HABAB &WAHOOSH WELLFIELDPLEASE CONTACT MR. REHMAN (050-5340018) FOR FURTHER CLARIFICATIONS.1.0#SCOPE OF WORKTHE SCOPES OF WORKS FOR THE PREVENTIVE & CORRECTIVE MAINTENANCE OF THEWELLS FIELD ARE FOLLO WS.#SUBMERSIBLE PUMP-MOTOR SPECIFICATIONS.#CAPACITY:##7.5 # 20 M3/HR, MOTOR-15 KW, 10KW, 7.5KW, 5KW.#HEAD:###288 # 147 M (VARIES BAS ED ON THE CAPACITY).#RPM:###3500#DETAILS OF WELLS.#THE TOTAL NO OF WELLS - 50NO#S.#THE AVERAGE DEPTH OF WELLS- 300FT.#GI PIPE DIAME TER 3# (EACH 10FT LENGTH).SCOPE OF WORKS (MECHANICAL)A.#REMOVAL/RETRIEVAL OF FAULTY/DETECTIVE SUBMERSIBLE PUMP-MOTOR	50	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412500889
DATE : 09.06.2025
REQ No : 1032502296
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 13.06.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SETSWITH GI RAI SER PIPES, DIPPING TUBE AND ITS FITTINGS FROM THE WELLS ANDSHIFTING THE PUMP-MOTOR SETS ALONG WITH PIPES TO WORKSHOP FOR REPAIRING/ MAINTENANCE PURPOSE IF REQUIRED, AS DIRECTED BY THE DEWA ENGINEERS.B.#INSTALLATION OF SUBMERSIBLE PUMP-MOTOR SET IN THE BORE WELL AL ONGWITH REPLACEMENT OF GI RAISER PIPES, DIPPING TUBES AND PIPE FITTINGS.C.#REPLACEMENT OF PUMP OUTLET CONNECTION ALONG WITH ENTIRE F ITTINGSLIKE- GATE VALVES, UNION. SOCKET, FLOW METER, NRV, AIR RELEASE VALVESETC. IF REQUIRES.D.#EXISTING DIPPIING TUBE & LEVEL RELAY SHALL BE REPLACED IF FOUND DAMAGE OTHERWISE SAME WILL BE INSTALLED IN THE RESPECTIVE WELL.E.#THE WELL NOT HAVING DIPPING TUBE SHALL BE INSTALLED AND WFO (WELLFIELD OPERATION, DEWA) WILL TEST THE DYNAMIC & STATIC LEVEL.</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412500889
DATE : 09.06.2025
REQ No : 1032502296
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 13.06.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ONCE WFO SATISFIED, THE PUMP WILL BE RETRIEVED AGAIN, ADD THE LEVEL RELAY AND REINSTALL THE PUMP.F.#INSTALLATION OF METAL / PVC PIPES FOR WELL CONNECTION AND CONSUMER CONNECTION, I F REQUIRES.G.#MODIFICATION OF THE EXISTING SYSTEM AS PER SITE REQUIREMENT IF REQUIRES.H.#WELL FLUSHING AND INSTALLATION OF CASING INSIDE THE EXISTING WELLS, IF REQUIRES.I.#PERFORMANCE TESTING OF THE WELL.SCOPE OF WORKS (ELECTRICAL) DETAILS OF ELECTRICAL SCOPE OF WORKS ON SUBMERSIBLE PUMP RETRIEVAL & RE-INSTALLATION Ø#UPON RECEIVING THE MOTOR AND CABLES THE CONTRACTOR ELECTRICIAN HAS TO CHECK FOR ANY PHYSICAL DAMAGE, IF ANY REPORT THE SAME IMMEDIATELY TO DEWA REPRESENTATIVES. Ø#INSULATION RESISTANCE TEST SHALL BE CARRIED OUT ON MOTORS AND CABLES BEFORE AND AFTER INSTALLING</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412500889
DATE : 09.06.2025
REQ No : 1032502296
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 13.06.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE PUMP USING AN INSULATION MEASURING UNIT(500 VDC) AND ENSURE THAT THE BELOW MINIMUM INSULATION RESISTANCE (500VDC;1 MIN;20 DEGREE C) WITH EXTENSION CABLE -#FOR A NEW MOTOR > 4 MEGA OHM -#FOR A USED MOTOR > 1 MEGA OHMAFTER INSTALLATION OF THE PUMP AND BEFORE CONNECTING THE MOTOR LEADS TOTHE STARTERS THE FOLLOWING POINTS HAS TO BE CHECKED AND VERIFIED.Ø#STARTER HAS TO BE CHECKED FOR PROPER VOLTAGE LEVEL (380 # 400 VAC &THE VOLTAGE TOLERANCE -10% TO +6% FOR 50 HZ) AT INCOMER MCCB AND MOTORLEAD CONNECTION TERMINALS.Ø#PROPER OPERATION OF THE LEVEL RELAY, ELCB, AND OLR HAS TO BESIMULATED AND CHECKED.Ø#OVERLOAD RELAY SETTING HAS TO BE ADJUSTED ACCORDING THE MOTORCURRENT.Ø#MOTOR LEADS TO BE CONNECTED TO THE DOL STARTER AND TEST RUN TO BECONDUCTED.Ø#VERIFY</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412500889
DATE : 09.06.2025
REQ No : 1032502296
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 13.06.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>DIRECTION OF MOTOR ROTATION AND CORRECT THE SAME IF REQUIRED.Ø#PUMP INSTALLATION / RETRIEVAL REPORT HAS TO BE FILLED PROPERLY ANDHAS TO BE RETURNED TO THE DEWA REPRESENTATIVES.Ø#IF ANY DIFFICULTY ARISES DURING THE INSTALLATI ON / RETRIEVAL, THESAME MUST BE REPORT TO DEWA REPRESENTATIVE IMMEDIATELY.Ø#IN PUMP RETRIEVAL CASE THE PUMP- MOTOR SET, PUMP DROP CA BLE AND LEVELWIRES HAS TO BE COILED IN PROPER WAY AND HANDED OVER TO DEWAREPRESENTATIVES FOR INSPECTION, TESTING AND REPAIR.Ø#ALL EL ECTRICAL WORKS CARRIED OUT MUST BE COMPLIED WITH DEWA STANDARD& TERMS AND CONDITIONS.2.0#PRIOR TO SUBMISSION OF QUOTATION, THE FOLLO WING SHALL BE DETERMINEDCAREFULLY:A.#THE CONTRACTOR SHALL VISIT THE SITE AND MAKE HIMSELF FULLY FAMILIARWITH THE WORK SCOPES, COMPLE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412500889
DATE : 09.06.2025
REQ No : 1032502296
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 13.06.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>XITIES, ETC., BEFORE SUBMITTING THE QUOTATION. B.# DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES /PRICES DURING AND AFTER THE EXECUTION OF WORK ORDERED. C.# THE CONTRACTOR SHOULD SUBMIT THE TIME SCHEDULE /BAR CHART INDICATING EACH ACTIVITY. D.# ON COMPLETION OF THE WORK, THE INSPECTION CHECKLIST OF QUALITY PROCEDURES, WHEREVER APPLICABLE SHOULD BE FILLED IN AND SUBMITTED. 4.0# TAKE OVER ON COMPLETION OF ALL WORK WITHIN THE SCOPE OF THE CONTRACT, FOR ACCEPTANCE OF THE MAINTENANCE WORK, CONTRACTOR SHALL NOTIFY DEWA IN WRITING. A CERTIFICATE OF COMPLETION WILL BE ISSUED BY DEWA ON FINAL INSPECTION ONLY WHEN THE CONTRACT WORK IS DEEMED TO HAVE BEEN TAKEN OVER BY DEWA AFTER NECESSARY CONDITION MONITORING CHECKS WHEREVER & WHENEVER REQUIRED. 5.0# WARRANTY A.# ALL THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412500889
DATE : 09.06.2025
REQ No : 1032502296
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 13.06.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>WORK CARRIED OUT SHALL L CARRY A WARRANTY FOR 8000 HOURS OFOPERATION OR 1 YEAR WHICHEVER IS EARLIER.B.#THE GUARANTEE WILL TAKE EFFECT FROM THE DATE OF TAKE OVER BY DEWA OFTHE JOB CARRIED OUT BY THE CONTRACTOR.C.#WHEN A DEFECT IS NOTICED DURING THE PERIOD OF WARRANTY, THECONTRACTOR MUST R ECTIFY THE DEFECT WITHIN A REASONABLE AMOUNT OF TIMEFIXED BY DEWA WITH NO CLAIM OR COMPENSATION.D. DURING RETRAVEL OF THE RISER PIPE ALONG WITH PUMP-MOTOR SET, IFFAILED TO RETRIEVE OR FELL DOWN INSIDE THE WELL, CONTRACTOR HAS TOFISH-OUT THE SAME BY THEIR OWN COST. ANY DAMAGE OF THE WELL DURINGFISHING OUT, CONTRACTOR TO BEAR THE ALL REPAIRING COST TO MAKE THE SAMEWELL IN OPERATION.6.0#DOCUMENTS :#ON SATISFACTORY COMPLETION OF THE WORK & HANDING OVER, THE CONTRACTORSHOULD</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412500889
DATE : 09.06.2025
REQ No : 1032502296
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 13.06.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SUBMIT THE FOLLOWING TO DEWA. ##A.#INSPECTION REPORT.B.#REPAIR/ACTION REPORT.C.#METHOD STATEMENT OF THE REPAIRING WORKS.D.#PHOTOS OF WELLS AFTER RETRIEVAL & BEFO RE INSTALLATION.E.#ALL TEST REPORTS.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Removal/Retrieval of faulty/detective submersible pump-motor sets with
 GI raiser pipes, dipping tube and its fittings from the wells and
 installation of the same on the same well for MARGAM, WAHOOSH, NAJWA,
 HABAB <(>&<)> AWEER WELLFIELD.

Please contact Mr. Rehman (050-5340018) for further clarifications.

STANDARD TERMS & CONDITIONS

- Prices should be 'DDP' delivery duty paid at DEWA stores.
- Quotation to be submitted only in local currency U.A.E Dirhams

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412500889
DATE : 09.06.2025
REQ No : 1032502296
REQ TITLE : Removal/Retrieval of faulty/d
DELIVERY LOCATION
CLOSING DATE : 13.06.2025
CLOSING TIME : 10:00:00

3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP