

# REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412501055

**DATE** : 04.07.2025

**REQ No** : 1012502816

**REQ TITLE** : CKT BRKR\_AIR 1012502816

**DELIVERY LOCATION**: 0021 - H2 STORE - AWEER

**CLOSING DATE** : 10.07.2025

CLOSING TIME : 10:00:00

SL NO ITEM CODE SERVICE ID		SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE				
1	2700086088		CIRCUIT BREAKER_AIR; AMPERAGE: 4KA; INTERRUPTING CAPACITY: 75KA; KVRATING: 12KV; VOLTAGE: 690VAC; STANDARD: IEC 60947-2; POLE: 4P; M OUNT:FIXED; MFR: ABB: MPN: E4S4000 PR121/P-LI: ADDITIONAL INFO: BRAND: SACEEMAX; W/PROTECTION MODULE; APPLICATION: INCOMER; SERIA L NO:F3720V03A;KKS CODE: 40BMA01-02	2	EA								
2	2700086086		CIRCUIT BREAKER_AIR; AMPERAGE: 1.6KA; INTERRUPTING CAPACITY: 50KA; KVRATING: 12KV; VOLTAGE: 690VAC; STANDARD: IEC 60947-2; POLE: 3P; MOUNT:FIXED/DRAW-OUT; MFR: ABB: MPN: E1N1600 PR121/P-LI: ADDITIONAL INFO:BRAND: SACE EMAX; CATEGORY: B; W/PROTECTION MODULE; APP L ICATION:INCOMER; KKS CODE: 40BFF05-06; 40BFF07-08	2	EA								
3	2700086078		CIRCUIT BREAKER_AIR; AMPERAGE: 1.25KA; CONNECTION: SCREW TERMINAL;INTERRUPTING CAPACITY: 50/66/42KA; KV RATING: 12KV; PHASE: 3PH; VO	2	EA								



### **REQUEST FOR QUOTATION LOCAL PURCHASE SECTION**

**RFQ NUMBER** : 2412501055

DATE : 04.07.2025

**REQ No** : 1012502816

**REQ TITLE** : CKT BRKR\_AIR 1012502816

: 10.07.2025

**DELIVERY LOCATION** : 0021 - H2 STORE - AWEER **CLOSING DATE** 

**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			LTAGE: 415/500/690VAC; STANDARD: IEC 60947-2, VDE 0660; POLE: 4P;MOUNT: DRAW-OUT; MFR: SIEMENS LTD: MPN: 3WL1112-3AA45-4GA4-Z: ADDIT IONAL INFO: RATED SERVICE SHORT CIRCUIT BREAKING CAPACITY/RATED SHORTTIME WITHSTAND CURRENT RATING: 50KA; WLI 1250S; APPLICATION: I NCOMERAND BUS-TIE; SERIAL NO: 491250713031; KKS CODE: 41-42-43 BFE-BM						
4	2700086079		CIRCUIT BREAKER_AIR; AMPERAGE: 800A; CONNECTION: SCREW TERMINAL;INTERRUPTING CAPACITY: 50/66/42KA; KV RATING: 12KV; PHASE: 3PH; VOLT AGE: 415/500/690VAC; STANDARD: IEC 60947-2, VDE 0660; POLE: 4P; MOUNT:DRAW-OUT; MFR: SIEMENS LTD: MPN: 3WL1108-3AA45-4GA4-Z: ADDIT I ONAL INFO:INTERRUPT CATEGORY: ICS-ICW; WLI 800S; APPLICATION: EMERGENCY BREAKER;SERIAL NO: 491250713031; KKS CODE: 41-42-43 BME	2	EA				

TOTAL AMOUNT IN WORDS: TOTAL AMOUNT:

### **SPECIAL NOTES / INSTRUCTIONS:**





## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412501055

**DATE** : 04.07.2025

**REQ No** : 1012502816

**REQ TITLE** : CKT BRKR\_AIR 1012502816

**DELIVERY LOCATION** : 0021 - H2 STORE - AWEER

**CLOSING DATE** : 10.07.2025

CLOSING TIME : 10:00:00

SWG Spare

#### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

CI.	IDI	DI	ı		D	'S	D	RΕΙ	۸л	Λ	D	и	œ	
-	, .	_	_,	_	١,		13		v	_	1	м		-

SUPPLIER'S SIGNATURE AND STAMP