

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	THIRD PARTY INTERNAL INSPECTION OF D-PH 2 BOILER 6 AT #D# STATION PHASE1 AS PER EIAC-RQ-IB-004 (FORMERLY DAC-REQ-08)1.#THIRD PARTY I NSPECTION OF AUX. BOILERSCOPE OF WORK FOR INSPECTION ACCORDING TO EIAC-RQ-IB-004 (DAC REQ-08):1.1: PRE OUTAGE INSPECTION:A. REVIEW OF MANUFACTURER#S CERTIFICATION FOR THE BOILER ANDIDENTIFICATION BASED ON MANUFACTURER#S MARKINGS/ASME/CE MARKINGS.B. REVIEW OF R ECORDS FOR SITE ERECTION AND FINAL EXAMINATIONRESULTS/REPAIR/ALTERATION RECORDS.C. VISUAL EXAMINATION ON ALL ACCESSIBLE AREAS.D. REVIEW AND VERIFY THERMOGRAPHY REPORTSE. EXTERNAL VISUAL EXAMINATION ON ALL ACCESSIBLE AREAS.F. WALK DOWN AND PUNCH LIST REPORT S BASED ON FINDINGS AND INTERVIEWSG. RECOMMENDATION FOR NDE TASKS TO BE PERFORMED DURING INSPECTIONSH. REVIEW OF LAST INSPECTION	1	JOB				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>REPORTI. REVIEW OF LATEST OPERATING DATA FROM CONTROL SYSTEM HISTORIAN AND OTHER AVAILABLE ARCHIVESJ. INSPECTION FOR VIBRATION OF PIPE, HEADERS, STEEL STRUCTURE, ETC.1.2: OUTAGE INSPECTION:A. A VISUAL SURVEY OF THE AUXILIARY BOILERS GENERAL CONDITION, EXTERNAL CASING, INTERNAL AIR/FLUE GAS DUCT SIDE MECHANICAL PARTS, PENTHOUSE AND AUXILIARY EQUIPMENT READILY ACCESSIBLE PRESSURE PARTS ETC.B . THE INTERNAL THOROUGH INSPECTION CONSTITUTES A VISUAL EXAMINATION /SURVEY OF THE ACCESSIBLE SURFACE OF THE BOILER PRESSURE PARTS , THE TUBES HEADERS, ACCESSIBLE SUPPORTING ARRANGEMENTS, REFRACTORY LINING, DRUMS, AND THE INTERNAL FITTINGS IN ORDER TO DETECT ANY SIGN OF GENERAL OR LOCALIZED DEFORMATION/DETERIORATION. WHERE APPLICABLE OR NECESSARY, NON-DESTRUCTIVE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TESTING METHODS, DESTRUCTIVE TESTING OF SAMPLES, IN-SITU METALLOGRAPHY ETC. SHALL BE USED TO COMPLEMENT THE VISUAL INSPECTION. C. EXTERNAL VISUAL EXAMINATIONS ARE CARRIED OUT IN ALL ACCESSIBLE AREAS. D. VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OF HIGH, MEDIUM AND LOW-PRESSURE STEAM PIPING AND HEADER SE. VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OF PRESSURE VESSELS AND PIPING SYSTEMS. F. REVIEW OF THICKNESS MEASUREMENT RECORDS TO VERIFY WHETHER THE CURRENT THICKNESS IS NOT LESS THAN THE MINIMUM ALLOWABLE WALL THICKNESS. G. REVIEW ALL CRITICAL STEAM-PIPING HANGERS BY CHECKING THE INDICATOR OF HOT POSITION & ADJUST IF NECESSARY. H. VISUAL INSPECTION / SURVEY OF BURNERS, AIR REGISTERS AND DAMPERS. I. INSPECT MAIN STACK & ITS ACCESSORIES FOR						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ANY DISCREPANCYJ. BASED ON VISUAL INSPECTION A</p> <p>ND PREVIOUS RECORD REVIEW, THEINSPECTOR MAY IDENTIFY ADDITIONAL NDE (THICKNESS MEASUREMENT, MT, PT,HARDNESS ETC.), THE NDE RESULTS W</p> <p>ILL BE REVIEWED COMPLIANCE WITHDRAWINGS, CODE AND SPECIFICATION IF AVAILABLE OR RETAINED FOR FUTUREREERENCE.K. ALL ABNORMAL CONDI</p> <p>TIONS SUCH AS POOR COATING,RUSTED/CORRODED/PITTED SURFACE, RUSTED BOLTS / NUTS, LOOSE BOLTEDASSEMBLIES, RUSTED WELD SEAMS, CRACKS, D</p> <p>ISTORTION, BENDS, DENTS,SAGGING, BULGING ITEMS, INDICATION OF LEAK, INDICATION OF WATER INGRESS, PIPING/TUBE EXCESSIVE VIBRATIONS, W</p> <p>ASTAGE REDUCTION OF PRESSURE RETAINING THICKNESS SHALL BE REPORTED.1.3 POST OUTAGE INSPECTION:A. REVIEW OF INSPECTION REPORT AND R</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RECORDS FOR REPAIR IF ANY PERFORMED. B. WITNESS OF HYDRO TEST AS APPLICABLE. C. WITNESS FUNCTIONALITY TEST AND REVIEW OF FUNCTIONALITY TEST REPORT. D. REVIEW / VERIFICATION OF CALIBRATION CERTIFICATES OF PRESSURE, TEMPERATURE GAUGES, TRANSMITTERS AND OTHER INSTRUMENTS. E. REVIEW OF WATER CHEMISTRY RECORDS. F. WITNESS SAFETY TESTS AND REVIEW OF SAFETY VALVE TEST CERTIFICATES. G. THE BOILER SHALL BE VISUALLY EXAMINED EXTERNALLY UNDER NORMAL WORKING CONDITIONS. H. WATER LEVEL GAUGE ACCURACY, FEED WATER CONTROLS, LOW/HIGH LEVEL WATER ALARMS, LOW WATER LEVEL ACTIONS, BLOW DOWN SYSTEM OPERATIONS ETC. WILL BE REVIEWED. I. REVIEW OF OPERATING AND DESIGN PARAMETER. J. VERIFICATION TO CHECK THE BOILER IS PROVIDED WITH THE NEEDED SAFETY ACCESSORIES AND THESE ACCESSORIES ARE IN PLACE. 4. DELIVER</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ABLES SHALL BE: ISSUE OF VISIT REPORT DETAILING SCOPE OF INSPECTION UNDERTAKENAS REQUIRED. ISSUE OF INSPECTION CERTI FICATE DETAILING SCOPE OF INSPECTIONUNDERTAKEN AND RESULTS & RECOMMENDATIONS UPON SATISFACTORY COMPLETION OF INSPECTION. ISSUE OF INSPECTION REPORT DETAILING SCOPE OF INSPECTIONUNDERTAKEN IF ANOMALIES IDENTIFIED ARE NOT RESOLVED IN ACCORDAN CE WITH EIAC-RQ-IB-004REQUIREMENTS.NOTE TO CONTRACTORS:#CONTRACTORS SHOULD VISIT THE SITE TO UNDERSTAND THE SITE CONDITIONS,CONTRAC T SCOPE, AND INTRICACIES OF THE WORK TO ENSURE THAT THEY FULLYUNDERSTAND THE SCOPE OF WORK FOR DESIGN, ENGINEERING, AND COSTESTIMATI ON.#NO CLAIMS FOR EXTRA PAYMENTS SHALL BE ACCEPTED FOR ANY ADDITIONALMATERIALS OR WORKS THAT WERE FOUND REQUIRED AT THE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TIME OF EXECUTION OF THE WORK DUE TO LACK OF UNDERSTANDING OF THE SCOPE, EXTENT OF WORK, PLANT/SITE RESTRICTIONS, UNDERESTIMATION OF THE SCOPE, ETC., IRRESPECTIVE OF BEING EXPLICITLY OR IMPLICITLY MENTIONED IN THE TENDER SPECIFICATION CONTRACTOR SHALL NOTE, ALL TECHNICAL AND ENGINEERING REQUIREMENTS ESSENTIAL TO COMPLETE THE SCOPE OF WORK ARE INCLUDED IN THIS TENDER DOCUMENT. ANY AMBIGUITIES OR DISCREPANCIES BETWEEN CONTRACTOR'S OFFER AND THIS TECHNICAL SPECIFICATION AFTER AWARD OF THE CONTRACT SHALL BE RESOLVED BY THE DEWA, WHO SHALL THEN INSTRUCT THE CONTRACTOR THEREON. INTERPRETATION, CHANGE, OR CORRECTION MADE BY DEWA WILL BE BINDING FOR THE CONTRACTOR IN THIS REGARD WITHOUT ANY ADDITIONAL COST TO DEWA. NO CLAIMS FOR EXTRA PAYMENTS SHALL BE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ACCEPTED FOR DE-MOBILIZATIONAND REMOBILIZATION OR WAIT ING TIME OR IDLE TIME DUE TO DEWA#SOPERATIONAL CONSTRAINTS OR OTHER CRITICAL MAINTENANCE ACTIVITIES CARRIEDOUT BY DEWA AT THE SITE.D EWA SCOPE:·#FRESH WATER, AIR, AND ELECTRICITY·#CRANE & FORKLIFT·#PERMITS AND PASSES·#ISOLATION OF THE SYSTEM						
2		ITEM-00001	THIRD PARTY INTERNAL INSPECTION OF D-PH 2 BOILER 7 AT #D# STATION PHASE1 AS PER EAC-RQ-IB-004 (FORMERLY DAC-REQ-08)1.#THIRD PARTY I NSPECTION OF AUX. BOILERSCOPE OF WORK FOR INSPECTION ACCORDING TO EAC-RQ-IB-004 (DAC REQ-08):1.1: PRE OUTAGE INSPECTION:A. REVIEW OF MANUFACTURER#S CERTIFICATION FOR THE BOILER ANDIDENTIFICATION BASED ON MANUFACTURER#S MARKINGS/ASME/CE MARKINGS.B. REVIEW OF R ECORDS FOR SITE ERECTION AND FINAL EXAMINATIONRESULTS/REPAIR/ALTERATION RECORDS.C. VISUAL EXAMINATION ON ALL	1	JOB				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ACCESSIBLE AREAS.D. REVIEW AND VERIFY THERMOGRAPHY REPORTSE. EXTERNAL VISUAL EXAMINATION ON ALL ACCESSIBLE AREAS.F. WALK DOWN AND PUNCH LIST REPORT S BASED ON FINDINGS AND INTERVIEWSG. RECOMMENDATION FOR NDE TASKS TO BE PERFORMED DURING INSPECTIONSH. REVIEW OF LAST INSPECTION REPORTI. REVIEW OF LATEST OPERATING DATA FROM CONTROL SYSTEM HISTORIAN ANDOTHER AVAILABLE ARCHIVESJ. INSPECTION FOR VIBRATION O F PIPE, HEADERS, STEEL STRUCTURE, ETC.1.2: OUTAGE INSPECTION:A. A VISUAL SURVEY OF THE AUXILIARY BOILERS GENERAL CONDITION,EXTERNA L CASING, INTERNAL AIR/FLUE GAS DUCT SIDE MECHANICAL PARTS,PENTHOUSE AND AUXILIARY EQUIPMENT READILY ACCESSIBLE PRESSURE PARTS ETC.B . THE INTERNAL THOROUGH INSPECTION CONSTITUTES A VISUAL EXAMINATION /SURVEY OF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE ACCESSIBLE SURFACE OF THE BOILER PRESSURE PARTS , THE TUBESHEADERS, ACCESSIBLE SUPPORTING ARRANGEMENTS, REFRACTORY LINING, DRUMS,AND THE INTERNAL FITTINGS IN ORDER TO DETECT ANY SIGN OF GENERAL ORLOCALIZED DEFORMATION/DETERIORATION. WHERE APPLICABLE OR NECESSARY,NON-DESTRUCTIVE TESTING METHODS, DESTRUCTIVE TESTING OF SAMPLES, IN-SITUMETALLOGRAPHY ETC. SHALL BE USED TO COMPLEMENT THE VISUAL INSPECTION.C. EXTERNAL VISUAL EXAMINATIONS ARE CARRIED OUT IN ALL ACCESSIBLEAREAS.D. VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OF HIGH,MEDIUM AND LOW-PRESSURE STEAM PIPING AND HEADERSE. VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OFPRESSURE VESSELS AND PIPING SYSTEMSF. REVIEW OF THICKNESS MEASUREMENT RECORDS TO						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>VERIFY WHETHER THE CURRENT THICKNESS IS NOT LESS THAN THE MINIMUM ALLOWABLE WALL THICKNESS. RE</p> <p>VIEW ALL CRITICAL STEAM-PIPING HANGERS BY CHECKING THE INDICATOR OF HOT POSITION & ADJUST IF NECESSARY. VISUAL INSPECTION / SURVEY</p> <p>OF BURNERS, AIR REGISTERS AND DAMPERS. INSPECT MAIN STACK & ITS ACCESSORIES FOR ANY DISCREPANCY. BASED ON VISUAL INSPECTION AND PREVIOUS RECORD REVIEW, THE INSPECTOR MAY IDENTIFY ADDITIONAL NDE (THICKNESS MEASUREMENT, MT, PT, HARDNESS ETC.), THE NDE RESULTS WILL BE REVIEWED COMPLIANCE WITH DRAWINGS, CODE AND SPECIFICATION IF AVAILABLE OR RETAINED FOR FUTURE REFERENCE. K. ALL ABNORMAL CONDITIONS SUCH AS POOR COATING, RUSTED/CORRODED/PITTED SURFACE, RUSTED BOLTS / NUTS, LOOSE BOLTED ASSEMBLIES, RUSTED WELD SEAMS,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CRACKS, DISTORTION, BENDS, DENTS, SAGGING, BULGING ITEMS, INDICATION OF LEAK, INDICATION OF WATER INGRESS, PIPING/TUBE EXCESSIVE VIBRATIONS, WASTAGE REDUCTION OF PRESSURE RETAINING THICKNESS SHALL BE REPORTED. 1.3 POST OUTAGE INSPECTION: A. REVIEW OF INSPECTION REPORT AND RECORDS FOR REPAIR IF ANY PERFORMED. B. WITNESS OF HYDRO TEST AS APPLICABLE. C. WITNESS FUNCTIONALITY TEST AND REVIEW OF FUNCTIONALITY TEST REPORT. D. REVIEW / VERIFICATION OF CALIBRATION CERTIFICATES OF PRESSURE, TEMPERATURE GAUGES, TRANSMITTERS AND OTHER INSTRUMENTS. E. REVIEW OF WATER CHEMISTRY RECORDS. F. WITNESS SAFETY TESTS AND REVIEW OF SAFETY VALVE TEST CERTIFICATES. G. THE BOILER SHALL BE VISUALLY EXAMINED EXTERNALLY UNDER NORMAL WORKING CONDITIONS. H. WATER LEVEL GAUGE ACCURACY, FEED WATER CONTROLS,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>LOW/HIGH LEVEL WATER ALARMS, LOW WATER LEVEL ACTIONS, BLOW DOWN SYSTEM OPERATIONS ETC.WILL BE REVIEWED.I. REVIEW OF OPERATING AND DESIGN PARAMETER</p> <p>SJ. VERIFICATION TO CHECK THE BOILER IS PROVIDED WITH THE NEEDED SAFETYACCESSORIES AND THESE ACCESSORIES ARE IN PLACE.4. DELIVER</p> <p>ABLES SHALL BE: ISSUE OF VISIT REPORT DETAILING SCOPE OF INSPECTION UNDERTAKENAS REQUIRED. ISSUE OF INSPECTION CERTIFICATE DETAILING SCOPE OF INSPECTIONUNDERTAKEN AND RESULTS & RECOMMENDATIONS UPON SATISFACTORY COMPLETION OF INSPECTION.</p> <p>ISSUE OF INSPECTION REPORT DETAILING SCOPE OF INSPECTIONUNDERTAKEN IF ANOMALIES IDENTIFIED ARE NOT RESOLVED IN ACCORDANCE WITH EIAC-RQ-IB-004REQUIREMENTS.NOTE TO CONTRACTORS:#CONTRACTORS SHOULD VISIT</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>THE SITE TO UNDERSTAND THE SITE CONDITIONS, CONTRACT SCOPE, AND INTRICACIES OF THE WORK TO ENSURE THAT THEY FULLY UNDERSTAND THE SCOPE OF WORK FOR DESIGN, ENGINEERING, AND COST ESTIMATION. #NO CLAIMS FOR EXTRA PAYMENTS SHALL BE ACCEPTED FOR ANY ADDITIONAL MATERIALS OR WORKS THAT WERE FOUND REQUIRED AT THE TIME OF EXECUTION OF THE WORK DUE TO LACK OF UNDERSTANDING OF THE SCOPE, EXTENT OF WORK, PLANT/SITE RESTRICTIONS, UNDERESTIMATION OF THE SCOPE, ETC., #IRRESPECTIVE OF BEING EXPLICITLY OR IMPLICITLY MENTIONED IN THE TENDER SPECIFICATION CONTRACTOR SHALL NOTE, ALL TECHNICAL AND ENGINEERING REQUIREMENTS ESSENTIAL TO COMPLETE THE SCOPE OF WORK ARE INCLUDED IN THIS TENDER DOCUMENT. #ANY AMBIGUITIES OR DISCREPANCIES BETWEEN CONTRACTOR'S OFFER AND</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THIS TECHNICAL SPECIFICATION AFTER AWARD OF THE CONTRACT SHALL BE RESOLVED BY THE DEWA, WHO SHALL THEN INSTRUCT THE CONTRACTOR THEREON. INTERPRETATION, CHANGE, OR CORRECTION MADE BY DEWA WILL BE BINDING FOR THE CONTRACTOR IN THIS REGARD WITHOUT ANY ADDITIONAL COST TO DEWA. #NO CLAIMS FOR EXTRA PAYMENTS SHALL BE ACCEPTED FOR DE-MOBILIZATION AND REMOBILIZATION OR WAITING TIME OR IDLE TIME DUE TO DEWA #S OPERATIONAL CONSTRAINTS OR OTHER CRITICAL MAINTENANCE ACTIVITIES CARRIED OUT BY DEWA AT THE SITE. DEWA SCOPE: #FRESH WATER, AIR, AND ELECTRICITY. #CRANE & FORKLIFT. #PERMITS AND PASSES. #ISOLATION OF THE SYSTEM						
3		ITEM-00001	THIRD PARTY INTERNAL INSPECTION OF D-PH 2 BOILER 8 AT #D# STATION PHASE 1 AS PER EIA-C-RQ-IB-004 (FORMERLY DAC-REQ-08) 1. #THIRD PARTY INSPECTION OF AUX. BOILERS SCOPE OF WORK FOR	1	JOB				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			INSPECTION ACCORDING TO EIAC-RQ-IB-004 (DAC REQ-08):1.1: PRE OUTAGE INSPECTION:A. REVIEW OF MANUFACTURER#S CERTIFICATION FOR THE BOILER AND IDENTIFICATION BASED ON MANUFACTURER#S MARKINGS/ASME/CE MARKINGS.B. REVIEW OF RECORDS FOR SITE ERECTION AND FINAL EXAMINATION RESULTS/REPAIR/ALTERATION RECORDS.C. VISUAL EXAMINATION ON ALL ACCESSIBLE AREAS.D. REVIEW AND VERIFY THERMOGRAPHY REPORTS.E. EXTERNAL VISUAL EXAMINATION ON ALL ACCESSIBLE AREAS.F. WALK DOWN AND PUNCH LIST REPORTS BASED ON FINDINGS AND INTERVIEWS.G. RECOMMENDATION FOR NDE TASKS TO BE PERFORMED DURING INSPECTIONS.H. REVIEW OF LAST INSPECTION REPORT.I. REVIEW OF LATEST OPERATING DATA FROM CONTROL SYSTEM HISTORIAN AND OTHER AVAILABLE ARCHIVES.J. INSPECTION FOR VIBRATION OF PIPE, HEADERS, STEEL STRUCTURE, ETC.1.2:						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>OUTAGE INSPECTION:A. A VISUAL SURVEY OF THE AUXILIARY BOILERS GENERAL CONDITION,EXTERNAL CASING, INTERNAL AIR/FLUE GAS DUCT SIDE MECHANICAL PARTS,PENTHOUSE AND AUXILIARY EQUIPMENT READILY ACCESSIBLE PRESSURE PARTS ETC.B</p> <p>. THE INTERNAL THOROUGH INSPECTION CONSTITUTES A VISUAL EXAMINATION /SURVEY OF THE ACCESSIBLE SURFACE OF THE BOILER PRESSURE PARTS , THE TUBESHEADERS, ACCESSIBLE SUPPORTING ARRANGEMENTS, REFRACTORY LINING, DRUMS,AND THE INTERNAL FITTINGS IN ORDER TO DETECT ANY SIGN OF GENERAL ORLOCALIZED DEFORMATION/DETERIORATION. WHERE APPLICABLE OR NECESSARY,NON-DESTRUCTIVE TESTING METHODS, DESTRUCTIVE TESTING OF SAMPLES, IN-SITU METALLOGRAPHY ETC. SHALL BE USED TO COMPLEMENT THE VISUAL INSPECTION.C. EXTERNAL VISUAL EXAMINATIONS ARE CA</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RRIED OUT IN ALL ACCESSIBLEAREAS.D. VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OF HIGH,MEDIUM AND LOW-PRESSURE STEA</p> <p>M PIPING AND HEADERSE. VISUAL INSPECTION AND WITNESS OF UT THICKNESS MEASUREMENT OFPRESSURE VESSELS AND PIPING SYSTEMSF. REVIEW</p> <p>OF THICKNESS MEASUREMENT RECORDS TO VERIFY WHETHER THECURRENT THICKNESS IS NOT LESS THAN THE MINIMUM ALLOWABLE WALL THICKNESSG. RE</p> <p>VIEW ALL CRITICAL STEAM-PIPING HANGERS BY CHECKING THE INDICATOROF HOT POSITION & ADJUST IF NECESSARYH. VISUAL INSPECTION / SURVEY</p> <p>OF BURNERS, AIR REGISTERS AND DAMPERSI. INSPECT MAIN STACK & ITS ACCESSORIES FOR ANY DISCREPANCYJ. BASED ON VISUAL INSPECTION A</p> <p>ND PREVIOUS RECORD REVIEW, THEINSPECTOR MAY IDENTIFY ADDITIONAL NDE (THICKNESS MEASUREMENT, MT, PT,HARDNESS ETC.), THE NDE</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>RESULTS WILL BE REVIEWED COMPLIANCE WITH DRAWINGS, CODE AND SPECIFICATION IF AVAILABLE OR RETAINED FOR FUTURE REFERENCE. K. ALL ABNORMAL CONDITIONS SUCH AS POOR COATING, RUSTED/CORRODED/PITTED SURFACE, RUSTED BOLTS / NUTS, LOOSE BOLTED ASSEMBLIES, RUSTED WELD SEAMS, CRACKS, DISTORTION, BENDS, DENTS, SAGGING, BULGING ITEMS, INDICATION OF LEAK, INDICATION OF WATER INGRESS, PIPING/TUBE EXCESSIVE VIBRATIONS, WASTAGE REDUCTION OF PRESSURE RETAINING THICKNESS SHALL BE REPORTED. 1.3 POST OUTAGE INSPECTION: A. REVIEW OF INSPECTION REPORT AND RECORDS FOR REPAIR IF ANY PERFORMED. B. WITNESS OF HYDRO TEST AS APPLICABLE. C. WITNESS FUNCTIONALITY TEST AND REVIEW OF FUNCTIONALITY TEST REPORT. D. REVIEW / VERIFICATION OF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CALIBRATION CERTIFICATES OF PRESSURE,TEMPERATURE GAUGES, TRANSMITTERS AND OTHER INSTRUMENTS. REVIEW OF WATER CHEMISTRY RECORDS. WITNESS SAFETY TESTS AND REVIEW OF SAFETY VALVE TEST CERTIFICATES. THE BOILER SHALL BE VISUALLY EXAMINED EXTERNALLY UNDER NORMAL WORKING CONDITIONS. H. WATER LEVEL GAUGE ACCURACY, FEED WATER CONTROLS, LOW/HIGH LEVEL WATER ALARMS, LOW WATER LEVEL ACTIONS, BLOW DOWN SYSTEM OPERATIONS ETC. WILL BE REVIEWED. I. REVIEW OF OPERATING AND DESIGN PARAMETER</p> <p>SJ. VERIFICATION TO CHECK THE BOILER IS PROVIDED WITH THE NEEDED SAFETY ACCESSORIES AND THESE ACCESSORIES ARE IN PLACE. 4. DELIVERABLES SHALL BE: ISSUE OF VISIT REPORT DETAILING SCOPE OF INSPECTION UNDERTAKEN AS REQUIRED. ISSUE OF INSPECTION CERTIFICATE DETAILING SCOPE OF</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>INSPECTION UNDERTAKEN AND RESULTS & RECOMMENDATIONS UPON SATISFACTORY COMPLETION OF INSPECTION.</p> <p>ISSUE OF INSPECTION REPORT DETAILING SCOPE OF INSPECTION UNDERTAKEN IF ANOMALIES IDENTIFIED ARE NOT RESOLVED IN ACCORDANCE WITH EIAC-RQ-IB-004 REQUIREMENTS. NOTE TO CONTRACTORS: #CONTRACTORS SHOULD VISIT THE SITE TO UNDERSTAND THE SITE CONDITIONS, CONTRACT SCOPE, AND INTRICACIES OF THE WORK TO ENSURE THAT THEY FULLY UNDERSTAND THE SCOPE OF WORK FOR DESIGN, ENGINEERING, AND COST ESTIMATION. #NO CLAIMS FOR EXTRA PAYMENTS SHALL BE ACCEPTED FOR ANY ADDITIONAL MATERIALS OR WORKS THAT WERE FOUND REQUIRED AT THE TIME OF EXECUTION OF THE WORK DUE TO LACK OF UNDERSTANDING OF THE SCOPE, EXTENT OF WORK, PLANT/SITE RESTRICTIONS, UNDERESTIMATION OF THE SCOPE, E</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TC.,#IRRESPECTIVE OF BEING EXPLICITLY OR IMPLICITLY MENTIONED IN THE TENDER SPECIFICATION CONTRACTOR SHALL NOTE, ALL TECHNICAL AND ENGINEERING REQUIREMENTS ESSENTIAL TO COMPLETE THE SCOPE OF WORK ARE INCLUDED IN THIS TENDER DOCUMENT.#ANY AMBIGUITIES OR DISCREPANCIES BETWEEN CONTRACTOR'S OFFER AND THIS TECHNICAL SPECIFICATION AFTER AWARD OF THE CONTRACT SHALL BE RESOLVED BY THE DEWA, WHO SHALL THEN INSTRUCT THE CONTRACTOR THEREON. INTERPRETATION, CHANGE, OR CORRECTION MADE BY DEWA WILL BE BINDING FOR THE CONTRACTOR IN THIS REGARD WITHOUT ANY ADDITIONAL COST TO DEWA.#NO CLAIMS FOR EXTRA PAYMENTS SHALL BE ACCEPTED FOR DE-MOBILIZATION AND REMOBILIZATION OR WAITING TIME OR IDLE TIME DUE TO DEWA'S OPERATIONAL CONSTRAINTS OR OTHER CRITICAL MAINTENANCE ACTIVITIES CARRIED OUT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BY DEWA AT THE SITE.D EWA SCOPE:·#FRESH WATER, AIR, AND ELECTRICITY·#CRANE & FORKLIFT·#PERMITS AND PASSES··#ISOLATION OF THE SYSTEM						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

D-PHASE 2 BOILERS THIRD PARTY INTERNAL INSPECTION. For queries contact Phone: 043226031 # satheeshkumar.ramadoss@dewa.gov.ae

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501327
DATE : 18.08.2025
REQ No : 1032503692
REQ TITLE : D-PHASE 2 BOILERS THIRD
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP