

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412501355  
**DATE** : 22.08.2025  
**REQ No** : 1032503604  
**REQ TITLE** : TREATPLT 1032503604  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.08.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	TREATPLT: REFUBRISHMENT OF DANFOSS 1.5 "DSVTHE SCOPE OF WORK FOR REFURBISHMENT OF EUROSAFE MAKE WATER MIST SYSTEMMOTORIZED DRY SECTI ONAL VALVES [SIZES 1INCH & 1.5 INCH] SHALL INCLUDE,NOT LIMITED TO THE FOLLOWING, INSPECTION, PREPARATIONS AND REPLACEMENTOF PARTS AS APPLICABLE AS FOLLOWS:-INSPECTION AND PREPARATION##THE CONTRACTOR MUST HAVE EXPERIENCE IN REPAIR AND RECTIFICATION OFEUROSAFE MAKE HP WATER MIST SYSTEM.##CLEAN INTERNAL COMPONENTS USING SUITABLE SOLVENTS.##REMOVE SCALE, RUST, OR DEBRIS USING BRUSHES##DRY ALL PART S THOROUGHLY WITH LINT-FREE CLOTHS OR COMPRESSED AIR.##CHECK BALL SURFACE FOR SCORING, PITTING, OR CORROSION.##EXAMINE SEATS AND SEA LS FOR WEAR, DEFORMATION, OR CRACKS.##INSPECT STEM AND TEFLON PAD AND O RINGS OF THE BALL VALVE.##CHECK ACTUATOR	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412501355  
**DATE** : 22.08.2025  
**REQ No** : 1032503604  
**REQ TITLE** : TREATPLT 1032503604  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.08.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>FOR SMOOTH OPERATION, AND SIGNAL RESPONSE.##THE REPLACEMENT OF COMPONENTS IF INVOLVED SHALL BE OF SAME MAKE &amp; MODEL OF THAT OF OEM.##ALL THE TESTING SHALL BE CARRIED OUT IN THE VENDOR TEST FACILITY OR ANY APPROVED TESTING LABORATORY.##A PROPER INSPECTION REPORT WITH PHOTOGRAPHS SHALL BE SUBMITTED TO DEWA CASE: -1 ACTUATOR IS WORKING PERFECTLY, AND VALVE NEED TO BE RECTIFIED RECTIFICATION OF DSV##REPLACE DAMAGED TEFLO N PAD ON THE BALL VALVE.##LAP THE BALL AND SEATS IF MINOR DAMAGE EXISTS.##LUBRICATE MOVING PARTS WITH APPROPRIATE VALVE GREASE.##REASSEMBLE VALVE IN CORRECT ORIENTATION AND TORQUE FASTENERS TO SPECIFICATION.##DO THE HYDRAULIC STATIC PRESSURE TEST WITH PRESSURE OF 2 10 BARS FOR 15 MIN.##IF THE PRESSURE TEST IS PASSED MOUNT ACTUATOR, ALIGN TO</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412501355  
**DATE** : 22.08.2025  
**REQ No** : 1032503604  
**REQ TITLE** : TREATPLT 1032503604  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.08.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PREVIOUS POSITION, AND TIGHTEN PROPERLY.##CONNECT ELECTRICAL LINES AS PER SPECIFICATIONS.##CALIBRATE ACTUATOR STROKE USING MANUAL TUNING.##ENSURE SMOOTH OPERATION OF VALVE AND ACTUATOR ASSEMBLY.##IF THE PRESSURE TEST FAILS DISPOSE THE VALVE##PROPOSE AND ASSEMBLE NEW VALVE TO THE ACTUATOR AND TEST AGAIN.##GENERATE VALVE REFURBISHMENT/REPLACEMENT REPORT WITH BEFORE AND AFTER PHOTOGRAPHS##WARRANTY FOR THE NEW VALVE SUPPLIED: 1 YEAR CASE: -2 VALVE IS FUNCTIONING PERFECTLY, AND ACTUATOR IS NOT WORKING##CHECK ACTUATOR FOR SMOOTH OPERATION, AND SIGNAL RESPONSE.##CLEAN THE MOVING PARTS AND LUBRICATE##CONNECT ELECTRICAL LINES AS PER SPECIFICATIONS AND TEST##IF THE VALVE IS NOT WORKING, REPLACE THE ACTUATOR [ULLI 10 SERIES] AND ASSEMBLE TO THE VALVE AND DO THE</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412501355  
**DATE** : 22.08.2025  
**REQ No** : 1032503604  
**REQ TITLE** : TREATPLT 1032503604  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.08.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>TESTING.##CONNECT ELECTRICAL LINES AS PER SPECIFICATIONS.##CALIBRATE ACTUATOR STROKE USING</p> <p>MANUAL TUNING.##ENSURE SMOOTH OPERATION OF VALVE AND ACTUATOR ASSEMBLY.##DO THE HYDRAULIC STATIC PRESSURE TEST WITH PRESSURE OF 210</p> <p>BARS FOR15 MIN.##GENERATE VALVE REFURBISHMENT/REPLACEMENT REPORT WITH BEFORE AND AFTERPHOTOGRAPHS##WARRANTY FOR THE NEW ACTUATOR SU</p> <p>PPLIED: 1 YEARTHE WORK SHALL BE COMPLETED WITHIN 4 WEEKS FROM DATE OF ISSUANCE OF PO.FOR ANY RELATED QUERIES AND FURTHER INFORMATION</p> <p>, CONTACT MR. VISHNUVIJAY [EMAIL : VISHNU.VIJAY@DEWA.GOV.AE , MOB: 0509463644] OR MR. ANEEZHUSSAIN [EMAIL : ANEEZ.ABDULRAZAK@DEWA.GO V.AE ,MOB:0559660850]</p>						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412501355  
**DATE** : 22.08.2025  
**REQ No** : 1032503604  
**REQ TITLE** : TREATPLT 1032503604  
**DELIVERY LOCATION**  
**CLOSING DATE** : 27.08.2025  
**CLOSING TIME** : 10:00:00

TREATPLT

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**