

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501358
DATE : 22.08.2025
REQ No : 1032503262
REQ TITLE : 1032503262-81 Internal
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	INTERNAL INSPECTION AND SERVICING OF ELECTRIC FIRE PUMP SET AT DIWLSUBSTATION.FIRE PUMP AND DRIVER DETAILS:PUMP - PATTERSON, SERIAL# FP-C6315-4UNDERPERFORMING @ 150% LOADPUMP RATED PRESSURE- 104 PSINET HEAD @150% LOAD- 57 PSIYEAR OF ACQUISITION: 2008SCOPE OF WORK: OVERHAULING, INSPECTION AND SERVICING OF ELECTRIC PUMP.UPON SERVICING, ENSURE THE ELECTRIC PUMP SET OPERATES SMOOTHLY AND MEETS ALL PERFORMANCE CRITERIA AS PER NAME PLATE.THE PUMP PERFORMANCE TEST TO BE CARRIED OUT IN THE PRESENCE OF DEWA WITNESS.THE WARRANTY FOR PUMP PERFORMANCE SHOULD BE ONE YEAR.CALL SHERIEF (529219010), USMAN (561721269) FOR ANY INQUIRY	1	EA				
2		ITEM-00002	INTERNAL INSPECTION AND SERVICING OF ELECTRIC FIRE PUMP SET AT KSWG SUBSTATION.FIRE PUMP AND DRIVER DETAILS:PUMP - PATTERSON, PUMP MO	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501358
DATE : 22.08.2025
REQ No : 1032503262
REQ TITLE : 1032503262-81 Internal
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			DEL: 8 X 6 YR, SERIAL# FP-C84466-2YEAR OF ACQUISITION: 2009SCOPE OF WORK:OVERHAULING, INSPECTION AND SERVICING OF ELECTRIC PUMP.UPON SERVICING, ENSURE THE ELECTRIC PUMP SET OPERATES SMOOTHLY AND MEETSALL PERFORMANCE CRITERIA AS PER NAME PLATE.THE PUMP PERFORMANCE TEST TO BE CARRIED OUT IN THE PRESENCE OF DEWAWITNESS.THE WARRANTY FOR PUMP PERFORMANCE SHOULD BE ONE YEAR.CALL NARAYANASAMY (058890 8575) FOR ANY INQUIRY						
3		ITEM-00003	INTERNAL INSPECTION AND SERVICING OF ELECTRIC FIRE PUMP SET AT DOCKSUBSTATION.FIRE PUMP AND DRIVER DETAILS:PUMP - PATTERSON, PUMP MO DEL: 8 X 6 YR, SERIAL# FP-C063012-004YEAR OF ACQUISITION: 2008LAST TEST RESULTSCOPE OF WORK:OVERHAULING, INSPECTION AND SERVICING OF ELECTRIC PUMP.UPON SERVICING, ENSURE THE ELECTRIC PUMP SET OPERATES SMOOTHLY AND	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501358
DATE : 22.08.2025
REQ No : 1032503262
REQ TITLE : 1032503262-81 Internal
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			MEETSALL PERFORMANCE CRITERIA AS PER NAME PLATE.THE PUMP PERFORMANCE TEST TO BE CARRIED OUT IN THE PRESENCE OF DEWAWITNESS.THE WARRANTY FOR PUMP PERFORMANCE SHOULD BE ONE YEAR.CALL N ARAYANASAMY (0588908575) FOR ANY INQUIRY						
4		ITEM-00004	INTERNAL INSPECTION AND SERVICING OF ELECTRIC FIRE PUMP SET AT KSWG SUBSTATION.FIRE PUMP AND DRIVER DETAILS:PUMP - PATTERSON, PUMP MODEL: 8 X 6 YR YEAR OF ACQUISITION: 2005 RATED PRESSURE: 100 PS INET HEAD PRESSURE @100% LOAD: 85 PS INET HEAD PRESSURE @150% LOAD: 45 PS I.SCOPE OF WORK:OVERHAULING, INSPECTION AND SERVICING OF ELECTRIC PUMP.UPON SERVICING, ENSURE THE ELECTRIC PUMP SET OPERATES SMOOTHLY AND MEETSALL PERFORMANCE CRITERIA AS PER NAME PLATE.THE PUMP PERFORMANCE TEST TO BE CARRIED OUT IN THE PRESENCE OF DEWAWITNESS.THE	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501358
DATE : 22.08.2025
REQ No : 1032503262
REQ TITLE : 1032503262-81 Internal
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			WARRANTY FOR PUMP PERFORMANCE SHOULD BE ONE YEAR.CALL SHERIEF (529219010), USMAN (561721269) FOR ANY INQUIRY						
5		ITEM-00005	INTERNAL INSPECTION AND SERVICING OF ELECTRIC FIRE PUMP SET AT MALLSUBSTATION.FIRE PUMP AND DRIVER DETAILS:PUMP - PATTERSON, PUMP MO DEL: 8 X 6 YR, SERIAL# FP-C084469PUMP RATED PRESSURE- 105 PSINET HEAD @100% LOAD- 94 PSINET HEAD @0% LOAD- 124 PSIYEAR OF ACQUISITION: 2010LAST TEST RESULTSCOPE OF WORK:OVERHAULING, INSPECTION AND SERVICING OF ELECTRIC PUMP.UPON SERVICING, ENSURE THE ELECTRIC PUMP SET OPERATES SMOOTHLY AND MEETSALL PERFORMANCE CRITERIA AS PER NAME PLATE.THE PUMP PERFORMANCE TEST TO BE CARRIED OUT IN THE PRESENCE OF DEWAWITNESS.THE WARRANTY FOR PUMP PERFORMANCE SHOULD BE ONE YEAR.CALL SHERIEF (529219010), USMAN (561721269) FOR ANY INQUIRY	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501358

DATE : 22.08.2025

REQ No : 1032503262

REQ TITLE : 1032503262-81 Internal

DELIVERY LOCATION

CLOSING DATE : 28.08.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
6		ITEM-00006	INTERNAL INSPECTION AND SERVICING OF ELECTRIC FIRE PUMP SET AT JMRV SUBSTATION. FIRE PUMP AND DRIVER DETAILS: PUMP - PATTERSON, PUMP MODEL: 8 X 6 YR, SERIAL# FP-C64269-1 CAPACITY = 1500 GPM RATED HEAD = 104 PSI MEASURED NET HEAD AT 100% = 92.5 PSI MEASURED NET HEAD AT 50% = 62 PSI YEAR OF ACQUISITION: 2008 LAST TEST RESULTS SCOPE OF WORK: OVERHAULING, INSPECTION AND SERVICING OF ELECTRIC PUMP. UPON SERVICING, ENSURE THE ELECTRIC PUMP SET OPERATES SMOOTHLY AND MEETS ALL PERFORMANCE CRITERIA AS PER NAME PLATE. THE PUMP PERFORMANCE TEST TO BE CARRIED OUT IN THE PRESENCE OF DEWA WITNESS. THE WARRANTY FOR PUMP PERFORMANCE SHOULD BE ONE YEAR. CALL MOHD YACOUB (0559761412), JITHU (0585742202), FARISH (0559764652) FOR ANY INQUIRY	1	EA				
7		ITEM-00007	INTERNAL INSPECTION AND SERVICING OF	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501358
DATE : 22.08.2025
REQ No : 1032503262
REQ TITLE : 1032503262-81 Internal
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELECTRIC FIRE PUMP SET AT MRDFSUBSTATION.FIRE PUMP AND DRIVER DETAILS:PUMP - SPP, PUMP MODEL: K P12X, SERIAL# 99375/1YEAR OF ACQUISITION: 2000SCOPE OF WORK:OVERHAULING, INSPECTION AND SERVICING OF ELECTRIC PUMP.UPON SERVICING, ENSURE THE ELECTRIC PUMP SET OPERATES SMOOTHLY AND MEETSALL PERFORMANCE CRITERIA AS PER NAME PLATE.THE PUMP PERFORMANCE TEST TO BE CARRIED OUT IN THE PRESENCE OF DEWAWITNESS.THE WARRANTY FOR PUMP PERFORMANCE SHOULD BE ONE YEAR.CALL NARAYANASAMY (0588908575) FOR ANY INQUIRY						
8		ITEM-00008	INTERNAL INSPECTION AND SERVICING OF ELECTRIC FIRE PUMP SET AT HTEC SUBSTATION.FIRE PUMP AND DRIVER DETAILS:PUMP - ARMSTRONG, PUMP MODEL: 8 X 6 X 12.5MFYEAR OF ACQUISITION: 2012RATED PRESSURE: 115 PSINET HEAD @100% LOAD: 107 PSINET HEAD @150% LOAD: 65	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501358
DATE : 22.08.2025
REQ No : 1032503262
REQ TITLE : 1032503262-81 Internal
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PSISCOPE OF WORK:OVERHAULING, INSPECTION AND SERVICING OF ELECTRIC PUMP.UPON SERVICING, ENSURE THE ELECTRIC PUMP SET OPERATES SMOOTHLY AND MEETS ALL PERFORMANCE CRITERIA AS PER NAME PLATE.THE PUMP PERFORMANCE TEST TO BE CARRIED OUT IN THE PRESENCE OF DEWAWITNESS.THE WARRANTY F OR PUMP PERFORMANCE SHOULD BE ONE YEAR.CALL SHERIEF (529219010), USMAN (561721269) FOR ANY INQUIRY						
9		ITEM-00009	INTERNAL INSPECTION AND SERVICING OF ELECTRIC FIRE PUMP SET AT JINDSUBSTATION.FIRE PUMP AND DRIVER DETAILS:PUMP - ARMSTRONG, PUMP MO DEL: 8 X 6 X 12.5MFYEAR OF ACQUISITION: 2000PUMP RATED PRESSURE: 98 PSINET HEAD @100% LOAD: 88 PSINET HEAD @150% LOAD: 28 PSISCOPE O F WORK:OVERHAULING, INSPECTION AND SERVICING OF ELECTRIC PUMP.UPON SERVICING, ENSURE THE ELECTRIC PUMP SET OPERATES	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501358
DATE : 22.08.2025
REQ No : 1032503262
REQ TITLE : 1032503262-81 Internal
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SMOOTHLY AND MEE TSALL PERFORMANCE CRITERIA AS PER NAME PLATE.THE PUMP PERFORMANCE TEST TO BE CARRIED OUT IN THE PRESENCE OF DEWAWITNESS.THE WARRANTY FOR PUMP PERFORMANCE SHOULD BE ONE YEARCALL SHERIEF (529219010), USMAN (561721269) FOR ANY INQUIRY						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Internal Inspection Electric Pump

STANDARD TERMS & CONDITIONS

- Prices should be 'DDP' delivery duty paid at DEWA stores.
- Quotation to be submitted only in local currency U.A.E Dirhams
- DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501358
DATE : 22.08.2025
REQ No : 1032503262
REQ TITLE : 1032503262-81 Internal
DELIVERY LOCATION
CLOSING DATE : 28.08.2025
CLOSING TIME : 10:00:00

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP