

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501430
DATE : 11.09.2025
REQ No : 1012503190
REQ TITLE : FLOWMETER 1012503190
DELIVERY LOCATION : 0014 - G STORE SPAR&CHE
CLOSING DATE : 16.09.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1	2700094023		FLOWMETER_TYPE: ELECTROMAGNETIC INDUCTIVE; SIZE/CONNECTION: 250MMFLANGED; RANGE: 0 TO 650CU M/HR; OUTPUT: 4 TO 20MA; ACCURACY: +/-0.2%;SERVICE: WATER; MATERIAL: STL; RATING: 10BAR; TEMPERATURE RATING: -5 TO80DEG C; ENCLOSURE: NEMA 4, 4X, 6P, IP66/67; TUBE MATER I AL: AUSS;STANDARD: EN 60529, IEC 529; COMMUNICATION PROTOCOL: HART; MFR: KROHNE;MPN: OPTIFLUX 2300W: ADDITIONAL INFO: CABLE CONNE CT ION: 4-WIRE; M20 X1.5; CONVERTER HOUSING: STD; POLYAMIDE; ELECTRICAL RATING: 100 TO 230VAC50/60HZ; FLANGE MATERIAL: STL 250GH; E LEC TRODES: HASTELLOY C22 (FIXEDELECTRODE); FINISH: STD (RAL 9006); FLOW CONVERTER TYPE: IFC 300W;GROUND RINGS: 316TI SS; INSTALLAT ION INSTRUCTION MANUAL LANGUAGES:ENGLISH; INCLUDE SOFTWARE: PACTWARE; LINING: HARD RUBBER; FULL FACELINED; OPERATION MANUAL LANGUA GES:	2	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501430
DATE : 11.09.2025
REQ No : 1012503190
REQ TITLE : FLOWMETER 1012503190
DELIVERY LOCATION : 0014 - G STORE SPAR&CHE
CLOSING DATE : 16.09.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ENGLISH; OVERALL DIMENSION:600MM/23.62IN; PRIMARY HEAD OPTIFLUX 2000F (SEPARATE VERSION);PROGRAMMING LANGUAGES: ENGLISH; PROC ESS DI AGNOSTIC: STD; SIGNAL CABLE:20M; TEMPERATURE RATING: 50DEG C; TERMINAL BOX: DIE CAST AL; PULSEOUTPUT STATUS: ACTIVE/PASSIVE; W/SIGN AL CONVERTER; SUITABLE FOR FFFLANGES; INCLUDING (4) GASKETS; 10 POINTS FACTORY CALIBRATIONCERTIFICATE; BS4504; FLAT FACE; E XCL GASK ETS AND RINGS						
2	2700092496		FLOWMETER_TYPE: ELECTROMAGNETIC; SIZE/CONNECTION: 100MM; RANGE: 0 TO110000CU M/HR; OUTPUT: 4 TO 20MA; ACCURACY: +/-0.2%; SERVICE: W ATER;MATERIAL: POWDER COATED DIE CAST AL; RATING: 40BAR; TEMPERATURE RATING:80DEG C; ENCLOSURE: NEMA 4X, IP67; TUBE MATERIAL: PU A N D HARD RUBBER;STANDARD: ANSI/ISA-S82.01, EN 60529, EN 61010, EN/IEC 61326, NAMUR NE21,	2	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501430
DATE : 11.09.2025
REQ No : 1012503190
REQ TITLE : FLOWMETER 1012503190
DELIVERY LOCATION : 0014 - G STORE SPAR&CHE
CLOSING DATE : 16.09.2025
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NAMUR NE 43, NAMUR NE 53; COMMUNICATION PRO COL: HART; MFR:ENDRESS+HAUSER MGMT AG; MPN: 50W1H-HLIBI-AC2AAWPROMAG: ADDITIONAL INFO:CABLE LENGTH: 10M; WARRANTY: 12MONTHS; W /GR GROUNDING RING						
3	2700092497		FLOWMETER_TYPE: ELECTROMAGNETIC; SIZE/CONNECTION: 80MM; RANGE: 0 TO110000CU M/HR; OUTPUT: 4 TO 20MA; ACCURACY: +/-0.2%; SERVICE: WA TER;MATERIAL: POWDER COATED DIE CAST AL; RATING: 40BAR; TEMPERATURE RATING:80DEG C; ENCLOSURE: NEMA 4X, IP67; TUBE MATERIAL: PU AN D HARD RUBBER;STANDARD: ANSI/ISA-S82.01, EN 60529, EN 61010, EN/IEC 61326, NAMUR NE21, NAMUR NE 43, NAMUR NE 53; COMMUNICATION PRO TO COL: HART; MFR:ENDRESS+HAUSER MGMT AG; MPN: 50W80-HL1B1-AC1AAAW: ADDITIONAL INFO:MODEL: PROMAG 50W80; W/GROUNDING RING	2	SET				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412501430
DATE : 11.09.2025
REQ No : 1012503190
REQ TITLE : FLOWMETER 1012503190
DELIVERY LOCATION : 0014 - G STORE SPAR&CHE
CLOSING DATE : 16.09.2025
CLOSING TIME : 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

FLOWMETER

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP