

**RFQ NUMBER** : 2412501887

**DATE** : 13.11.2025

**REQ No** : 1032504927

**REQ TITLE** : 1-E#STN FLOW DIVIDER

**DELIVERY LOCATION** 

**CLOSING DATE** : 19.11.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	RADIAL FLOW DIVIDER: - SCOPE OF WORK:1. CLEAN ALL THE COMPONENTS USING CORRECT NOT DAMAGING TECHNIQUES -THESE INCLUDE: ALKALINE DECA RBONISING SOLUTION, FINE MEDIA BLASTING, CHEMICAL ULTRA-SONIC CLEANING, SOLVENTS CLEANERS, LIGHT AND HEAVYSCRUBBING PADS.2. CARRY OUT A COMPLETE INSPECTION OF ALL INTERNAL AND EXTERNAL COMPONENTS - INCLUDING: MAIN HOUSING, HOUSING BACK PLATE, HOUSINGS, GEARS, GEAR HO USING, BEARINGS HOUSING, DRIVE & IDLER SHAFTS, SUN-GEARAND ALL PARTS SUBJECT TO	1	EA				PRICE
			WEAR + ALL CONSUMABLES ETC.3. INITIAL INSPECTION REP ORT, THE REPORT WILL SHOW ALL INSPECTIONFINDINGS, CONDITION OF EACH COMPONENT AND RECOMMENDED/SUGGESTED BESTCOURSE OF ACTION. ANY CO NCERNS REGARDING SERVICEABILITY OR WORK OUTSIDETHE ORIGINAL SCOPE OF WORK WILL BE QUOTED FOR AT THIS POINT.4. AFTER						



**RFQ NUMBER** : 2412501887

**DATE** : 13.11.2025

**REQ No** : 1032504927

**REQ TITLE** : 1-E#STN FLOW DIVIDER

**DELIVERY LOCATION** 

**CLOSING DATE** : 19.11.2025

CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CONFIRMATION IS						
			RECEIVED, RTPT WILL CARRY OUT THE						
			RELEVANTREPAIR SCOPE AS MENTIONED ON THE						
			INITIAL INSPECTION REPORT # INCLUDINGPARTS.5.						
			INSPECTION						
			OF ALL NEW REPLACEMENT/REFURBISHED PARTS,						
			RE-CHECK OFPARTS DEEMED SERVICEABLE.6.						
			WHEN THE FLOW DIVIDER HAS BEEN						
			REASSEMBLED, THE ASS						
			EMBLY WILL BEHYDROSTATICALLY PRESSURE						
			TESTED TO THE REQUIRED SPECIFICATION						
			ANDCHECKED FOR PRESSURE						
			DETERIORATION/LEAKS OVER 15 MINUT						
			ES.7. AFTER PRESSURE INTEGRITY HAS BEEN						
			CONFIRMED, A DYNAMIC FLOW TEST OF THE FLOW						
			DIVIDER WILL BE COMPLETED USING THE RTPT						
			FLOW DIVI						
			DER TESTBENCH. THIS CONSISTS OF RUNNING						
			THE FLOW DIVIDER AT NORMAL						
			OPERATINGSPEED/PRESSURES AS WELL AS HIGH						
			SPEED/PRESSURES. THE TES						
			TING PROCESSESCHECK THE ASSEMBLY FOR						
			CORRECT BREAKAWAY, CORRECT FUNCTION,		1				





**RFQ NUMBER** : 2412501887

**DATE** : 13.11.2025

**REQ No** : 1032504927

**REQ TITLE** : 1-E#STN FLOW DIVIDER

**DELIVERY LOCATION** 

**CLOSING DATE** : 19.11.2025

**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELEMENTOUTPUT FLOW, GEAR SLIP AND PUMP						
			SLIP. THE TESTS COM						
			PLETED ENSURE PLUGAND PLAY OPERATION AND						
			THAT THE PERFORMANCE						
			CRITERIA/SPECIFICATION ISACHIEVED. ALL						
			RECORDED TEST RESULTS WILL BE S						
			HOWN ON THE REBUILD ANDTEST DATA SHEET.8. A						
			FINAL QUALITY ASSURANCE CHECK WILL BE						
			CARRIED OUT, CHECKING THEASSEMBLY AND						
			DOCUMENTATIO						
			N9. PROVIDE THE FINAL REPORT ALONG WITH THE						
			TEST DATA SHEET.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

#### **SPECIAL NOTES / INSTRUCTIONS:**

E#STATION FLOW DIVIDER SERVICING FOR GAS TURBINE FRAME 9E, DIVIDER\_FLOW;

MFR: GENERAL ELECTRIC: MPN: 298A7694P10, SERIAL NO:GE41622, FUGURE

NO:20409, TYPE -1, MFR: ROPER PUMP CO

FOR FURTHER DETAILS, PLEASE CONTACT ASM MYNUDDIN (0503620814)





**RFQ NUMBER** : 2412501887

**DATE** : 13.11.2025

**REQ No** : 1032504927

**REQ TITLE** : 1-E#STN FLOW DIVIDER

**DELIVERY LOCATION** 

**CLOSING DATE** : 19.11.2025

CLOSING TIME : 10:00:00

MYNUDDIN.HOSSAIN@DEWA.GOV.AE/MARWAN AL MHEIRI (0501136322) (MARWAN.ALM HEIRI@DEWA.GOV.AE)/AHMED ZAKARIA(0524781810)ahmed.eldaly@dewa.gov.ae

### **STANDARD TERMS & CONDITIONS**

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
- 6)Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.



**RFQ NUMBER** : 2412501887

**DATE** : 13.11.2025

**REQ No** : 1032504927

**REQ TITLE** : 1-E#STN FLOW DIVIDER

**DELIVERY LOCATION** 

SUPPLIER'S REMARKS:

SUPPLIER'S SIGNATURE AND STAMP