

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	RADIAL FLOW DIVIDER: - SCOPE OF WORK:1. CLEAN ALL THE COMPONENTS USING CORRECT NOT DAMAGING TECHNIQUES -THESE INCLUDE: ALKALINE DECA RBONISING SOLUTION, FINE MEDIA BLASTING,CHEMICAL ULTRA-SONIC CLEANING, SOLVENTS CLEANERS, LIGHT AND HEAVYSCRUBBING PADS.2. CARRY OUT A COMPLETE INSPECTION OF ALL INTERNAL AND EXTERNALCOMPONENTS - INCLUDING: MAIN HOUSING, HOUSING BACK PLATE, HOUSINGS,GEARS, GEAR HO USING, BEARINGS HOUSING, DRIVE & IDLER SHAFTS, SUN-GEARAND ALL PARTS SUBJECT TO WEAR + ALL CONSUMABLES ETC.3. INITIAL INSPECTION REP ORT, THE REPORT WILL SHOW ALL INSPECTIONFINDINGS, CONDITION OF EACH COMPONENT AND RECOMMENDED/SUGGESTED BESTCOURSE OF ACTION. ANY CO NCERNS REGARDING SERVICEABILITY OR WORK OUTSIDETHE ORIGINAL SCOPE OF WORK WILL BE QUOTED FOR AT THIS POINT.4. AFTER	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONFIRMATION IS RECEIVED, RTPT WILL CARRY OUT THE RELEVANTREPAIR SCOPE AS MENTIONED ON THE INITIAL INSPECTION REPORT # INCLUDINGPARTS.5. INSPECTION OF ALL NEW REPLACEMENT/REFURBISHED PARTS, RE-CHECK OFPARTS DEEMED SERVICEABLE.6. WHEN THE FLOW DIVIDER HAS BEEN REASSEMBLED, THE ASS EMBLY WILL BEHYDROSTATICALLY PRESSURE TESTED TO THE REQUIRED SPECIFICATION ANDCHECKED FOR PRESSURE DETERIORATION/LEAKS OVER 15 MINUT ES.7. AFTER PRESSURE INTEGRITY HAS BEEN CONFIRMED, A DYNAMIC FLOW TEST OFTHE FLOW DIVIDER WILL BE COMPLETED USING THE RTPT FLOW DIVI DER TESTBENCH. THIS CONSISTS OF RUNNING THE FLOW DIVIDER AT NORMAL OPERATINGSPEED/PRESSURES AS WELL AS HIGH SPEED/PRESSURES. THE TES TING PROCESSES CHECK THE ASSEMBLY FOR CORRECT BREAKAWAY, CORRECT FUNCTION,</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELEMENT OUTPUT FLOW, GEAR SLIP AND PUMP SLIP. THE TESTS COMPLETED ENSURE PLUG AND PLAY OPERATION AND THAT THE PERFORMANCE CRITERIA/SPECIFICATION IS ACHIEVED. ALL RECORDED TEST RESULTS WILL BE SHOWN ON THE REBUILD AND TEST DATA SHEET. 8. A FINAL QUALITY ASSURANCE CHECK WILL BE CARRIED OUT, CHECKING THE ASSEMBLY AND DOCUMENTATION. 9. PROVIDE THE FINAL REPORT ALONG WITH THE TEST DATA SHEET.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

E#STATION FLOW DIVIDER SERVICING FOR GAS TURBINE FRAME 9E, DIVIDER\_FLOW; MFR: GENERAL ELECTRIC; MPN: 298A7694P10, SERIAL NO: GE41622, FUGURENO: 20409, TYPE -1, MFR: ROPER PUMP CO FOR FURTHER DETAILS, PLEASE CONTACT ASM MYNUDDIN (0503620814) MYNUDDIN.HOSSAIN@DEWA.GOV.AE/MARWAN AL MHEIRI (0501136322) (MARWAN.ALMHEIRI@DEWA.GOV.AE)/AHMED 0524781810) ahmed.eldaly@dewa.gov.ae

### STANDARD TERMS & CONDITIONS

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page 3 of 4

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
  - 2) Quotation to be submitted only in local currency U.A.E Dirhams
  - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
  - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
  - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
  - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	RADIAL FLOW DIVIDER: - SCOPE OF WORK:1. CLEAN ALL THE COMPONENTS USING CORRECT NOT DAMAGING TECHNIQUES -THESE INCLUDE: ALKALINE DECA RBONISING SOLUTION, FINE MEDIA BLASTING,CHEMICAL ULTRA-SONIC CLEANING, SOLVENTS CLEANERS, LIGHT AND HEAVYSCRUBBING PADS.2. CARRY OUT A COMPLETE INSPECTION OF ALL INTERNAL AND EXTERNALCOMPONENTS - INCLUDING: MAIN HOUSING, HOUSING BACK PLATE, HOUSINGS,GEARS, GEAR HO USING, BEARINGS HOUSING, DRIVE & IDLER SHAFTS, SUN-GEARAND ALL PARTS SUBJECT TO WEAR + ALL CONSUMABLES ETC.3. INITIAL INSPECTION REP ORT, THE REPORT WILL SHOW ALL INSPECTIONFINDINGS, CONDITION OF EACH COMPONENT AND RECOMMENDED/SUGGESTED BESTCOURSE OF ACTION. ANY CO NCERNS REGARDING SERVICEABILITY OR WORK OUTSIDETHE ORIGINAL SCOPE OF WORK WILL BE QUOTED FOR AT THIS POINT.4. AFTER	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONFIRMATION IS RECEIVED, RTPT WILL CARRY OUT THE RELEVANTREPAIR SCOPE AS MENTIONED ON THE INITIAL INSPECTION REPORT # INCLUDINGPARTS.5. INSPECTION OF ALL NEW REPLACEMENT/REFURBISHED PARTS, RE-CHECK OFPARTS DEEMED SERVICEABLE.6. WHEN THE FLOW DIVIDER HAS BEEN REASSEMBLED, THE ASS EMBLY WILL BEHYDROSTATICALLY PRESSURE TESTED TO THE REQUIRED SPECIFICATION ANDCHECKED FOR PRESSURE DETERIORATION/LEAKS OVER 15 MINUT ES.7. AFTER PRESSURE INTEGRITY HAS BEEN CONFIRMED, A DYNAMIC FLOW TEST OFTHE FLOW DIVIDER WILL BE COMPLETED USING THE RTPT FLOW DIVI DER TESTBENCH. THIS CONSISTS OF RUNNING THE FLOW DIVIDER AT NORMAL OPERATINGSPEED/PRESSURES AS WELL AS HIGH SPEED/PRESSURES. THE TES TING PROCESSES CHECK THE ASSEMBLY FOR CORRECT BREAKAWAY, CORRECT FUNCTION,</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELEMENT OUTPUT FLOW, GEAR SLIP AND PUMP SLIP. THE TESTS COMPLETED ENSURE PLUG AND PLAY OPERATION AND THAT THE PERFORMANCE CRITERIA/SPECIFICATION IS ACHIEVED. ALL RECORDED TEST RESULTS WILL BE SHOWN ON THE REBUILD AND TEST DATA SHEET. 8. A FINAL QUALITY ASSURANCE CHECK WILL BE CARRIED OUT, CHECKING THE ASSEMBLY AND DOCUMENTATION. 9. PROVIDE THE FINAL REPORT ALONG WITH THE TEST DATA SHEET.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

E#STATION FLOW DIVIDER SERVICING FOR GAS TURBINE FRAME 9E, DIVIDER\_FLOW; MFR: GENERAL ELECTRIC; MPN: 298A7694P10, SERIAL NO: GE41622, FUGURENO: 20409, TYPE -1, MFR: ROPER PUMP CO FOR FURTHER DETAILS, PLEASE CONTACT ASM MYNUDDIN (0503620814) MYNUDDIN.HOSSAIN@DEWA.GOV.AE/MARWAN AL MHEIRI (0501136322) (MARWAN.ALMHEIRI@DEWA.GOV.AE)/AHMED 0524781810) ahmed.eldaly@dewa.gov.ae

### STANDARD TERMS & CONDITIONS

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page 3 of 4

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
  - 2) Quotation to be submitted only in local currency U.A.E Dirhams
  - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
  - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
  - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
  - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**



## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	RADIAL FLOW DIVIDER: - SCOPE OF WORK:1. CLEAN ALL THE COMPONENTS USING CORRECT NOT DAMAGING TECHNIQUES -THESE INCLUDE: ALKALINE DECA RBONISING SOLUTION, FINE MEDIA BLASTING,CHEMICAL ULTRA-SONIC CLEANING, SOLVENTS CLEANERS, LIGHT AND HEAVYSCRUBBING PADS.2. CARRY OUT A COMPLETE INSPECTION OF ALL INTERNAL AND EXTERNALCOMPONENTS - INCLUDING: MAIN HOUSING, HOUSING BACK PLATE, HOUSINGS,GEARS, GEAR HO USING, BEARINGS HOUSING, DRIVE & IDLER SHAFTS, SUN-GEARAND ALL PARTS SUBJECT TO WEAR + ALL CONSUMABLES ETC.3. INITIAL INSPECTION REP ORT, THE REPORT WILL SHOW ALL INSPECTIONFINDINGS, CONDITION OF EACH COMPONENT AND RECOMMENDED/SUGGESTED BESTCOURSE OF ACTION. ANY CO NCERNS REGARDING SERVICEABILITY OR WORK OUTSIDETHE ORIGINAL SCOPE OF WORK WILL BE QUOTED FOR AT THIS POINT.4. AFTER	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONFIRMATION IS RECEIVED, RTPT WILL CARRY OUT THE RELEVANTREPAIR SCOPE AS MENTIONED ON THE INITIAL INSPECTION REPORT # INCLUDINGPARTS.5. INSPECTION OF ALL NEW REPLACEMENT/REFURBISHED PARTS, RE-CHECK OFPARTS DEEMED SERVICEABLE.6. WHEN THE FLOW DIVIDER HAS BEEN REASSEMBLED, THE ASS EMBLY WILL BEHYDROSTATICALLY PRESSURE TESTED TO THE REQUIRED SPECIFICATION ANDCHECKED FOR PRESSURE DETERIORATION/LEAKS OVER 15 MINUT ES.7. AFTER PRESSURE INTEGRITY HAS BEEN CONFIRMED, A DYNAMIC FLOW TEST OFTHE FLOW DIVIDER WILL BE COMPLETED USING THE RTPT FLOW DIVI DER TESTBENCH. THIS CONSISTS OF RUNNING THE FLOW DIVIDER AT NORMAL OPERATINGSPEED/PRESSURES AS WELL AS HIGH SPEED/PRESSURES. THE TES TING PROCESSES CHECK THE ASSEMBLY FOR CORRECT BREAKAWAY, CORRECT FUNCTION,</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELEMENT OUTPUT FLOW, GEAR SLIP AND PUMP SLIP. THE TESTS COMPLETED ENSURE PLUG AND PLAY OPERATION AND THAT THE PERFORMANCE CRITERIA/SPECIFICATION IS ACHIEVED. ALL RECORDED TEST RESULTS WILL BE SHOWN ON THE REBUILD AND TEST DATA SHEET. 8. A FINAL QUALITY ASSURANCE CHECK WILL BE CARRIED OUT, CHECKING THE ASSEMBLY AND DOCUMENTATION. 9. PROVIDE THE FINAL REPORT ALONG WITH THE TEST DATA SHEET.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

E#STATION FLOW DIVIDER SERVICING FOR GAS TURBINE FRAME 9E, DIVIDER\_FLOW; MFR: GENERAL ELECTRIC; MPN: 298A7694P10, SERIAL NO: GE41622, FUGURENO: 20409, TYPE -1, MFR: ROPER PUMP CO FOR FURTHER DETAILS, PLEASE CONTACT ASM MYNUDDIN (0503620814) MYNUDDIN.HOSSAIN@DEWA.GOV.AE/MARWAN AL MHEIRI (0501136322) (MARWAN.ALMHEIRI@DEWA.GOV.AE)/AHMED 0524781810) ahmed.eldaly@dewa.gov.ae

### STANDARD TERMS & CONDITIONS

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page 3 of 4

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
  - 2) Quotation to be submitted only in local currency U.A.E Dirhams
  - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
  - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
  - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
  - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	RADIAL FLOW DIVIDER: - SCOPE OF WORK:1. CLEAN ALL THE COMPONENTS USING CORRECT NOT DAMAGING TECHNIQUES -THESE INCLUDE: ALKALINE DECA RBONISING SOLUTION, FINE MEDIA BLASTING,CHEMICAL ULTRA-SONIC CLEANING, SOLVENTS CLEANERS, LIGHT AND HEAVYSCRUBBING PADS.2. CARRY OUT A COMPLETE INSPECTION OF ALL INTERNAL AND EXTERNALCOMPONENTS - INCLUDING: MAIN HOUSING, HOUSING BACK PLATE, HOUSINGS,GEARS, GEAR HO USING, BEARINGS HOUSING, DRIVE & IDLER SHAFTS, SUN-GEARAND ALL PARTS SUBJECT TO WEAR + ALL CONSUMABLES ETC.3. INITIAL INSPECTION REP ORT, THE REPORT WILL SHOW ALL INSPECTIONFINDINGS, CONDITION OF EACH COMPONENT AND RECOMMENDED/SUGGESTED BESTCOURSE OF ACTION. ANY CO NCERNS REGARDING SERVICEABILITY OR WORK OUTSIDETHE ORIGINAL SCOPE OF WORK WILL BE QUOTED FOR AT THIS POINT.4. AFTER	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>CONFIRMATION IS RECEIVED, RTPT WILL CARRY OUT THE RELEVANTREPAIR SCOPE AS MENTIONED ON THE INITIAL INSPECTION REPORT # INCLUDINGPARTS.5. INSPECTION OF ALL NEW REPLACEMENT/REFURBISHED PARTS, RE-CHECK OFPARTS DEEMED SERVICEABLE.6. WHEN THE FLOW DIVIDER HAS BEEN REASSEMBLED, THE ASS EMBLY WILL BEHYDROSTATICALLY PRESSURE TESTED TO THE REQUIRED SPECIFICATION ANDCHECKED FOR PRESSURE DETERIORATION/LEAKS OVER 15 MINUT ES.7. AFTER PRESSURE INTEGRITY HAS BEEN CONFIRMED, A DYNAMIC FLOW TEST OFTHE FLOW DIVIDER WILL BE COMPLETED USING THE RTPT FLOW DIVI DER TESTBENCH. THIS CONSISTS OF RUNNING THE FLOW DIVIDER AT NORMAL OPERATINGSPEED/PRESSURES AS WELL AS HIGH SPEED/PRESSURES. THE TES TING PROCESSES CHECK THE ASSEMBLY FOR CORRECT BREAKAWAY, CORRECT FUNCTION,</p>						

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ELEMENT OUTPUT FLOW, GEAR SLIP AND PUMP SLIP. THE TESTS COMPLETED ENSURE PLUG AND PLAY OPERATION AND THAT THE PERFORMANCE CRITERIA/SPECIFICATION IS ACHIEVED. ALL RECORDED TEST RESULTS WILL BE SHOWN ON THE REBUILD AND TEST DATA SHEET. 8. A FINAL QUALITY ASSURANCE CHECK WILL BE CARRIED OUT, CHECKING THE ASSEMBLY AND DOCUMENTATION. 9. PROVIDE THE FINAL REPORT ALONG WITH THE TEST DATA SHEET.						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### SPECIAL NOTES / INSTRUCTIONS:

E#STATION FLOW DIVIDER SERVICING FOR GAS TURBINE FRAME 9E, DIVIDER\_FLOW; MFR: GENERAL ELECTRIC; MPN: 298A7694P10, SERIAL NO: GE41622, FUGURENO: 20409, TYPE -1, MFR: ROPER PUMP CO FOR FURTHER DETAILS, PLEASE CONTACT ASM MYNUDDIN (0503620814) MYNUDDIN.HOSSAIN@DEWA.GOV.AE/MARWAN AL MHEIRI (0501136322) (MARWAN.ALMHEIRI@DEWA.GOV.AE)/AHMED 0524781810) ahmed.eldaly@dewa.gov.ae

### STANDARD TERMS & CONDITIONS

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page 3 of 4

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2412502046  
**DATE** : 12.12.2025  
**REQ No** : 1032504927  
**REQ TITLE** : 1-E#STN FLOW DIVIDER  
**DELIVERY LOCATION**  
**CLOSING DATE** : 18.12.2025  
**CLOSING TIME** : 10:00:00

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
  - 2) Quotation to be submitted only in local currency U.A.E Dirhams
  - 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
  - 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
  - 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.
  - 6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.
- If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements
- The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**