

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATION</p> <p>TITLE: REPLACEMENT OF DEFECTIVE STEAM TRAPS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEM</p> <p>CONTACT: MUHAMMED.KAJAMOIDEEN@DEWA.GOV.AE; MOB:0528391552</p> <p>SIZE AND QUANTITY:#CUTTING & REPLACEMENT OF 1" SCH 80 ELBOW - SOCKET WELDED, NO. OF JOINTS - 8, MATERIAL - CARBON STEEL,</p> <p>QTY. - 4 NOS.)</p> <p>WORK SCHEDULE: DURATION - 3 DAYS (COMMON FOR ALL THE LINE ITEMS)</p> <p>PRE-BID SITE INSPECTION: THE CONTRACTOR SHALL VISIT THE SITE AND BE FULLY FAMILIAR WITH THE WORK SCOPE, PLANT ACCESS, FACILITIES,COMPLEXITIES, ETC., BEFORE SUBMITTING THE BID. DEWA WILL NOT ACCEPT ANY CLAIM FOR EXTRAS BEYOND THE ORDER RATES / PRICES DURING AND AFTER THE EXECUTION OF WORK.</p> <p>SCOPE OF WORK</p>	4	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>(COMMON FOR ALL THE LINE ITEMS): #MOBILIZE MEN/EQUIPMENT WITHIN 01 DAY OF ADVANCE NOTICE. #SUBMIT FOLLOWING DOCUMENTS TO OBTAIN PTW: #METHOD STATEMENT #RISK ASSESSMENT OF THE WORK #TOOLBOX TALK REPORT. #OBTAIN PTW (PERMIT TO WORK) AND LC (LINE CLEARANCE) FROM DEWA. #CONDUCT SITE SURVEY AND SAFETY INSPECTION, TO ASSESS THE WORKING ENVIRONMENT. #ENSURE SITE AREA IS CORRECTLY SECURED AND SAFE TO WORK ON IN ALL RESPECTS. #ENSURE PROPER ISOLATION OF THE LINE & DEWA CHEMIST CLEARANCE FOR LEL & HWP ARE OBTAINED DAILY BEFORE START OF WORK. #ENSURE NO FLAMMABLE MATERIALS NEAR THE HOT WORK AREA. #IF THE WORKING ENVIRONMENT IS SAFE, PROCEED WITH THE FOLLOWING STEPS. #IDENTIFY ALONG WITH DEWA THE AREA WHERE SPOOLS TO BE REPLACED IN THE PIPE RACK. #ALL THE REQUIRED</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FABRICATION WORKS (CUTTING, EDGE PREPARATIONS AND WELDING) TO BE CARRIED OUT.#PROVIDE TEMPORARY PIPE SUPPORT AS REQUIRED.#FOR HOT WORK, WELDING BOOTHS BE PROVIDED TO PREVENT WELDING SPARKS OR CUTTING MATERIALS COMING OUT FROM HOT WORK AREA. ENSURE TO PROVIDE ENOUGH FIRE EXTINGUISHER, FIRE BLANKETS AT SITE.#PROTECT THE NEARBY LINES / CABLES USING FIRE BLANKET.#BARRICADE THE AREA BELOW WITH SIGNAGE.#PROCEED WITH CUTTING/REMOVAL OF PIPE & PREP ARE THE JOINTS.#WELD THE PIPE FITTINGS.#QUALIFIED JOB SUPERVISOR SHALL BE ASSIGNED FOR THE JOB.#SKILLED FABRICATORS / WELDERS SHALL CARRY OUT ALL THE JOBS.#WELD JOINTS TO BE MADE BY QUALIFIED WELDER ACCORDING TO APPLICABLE WPS & ASME REQUIREMENTS. (WPS & WELDER CERTIFICATES TO BE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>PROVIDED).#HOUSEKEEPING AND DISPOSAL OF WASTE TO BE DONE BEFORE SITE CLEARANCE..#DE-MOBILIZE MEN AND EQUIPMENT A</p> <p>FTER COMPLETION OF THE JOB..#WORK COMPLETION REPORTS TO BE SUBMITTED. REPORT SHALL CONTAINRELEVANT PHOTOS..#ALL TOOLS & TACKLES ARE IN CONTRACTOR'S SCOPE..#PROPER AND TESTED TOOLS TO BE USED..#ALL LIFTING & POWER TOOLS SHALL HAVE VALID 3RD PARTY TESTCERTIFICATE..#</p> <p>WELDING MACHINES SHOULD HAVE 3RD PARTY CALIBRATION CERTIFICATE..#DEWA SCOPE (COMMON FOR ALL THE LINE ITEMS):\$#SCAFFOLDING\$#MATERIAL SUPPLY:\$#NDEWARRANTY (COMMON FOR ALL THE LINE ITEMS)\$#THE WARRANTY PERIOD FOR THE WORK SHALL BE ONE YEAR FROM THE DATE OFCOMPLETION OF WORK CERTIFIED BY DEWAGENERAL TERMS & CONDITIONS.#THE CONTRACTOR SHALL VISIT THE SITE AND BE FULLY FAMILIAR WITH THEWORK</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SCOPE, PLANT ACCESS, FACILITIES, COMPLEXITIES, SAFETY MEASURES ETC., BEFORE HE SUBMITS HIS BID. # THE CONTRACTOR SHALL ENSURE HOUSEKEEPING DAILY AND THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL WASTE MATERIAL DISPOSALS TO DESIGNATED PLACES. # ALL DEWA SAFETY & ENVIRONMENT POLICY, RULES AND REGULATIONS SHALL BE FOLLOWED AT WORK SITE DURING THE EXECUTION OF THE WORK. THE CONTRACTOR # ENGINEER SHOULD BE FAMILIAR WITH SAFETY REGULATIONS WHILE WORKING IN A HAZARDOUS AREA. # SCAFFOLDING IF REQUIRED SHALL BE ARRANGED BY DEWA. # QUALIFIED RIGGERS SHOULD BE ARRANGED BY CONTRACTOR FOR RIGGING ACTIVITIES. # THE WORK SHALL BE EXECUTED UNDER DEWA SUPERVISION AND AS PER QUALITY/SCHEDULE REQUIREMENT. # CONTRACTOR # S SUPERVISOR SHALL BE AVAILABLE AT SITE THROUGHOUT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			THE PERIOD OF WORK..#SERVICE AIR, ELECTRICITY AND WATER F OR WORK AT DEWA SITE. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO HAVE HIS OWN ARRANGEMENT IN EXTENDING THE ELECTRICITY AND WATER UTILITY TO HIS PLACES OF WORK INCLUDING LIGHTING, SAFETY, HEALTH AND ENVIRONMENT (COMMON FOR ALL THE LINE ITEMS).#THE CONTRACTOR SHALL COMPLY WITH ALL THE REQUIREMENTS STIPULATED IN THE FOLLOWING OHS DOCUMENT FROM DEWA FOR HEALTH, SAFETY AND ENVIRONMENTAL REQUIREMENTS DURING THE EXECUTION OF THE PROJECT. #IMSP01 # SP 06 # H&S PROCEDURE FOR CONTRACTOR AND CONSULTANTS #IMSP01 # SP 15 # CONTROL OF SUBSTANCES HAZARDOUS TO HEALTH (COSHS) #10.1.3. JAPS/H-18 # ENVIRONMENTAL MANAGEMENT SYSTEM PROCEDURE. #THE CONTRACTOR'S WORK WILL FALL WITHIN THE PURVIEW OF SAFETY						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>SURVEYS CONDUCTED REGULARLY BY THE DEWA SAFETY SECTION. ALL THEIR SAFETY REQUIREMENTS SHALL BE PROMPTLY MET. THE CONTRACTOR SHALL CHECK THE CONDITIONS SUITABLE FOR CARRYING OUT THE WORK CONDUCT SITE SURVEY AND SAFETY INSPECTION TO ASSESS THE WORKING ENVIRONMENT. # NO WASTAGES SHALL BE LEFT ON THE GROUND OR AT ANY AREA BEING PART OF THE CONTRACTOR'S WORK AREA. SUGGESTED TO USE TARPAULIN AND/OR MESH COVERS SURROUND SYSTEM. SECURITY PERMISSIONS (COMMON FOR ALL THE LINE ITEMS). # THE CONTRACTOR SHOULD SUBMIT THE FOLLOWING PARTICULARS WELL IN ADVANCE FOR DEWA TO ISSUE ENTRY PASSES FOR THEM VALID UP TO THE PERIOD OF CONTRACT WORK. # LIST OF HIS STAFF PROPOSED TO BE ENGAGED ON THE JOB WITH DESIGNATION, COPY OF THEIR VALID PASSPORT, LABOR CARD AND TWO PP SIZE PHOTOGRAPHS. FOR V</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			HICLE DRIVERS, COPIES OF THEIR VALID DRIVING LICENSE ALSO ARE TOBE ATTACHED. #.#LIST OF VEHICLES WITH A COPY OF VALID REGISTRATION C ERTIFICATE/VEHICLE LICENSE OF EACH VEHICLE.#LIST OF TOOLS, EQUIPMENT, CONSUMABLES, ETC., WITH DELIVERY NOTES FOREACH.#TRAVEL DECLARATION FORM.#UNDERTAKING LETTER.#THE CONTRACTOR SHALL BRING THEIR MATERIALS, EQUIPMENT, OFFICEFACILITIES, SUBSTANCES, COMPUTERS, CAM ERAS ETC. WITH THEIR DELIVERY NOTEAFTER DEWA APPROVAL ONLY FOR THE INTENDED CONTRACT PURPOSE. #.#ALL MATERIAL AND TOOLS BROUGHT IN SHALL BE DECLARED AT POWER STATIONSECURITY GATE AND THE LIST OF THESE ITEMS SHALL BE SIGNED BY DEWASECURITY. THESE DOCUMENTS INCLUDIN G DELIVERY NOTE WILL BE THE BASIS FORTHE CLEARANCE (GATE PASS) TO TAKE THE MATERIAL & TOOLS OUT ON COMPLETIONOF THE JOB.#AT						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			ALL TIMES CONTRACTORS# PERSONNEL MUST STRICTLY ADHERE TO THESECURITY PROCEDURES OF DEWA DURING THEIR PRESENCE AND WHILE WORKINGINSIDE DEWA PREMISES.#THE PRESENCE OF CONTRACTOR#S MANPOWER SHALL BE RESTRICTED TO THEWORKING AREAS ONLY. ANY CONTRACTOR#S STAFF VIOLATING THIS WOULD BEBARRED FROM ENTERING DEWA PREMISES.#EXTENSION OF CONTRACTOR#S WORKING TIME BEYOND DEWA#S NORMAL DUTY TIME SHALL BE GRANTED FURTHER TO THE APPROVAL OF DEWA CONCERNED SITEENGINEER. #.#NO STAFF OR VEHICLES OF THE CONTRACTOR WILL BE PERMITTED TO STAYINSIDE DEWA PREMISES AFTER CLOSE OF BUSINESS HOURS.#CONTRACTOR WHILE WORKING AT SITE SHALL HAVE ALL THE DATASHEETS, DAILYTOOLBOX TALK RECORDS, PERMIT TO WORK DOCUMENTS, HOT WORK PERMITDISPLAYED AT SITE AND THE WARNING						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SIGN BOARD SHALL BE AVAILABLE AT SITEAT ALL TIMES. #						
2		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TRAPS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY: CUTTING & REPLACEMENT OF 1 " SCH 80 45-DEGREE BEND, SOCKET WELDED, NO. OF JOINTS - 2, MATERIAL: CARBON STEEL, QTY. - 1 NO.	1	EA				
3		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TRAPS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY: CUTTING & REPLACEMENT OF 1 " SCH 80 SOCKOLET - SOCKET WELDED, NO. OF JOINTS - 3, MATERIAL: CARBON STEEL, QTY. - 3	3	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			NOS.						
4		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATION TITLE: REPLACEMENT OF DEFECTIVE STEAM TRAPS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEM SIZE AND QUANTITY: CUTTING & REPLACEMENT OF 1" 800# GLOBE VALVE, SOCKET WELDED, NO. OF JOINTS - 4, MATERIAL: A105, QTY. - 2 NOS.	2	EA				
5		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATION TITLE: REPLACEMENT OF DEFECTIVE STEAM TRAPS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEM SIZE AND QUANTITY: CUTTING & REPLACEMENT OF 1" 1500# GLOBE VALVE, SOCKET WELDED, NO. OF JOINTS - 4, MATERIAL: F22, QTY. - 2 NOS.	2	EA				
6		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI	2	EA				

**REQUEST FOR QUOTATION
LOCAL PURCHASE SECTION**

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TRAPS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY: CUTTING & REPLACEMENT OF 2 " SCH 80 ELBOW, SOCKET WELDED, NO. OF JOINTS -4, MATERIAL: CARBON STEEL, QTY. - 2 NOS.						
7		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TRAPS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY: CUTTING & REPLACEMENT OF 2 " SCH 80 45-DEGREE BEND, SOCKET WELDED, NO. OF JOINTS - 2, MATERIAL: CARBON STEEL, QTY. - 1 NO.	1	EA				
8		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TR	2	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			APS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY:CUTTING & REPLACEMENT OF 2 " 1500# GLOBE VALVES, BUTT WELDED, NO. OF JOINTS - 4, MATERIAL: F22, QTY. - 2 NOS						
9		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TR APS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY:CUTTING & REPLACEMENT OF 3 " FLANGE BUTT WELDED, NO. OF JOINTS - 2,MATERIAL: CARBON STEEL, QTY. - 2 NOS.	2	EA				
10		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TR APS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY:CUTTING &	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			REPLACEMENT OF 3 " SCH 80 45-DEGREE BEND, BUTT WELDED, NO. OF JOINTS - 2, MATERIAL: CARBON STEEL, QTY. - 1 NO.						
11		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TR APS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY: CUTTING & REPLACEMENT OF 8 " SCH 80 PIPE, LENGTH - 1 M, BUTT WELDED, NO.OF JOINTS - 2 NOS., MATERIAL: CARBON STEEL, QTY- 1 NO.	1	EA				
12		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TR APS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY: CUTTING & REPLACEMENT OF 1	3	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			" 800# STEAM TRAP, SOCKET WELDED, NO. OF JOINTS - 6, MATERIAL: F22, QTY.- 3 NOS.						
13		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TRAPS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY: CUTTING & REPLACEMENT OF 2 " 800# STEAM TRAP, SOCKET WELDED, NO. OF JOINTS - 4, MATERIAL: F22, QTY. - 2 NOS.	2	EA				
14		ITEM-00001	TECHNICAL AND GENERAL SPECIFICATION OF OUTSOURCING WORK AT K STATION,JEBEL ALI POWER STATIONTITLE: REPLACEMENT OF DEFECTIVE STEAM TRAPS, PIPES & FITTINGS (ELBOWS,BENDS), FLANGES AND VALVES IN THE HP, MP & LP STEAM SYSTEMSIZE AND QUANTITY: CUTTING & REPLACEMENT OF 1 " SCH 80 PIPE, SOCKET WELDED, LENGTH - 6 M, NO. OF JOINTS - 6 NOS., MATERIAL: CARBON STEEL	1	EA				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2412600207
DATE	: 29.01.2026
REQ No	: 1032506748
REQ TITLE	: Replacement of defective stea
DELIVERY LOCATION	
CLOSING DATE	: 04.02.2026
CLOSING TIME	: 10:00:00

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Replacement of defective steam traps, pipes and fittings (elbows,bends), flanges and valves in the HP, MP <(>&<>) LP Steam System C

ontact :muhammed.kajamoideen@dewa.gov.ae;Mob:0528391552

STANDARD TERMS & CONDITIONS

- 1) Prices should be 'DDP' delivery duty paid at DEWA stores.
- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by theSupplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600207
DATE : 29.01.2026
REQ No : 1032506748
REQ TITLE : Replacement of defective stea
DELIVERY LOCATION
CLOSING DATE : 04.02.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP