

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	<p>GENERAL:THE CONTRACTOR SHALL PROVIDE ALL ENGINEERING, MATERIALS, AND LABOUR REQUIRED FOR THE SUPPLY, INSTALLATION, AND COMMISSIONING. BEFORE SUBMITTING THE PRICE, THE PARTIES SHALL VISIT THE SITE TO THOROUGHLY ACQUAINT THEMSELVES WITH LOCAL CONDITIONS, ASSESS THE SCOPE OF WORK, AND DETERMINE THE REQUIRED LABOUR AND MATERIALS. SCOPE OF WORK THE SCOPE OF WORK INCLUDES, BUT IS NOT LIMITED TO, THE FOLLOWING:</p> <p>THE SCOPE OF WORK FOR THE "SUPPLY & INSTALLATION OF SEWAGE PUMP (1D+1S), AUTO COUPLING, GUIDE RAIL, AND LIFTING CHAIN" PROJECT</p> <p>ENCOMPASSES A COMPREHENSIVE SET OF TASKS TO ENSURE THE SUCCESSFUL REPLACEMENT AND ENHANCEMENT OF THE EXISTING SEWAGE SYSTEM. THE PROJECT WILL BE CONDUCTED WITH UTMOST PRECISION AND ADHERENCE TO SPECIFICATIONS, INVOLVING THE FOLLOWING TASKS:</p> <ol style="list-style-type: none"> 1. INITIAL SITE 	1	LS				

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>ASSESSMENT: # A JOINT SITE VISIT WILL BE CONDUCTED BY BOTH PARTIES TO EVALUATE LOCAL CONDITIONS, ASSESS THE SCOPE OF WORK, AND DETERMINE REQUIRED RESOURCES. 2. REMOVAL OF OLD EQUIPMENT: # DISCONNECTION, REMOVAL, AND PROPER DISPOSAL OF THE OLD SEWAGE PUMP, INCLUDING ASSOCIATED ELECTRICAL CONNECTIONS AND COMPONENTS. # DISMANTLING AND REMOVAL OF THE OUTDATED GUIDE RAIL AND AUTO COUPLING. 3. INSTALLATION OF NEW EQUIPMENT: # IMPECCABLE INSTALLATION OF TWO (2) NEW SEWAGE PUMPS, SPECIFICALLY THE GRP26D MODEL FROM HOMA GERMANY, EACH WITH A POWER RATING OF 2KW. # SKILLFUL INSTALLATION OF TWO (2) NEW AUTO COUPLINGS, ENSURING EFFICIENT AND SECURE CONNECTIONS FOR SIMPLIFIED PUMP INSTALLATION AND REMOVAL. # PRECISE INSTALLATION OF THREE (3) NEW FLOAT SWITCHES,</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			PROVIDING ACCURATE LEVEL SENSING CAPABILITIES FOR OPTIMAL PUMP OPERATION. 4. GUIDE RAIL AND LIFTING CHAIN INSTALLATION: # INSTALLATION OF TWO (2)SETS OF ROBUST GUIDE RAILS, METICULOUSLY DESIGNED TO FACILITATE PROPER ALIGNMENT AND RELIABLE SUPPORT FOR THE SEWAGE PUMPS.# INCORPORATION OF NEW LIFTING CHAINS FOR EACH PUMP TO STREAMLINE MAINTENANCE PROCEDURES AND ENABLE EFFICIENT REMOVAL WHEN NECESSARY.5. CONTROL PANEL RECTIFICATION: # STRATEGIC ADJUSTMENTS TO THE EXISTING CONTROL PANEL, ENSURING SEAMLESS INTEGRATION OF THE NEW PUMPS AND ASSOCIATED EQUIPMENT.# IMPLEMENTATION OF A PUMP ROTATION MECHANISM, WHERE ONE PUMP ACTS AS THE DUTY PUMP DURING EACH CYCLE, MINIMIZING WEAR AND TEAR ON A SINGLE PUMP AND OPTIMIZING OVERALL SYSTEM EFFICIENCY.6. QUALITY ASSURANCE AND						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			SAFETY MEASURES: # RIGOROUS QUALITY CHECKS AND INSPECTIONS AT VARIOUS STAGES OF INSTALLATION TO ENSURE COMPLIANCE WITH EXACTING TECHNICAL SPECIFICATIONS AND PREVAILING INDUSTRY STANDARDS.# IMPLEMENTATION OF COMPREHENSIVE SAFETY MEASURES DURING INSTALLATION AND TESTING TO ENSURE THE SAFETY AND WELL-BEING OF ALL PERSONNEL INVOLVED.7. DOCUMENTATION AND REPORTING: # METICULOUS PREPARATION OF COMPREHENSIVE DOCUMENTATION, INCLUDING EQUIPMENT MANUALS, DETAILED INSTALLATION RECORDS, AND COMPREHENSIVE TESTING RESULTS.SPECIFICATIONS THE TECHNICAL SPECIFICATIONS FOR THE PROJECT ARE AS FOLLOWS:SEWAGE PUMPS (2 NOS):# BRAND: HOMA GERMANY# MODEL: GRP26D# POWER RATING: 2KW# TYPE: SUBMERSIBLE SEWAGE PUMP# CAPACITY: AS PER DESIGN REQUIREMENTS AUTO COUPLINGS (2 NOS)						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
):# DESIGNED FOR EFFICIENT AND SECURE CONNECTIONS, FACILITATING QUICK PUMP INSTALLATION AND REMOVAL.GUIDE RAILS (2 SETS):# STURDY AND PRECISELY DESIGNED GUIDE RAIL SYSTEM, ENSURING ACCURATE PUMP ALIGNMENT AND RELIABLE SUPPORT.DEWA-CONFIDENTIAL LIFTING CHAINS:# DURABLE LIFTING CHAINS FOR CONVENIENT PUMP MAINTENANCE AND REMOVAL.FLOAT SWITCHES (3 NOS):# ACCURATE LEVEL SENSING FOR DEPENDABLE PUMP OPERATION.CONTROL PANEL RECTIFICATION:# MODIFICATION OF THE EXISTING CONTROL PANEL TO ACCOMMODATE NEW EQUIPMENT, INCORPORATING A PUMP ROTATION MECHANISM FOR ENHANCED OPERATIONAL EFFICIENCY.TESTING AND COMMISSIONING:# THOROUGH TESTING AND CALIBRATION TO ENSURE OPTIMAL FUNCTIONING OF PUMPS, AUTO COUPLINGS, AND CONTROL SYSTEMS.ENVIRONMENTAL CONDITIONS:# THE EQUIPMENT SHALL BE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			CAPABLE OF CONTINUOUS OPERATION IN ANENVIRONMENT WITH TEMPERATURES OF UP TO 50 DEGREES CELSIUS AND 80%HUMIDITY.MATERIALS AND MANUFACTURING:# ALL COMPONENTS SH ALL BE CONSTRUCTED FROM HIGH-QUALITY,CORROSION-RESISTANT MATERIALS.# GATE VALVES AND NON-RETURN VALVES (NRVS) SHALL BE SOURCED FROMA PPROVED MANUFACTURERS SUCH AS PEGLER UK, CRANE, OR MANUFACTURERS WITH ACOMPARABLE RATING.SAFETY AND COMPLIANCE:# ADHERENCE TO ALL RE LEVANT SAFETY REGULATIONS, TECHNICAL STANDARDS, ANDGUIDELINES THROUGHOUT THE PROJECT'S EXECUTION.WARRANTY AND PERFORMANCE:# THE COMPLETION OF THE PROJECT WILL RESULT IN A FULLY OPERATIONALSEWAGE PUMP SYSTEM, CHARACTERIZED BY ENHANCED EFFICIENCY AND RELIABLEPERFORMANCE. THE INSTALLING CONTRACTOR SHALL PROVIDE A ONE-YEARINSTALLATION WARRANTY,						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			COVERING ALL MATERIALS, LABOR, AND MISCELLANEOUS COSTS. THE CONTRACTOR IS RESPONSIBLE FOR WARRANTY REPAIRS AND MAY SEEK REIMBURSEMENT FROM THE MANUFACTURER OR ANY OTHER ENTITY PROVIDING WARRANTIES FOR THE EQUIPMENT INSTALLED. ONSITE REPAIRS FOR ELECTRICAL OR WATER SERVICE SYSTEMS WITHIN THE WARRANTY PERIOD MUST BE PROVIDED WITHIN 72 HOURS OF NOTIFICATION OF AN OPERATIONAL PROBLEM OR FAILURE. CONTROL PANEL RECTIFICATION: # MODIFICATIONS TO THE EXISTING CONTROL PANEL TO ACCOMMODATE NEW EQUIPMENT. ONCE THE MAIN PUMP STARTS AND STOP DURING THE NEXT CYCLE ONE OF THE OTHER PUMP ACTS AS A DUTY PUMP HENCE AVOIDING THE FREQUENT RUNNING OF THE SAME PUMP PARTICULAR PERIOD. PUMP START AND STOP WILL BE CONTROLLED BY A FLOAT SWI						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TCH.TESTING AND COMMISSIONING:# RIGOROUS TESTING AND CALIBRATION OF ALL NEWLY INSTALLED COMPONENTS TO VALIDATE THEIR PROPER FUNCTIONALITY AND PERFORMANCE.# THOROUGH COMMISSIONING OF THE ENTIRE SEWAGE PUMP SYSTEM TO ENSURE SEAMLESS INTEGRATION, FLAWLESS OPERATION, AND ADHERENCE TO DESIGN SPECIFICATIONS.# COMPREHENSIVE TESTING TO ENSURE THE PROPER FUNCTIONING OF PUMPS, AUTOCOUPINGS, AND CONTROL SYSTEMS.# THE CONTRACTOR SHALL ADHERE TO ALL APPLICABLE SAFETY REGULATIONS, TECHNICAL STANDARDS, AND GUIDELINES THROUGHOUT THE PROJECT EXECUTION. THE COMPLETION OF THE PROJECT SHALL RESULT IN A FULLY OPERATIONAL SEWAGE PUMP SYSTEM WITH ENHANCED EFFICIENCY AND PERFORMANCE.# THE SETS SHALL BE CAPABLE OF CONTINUOUS SATISFACTORY OPERATION IN AN ENVIRONMENT WITH 50 DEGREES CENTIGRADE						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			<p>/80 PER CENT HUMIDITY.# PUMP SHALL BE DESIGNED TO PERMIT THE REMOVAL OF THE IMPELLER SHAFT AND BEARING WITHOUT DISTURBING THE SUCTION AND DISCHARGE CONNECTION. SHALL BE STAINLESS STEEL.# ALL COMPONENTS SHALL BE CONSTRUCTED OR MANUFACTURED OUT OF HIGH-QUALITY CORROSION-RESISTING MATERIAL. ALL GATE VALVE NRV FROM APPROVED MANUFACTURERS SUCH AS PEGLER UK /CRANE.# PAINTING REQUIREMENTS FOR SPARE PARTS SHALL BE IDENTICAL TO THOSE FOR ORIGINAL INSTALLED PARTS. WHERE NO PAINTING OR PROTECTIVE COATING IS SPECIFIED, SUITABLE PROVISIONS SHALL BE MADE TO PROTECT AGAINST CORROSION.# ALL PARTS OF THE UNITS IN CONTACT WITH WATER SHALL BE MANUFACTURED FROM MATERIALS, WHICH ARE CONVENTIONALLY KNOWN TO BE NON-TOXIC, NON-CONTAMINATING AND BIOLOGICALLY INERT. THESE MATERIALS SHALL</p>						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			BE RESISTANT TO INTERNAL AND EXTERNAL CORROSION OR PROTECTED FROM CORROSION BY SUITABLE SURFACE TREATMENT. # THE CONTRACTOR SHALL SUPPLY AND INSTALL WATER CONTAINING SLUDGE TRANSFER PUMP SMART SEAL AUTO-COUPLING GASKET WITH A COMPLETELY LEAK-PROOF CONNECTION BETWEEN THE PUMP AND THE BASE UNIT OF THE AUTO-COUPLING SYSTEM. THE SHAFT SEAL SHALL BE CAPABLE OF ROTATING IN EITHER DIRECTION. WHEN THE PUMPS INSTALL WITH SEPARATE PIPEWORK, SLUDGE SEDIMENTATION CAN BE AVOIDED BY BACKFLUSHING THE SYSTEM AT REGULAR INTERVALS. # SENSORS SHOULD BE AVAILABLE FOR MONITORING THE PUMP, INCLUDING BEARING AND WINDING TEMPERATURE, VIBRATIONS, AND WATER. # THE PUMPS SHOULD BE SUITABLE FOR THE FOLLOWING APPLICATIONS: DEWA-CONFIDENTIAL # TRANSFER OF UNSCREENED RAW SEWAGE#						

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TRANSFER OF RAW WATER# PUMPING OF WATER CONTAINING SLUDGE# PUMPING OF INDUSTRIAL EFFLUENT.NOTE: # THE SUPPLY SHALL INCLUDE ALL EQUIPMENT, ACCESSORIES, AND OTHER MATERIALS NECESSARY FOR THE COMPLETION AND PROPER FUNCTIONING OF THE INSTALLATIONS. ALL THE MATERIAL IN GENERAL WILL CONFIRM AS PER THE LATEST STANDARDS AND SHALL BE SUBMITTED TO DEWA FOR EN						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

SPECIAL NOTES / INSTRUCTIONS:

Supply and Replacement testing, commissioning of Sewage pump(1D+1S) at DEWA sustainable building

Contact: Thomaskuty/ 0503014789

Site Visit: 7 Jan 2026

Payment: 100% on satisfactory completion

STANDARD TERMS & CONDITIONS

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.

Page 11 of 13

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER	: 2412600266
DATE	: 11.02.2026
REQ No	: 1032506743
REQ TITLE	: Supply and Replacement testin
DELIVERY LOCATION	
CLOSING DATE	: 16.02.2026
CLOSING TIME	: 10:00:00

2) Quotation to be submitted only in local currency U.A.E Dirhams

3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material

4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.

5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

6) Confidentiality Clause: The Supplier/Service Provider shall treat all information and data (excluding open data) contained in the Purchase Order or obtained by the Supplier/Service Provider in connection with the execution of Works as proprietary and strictly confidential. In particular, the Supplier/ Service Provider shall not publish or disclose any data or information including but not limited to personally identifiable information, government data, project details, specifications, drawings or photographs concerning the Works to any third parties without the prior written consent of the Employer.

If the Supplier/Service Provider is obligated to obtain NOCs / Permits /Permissions for the Project from Government agencies as per the terms and scope of the Contract, the Supplier/Service Provider shall submit only the specific data required for the purpose to the authorized team of the agency, through their prescribed channel / system, subject to information security requirements

The Supplier/Service Provider shall comply with all the applicable data protection laws and regulations.

REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

RFQ NUMBER : 2412600266
DATE : 11.02.2026
REQ No : 1032506743
REQ TITLE : Supply and Replacement testin
DELIVERY LOCATION
CLOSING DATE : 16.02.2026
CLOSING TIME : 10:00:00

SUPPLIER'S REMARKS :

SUPPLIER'S SIGNATURE AND STAMP